


ND 8442-1




**AUDACY** M/N: LCE20A1000  
120/277 VAC 20 AMP 50/60 Hz  
For Electronic Ballasts and LED LIGHTING LOAD  
Drivers only  
FCC ID: 2AAMXLCE20A1000  
IC: 11250A - LCE20A1000

 **LISTED**  
Energy Management  
Equipment  
E359679

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

S/N: 1B000001  
IDEAL INDUSTRIES, INC.  
Pat. Pending

S/N: 1B000001



**Notes to Supplier:**

- First two digits of S/N # are fixed. Remaining digits are hexadecimal format and sequential.
- Bar code format: 3 of 9
- Label dimension must be 3 inches wide by 1.5 inches tall
- Must print in a minimum of 600 dpi resolution or similar. All other resolutions must be approved by IDEAL Engineering.
- Vendor or supplier must verify bar code can be read using iOS device Audacy application and using Motorola part number "LS2208-7AZU0100ZNA" laser line scanner.
- Must use UL approved label material, verbiage and lettering.