

ND 8563-1

<b>AUDACY</b> M/N SCLED1002 5A 50/60 Hz 120 to 277 VAC For Electronic Ballasts and LED drivers only	<b>S/N: 21000001</b> 
<b>FCC ID: 2AAMXSCD1002</b> This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.	<b>IC: 11250A-SCD1002</b> <b>S/N: 21000001</b> IDEAL INDUSTRIES, INC. 
	 LISTED Energy Management Equipment E595679

**Notes to Supplier:**

- First two digits of S/N # are fixed. Remaining digits are hexadecimal format and sequential.
- Bar code format: 3 of 9
- Label dimension must be 3 in. wide by 1.5 in. tall
- Must print in a minimum of 600 dpi resolution or similar. All other resolutions must be approved by IDEAL Engineering.
- Vendor or supplier must verify bar code can be read using iOS device Audacy application and using Motorola part number "LS2208-7AZU0100ZNA" laser scanner.
- Must use UL approved material, verbiage and lettering.