





# Test Report



Curtis-Straus LLC, a wholly owned subsidiary of BV CPS

Report No	ES3054-1
Client	Ideal Industries, Inc.
Address	Becker Place Sycamore, IL 60178
Phone	(815) 895-1295
Items tested	SRC2100
FCC ID	2AAMXSRC2100
IC	11250A-SRC2100
FRN	0002862225
Equipment Type	Digital Transmission System
Equipment Code	DTS
Emission Designator	753KG1D
FCC/IC Rule Parts	CFR Title 47 FCC Part 15.247, ISED Canada RSS-247 Issue 2
Test Dates	October 23-24, 2018 and November 2, 2018
Results	As detailed within this report
Prepared by	 Christopher Bramley – Test Engineer
Authorized by	 Yunus Faziloglu – Sr. Engineer
Issue Date	1/18/2019
Conditions of Issue	This Test Report is issued subject to the conditions stated in the 'Conditions of Testing' section on page 40 of this report.

Curtis-Straus LLC is accredited by the American Association for Laboratory Accreditation for the specific scope of accreditation under Certificate Number 1627-01. This report may contain data which is not covered by the A2LA accreditation.



Curtis-Straus LLC, a wholly owned subsidiary of BV CPS  
One Distribution Center Circle, #1 • Littleton, MA • TEL (978) 486-8880 • FAX (978) 486-8828



**Contents**

Contents.....2

Summary.....3

Test Methodology.....4

Product Tested - Configuration Documentation .....5

Statement of Conformity .....6

Test Results .....7

*6dB Bandwidth*.....7

*Output Power*.....10

*Band Edge (Conducted)*.....13

*Radiated Spurious Emissions* .....15

*Conducted Spurious Emissions* .....24

*Power Spectral Density*.....27

*AC Line Conducted Emissions*.....30

*Occupied Bandwidth*.....36

Measurement Uncertainty.....39

Conditions Of Testing.....40

Form Final Report REV 7-20-07 (DW)



## Summary

This test report supports an application for certification of a transmitter operating pursuant to: CFR Title 47 FCC Part 15.247, ISED Canada RSS-247 Issue 2.

The product is the SRC2100. It is a digitally modulated transmitter that operates in the 902.7 – 927.3MHz frequency range.

Antenna: Non-detachable PCB trace with 3.0dBi gain.

We found that the product met the above requirements without modification. Test samples were received in good condition.

**Test Methodology**

All testing was performed according to the following rules/procedures/documents;  
 CFR Title 47 FCC Part 15.247, ISED Canada RSS-247 Issue 2, ISED Canada RSS-Gen Issue 5, FCC KDB 558074 D01 15.247 Measurement Guidance v05 and ANSI C63.10-2013.

Radiated emissions were maximized by rotating the device around three orthogonal planes (X, Y and Z) as well as varying the test antenna’s height and polarity. X orientation was found to be the worst and all radiated emissions tests were performed in this orientation. AC line conducted emissions testing was performed with a 50Ω/50μH LISN. The EUT operating voltage was 120/277VAC at 60Hz.

RF measurements were performed at the antenna port on 3 channels as follows:

Low channel = 902.7MHz

Mid channel = 915MHz

High channel = 927.3MHz

The following bandwidths were used during radiated spurious and AC line conducted emissions tests:

Frequency	RBW	VBW
0.15-30MHz	9kHz	30kHz
30-1000MHz	120kHz	1MHz
1-10GHz	1MHz	3MHz



**Product Tested - Configuration Documentation**

EUT Configuration										
<b>Work Order:</b>		S3054								
<b>Company:</b>		Ideal Industries								
<b>Company Address:</b>		Becker Place Sycamore, IL 60178								
<b>Contact:</b>		Tim Tunnell								
		MN				SN				
<b>EUT:</b>		SRC2100				Sample 1				
<b>EUT Description:</b>		Single Room Controller								
<b>EUT Tx Frequency:</b>		902.7-927.3MHz								
Port Label	Port Type	# ports	# populated	cable type	shielded	ferrites	length (m)	in/out	under test	comment
AC Mains	Power AC	1	1	Power AC	No	No	1.5	in	yes	
Load	other	1	1	other	No	No	0.1	in	yes	Power output from Single Room Controller to AC Lighting Load
Dim	other	1	1	other	No	No	0.2	in	yes	0-10Vdc Dimming control
<b>Software Operating Mode Description:</b>										
The EUT was set to transmit at Low (902.7MHz), Mid (915MHz), and High (927.3MHz) channels.										



**Statement of Conformity**

RSS-GEN	RSP-100	RSS 247	Part 15	Comments
6.4			15.15(b)	There are no controls accessible to the user that varies the output power to operate in violation of the regulatory requirements.
	3.1		15.19	The label is shown in the label exhibit.
	3.2		15.21	Information to the user is shown in the instruction manual exhibit.
			15.27	No special accessories are required for compliance.
3.2			15.31	The EUT was tested in accordance with the measurement standards in this section.
6.13.2			15.33	Frequency range was investigated according to this section, unless noted in specific rule section under which the equipment operates.
6.13.1			15.35	The EUT emissions were measured using the measurement detector and bandwidth specified in this section, unless noted in specific rule section under which the equipment operates.
6.8			15.203	The antenna for this device is non-detachable PCB trace with 3.0dBi gain.
8.10			15.205 15.209	The fundamental is not in a Restricted band and the spurious and harmonic emissions in the Restricted bands comply with the general emission limits of 15.209 or RSS-Gen as applicable
8.8			15.207	EUT meets the AC Line conducted emissions requirements of this section.
			15.247	The unit complies with the requirements of 15.247
		RSS 247		The unit complies with the requirements of RSS-247
6.7				Occupied Bandwidth measurements were made.



## Test Results

### 6dB Bandwidth

#### LIMIT

The minimum 6 dB bandwidth shall be at least 500 kHz. [15.247(a) (2)]

### MEASUREMENTS / RESULTS

6dB Bandwidth					
Date: 02-Nov-18		Company: Ideal Industries, Inc.		Work Order: S3054	
Engineer: Chris Bramley		EUT: SRC2100		Operating Voltage/Frequency: 120V/60Hz	
Temp: 23.1°C		Humidity: 49%		Pressure: 998mBar	
Frequency Range: 900-930MHz			Measurement Type: Conducted		
Measurement Method: FCC 558074 D01 DTS Meas Guidance v05					
Notes:					
Frequency (MHz)	Reading (kHz)	6dB Bandwidth			
		Limit (kHz)	Margin (kHz)	Result (Pass/Fail)	
902.7	651.8	≥500	152	Pass	
915	652.9	≥500	153	Pass	
927.3	653.5	≥500	154	Pass	
Test Site: CEMI-3		Cable: Asset 2289		40dB Attenuator: Asset 2096	
Analyzer: EXA 1118473		Copyright Curtis-Straus LLC 2000			


Rev. 10/31/2018

Spectrum Analyzers / Receivers/Preselectors	Range	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on
Rental EXA Signal Analyzer(1118473)	9KHz-26.5GHz	N9010A-526;N	AT	MY51170076	1118473	I	6/19/2019	6/19/2018
Conducted Test Sites (Mains / Telco)	FCC Code		VCCI Code			Cat	Calibration Due	Calibrated on
CEMI 3	719150		A-0015			III	NA	N/A
Meteorological Meters/Chambers		MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on
Weather Clock (Pressure Only)		BA928	Oregon Scientific	C3166-1	831	I	5/15/2020	5/15/2018
TH A#2078		HTC-1	HDE		2078	II	3/22/2019	3/22/2018
Cables	Range		Mfr			Cat	Calibration Due	Calibrated on
Asset #2289	9KHz-26.5GHz	FLC-1.5FT-SMSM+	Mini-Circuits	16021029		II	1/29/2019	1/29/2018
Preamps /Couplers Attenuators / Filters	Range	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on
40dB 100W Attenuator	0.009-4000MHz	BW-40N100W+	Mini-Circuits	V N383401508	2096	II	10/9/2019	10/9/2018


All equipment is calibrated using standards traceable to NIST or other nationally recognized calibration standard.



PLOT(S)




6dB Bandwidth – Low Channel



6dB Bandwidth – Mid Channel





6dB Bandwidth – High Channel

**Output Power**

**LIMIT**

Conducted Output Power

1 Watt

[15.247(b) (3)]

Per ANSI C63.10 – 2013 Section 11.9.2.2.2 Method AVGSA-1

**MEASUREMENTS / RESULTS**

Peak Output Power								
Date: 02-Nov-18		Company: Ideal Industries, Inc.			Work Order: S3054			
Engineer: Chris Bramley		EUT: SRC2100			Operating Voltage/Frequency: 120V/60Hz			
Temp: 23.1°C		Humidity: 49%		Pressure: 998mBar				
Frequency Range: 900-930MHz				Measurement Type: Conducted				
					Measurement Method: FCC 558074 D01 DTS Meas Guidance v05			
Notes: Average Method Used - 8.3.2.2 Method AVGSA-1								
Frequency (MHz)	Peak Reading (dBm)	Cable Loss (dB)	Attenuator Loss (dB)	Peak Output Power (dBm)	Average Limit (dBm)	Margin (dB)	Result (Pass/Fail)	
902.7	-22.96	0.17	38.50	15.71	30	-14.29	Pass	
915.0	-24.25	0.17	38.50	14.42	30	-15.58	Pass	
927.3	-25.20	0.17	38.50	13.47	30	-16.53	Pass	
Test Site: CEMI-3		Cable: Asset 2289		40dB Attenuator: Asset 2096				
Analyzer: EXA 1118473								
Peak Output Power (dBm) = Peak Reading (dBm) + Cable Loss (dB) + Attenuator Loss (dB)						Copyright Curtis-Straus LLC 2000		


Rev. 10/31/2018

Spectrum Analyzers / Receivers / Preselectors	Range	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on
Rental EXA Signal Analyzer(1118473)	9KHz-26.5GHz	N9010A-526;N	AT	MY51170076	1118473	I	6/19/2019	6/19/2018
Conducted Test Sites (Mains / Telco)	FCC Code	VCCI Code		Cat	Calibration Due	Calibrated on		
CEMI 3	719150	A-0015		III	NA	N/A		
Meteorological Meters/Chambers	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on	
Weather Clock (Pressure Only) TH A#2078	BA928 HTC-1	Oregon Scientific HDE	C3166-1	831 2078	I II	5/15/2020 3/22/2019	5/15/2018 3/22/2018	
Cables	Range	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on	
Asset #2289	9KHz-26.5GHz	FLC-1.5FT-SMSM+	Mini-Circuits	16021029	II	1/29/2019	1/29/2018	
Preamps / Couplers Attenuators / Filters	Range	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on
40dB 100W Attenuator	0.009-4000MHz	BW-40N100W+	Mini-Circuits	V N383401508	2096	II	10/9/2019	10/9/2018


All equipment is calibrated using standards traceable to NIST or other nationally recognized calibration standard.



PLOTS



Channel Power – Low Channel



Channel Power – Mid Channel



Channel Power – High Channel

**Band Edge (Conducted)**

Band Edge readings must be more than 30dB below the value of the fundamental.

**MEASUREMENTS / RESULTS**

Conducted Bandedge				
Date: 02-Nov-18		Company: Ideal Industries, Inc.		Work Order: S3054
Engineer: Chris Bramley		EUT: SRC2100		Operating Voltage/Frequency: 120V/60Hz
Temp: 23.1°C		Humidity: 49%		Pressure: 998mBar
Frequency Range: 902-928 MHz			Measurement Type: Conducted	
Notes:				
		Bandedge Delta (dB)		Limit (dB)
				Result (Pass/Fail)
902.7MHz	Low Bandedge	36.0		≥ 30
927.3MHz	High Bandedge	37.5		≥ 30
Test Site: CEMI-3		Cable: Asset 2289		40dB Attenuator: Asset 2096
Analyzer: EXA 1118473		Copyright Curtis-Straus LLC 2000		


Rev. 10/31/2018

Spectrum Analyzers / Receivers / Preselectors	Range	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on
Rental EXA Signal Analyzer(1118473)	9KHz-26.5GHz	N9010A-526;N	AT	MY51170076	1118473	I	6/19/2019	6/19/2018
Conducted Test Sites (Mains / Telco)	FCC Code	VCCI Code		Cat	Calibration Due	Calibrated on		
CEMI 3	719150	A-0015		III	NA	N/A		
Meteorological Meters/Chambers		MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on
Weather Clock (Pressure Only)		BA928	Oregon Scientific	C3166-1	831	I	5/15/2020	5/15/2018
TH A#2078		HTC-1	HDE		2078	II	3/22/2019	3/22/2018
Cables	Range		Mfr			Cat	Calibration Due	Calibrated on
Asset #2289	9KHz-26.5GHz	FLC-1.5FT-SMSM+	Mini-Circuits	16021029		II	1/29/2019	1/29/2018
Preamps / Couplers Attenuators / Filters	Range	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on
40dB 100W Attenuator	0.009-4000MHz	BW-40N100W+	Mini-Circuits	V N383401508	2096	II	10/9/2019	10/9/2018


All equipment is calibrated using standards traceable to NIST or other nationally recognized calibration standard.



PLOTS



Low Band Edge



High Band Edge



## ***Radiated Spurious Emissions***

### **LIMITS**

*In any 100 kHz bandwidth outside the frequency band in which the spread spectrum or digitally modulated intentional radiator is operating, the radio frequency power that is produced by the intentional radiator shall be at least 20 dB below that in the 100 kHz bandwidth within the band that contains the highest level of the desired power, based on either an RF conducted or a radiated measurement, provided the transmitter demonstrates compliance with the peak conducted power limits. If the transmitter complies with the conducted power limits based on the use of RMS averaging over a time interval, as permitted under paragraph (b)(3) of this section, the attenuation required under this paragraph shall be 30 dB instead of 20 dB. Attenuation below the general limits specified in §15.209(a) is not required. In addition, radiated emissions which fall in the restricted bands, as defined in §15.205(a), must also comply with the radiated emission limits specified in §15.209(a) (see §15.205(c)).*

[15.247(d)]

**MEASUREMENTS / RESULTS**

**Digital Modulation, 40Kbps for all channels**

Curtis Straus - a Bureau Veritas Company	Work Order - S3054
Radiated Emissions Electric Field 3m Distance	EUT Power Input - 120V 60Hz
Top Peaks Vertical 30-1000MHz	Test Site - CH2
Operator: CCH	Conditions - 23.4°C; 35%RH; 1002mBar
Notes:	Witnessed by - N/A
902MHz Low channel	EUT Maximum Frequency - 927MHz

Data Taken at October 24, 2018

Frequency (MHz)	Peak Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Lim1: FCC_pt15_2 09 (dBµV/m)	Lim1 Margin (dB)	Lim1 Test Results (Pass/Fail)	Worst Margin Lim1 (dB)
30.073	29.4	-7.6	21.8	40	-18.2	PASS	
210.105	40.2	-18.1	22	43.5	-21.5	PASS	
216.652	39.6	-17.7	21.9	46	-24.1	PASS	
218.18	39.5	-17.6	21.9	46	-24.1	PASS	
219.853	39.4	-17.5	21.9	46	-24.1	PASS	
759.052	32.7	-3.4	29.4	46	-16.6	PASS	-16.6

Curtis Straus - a Bureau Veritas Company	Work Order - S3054
Radiated Emissions Electric Field 3m Distance	EUT Power Input - 120V 60Hz
Top Peaks Horizontal 30-1000MHz	Test Site - CH2
Operator: CCH	Conditions - 23.4°C; 35%RH; 1002mBar
Notes:	Witnessed by - N/A
902MHz Low channel	EUT Maximum Frequency - 927MHz

Data Taken at October 24, 2018

Frequency (MHz)	Peak Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Lim1: FCC_pt15_2 09 (dBµV/m)	Lim1 Margin (dB)	Lim1 Test Results (Pass/Fail)	Worst Margin Lim1 (dB)
366.008	35.8	-13	22.8	46	-23.2	PASS	
370.931	35.8	-12.9	22.9	46	-23.1	PASS	
372.483	36.5	-12.9	23.6	46	-22.4	PASS	
374.083	36.8	-12.9	23.9	46	-22.1	PASS	
375.732	36.9	-12.9	24.1	46	-21.9	PASS	
813.93	31.4	-2.4	29	46	-17	PASS	-17





Curtis Straus - a Bureau Veritas Company Work Order - S3054  
 Radiated Emissions Electric Field 3m Distance EUT Power Input - 120V 60Hz  
 Top Peaks Vertical 30-1000MHz Test Site - CH2  
 Operator: CCH Conditions - 23.4°C; 35%RH; 1002mBar  
 Notes: Witnessed by - N/A  
 915MHz mid channel EUT Maximum Frequency - 927MHz

Data Taken at October 24, 2018

Frequency (MHz)	Peak Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Lim1: FCC_pt15_2 09 (dBµV/m)	Lim1 Margin (dB)	Lim1 Test Results (Pass/Fail)	Worst Margin Lim1 (dB)
206.807	39.2	-17.6	21.6	43.5	-21.9	PASS	
208.456	39.8	-17.9	21.9	43.5	-21.6	PASS	
216.749	39.6	-17.7	21.9	46	-24.1	PASS	
218.326	39.9	-17.6	22.3	46	-23.7	PASS	
219.926	40	-17.5	22.5	46	-23.5	PASS	
797.876	31.8	-2.7	29.1	46	-16.9	PASS	-16.9

Curtis Straus - a Bureau Veritas Company Work Order - S3054  
 Radiated Emissions Electric Field 3m Distance EUT Power Input - 120V 60Hz  
 Top Peaks Horizontal 30-1000MHz Test Site - CH2  
 Operator: CCH Conditions - 23.4°C; 35%RH; 1002mBar  
 Notes: Witnessed by - N/A  
 915MHz mid channel EUT Maximum Frequency - 927MHz

Data Taken at October 24, 2018

Frequency (MHz)	Peak Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Lim1: FCC_pt15_2 09 (dBµV/m)	Lim1 Margin (dB)	Lim1 Test Results (Pass/Fail)	Worst Margin Lim1 (dB)
372.701	37.2	-12.9	24.3	46	-21.7	PASS	
374.253	37.6	-12.9	24.7	46	-21.3	PASS	
375.902	38.2	-12.9	25.3	46	-20.7	PASS	
377.527	36.1	-12.8	23.3	46	-22.7	PASS	
379.976	35.8	-12.7	23.1	46	-22.9	PASS	
778.622	31.8	-2.7	29.1	46	-16.9	PASS	-16.9



Curtis Straus - a Bureau Veritas Company Work Order - S3054  
 Radiated Emissions Electric Field 3m Distance EUT Power Input - 120V 60Hz  
 Top Peaks Vertical 30-1000MHz Test Site - CH2  
 Operator: CCH Conditions - 23.4°C; 35%RH; 1002mBar  
 Notes: Witnessed by - N/A  
 927MHz high channel EUT Maximum Frequency - 927MHz

Data Taken at October 24, 2018

Frequency (MHz)	Peak Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Lim1: FCC_pt15_2 09 (dBµV/m)	Lim1 Margin (dB)	Lim1 Test Results (Pass/Fail)	Worst Margin Lim1 (dB)
214.979	40.4	-17.8	22.5	43.5	-21	PASS	
216.604	39.9	-17.7	22.1	46	-23.9	PASS	
218.131	39.5	-17.6	21.9	46	-24.1	PASS	
219.15	39.7	-17.6	22.2	46	-23.8	PASS	
220.702	39.1	-17.5	21.6	46	-24.4	PASS	
799.186	31.8	-2.7	29.1	46	-16.9	PASS	-16.9

Curtis Straus - a Bureau Veritas Company Work Order - S3054  
 Radiated Emissions Electric Field 3m Distance EUT Power Input - 120V 60Hz  
 Top Peaks Horizontal 30-1000MHz Test Site - CH2  
 Operator: CCH Conditions - 23.4°C; 35%RH; 1002mBar  
 Notes: Witnessed by - N/A  
 927MHz high channel EUT Maximum Frequency - 927MHz

Data Taken at October 24, 2018

Frequency (MHz)	Peak Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Lim1: FCC_pt15_2 09 (dBµV/m)	Lim1 Margin (dB)	Lim1 Test Results (Pass/Fail)	Worst Margin Lim1 (dB)
366.517	35.7	-13	22.7	46	-23.3	PASS	
369.743	35.7	-12.9	22.8	46	-23.2	PASS	
373.016	36.9	-12.9	24	46	-22	PASS	
374.908	35.6	-12.9	22.7	46	-23.3	PASS	
376.217	36	-12.9	23.1	46	-22.9	PASS	
781.071	31.8	-2.6	29.1	46	-16.9	PASS	-16.9



Curtis Straus - a Bureau Veritas Company Radiated Emissions Electric Field 3m Distance 1-6GHz Vertical Data Operator: CCH Notes: 902MHz Low channel	Work Order - S3054 EUT Power Input - 120V 60Hz Test Site - CH2 Conditions - 23.4°C; 35%RH; 1002mBar Witnessed by - N/A EUT Maximum Frequency - 927MHz
--	--

Data Taken at October 24, 2018

Frequency (MHz)	Raw Peak Reading (dBµV)	Raw Avg Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Pk Lim: FCC_pt15_2 09_Peak (dBµV/m)	Peak Margin (dB)	Peak Results (Pass/Fail)	Worst Peak Margin (dB)	Adjusted Avg Amplitude (dBµV/m)	Av Lim: FCC_pt15_2 09_Average (dBµV/m)	Avg Margin (dB)	Avg Results (Pass/Fail)	Worst Avg Margin (dB)
3227.6	41.2	32.6	2.1	43.4	74	-30.6	PASS		34.7	54	-19.3	PASS	
4221	39.6	31.2	3.3	42.9	74	-31.1	PASS		34.6	54	-19.4	PASS	
5762.6	40.3	30.9	6.3	46.6	74	-27.4	PASS	-27.4	37.2	54	-16.8	PASS	-16.8

Curtis Straus - a Bureau Veritas Company Radiated Emissions Electric Field 3m Distance 1-6GHz Horizontal Data Operator: CCH Notes: 902MHz Low channel	Work Order - S3054 EUT Power Input - 120V 60Hz Test Site - CH2 Conditions - 23.4°C; 35%RH; 1002mBar Witnessed by - N/A EUT Maximum Frequency - 927MHz
--	--

Data Taken at October 24, 2018

Frequency (MHz)	Raw Peak Reading (dBµV)	Raw Avg Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Pk Lim: FCC_pt15_2 09_Peak (dBµV/m)	Peak Margin (dB)	Peak Results (Pass/Fail)	Worst Peak Margin (dB)	Adjusted Avg Amplitude (dBµV/m)	Av Lim: FCC_pt15_2 09_Average (dBµV/m)	Avg Margin (dB)	Avg Results (Pass/Fail)	Worst Average Margin (dB)
3519.5	41.6	32.6	2.7	44.3	74	-29.7	PASS		35.3	54	-18.7	PASS	
5930	39.5	30.8	6.8	46.4	74	-27.6	PASS	-27.6	37.6	54	-16.4	PASS	-16.4

Curtis Straus - a Bureau Veritas Company Radiated Emissions Electric Field 3m Distance 1-6GHz Vertical Data Operator: CCH Notes: 915MHz mid channel	Work Order - S3054 EUT Power Input - 120V 60Hz Test Site - CH2 Conditions - 23.4°C; 35%RH; 1002mBar Witnessed by - N/A EUT Maximum Frequency - 927MHz
--	--

Data Taken at October 24, 2018

Frequency (MHz)	Raw Peak Reading (dBµV)	Raw Avg Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Pk Lim: FCC_pt15_2 09_Peak (dBµV/m)	Peak Margin (dB)	Peak Results (Pass/Fail)	Worst Peak Margin (dB)	Adjusted Avg Amplitude (dBµV/m)	Av Lim: FCC_pt15_2 09_Average (dBµV/m)	Avg Margin (dB)	Avg Results (Pass/Fail)	Worst Avg Margin (dB)
3525.4	42.2	32.7	2.6	44.8	74	-29.2	PASS		35.3	54	-18.7	PASS	
5907.9	39.5	30.9	6.8	46.4	74	-27.6	PASS	-27.6	37.7	54	-16.3	PASS	-16.3



Curtis Straus - a Bureau Veritas Company						Work Order - S3054							
Radiated Emissions Electric Field 3m Distance						EUT Power Input - 120V 60Hz							
1-6GHz Horizontal Data						Test Site - CH2							
Operator: CCH						Conditions - 23.4°C; 35%RH; 1002mBar							
Notes:						Witnessed by - N/A							
915MHz mid channel						EUT Maximum Frequency - 927MHz							
Data Taken at October 24, 2018													
Frequency (MHz)	Raw Peak Reading (dBµV)	Raw Avg Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Pk Lim: FCC_pt15_2 09_Peak (dBµV/m)	Peak Margin (dB)	Peak Results (Pass/Fail)	Worst Peak Margin (dB)	Adjusted Avg Amplitude (dBµV/m)	Av Lim: FCC_pt15_2 09_Average (dBµV/m)	Avg Margin (dB)	Avg Results (Pass/Fail)	Worst Average Margin (dB)
3471.4	42.3	32.6	2.3	44.6	74	-29.4	PASS		34.9	54	-19.1	PASS	
4229.9	40.9	31.3	3.3	44.2	74	-29.8	PASS		34.5	54	-19.5	PASS	
5885.6	38.5	30.8	6.7	45.2	74	-28.8	PASS	-28.8	37.6	54	-16.4	PASS	-16.4

Curtis Straus - a Bureau Veritas Company						Work Order - S3054							
Radiated Emissions Electric Field 3m Distance						EUT Power Input - 120V 60Hz							
1-6GHz Vertical Data						Test Site - CH2							
Operator: CCH						Conditions - 23.4°C; 35%RH; 1002mBar							
Notes:						Witnessed by - N/A							
927MHz high channel						EUT Maximum Frequency - 927MHz							
Data Taken at October 24, 2018													
Frequency (MHz)	Raw Peak Reading (dBµV)	Raw Avg Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Pk Lim: FCC_pt15_2 09_Peak (dBµV/m)	Peak Margin (dB)	Peak Results (Pass/Fail)	Worst Peak Margin (dB)	Adjusted Avg Amplitude (dBµV/m)	Av Lim: FCC_pt15_2 09_Average (dBµV/m)	Avg Margin (dB)	Avg Results (Pass/Fail)	Worst Avg Margin (dB)
1204	40.1	32.3	-4.2	35.9	74	-38.1	PASS		28.1	54	-25.9	PASS	
3558.9	42.9	32.6	2.4	45.3	74	-28.7	PASS		35	54	-19	PASS	
5874.9	40.4	30.8	6.7	47.1	74	-26.9	PASS	-26.9	37.5	54	-16.5	PASS	-16.5

Curtis Straus - a Bureau Veritas Company						Work Order - S3054							
Radiated Emissions Electric Field 3m Distance						EUT Power Input - 120V 60Hz							
1-6GHz Horizontal Data						Test Site - CH2							
Operator: CCH						Conditions - 23.4°C; 35%RH; 1002mBar							
Notes:						Witnessed by - N/A							
927MHz high channel						EUT Maximum Frequency - 927MHz							
Data Taken at October 24, 2018													
Frequency (MHz)	Raw Peak Reading (dBµV)	Raw Avg Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Pk Lim: FCC_pt15_2 09_Peak (dBµV/m)	Peak Margin (dB)	Peak Results (Pass/Fail)	Worst Peak Margin (dB)	Adjusted Avg Amplitude (dBµV/m)	Av Lim: FCC_pt15_2 09_Average (dBµV/m)	Avg Margin (dB)	Avg Results (Pass/Fail)	Worst Average Margin (dB)
3477.4	42.6	32.6	2.4	45	74	-29	PASS		35	54	-19	PASS	
4207.7	39.7	31.3	3.4	43.1	74	-30.9	PASS		34.7	54	-19.3	PASS	
5675.3	39.2	30.8	5.9	45	74	-29	PASS	-29	36.7	54	-17.3	PASS	-17.3



Curtis Straus - a Bureau Veritas Company Radiated Emissions Electric Field 1m Distance 6-18GHz Vertical Data Operator: CCH Notes: 902MHz Low channel	Work Order - S3054 EUT Power Input - 120V 60Hz Test Site - CH2 Conditions - 23.4°C; 35%RH; 1002mBar Witnessed by - N/A EUT Maximum Frequency - 927MHz
---	--

Data Taken at October 24, 2018

Frequency (MHz)	Raw Peak Reading (dBµV)	Raw Avg Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Pk Lim: FCC_pt15_2 09_Peak (dBµV/m)	Peak Margin (dB)	Peak Results (Pass/Fail)	Worst Peak Margin (dB)	Adjusted Avg Amplitude (dBµV/m)	Av Lim: FCC_pt15_2 09_Average (dBµV/m)	Avg Margin (dB)	Avg Results (Pass/Fail)	Worst Avg Margin (dB)
8710.2	37.9	30	14.1	52	83.5	-31.5	PASS		44.1	63.5	-19.4	PASS	
9942	39.4	30.3	16.3	55.7	83.5	-27.8	PASS	-27.8	46.7	63.5	-16.8	PASS	-16.8

Curtis Straus - a Bureau Veritas Company Radiated Emissions Electric Field 1m Distance 6-18GHz Horizontal Data Operator: CCH Notes: 902MHz Low channel	Work Order - S3054 EUT Power Input - 120V 60Hz Test Site - CH2 Conditions - 23.4°C; 35%RH; 1002mBar Witnessed by - N/A EUT Maximum Frequency - 927MHz
---	--

Data Taken at October 24, 2018

Frequency (MHz)	Raw Peak Reading (dBµV)	Raw Avg Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Pk Lim: FCC_pt15_2 09_Peak (dBµV/m)	Peak Margin (dB)	Peak Test Results (Pass/Fail)	Worst Peak Margin (dB)	Adjusted Avg Amplitude (dBµV/m)	Av Lim: FCC_pt15_2 09_Average (dBµV/m)	Avg Margin (dB)	Avg Test Results (Pass/Fail)	Worst Avg Margin (dB)
8688.4	38.2	30.1	14	52.3	83.5	-31.2	PASS		44.1	63.5	-19.4	PASS	
9964	40.1	30.4	16.2	56.3	83.5	-27.2	PASS	-27.2	46.6	63.5	-16.9	PASS	-16.9

Curtis Straus - a Bureau Veritas Company Radiated Emissions Electric Field 1m Distance 6-18GHz Vertical Data Operator: CCH Notes: 915MHz mid channel	Work Order - S3054 EUT Power Input - 120V 60Hz Test Site - CH2 Conditions - 23.4°C; 35%RH; 1002mBar Witnessed by - N/A EUT Maximum Frequency - 927MHz
---	--

Data Taken at October 24, 2018

Frequency (MHz)	Raw Peak Reading (dBµV)	Raw Avg Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Pk Lim: FCC_pt15_2 09_Peak (dBµV/m)	Peak Margin (dB)	Peak Results (Pass/Fail)	Worst Peak Margin (dB)	Adjusted Avg Amplitude (dBµV/m)	Av Lim: FCC_pt15_2 09_Average (dBµV/m)	Avg Margin (dB)	Avg Results (Pass/Fail)	Worst Avg Margin (dB)
6536.6	39.2	30.3	12.6	51.8	83.5	-31.7	PASS		42.9	63.5	-20.6	PASS	
9989.5	40.3	30.6	16	56.3	83.5	-27.2	PASS	-27.2	46.6	63.5	-16.9	PASS	-16.9



Curtis Straus - a Bureau Veritas Company				Work Order - S3054									
Radiated Emissions Electric Field 1m Distance				EUT Power Input - 120V 60Hz									
6-18GHz Horizontal Data				Test Site - CH2									
Operator: CCH				Conditions - 23.4°C; 35%RH; 1002mBar									
Notes:				Witnessed by - N/A									
915MHz mid channel				EUT Maximum Frequency - 927MHz									
Data Taken at October 24, 2018													
Frequency (MHz)	Raw Peak Reading (dBµV)	Raw Avg Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Pk Lim: FCC_pt15_2 09_Peak (dBµV/m)	Peak Margin (dB)	Peak Test Results (Pass/Fail)	Worst Peak Margin (dB)	Adjusted Avg Amplitude (dBµV/m)	Av Lim: FCC_pt15_2 09_Average (dBµV/m)	Avg Margin (dB)	Avg Test Results (Pass/Fail)	Worst Avg Margin (dB)
9728	38.4	30	16.2	54.6	83.5	-28.9	PASS	-28.9	46.2	63.5	-17.3	PASS	-17.3

Curtis Straus - a Bureau Veritas Company				Work Order - S3054									
Radiated Emissions Electric Field 1m Distance				EUT Power Input - 120V 60Hz									
6-18GHz Vertical Data				Test Site - CH2									
Operator: CCH				Conditions - 23.4°C; 35%RH; 1002mBar									
Notes:				Witnessed by - N/A									
927MHz high channel				EUT Maximum Frequency - 927MHz									
Data Taken at October 24, 2018													
Frequency (MHz)	Raw Peak Reading (dBµV)	Raw Avg Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Pk Lim: FCC_pt15_2 09_Peak (dBµV/m)	Peak Margin (dB)	Peak Test Results (Pass/Fail)	Worst Peak Margin (dB)	Adjusted Avg Amplitude (dBµV/m)	Av Lim: FCC_pt15_2 09_Average (dBµV/m)	Avg Margin (dB)	Avg Test Results (Pass/Fail)	Worst Avg Margin (dB)
9959.5	39.5	30.4	16.2	55.8	83.5	-27.7	PASS	-27.7	46.6	63.5	-16.9	PASS	-16.9

Curtis Straus - a Bureau Veritas Company				Work Order - S3054									
Radiated Emissions Electric Field 1m Distance				EUT Power Input - 120V 60Hz									
6-18GHz Horizontal Data				Test Site - CH2									
Operator: CCH				Conditions - 23.4°C; 35%RH; 1002mBar									
Notes:				Witnessed by - N/A									
927MHz high channel				EUT Maximum Frequency - 927MHz									
Data Taken at October 24, 2018													
Frequency (MHz)	Raw Peak Reading (dBµV)	Raw Avg Reading (dBµV)	Correction Factor (dB/m)	Adjusted Peak Amplitude (dBµV/m)	Pk Lim: FCC_pt15_2 09_Peak (dBµV/m)	Peak Margin (dB)	Peak Test Results (Pass/Fail)	Worst Peak Margin (dB)	Adjusted Avg Amplitude (dBµV/m)	Av Lim: FCC_pt15_2 09_Average (dBµV/m)	Avg Margin (dB)	Avg Test Results (Pass/Fail)	Worst Avg Margin (dB)
8731.6	38.9	29.9	14	53	83.5	-30.5	PASS		44	63.5	-19.5	PASS	
9917.3	38.6	30.2	16.5	55.1	83.5	-28.4	PASS	-28.4	46.6	63.5	-16.9	PASS	-16.9



Rev. 10/23/2018

<b>Spectrum Analyzers / Receivers / Preselectors</b>		<b>Range</b>	<b>MN</b>	<b>Mfr</b>	<b>SN</b>	<b>Asset</b>	<b>Cat</b>	<b>Calibration Due</b>	<b>Calibrated on</b>
2093 MXE EMI Receiver		20Hz-26.5GHz	N9038A	Agilent	MY51210181	2093	I	11/16/2018	11/16/2017
<b>Radiated Emissions Sites</b>		<b>FCC Code</b>	<b>IC Code</b>	<b>VCCI Code</b>	<b>Range</b>	<b>Asset</b>	<b>Cat</b>	<b>Calibration Due</b>	<b>Calibrated on</b>
EMI Chamber 2		719150	2762A-7	A-0015	30-1000MHz	1686	I	12/21/2018	12/21/2016
EMI Chamber 2		719150	2762A-7	A-0015	1-18GHz	1686	I	12/21/2018	12/21/2016
<b>Preamps / Couplers Attenuators / Filters</b>		<b>Range</b>	<b>MN</b>	<b>Mfr</b>	<b>SN</b>	<b>Asset</b>	<b>Cat</b>	<b>Calibration Due</b>	<b>Calibrated on</b>
2310 PA		1-1000MHz	PAM-103	COM-POWER	441175	2310	II	10/29/2018	10/29/2017
2111 HF Preamp		0.5-18GHz	PAM-118A	COM-POWER	551063	2111	II	11/19/2018	11/19/2017
<b>Antennas</b>		<b>Range</b>	<b>MN</b>	<b>Mfr</b>	<b>SN</b>	<b>Asset</b>	<b>Cat</b>	<b>Calibration Due</b>	<b>Calibrated on</b>
Red-Brown Bilog		30-2000MHz	JB1	Sunol	A0032406	1218	I	1/13/2019	1/13/2017
Blue Horn		1-18Ghz	3117	ETS	157647	1861	I	2/14/2019	2/14/2017
<b>Meteorological Meters/Chambers</b>			<b>MN</b>	<b>Mfr</b>	<b>SN</b>	<b>Asset</b>	<b>Cat</b>	<b>Calibration Due</b>	<b>Calibrated on</b>
Weather Clock (Pressure Only)			BA928	Oregon Scientific	C3166-1	831	I	5/15/2020	5/15/2018
TH A#2082			HTC-1	HDE		2082	II	3/22/2019	3/22/2018
<b>Cables</b>		<b>Range</b>		<b>Mfr</b>			<b>Cat</b>	<b>Calibration Due</b>	<b>Calibrated on</b>
Asset #2051		9kHz - 18GHz		Florida RF			II	3/7/2019	3/7/2018
Asset #2054		9kHz - 18GHz		Florida RF			II	10/31/2018	10/31/2017
Asset #2464		9KHz-18GHz		MegaPhase			II	10/29/2018	10/29/2017

All equipment is calibrated using standards traceable to NIST or other nationally recognized calibration standard.

### Test Equipment Used



## Conducted Spurious Emissions


### LIMITS

In any 100 kHz bandwidth outside the frequency band in which the spread spectrum or digitally modulated intentional radiator is operating, the radio frequency power that is produced by the intentional radiator shall be at least 20dB below that in the 100kHz bandwidth that contains the highest level of desired power based on either an RF conducted or a radiated measurement, provided the transmitter demonstrates compliance with the peak conducted power limits. If the transmitter complies with the conducted power limits based on the use of RMS averaging over a time interval, as permitted under paragraph (b)(3) of this section, the attenuation required under this paragraph shall be 30 dB instead of 20 dB ...

[15.247(d)]


Conducted spurious emissions at the antenna port were measured in accordance with ANSI C63.10-2013 Section 11.11.

Frequency range up to 10GHz was investigated for all 3 channels (low, middle and high) at the EUT antenna port. No emissions within 30dB of their corresponding fundamental were found.




Low Channel





Mid Channel



High Channel



Rev. 10/22/2018

	Range	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on
<b>Spectrum Analyzers / Receivers/Preselectors</b> Rental EXA Signal Analyzer(1118472)	9KHz-26.5GHz	N9010A-526;K	AT	MY51170010	1118472	I	8/10/2019	8/10/2018
<b>Preamps/Couplers Attenuators / Filters</b> API - 30dB 20W Attenuator	9KHz-40GHz	89-30-11	API Weinschel	703	2121	I	3/23/2019	3/23/2018
<b>Meteorological Meters/Chambers</b> Weather Clock (Pressure Only) TH A#2084		MN BA928 HTC-1	Mfr Oregon Scientific HDE	SN C3166-1	Asset 831 2084	Cat I II	Calibration Due 5/15/2020 3/22/2019	Calibrated on 5/15/2018 3/22/2018
<b>Cables</b> Asset #2289	9KHz-26.5GHz	FLC-1.5FT-SMSM+	Mfr Mini-Circuits	SN 16021039		Cat II	Calibration Due 1/29/2019	Calibrated on 1/29/2018

All equipment is calibrated using standards traceable to NIST or other nationally recognized calibration standard.



# Power Spectral Density

## LIMIT

...the power spectral density conducted from the intentional radiator to the antenna shall not be greater than 8dBm in any 3 kHz band during any time interval of continuous transmission.  
[15.247(e)]

## MEASUREMENTS / RESULTS

Peak Power Spectral Density								
Date: 02-Nov-18		Company: Ideal Industries, Inc.			Work Order: S3054			
Engineer: Chris Bramley		EUT: SRC2100			Operating Voltage/Frequency: 120V/60Hz			
Temp: 23.1°C		Humidity: 49%		Pressure: 998mBar				
Frequency Range: 900-930MHz			Measurement Type: Conducted					
						Measurement Method: FCC 558074 D01 DTS Meas Guidance v05		
Notes: Average Method Used - 8.4 Method AVGPSSD-1								
Frequency (MHz)	Peak Reading (dBm)	Cable Loss (dB)	Attenuator Loss (dB)	Peak PSD (dBm)	Average Limit (dBm)	Margin (dB)	Result	
902.7	-32.94	0.17	38.5	5.73	8.0	-2.27	Pass	
915.0	-33.98	0.17	38.5	4.69	8.0	-3.31	Pass	
927.3	-35.25	0.17	38.5	3.42	8.0	-4.58	Pass	
Test Site: CEMI-3		Cable: Asset 2289		40dB Attenuator: Asset 2096				
Analyzer: EXA 1118473		Copyright Curtis-Straus LLC 2000						
PSD(dBm) = Reading (dBm) + Cable Loss (dB) + Attenuator Loss (dBm)								


Rev. 10/31/2018

Spectrum Analyzers / Receivers/Preselectors	Range	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on	
Rental EXA Signal Analyzer(1118473)	9KHz-26.5GHz	N9010A-526;N	AT	MY51170076	1118473	I	6/19/2019	6/19/2018	
Conducted Test Sites (Mains / Telco)	FCC Code	VCCI Code		Cat	Calibration Due	Calibrated on			
CEMI 3	719150	A-0015		III	NA	N/A			
Meteorological Meters/Chambers	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on		
Weather Clock (Pressure Only) TH A#2078	BA928 HTC-1	Oregon Scientific HDE	C3166-1	831 2078	I II	5/15/2020 3/22/2019	5/15/2018 3/22/2018		
Cables	Range	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on		
Asset #2289	9KHz-26.5GHz	FLC-1.5FT-SMSM+	Mini-Circuits	16021029	II	1/29/2019	1/29/2018		
Preamps/Couplers Attenuators / Filters	Range	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on	
40dB 100W Attenuator	0.009-4000MHz	BW-40N100W+	Mini-Circuits	V N383401508	2096	II	10/9/2019	10/9/2018	


All equipment is calibrated using standards traceable to NIST or other nationally recognized calibration standard.



PLOTS




PSD – Low Channel



PSD – Mid Channel





PSD – High Channel



**AC Line Conducted Emissions  
LIMITS**

Frequency of emission (MHz)	Quasi-peak limit (dB $\mu$ V)	Average limit (dB $\mu$ V)
0.15-0.5	66 to 56*	56 to 46*
0.5-5	56	46
5-30	60	50

\*Decreases with the logarithm of the frequency.

[47 CFR 15.207(a)]

**MEASUREMENTS / RESULTS**

Curtis Straus - a Bureau Veritas Company  
 Conducted Emissions per CISPR 16-2-1  
 Quasi-peak Detector Data  
 Notes:  
 EUT Line tested: 120VAC/60Hz; Phase  
 EUT Mode of Operation: Tx on Low Channel (902.7MHz)

Work Order # - S3054  
 EUT Power Input - 120VAC/ 60Hz  
 Test Site - CEMI-3  
 Conditions: - 22.9°C; 51%RH; 998mBar  
 Test Engineer - Chris Bramley  
 Witnessed by - N/A

Data Taken at 05:53:01 PM, Friday, November 02, 2018

Frequency (MHz)	Raw QP Reading (dBµV)	Correction Factor (dB)	Adjusted QP Amplitude (dBµV)	QP Lim: Mains_FCC&CISPR_QP_Class_B (dBµV)	Margin to QP Limit (dB)	QP Limit Results (Pass/Fail)	Worst Margin (QP Limit) (dB)
0.513	32.144	18.7	50.9	56	-5.1	PASS	-5.1
0.598	30.47	18.7	49.2	56	-6.8	PASS	
0.854	30.484	18.7	49.2	56	-6.8	PASS	
1.707	29.573	18.8	48.3	56	-7.7	PASS	
1.962	29.627	18.8	48.4	56	-7.6	PASS	
2.046	29.131	18.8	47.9	56	-8.1	PASS	

Curtis Straus - a Bureau Veritas Company  
 Conducted Emissions per CISPR 16-2-1, CISPR Average Detector  
 Quick Average Detector Data  
 Notes:  
 EUT Line tested: 120VAC/60Hz; Phase  
 EUT Mode of Operation: Tx on Low Channel (902.7MHz)

Work Order # - S3054  
 EUT Power Input - 120VAC/ 60Hz  
 Test Site - CEMI-3  
 Conditions: - 22.9°C; 51%RH; 998mBar  
 Test Engineer - Chris Bramley  
 Witnessed by - N/A

Data Taken at 05:49:42 PM, Friday, November 02, 2018

Frequency (MHz)	Raw Avg Reading (dBµV)	Correction Factor (dB)	Adjusted Avg Amplitude (dBµV)	Av Lim: Mains_FCC&CISPR_Avg_Class_B (dBµV)	Avg Margin (dB)	Avg Results (Pass/Fail)	Worst Avg Margin (dB)
0.858	19.5	18.7	38.1	46	-7.9	PASS	-7.9
0.941	19.3	18.7	37.9	46	-8.1	PASS	
1.284	18.9	18.7	37.6	46	-8.4	PASS	
1.542	17.7	18.8	36.5	46	-9.5	PASS	
1.634	18	18.8	36.7	46	-9.3	PASS	
1.972	17.4	18.8	36.2	46	-9.8	PASS	

**120V 60Hz Line**



Curtis Straus - a Bureau Veritas Company  
 Conducted Emissions per CISPR 16-2-1  
 Quasi-peak Detector Data  
 Notes:  
 EUT Line tested: 120VAC/60Hz; Neutral  
 EUT Mode of Operation: Tx on Low Channel (902.7MHz)

Work Order # - S3054  
 EUT Power Input - 120VAC/ 60Hz  
 Test Site - CEMI-3  
 Conditions: - 22.9°C; 51%RH; 998mBar  
 Test Engineer - Chris Bramley  
 Witnessed by - N/A

Data Taken at 05:42:53 PM, Friday, November 02, 2018

Frequency (MHz)	Raw QP Reading (dBµV)	Correction Factor (dB)	Adjusted QP Amplitude (dBµV)	QP Lim: Mains_FCC&CISPR_QP_Class_B (dBµV)	Margin to QP Limit (dB)	QP Limit Results (Pass/Fail)	Worst Margin (QP Limit) (dB)
0.793	18.933	18.7	37.6	56	-18.4	PASS	-18.4
1.146	11.11	18.7	29.8	56	-26.2	PASS	
1.957	11.551	18.8	30.3	56	-25.7	PASS	
2.218	5.806	18.8	24.6	56	-31.4	PASS	
2.325	10.82	18.8	29.6	56	-26.4	PASS	
2.395	12.386	18.8	31.2	56	-24.8	PASS	

Curtis Straus - a Bureau Veritas Company  
 Conducted Emissions per CISPR 16-2-1, CISPR Average Detector  
 Quick Average Detector Data  
 Notes:  
 EUT Line tested: 120VAC/60Hz; Neutral  
 EUT Mode of Operation: Tx on Low Channel (902.7MHz)

Work Order # - S3054  
 EUT Power Input - 120VAC/ 60Hz  
 Test Site - CEMI-3  
 Conditions: - 22.9°C; 51%RH; 998mBar  
 Test Engineer - Chris Bramley  
 Witnessed by - N/A

Data Taken at 05:39:21 PM, Friday, November 02, 2018

Frequency (MHz)	Raw Avg Reading (dBµV)	Correction Factor (dB)	Adjusted Avg Amplitude (dBµV)	Av Lim: Mains_FCC&CISPR_Avg_Class_B (dBµV)	Avg Margin (dB)	Avg Results (Pass/Fail)	Worst Avg Margin (dB)
0.155	31	18.8	49.8	55.7	-5.9	PASS	
0.524	20.8	18.7	39.5	46	-6.5	PASS	
0.887	22.3	18.7	41	46	-5	PASS	-5
1.227	21.8	18.7	40.5	46	-5.5	PASS	
1.314	21.2	18.7	39.9	46	-6.1	PASS	
1.578	21.2	18.8	40	46	-6	PASS	

**120V 60Hz Neutral**





Curtis Straus - a Bureau Veritas Company  
 Conducted Emissions per CISPR 16-2-1  
 Quasi-peak Detector Data  
 Notes:  
 EUT Line tested: 277VAC/60Hz; Phase  
 EUT Mode of Operation: Tx on Low Channel (902.7MHz)

Work Order # - S3054  
 EUT Power Input - 277VAC/ 60Hz  
 Test Site - CEMI-3  
 Conditions: - 22.9°C; 51%RH; 998mBar  
 Test Engineer - Chris Bramley  
 Witnessed by - N/A

Data Taken at 07:27:34 PM, Tuesday, November 20, 2018

Frequency (MHz)	Raw QP Reading (dBµV)	Correction Factor (dB)	Adjusted QP Amplitude (dBµV)	QP Lim: Mains_FCC&CISPR_QP_Class_A (dBµV)	Margin to QP Limit (dB)	QP Limit Results (Pass/Fail)	Worst Margin (QP Limit) (dB)
0.581	34.612	18.7	53.3	73	-19.7	PASS	
0.997	34.625	18.7	53.3	73	-19.7	PASS	
1.079	36.88	18.7	55.6	73	-17.4	PASS	-17.4
1.328	34.039	18.7	52.7	73	-20.3	PASS	
1.822	35.217	18.8	54	73	-19	PASS	
1.911	30.093	18.8	48.9	73	-24.1	PASS	
1.989	34.574	18.8	53.3	73	-19.7	PASS	
2.08	22.239	18.8	41	73	-32	PASS	
2.581	17.975	18.8	36.8	73	-36.2	PASS	
2.65	33.28	18.8	52.1	73	-20.9	PASS	
2.874	21.085	18.8	39.9	73	-33.1	PASS	
3.544	29.848	18.8	48.7	73	-24.3	PASS	
3.637	32.248	18.8	51.1	73	-21.9	PASS	

Curtis Straus - a Bureau Veritas Company  
 Conducted Emissions per CISPR 16-2-1, CISPR Average Detector  
 Quick Average Detector Data  
 Notes:  
 EUT Line tested: 277VAC/60Hz; Phase  
 EUT Mode of Operation: Tx on Low Channel (902.7MHz)

Work Order # - S3054  
 EUT Power Input - 277VAC/ 60Hz  
 Test Site - CEMI-3  
 Conditions: - 22.9°C; 51%RH; 998mBar  
 Test Engineer - Chris Bramley  
 Witnessed by - N/A

Data Taken at 07:27:34 PM, Tuesday, November 20, 2018

Frequency (MHz)	Raw Avg Reading (dBµV)	Correction Factor (dB)	Adjusted Avg Amplitude (dBµV)	Av Lim: Mains_FCC&CISPR_Avg_Class_A (dBµV)	Avg Margin (dB)	Avg Results (Pass/Fail)	Worst Avg Margin (dB)
0.153	35.7	18.8	54.5	66	-11.5	PASS	-11.5
1.003	23.7	18.7	42.4	60	-17.6	PASS	
1.084	24.4	18.7	43.1	60	-16.9	PASS	
1.165	23.8	18.7	42.4	60	-17.6	PASS	
1.25	25	18.7	43.7	60	-16.3	PASS	
1.832	23.5	18.8	42.3	60	-17.7	PASS	

**277V 60Hz Line**



Curtis Straus - a Bureau Veritas Company  
 Conducted Emissions per CISPR 16-2-1  
 Quasi-peak Detector Data  
 Notes:  
 EUT Line tested: 277VAC/60Hz; Neutral  
 EUT Mode of Operation: Tx on Low Channel (902.7MHz)

Work Order # - S3054  
 EUT Power Input - 277VAC/ 60Hz  
 Test Site - CEMI-3  
 Conditions: - 22.9°C; 51%RH; 998mBar  
 Test Engineer - Chris Bramley  
 Witnessed by - N/A

Data Taken at 07:32:26 PM, Tuesday, November 20, 2018

Frequency (MHz)	Raw QP Reading (dBµV)	Correction Factor (dB)	Adjusted QP Amplitude (dBµV)	QP Lim: Mains_FCC&CISPR_QP_Class_A (dBµV)	Margin to QP Limit (dB)	QP Limit Results (Pass/Fail)	Worst Margin (QP Limit) (dB)
0.494	35.956	18.7	54.7	79	-24.3	PASS	
0.575	35.433	18.7	54.2	73	-18.8	PASS	
0.988	34.098	18.7	52.8	73	-20.2	PASS	
1.069	36.937	18.7	55.6	73	-17.4	PASS	
1.233	37.65	18.7	56.3	73	-16.7	PASS	-16.7
1.316	36.053	18.7	54.7	73	-18.3	PASS	
2.795	34.445	18.8	53.3	73	-19.7	PASS	
3.535	33.238	18.8	52.1	73	-20.9	PASS	

Curtis Straus - a Bureau Veritas Company  
 Conducted Emissions per CISPR 16-2-1, CISPR Average Detector  
 Quick Average Detector Data  
 Notes:  
 EUT Line tested: 277VAC/60Hz; Neutral  
 EUT Mode of Operation: Tx on Low Channel (902.7MHz)

Work Order # - S3054  
 EUT Power Input - 277VAC/ 60Hz  
 Test Site - CEMI-3  
 Conditions: - 22.9°C; 51%RH; 998mBar  
 Test Engineer - Chris Bramley  
 Witnessed by - N/A

Data Taken at 07:32:25 PM, Tuesday, November 20, 2018

Frequency (MHz)	Raw Avg Reading (dBµV)	Correction Factor (dB)	Adjusted Avg Amplitude (dBµV)	Av Lim: Mains_FCC&CISPR_Avg_Class_A (dBµV)	Avg Margin (dB)	Avg Results (Pass/Fail)	Worst Avg Margin (dB)
0.151	33.1	18.8	51.9	66	-14.1	PASS	-14.1
1.069	25.6	18.7	44.3	60	-15.7	PASS	
1.151	25.8	18.7	44.4	60	-15.6	PASS	
1.23	24.4	18.7	43.1	60	-16.9	PASS	
1.315	24.8	18.7	43.5	60	-16.5	PASS	
1.973	23.7	18.8	42.5	60	-17.5	PASS	

**277V 60Hz Neutral**



Rev. 10/31/2018

<b>Spectrum Analyzers / Receivers / Preselectors</b>									
	Range	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on	
Rental EXA Signal Analyzer(1118473)	9KHz-26.5GHz	N9010A-526;N	AT	MY51170076	1118473	I	6/19/2019	6/19/2018	
<b>LISNs/Measurement Probes</b>									
	Range	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on	
LISN Asset 1728	150kHz-30MHz	LI-150A	Com-Power	201084	1728	I	5/16/2019	5/16/2018	
LISN Asset 1729	150kHz-30MHz	LI-150A	Com-Power	201085	1729	I	5/16/2019	5/16/2018	
<b>Conducted Test Sites (Mains / Telco)</b>									
	FCC Code		VCCI Code			Cat	Calibration Due	Calibrated on	
CEMI 3	719150		A-0015			III	NA	NA	
<b>Meteorological Meters/Chambers</b>									
		MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on	
Weather Clock (Pressure Only)		BA928	Oregon Scientific	C3166-1	831	I	5/15/2020	5/15/2018	
TH A#2078		HTC-1	HDE		2078	II	3/22/2019	3/22/2018	
<b>Cables</b>									
	Range		Mfr			Cat	Calibration Due	Calibrated on	
CEMI-02	9kHz - 2GHz		Pasternack			II	7/31/2019	7/31/2018	
<b>Attenuators</b>									
	Range	MN	Mfr	SN	Asset	Cat	Calibration Due	Calibrated on	
20dB Attenuator-60	9kHz-2GHz			N/A		II	9/29/2019	9/29/2018	

All equipment is calibrated using standards traceable to NIST or other nationally recognized calibration standard.

TEU



# Occupied Bandwidth

## REQUIREMENT

When an occupied bandwidth is not specified in the applicable RSS, the transmitted signal bandwidth to be reported is its 99% emission bandwidth, as calculated or measured.  
 [RSS-GEN Issue 5 Section 6.7]

## MEASUREMENTS / RESULTS

99% Occupied Bandwidth			
Date: 02-Nov-18	Company: Ideal Industries, Inc.	Work Order: S3054	
Engineer: Chris Bramley	EUT: SRC2100	Operating Voltage/Frequency: 120V/60Hz	
Temp: 23.1°C	Humidity: 49%	Pressure: 998mBar	
Frequency Range: 900-930MHz		Measurement Type: Conducted	
Measurement Method: FCC 558074 D01 DTS Meas Guidance v05			
Notes:			
Frequency (MHz)		99% OBW (kHz)	
902.7		753.15	
915		752.45	
927.3		753.46	
Test Site: CEMI-3		Cable: Asset 2289	40dB Attenuator: Asset 2096
Analyzer: EXA 1118473		Copyright Curtis-Straus LLC 2000	


Rev. 10/31/2018

<b>Spectrum Analyzers / Receivers/Preselectors</b>	<b>Range</b>	<b>MN</b>	<b>Mfr</b>	<b>SN</b>	<b>Asset</b>	<b>Cat</b>	<b>Calibration Due</b>	<b>Calibrated on</b>
Rental EXA Signal Analyzer(1118473)	9KHz-26.5GHz	N9010A-526;N	AT	MY51170076	1118473	I	6/19/2019	6/19/2018
<b>Conducted Test Sites (Mains / Telco)</b>	<b>FCC Code</b>	<b>VCCI Code</b>				<b>Cat</b>	<b>Calibration Due</b>	<b>Calibrated on</b>
CEMI 3	719150	A-0015				III	NA	N/A
<b>Meteorological Meters/Chambers</b>		<b>MN</b>	<b>Mfr</b>	<b>SN</b>	<b>Asset</b>	<b>Cat</b>	<b>Calibration Due</b>	<b>Calibrated on</b>
Weather Clock (Pressure Only)		BA928	Oregon Scientific	C3166-1	831	I	5/15/2020	5/15/2018
TH A#2078		HTC-1	HDE		2078	II	3/22/2019	3/22/2018
<b>Cables</b>	<b>Range</b>		<b>Mfr</b>			<b>Cat</b>	<b>Calibration Due</b>	<b>Calibrated on</b>
Asset #2289	9KHz-26.5GHz	FLC-1.5FT-SMSM+	Mini-Circuits	16021029		II	1/29/2019	1/29/2018
<b>Preamps /Couplers Attenuators / Filters</b>	<b>Range</b>	<b>MN</b>	<b>Mfr</b>	<b>SN</b>	<b>Asset</b>	<b>Cat</b>	<b>Calibration Due</b>	<b>Calibrated on</b>
40dB 100W Attenuator	0.009-4000MHz	BW-40N100W+	Mini-Circuits	V N383401508	2096	II	10/9/2019	10/9/2018


All equipment is calibrated using standards traceable to NIST or other nationally recognized calibration standard.




Plot(s)



Occupied Bandwidth – Low Channel



Occupied Bandwidth – Middle Channel



Occupied Bandwidth – High Channel

### Measurement Uncertainty

The listed uncertainties are the worst case uncertainty for the entire range of measurement. Please note that the uncertainty values are provided for informational purposes only and are not used in determining the PASS/FAIL results.

Measurement	Expanded Uncertainty k=2	Maximum allowable uncertainty
Radiated Emissions (30-1000MHz)		
NIST	5.6dB	N/A
CISPR	4.6dB	5.2dB (Ucisprr)
Radiated Emissions (1-26.5GHz)	4.6dB	N/A
Radiated Emissions (above 26.5GHz)	4.9dB	N/A
Magnetic Radiated Emissions	5.6dB	N/A
Conducted Emissions		
NIST	3.9dB	N/A
CISPR	3.6dB	3.6dB (Ucisprr)
Telco Conducted Emissions (Current)	2.9dB	N/A
Telco Conducted Emissions (Voltage)	4.4dB	N/A
Electrostatic Discharge	11.5%	N/A
Radiated RF Immunity (Uniform Field)	1.6dB	N/A
Electrical Fast Transients	23.1%	N/A
Surge	23.1%	N/A
Conducted RF Immunity	3dB	N/A
Magnetic Immunity	12.8%	N/A
Dips and Interrupts	2.3V	N/A
Harmonics	3.5%	N/A
Flicker	3.5%	N/A
Radio frequency (@ 2.4GHz)	$3.23 \times 10^{-8}$	$1 \times 10^{-7}$
RF power, conducted	0.40dB	0.75dB
Maximum frequency deviation:		
• Within 300Hz and 6kHz of audio frequency / Within 6kHz and 25kHz of audio frequency	3.4%	5%
Adjacent channel power	0.3dB	3dB
Conducted spurious emission of transmitter, valid up to 12.75GHz	1.9dB	3dB
Conducted emission of receivers	2.39dB	3dB
Radiated emission of transmitter, valid up to 26.5GHz	1.3dB	3dB
Radiated emission of transmitter, valid up to 80GHz	3.9dB	6dB
Radiated emission of receiver, valid up to 26.5GHz	3.3dB	6dB
Radiated emission of receiver, valid up to 80GHz	3.9dB	6dB
Humidity	3.3dB	6dB
Temperature	2.37%	5%
Time	0.7°C	1.0°C
RF Power Density, Conducted	4.1%	10%
DC and low frequency voltages	0.4dB	3dB
Voltage (AC, <10kHz)	1.3%	3%
Voltage (DC)	1.3%	2%
Voltage (DC)	0.62%	1%

The above reflects a 95% confidence level



## Conditions Of Testing

[Bureau Veritas Consumer Products Services, Inc., a Massachusetts corporation], and/or its affiliates (collectively, the "Company") will conduct, at the request of the Submitter ("Client"), the tests specified on the submitted Test Request Form or equivalent in accordance with, and subject to, the following terms and conditions (collectively, "Conditions"):

1. All orders for tests are subject to acceptance by the Company, and no order will constitute a binding commitment of the Company unless and until such order is accepted by it, as evidenced by the issuance of a written report ("Test Report") by the Company. The Test Report is issued solely by the Company, is intended for the exclusive use of Client and shall not be published, used for advertising purposes, copied or replicated for distribution to any other person or entity or otherwise publicly disclosed without the prior written consent of the Company. By submitting a request for services to the Company, Client consents to the disclosure to accreditation bodies of those records of Client relevant to the accreditation body's assessment of the Company's competence and compliance with relevant accreditation criteria. The Company shall not be liable for any loss or damage whatsoever resulting from the failure of the Company to provide its services within any time period for completion estimated by the Company. If Client anticipates using the Test Report in any legal proceeding, arbitration, dispute resolution forum or other proceeding, it shall so notify the Company prior to submitting the Test Report in such proceeding. The Company has no obligation to provide a fact or expert witness at such proceeding unless the Company agrees in advance to do so for a separate and additional fee.
2. The Test Report will set forth the findings of the Company solely with respect to the test samples identified therein. Unless specifically and expressly indicated in the Test Report, the results set forth in such Test Report are not intended to be indicative or representative of the quality or characteristics of the lot from which a test sample is taken, and Client shall not rely upon the Test Report as being so indicative or representative of the lot or of the tested product in general. The Test Report will reflect the findings of the Company at the time of testing only, and the Company shall have no obligation to update the Test Report after its issuance. The Test Report will set forth the results of the tests performed by the Company based upon the written information provided to the Company. The Test Report will be based solely on the samples and written information submitted to the Company by Client, and the Company shall not be obligated to conduct any independent investigation or inquiry with respect thereto.
3. The Company may, in its sole discretion, destroy samples which have been furnished to the Company for testing and which have not been destroyed in the course of testing. The Company may delegate the performance of all or a portion of the services contemplated hereunder to an affiliate, agent or subcontractor of the Company, and Client consents to such delegation.
4. These Conditions and the Test Report represent the entire understanding of the parties hereto with respect to the subject matter hereof and of the Test Report, and no modification, variance or extrapolation with respect thereto shall be permitted without the prior written consent of the Company.
5. The names, service marks, trademarks and copyrights of the Company and its affiliates, including the names "BUREAU VERITAS," "BUREAU VERITAS CONSUMER PRODUCTS SERVICES," "BVCPS", "MTL", "ACTS", "MTL-ACTS" and CURTIS-STRAUS (collectively, the "Marks") are and shall remain the sole property of the Company or its affiliates and shall not be used by Client except solely to the extent that Client obtains the prior written approval of the Company and then only in the manner prescribed by the Company. Client shall not contest the validity of the Marks or take any action that might impair the value or goodwill associated with the Marks or the image or reputation of the Company or its affiliates.
6. Payment in full shall be due 30 days after the date of invoice. Interest shall be due on overdue amounts from the due date until paid at an interest rate of 1.5% per month or, if less, the maximum rate permitted by law. The Company reserves the right, at any time and from time to time, to revoke any credit extended to Client. Client shall reimburse the Company for any costs it incurs in collecting past due amounts, including court costs and fees and expenses of attorneys and collection agencies. The Test Report may not be used or relied upon by Client if and for so long as Client fails to pay when due any invoice issued by the Company or any affiliate of it to Client or any affiliate or subsidiary of Client together with interest and penalties, if any, accrued thereon.
7. The Company disclaims any and all responsibility or liability arising out of or in connection with e-mail transmissions of such information.
8. Client understands and agrees that the Company is neither an insurer nor a guarantor, that the Company does not take the place of Client or any designer, manufacturer, agent, buyer, distributor or transportation or shipping company, and that the Company disclaims all liability in such capacities. Client further understands that if it seeks assurance against loss or damage, it should obtain appropriate insurance.
9. Client agrees that the Company, by providing the services, does not take the place of Client nor any third party, nor does the Company release them from any of their obligations, nor does the Company otherwise assume, abridge, abrogate or undertake to discharge any duty of any third party to Client or any duty of Client or any third party to any other third party, and Client will not release any third party from its obligations and duties with respect to the tested goods.
10. Client shall, on a timely basis, (a) provide adequate instructions to the Company in order to enable the Company to perform properly its services, (b) provide, or cause Client's suppliers and contractors to provide, the Company with all documents necessary to enable the Company to perform its services, (c) furnish the Company with all relevant information regarding Client's intended use and purposes of the tested goods, (d) advise the Company of essential dates and deadlines relevant to the tested goods and (e) fully exercise all rights and remedies available to Client against third parties in respect of the tested goods.
11. The Company shall undertake due care and ordinary skill in the performance of its services to Client, and the Company shall accept responsibility only where such skill has not been exercised and, even in such event, only to the extent of the limitation of liability set forth herein.
12. If Client desires to assert a claim arising from or relating to (i) the performance, purported performance or non-performance of any services by the Company or (ii) the sale, resale, manufacture, distribution or use of any tested goods, it must submit that claim to the Company in a writing that sets forth with particularity the basis for such claim within 60 days from discovery of the potential claim and not more than six months after the date of issuance of the Test Report to Client. Client waives any and all





such claims including, without limitation, claims that the Test Report is inaccurate, incomplete or misleading or that additional or different testing is required, unless and then only to the extent that Client submits a written claim to the Company within both such time periods.

13. CLIENT SHALL, EXCEPT TO THE EXTENT OF COMPANY'S LIABILITY TO CLIENT HEREUNDER (WHICH IN NO EVENT SHALL EXCEED THE LIMITATION OF LIABILITY HEREIN), HOLD HARMLESS AND INDEMNIFY THE COMPANY, ITS AFFILIATES AND THEIR RESPECTIVE DIRECTORS, OFFICERS, EMPLOYEES, AGENTS AND SUBCONTRACTORS AGAINST ALL ACTUAL OR ALLEGED THIRD PARTY CLAIMS FOR LOSS, DAMAGE OR EXPENSE OF WHATSOEVER NATURE AND HOWSOEVER ARISING FROM OR RELATING TO (i) THE PERFORMANCE, PURPORTED PERFORMANCE OR NON-PERFORMANCE OF ANY SERVICES BY THE COMPANY OR (ii) THE SALE, RESALE, MANUFACTURE, DISTRIBUTION OR USE OF ANY TESTED GOODS.

14. EXCEPT AS MAY OTHERWISE BE EXPRESSLY AGREED TO IN WRITING BY THE COMPANY AND NOTWITHSTANDING ANY PROVISION TO THE CONTRARY CONTAINED HEREIN OR IN ANY TEST REPORT, NO WARRANTY OR GUARANTEE, EXPRESS OR IMPLIED, INCLUDING ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OR USE, IS MADE.

15. (A) IN NO EVENT WHATSOEVER SHALL THE COMPANY BE LIABLE FOR ANY CONSEQUENTIAL, SPECIAL, INCIDENTAL, EXEMPLARY OR PUNITIVE DAMAGES IN CONNECTION WITH, RELATING TO OR ARISING OUT OF THE TEST REPORT OR THE SERVICES PROVIDED BY THE COMPANY HEREUNDER, INCLUDING WITHOUT LIMITATION LOSS OF OR DAMAGE TO PROPERTY; LOSS OF INCOME, PROFIT OR USE; OR ANY CLAIMS OR DEMANDS MADE AGAINST CLIENT OR ANY OTHER PERSON BY ANY THIRD PARTY IN CONNECTION WITH, RELATING TO OR ARISING OUT OF THE SERVICES PROVIDED BY THE COMPANY HEREUNDER.

(B) NOTWITHSTANDING ANY PROVISION TO THE CONTRARY CONTAINED HEREIN, AND IN RECOGNITION OF THE RELATIVE RISKS AND BENEFITS TO CLIENT AND THE COMPANY ASSOCIATED WITH THE TESTING SERVICES CONTEMPLATED HEREBY, THE RISKS HAVE BEEN ALLOCATED SUCH THAT UNDER NO CIRCUMSTANCES WHATSOEVER SHALL THE LIABILITY OF THE COMPANY TO CLIENT OR ANY THIRD PARTY IN RESPECT OF ANY CLAIM FOR LOSS, DAMAGE OR EXPENSE, OF WHATSOEVER NATURE OR MAGNITUDE, AND HOWSOEVER ARISING, EXCEED AN AMOUNT EQUAL TO FIVE (5) TIMES THE AMOUNT OF THE FEES PAID TO THE COMPANY FOR THE SPECIFIC SERVICES WHICH GAVE RISE TO SUCH CLAIM OR U.S.\$10,000, WHICHEVER IS THE LESSER AMOUNT.

16. The Company shall not be liable for any loss or damage resulting from any delay or failure in performance of its obligations hereunder resulting directly or indirectly from any event of force majeure or any event outside the control of the Company. If any such event occurs, the Company may immediately cancel or suspend its performance hereunder without incurring any liability whatsoever to Client.

Company's services, including these Conditions, shall be governed by, and construed in accordance with, the local laws of the country where the Company performs the tests or, in the case of tests performed in the United States of America, the laws of Massachusetts without regard to conflicts of laws principles. If any aspect(s) of these Conditions is found to be illegal or unenforceable, the validity, legality and enforceability of all remaining aspects of these Conditions shall not in any way be affected or impaired thereby. Any proceeding related to the subject matter hereof shall be brought, if at all, in the courts of the country where the Company performs the tests or, in the case of tests performed in the United States of America, in the courts of Massachusetts. Client waives the right to interpose any counterclaim or setoffs of any nature in any litigation arising hereunder.

The complete list of the Approved Subcontractors Curtis-Straus may use to delegate the performance of work can be provided upon request.

