



Model: EIA660iW
Single Station Smoke Alarm
with Supplemental Heat Alarm

WARNING

Please see user manual for important information on maintenance and battery life (B18486 Rev0). Constant use at high humidity may reduce battery life. Use only batteries specified, the use of other batteries may have a detrimental effect on alarm operation. Maintenance: Clear Alarm monthly by gently vacuuming the openings in the exterior of the Alarm.

Standby: No Beep or flash
Low Battery: 1 beep + 1 yellow flash every 48 sec
Alarm: 3 long beeps, repeating with flashing red LED
End of Life: 3 beeps with 3 yellow flashes
Alarm Silence: 1 red flash every 8 sec
Sensitivity: 1.96%-4.0% OBS/FT
Conforms to: ANS/UL 217

For repair or service return to:
Ei Electronics US, 2 Tunxis
Road, Suite 209, Torrville,
Connecticut 06068

Made in Ireland

RF-UT-BOSCH-SMOKE
Rev X2

SAMPLE

NO BATTERY
Please read user manual -
Use only: Panasonic CR123A

A18626 Rev0

X2-1



DO NOT

A19627 Rev 0

Date Mfg: 2018 Jul 5
CELL: 23
Replace By: Jul 2029
SW Rev:0a

