

EMISSIONS TEST REPORT

Report Number: 102172761BOX-001b Project Number: G102172761

Report Issue Date: 09/04/2015

Product Designation: NC-210

Standards: CFR47 FCC Part 15 Subpart C 15.247:2015 CFR47 FCC Part 15 Subpart B:2015 IC RSS-247 Issue 1 May 2015 IC RSS-Gen Issue 4 November 2014 IC ICES-003 Issue 5 August 2012 IC RSS-102 Issue 5 March 2015 updated December 2010

Tested by: Intertek Testing Services NA, Inc. 70 Codman Hill Road Boxborough, MA 01719 Client: Mircom Technologies Ltd. 25 Interchange Way Vaughan ON L4K 5W3 Canada

Report prepared by Reviewer

Veithan 2 Vor

Vathana F. Ven/Seni Engineer, EMC

Report reviewed by

Kouma Sinn / Staff Engineer, EMC

1 Introduction and Conclusion

The tests indicated in section 2.0 were performed on the product constructed as described in section 4.0. The remaining test sections are the verbatim text from the actual data sheets used during the investigation. These test sections include the test name, the specified test Method, a list of the actual Test Equipment Used, documentation Photos, Results and raw Data. No additions, deviations, or exclusions have been made from the standard(s) unless specifically noted.

Based on the results of our investigation, we have concluded the product tested **complies** with the requirements of the standard(s) indicated. The results obtained in this test report pertain only to the item(s) tested.

2 Test Summary

| Section | Test full name | Result |
|---------|---|--------|
| 3 | Client Information | |
| 4 | Description of Equipment Under Test | |
| 5 | System Setup and Method | |
| 6 | RF Output Power, Duty Cycle, and Human RF Exposure (CFR47 FCC Part 15 Subpart C 15.247(b)(3), KDB 558074, IC RSS-247 Issue 1 May 2015 5.4(4), IC RSS-102 Issue 5 March 2015) | Pass |
| 7 | 6 dB Bandwidth (CFR47 FCC Part 15 Subpart C 15.247(a)(2), IC RSS-247 Issue 1 May 2015 5.2, IC RSS-Gen Section 6.6, KDB 558074) | Pass |
| 8 | Peak Power Spectral Density (FCC 15:2015 Subpart C Section 15.247 (e), RSS-247 Issue 1 May 2015 5.2(2), KDB 558074) | Pass |
| 9 | Band Edge Compliance (FCC 15:2015 Subpart C Section 15.247 (d), RSS-247 Issue 1 May 2015 5.2(2), KDB 558074) | Pass |
| 10 | Transmitter Radiated Spurious Emissions (CFR47 FCC Part 15:2015 Subpart C 15.247(d), IC RSS-247 Issue 1 May 2015 5.5, KDB 558074) | Pass |
| 11 | Digital Devices and Receiver Radiated Spurious Emissions (CFR47 FCC Part 15 Subpart B 15.109, IC RSS-Gen Sections 7.1 & IC ICES-003 Issue 5 August 2012) | Pass |
| 12 | AC Mains Conducted Emissions CFR47 FCC Part 15:2015 Subpart B Section 15.207 IC RSS-Gen Issue 4 November 2014, 7.2.2 (Table 2) | Pass |
| 13 | Revision History | |

3 Client Information

This EUT was tested at the request of:

| Company: | Mircom Technologies Ltd. 25 Interchange Way Vaughan ON L4K 5W3 Canada |
|------------|--|
| Contact: | Mr. Mike Mahoney |
| Telephone: | (905) 660-4655 |
| Fax: | (905) 695-3538 |
| Email: | mmahoney@mircomgroup.com |

4 Description of Equipment Under Test

| Equipment Under Test | | | | | | | | | |
|--------------------------|--|--|--|--|--|--|--|--|--|
| Manufacturer | Model Number | Serial Number | | | | | | | |
| Mircom Technologies Ltd. | NC-210 | 0006 | | | | | | | |
| | | Transmit mode | | | | | | | |
| Mircom Technologies Ltd. | NC-210 | 0009 | | | | | | | |
| | | Normal mode | | | | | | | |
| Mircom Technologies Ltd. | NC-210 | 00309 | | | | | | | |
| | | Transmit mode | | | | | | | |
| | Manufacturer Mircom Technologies Ltd. Mircom Technologies Ltd. | ManufacturerModel NumberMircom Technologies Ltd.NC-210Mircom Technologies Ltd.NC-210 | | | | | | | |

| Receive Date: | 06/04/2012, 07/30/2015 | Start Date: | 09/18/2012 |
|---------------------|------------------------|----------------|------------|
| Received Condition: | Good | Complete date: | 08/27/2015 |
| Type: Prototype | | | |

Description of Equipment Under Test (provided by client)

The EUT is a Beacon-Router with Zigbee wireless application. The Zigbee transceiver operates in the 2400-2483.5 MHz band from 2405-2480MHz using an integral antenna.

| Equipment Under Test Power Configuration | | | | | | | |
|--|-----|-------|---|--|--|--|--|
| Rated Voltage Rated Current Rated Frequency Number of Phases | | | | | | | |
| 120VAC | N/A | 50/60 | 1 | | | | |

Operating modes of the EUT:

| | No. | Descriptions of EUT Exercising |
|---|-----|---|
| | 1 | The device was in transmit mode, channels 11 (2405 MHz), 18 (2440 MHz), 26 (2480 MHz) |
| ſ | 2 | The device was also tested in receive mode |

5 System Setup and Method


| | Cables | | | | | | | | |
|----|-------------|---------------|-----------|----------|-------------|--|--|--|--|
| ID | Description | Length (m) | Shielding | Ferrites | Termination | | | | |
| | None | | | | | | | | |
| | | | | | | | | | |

| Support Equipment | | | | | | | | |
|---|----------------|------------|-----|--|--|--|--|--|
| Description Manufacturer Model Number Serial Number | | | | | | | | |
| Laptop | HP | 350 | N/A | | | | | |
| AC adapter | Direct Plug-in | 35-D12-200 | N/A | | | | | |

5.1 Method:

Configuration as required by ANSI C63.10:2013, ANSI C63.4:2014, and KDB 558074.

5.2 EUT Block Diagram:



6 RF Output Power, Duty Cycle, and Human RF Exposure

6.1 Method

Tests are performed in accordance with FCC Part 15 Subpart C Section 15.247, *KDB 558074*, ANSI C63.10, RSS-102, FCC Part 2 and KDB 447498, and RSS-247.

TEST SITE: 10m ALSE

The 10m ALSE is 13m (Length) x 21m (Depth) x 10m (Height) with the effective size in terms of space from the tips of the absorber is 12m (Length) x 20m (Depth) x 8.5m (Height). This chamber achieves broadband performance using a unique arrangement of hybrid and ferrite tile absorber. This chamber has a built in 3m diameter turntable (Embedded type). The metal structure of the table makes electrical connection around the entire circumference of the turntable to the ground plane with a metal brush type connection. The turntable is located on one end of the chamber and the antennas are mounted 3 and 10 meters away at the other end of the chamber on the adjustable an Antenna Mast. The antenna mast is a non-conductive bore sighted type with remote control of antenna height and polarization. The Antenna Mast and the turntable can be remotely controlled through the controller located in the adjacent Control room. A wooden table 80 cm high is used for table-top equipment.

Measurement Uncertainty

For radiated emissions, U_{lab} (3.5 dB at 3m and 3.5 dB at 10m below 1 GHz, and 4.2 dB at 3m above 1

GHz) < U_{CISPR} (5.2 dB), which is the reference value in CISPR 16-4-2 Table 1, hence the compliance of the product is only based on the measured value, and no measurement uncertainty correction is required, based on CISPR 22 and CISPR 11 (for 2006 and later revisions) Clause 11.

Sample Calculation

The field strength is calculated by adding the Antenna Factor and Cable Factor, and subtracting the Amplifier Gain (if any) from the measured reading. The basic equation with a sample calculation is as follows:

| CF - AG |
|---|
| FS = Field Strength in $dB\mu V/m$ |
| RA = Receiver Amplitude (including preamplifier) in $dB\mu V$ |
| CF = Cable Attenuation Factor in dB |
| AF = Antenna Factor in dB |
| AG = Amplifier Gain in dB |
| |

In the following table(s), the reading shown on the data table reflects the preamplifier gain. An example for the calculations in the following table is as follows.

Assume a receiver reading of 52.0 dB μ V is obtained. The antenna factor of 7.4 dB and cable factor of 1.6 dB is added. The amplifier gain of 29 dB is subtracted, giving a field strength of 32 dB μ V/m. This value in dB μ V/m was converted to its corresponding level in μ V/m.

RA = 52.0 dB μ V AF = 7.4 dB/m CF = 1.6 dB AG = 29.0 dB FS = 32 dB μ V/m

To convert from $dB\mu V$ to μV or mV the following was used:

UF = $10^{(NF/20)}$ where UF = Net Reading in μ V NF = Net Reading in dB μ V

Example:

FS = RA + AF + CF - AG = 52.0 + 7.4 + 1.6 - 29.0 = 32.0 UF = $10^{(32 \text{ dB}\mu\text{V}/20)}$ = 39.8 $\mu\text{V/m}$

6.2 Test Equipment Used:

| Asset | Description | Manufacturer | Model | Serial | Cal Date | Cal Due |
|----------|--|-------------------|---------------|------------|------------|------------|
| | | | | PE80529A61 | | |
| DAV004' | Weather Station | Davis Instruments | 7400 | A | 10/06/2014 | 10/06/2015 |
| 145128' | EMI Receiver (20 Hz - 40 Ghz) | Rohde & Schwarz | ESIB 40 | 839283/001 | 03/14/2015 | 03/14/2016 |
| ETS001' | 1-18GHz DRG Horn Antenna | ETS-Lindgren | 3117 00143259 | | 01/14/2015 | 01/14/2016 |
| | | | 3m Track B | | | |
| 145-416' | Cables 145-400 145-402 145-404 145-408 | Huber + Suhner | cables | multiple | 10/04/2014 | 10/04/2015 |


Software Utilized:

| Name | Manufacturer | Version |
|--------------------|--------------|------------|
| EMI Boxborough.xls | Intertek | 08/27/2010 |

6.3 Results:

The sample tested was found to Comply. The EIRP must not exceed 30 dBm. The RSS-102 Issue 5 Human Exposure Limit at 2.48 GHz = 5.47 W/m^2 .

6.4 Setup Photographs:



Intertek

6.5 Plots/Data:


RF Output Power


Radiated Emissions

| Model #: | Company: Mircom Technologies Ltd. Model #: NC-210 | | | | | | | Antenna & Cables: HF Bands: N, LF, HF Antenna: ETS001 01-14-16.txt ETS001 01-14-16 Cable(s): 145-416 3mTrkB 10-04-2015.txt NONE. | | | | |
|---|--|---------------|------------|---------------------------|---------------------------|-------------|------------------|--|--------------|--------------|-------------|-----|
| Serial #: 00309 Engineers: Vathana Ven Location: 10M | | | | | Barometer: | | 3 10-04-2015.txt | Filter: | NONE | | | |
| 0 | G1021795 | | Date(s): | 00/07/15 | LUCATION. | | Darometer. | DAV004 | | Filler. | NONE | |
| , | | | Date(s). | 00/27/15 | | | Tomn/Llumia | lity/Drocourou | 22 dog C | 410/ | 1006 mB | |
| | | 5C, 15.247 | 01 0014 | Limit Di | otonoo (m); | 2 | remp/numic | lity/Pressure: | zz deg C | 41% | 1000 1116 | |
| | ` | 145-128) 10-0 | 01-2014 | | stance (m): | | | | | | | |
| • | 145014 05 | | Ν | | stance (m): | | n a wa na d | Energy | nev Dennev | Funda | un o inte l | |
| F | | ed? (Y or N): | | 0 | Frequency: | , | powered | | ncy Range: | | imental | |
| De elu F | | iding (dBuV/r | , | | , | | , , | () | | , , | | |
| Реак: н | | Peak: QP Av | erage: AVG | | | | | d Band; Bar | nawiath den | oted as RB | W/VBW | 1 |
| | Ant. | _ | | Antenna | Cable | Pre-amp | Distance | | | | | |
| Detector | Pol. | Frequency | 0 | Factor | Loss | Factor | Factor | Net | Limit | - 5 | Bandwidth | |
| Туре | (V/H) | MHz | dB(uV) | dB(1/m) | dB | dB | dB | dB(uV/m) | dB(uV/m) | dB | | FCC |
| | | | | | Note: RF O | | | | | | | |
| | Note: EIRP | Obtained by | | • | | | | , <u>,</u> | 3m - 95.22 : | = dBm EIRF | 0 | |
| | | | | | | | al Orientatio | Г — — — — — — — — — — — — — — — — — — — | | | - | |
| PK | Н | 2405.000 | 46.70 | 31.97 | 5.92 | 0.00 | 0.00 | -10.63 | 30.00 | -40.63 | 5/10MHz | |
| PK | V | 2405.000 | 43.68 | 31.97 | 5.92 | 0.00 | 0.00 | -13.65 | 30.00 | -43.65 | 5/10MHz | |
| | | | CH | 118 - 2440N | <mark>/Hz, No pre-</mark> | -amp, Typic | al Orientatio | n | | | | |
| PK | Н | 2440.000 | 47.46 | 32.11 | 5.98 | 0.00 | 0.00 | -9.67 | 30.00 | -39.67 | 5/10MHz | |
| PK | V | 2440.000 | 47.85 | 32.11 | 5.98 | 0.00 | 0.00 | -9.28 | 30.00 | -39.28 | 5/10MHz | |
| | | | Cl | <mark>-126 - 2480N</mark> | /Hz, No pre | -amp, Typic | al Orientatio | on | | | | |
| PK | Н | 2480.000 | 48.24 | 32.26 | 6.06 | 0.00 | 0.00 | -8.66 | 30.00 | -38.66 | 5/10MHz | |
| PK | V | 2480.000 | 47.98 | 32.26 | 6.06 | 0.00 | 0.00 | -8.92 | 30.00 | -38.92 | 5/10MHz |] |


Duty Cycle

The worst-case duty cycle for typical EUT operation is shown below. The pulse train of the EUT extends beyond 100 ms as shown in the following plot.





Date: 22.SEP.2012 20:11:28



Date: 22.SEP.2012 20:16:41

There was 1 pulse train in 100 ms period and the length of the pulse train was 551.102μ S. The duty cycle is therefore, 0.5511 ms in a 100ms period, or 0.5511%, for a duty cycle correction factor of 45.18 dB.

RSS-102 Issue 5 Exposure Limits:

| Table 4: RF Field Strength Limits for Devices Used by the General Public |
|--|
| (Uncontrolled Environment) |

Intertek

| Frequency Range | Electric Field | Magnetic Field | Power Density | Reference Period | | |
|--|----------------------|----------------------------|---------------------------|------------------|--|--|
| (MHz) | (V/m rms) | (A/m rms) | (W/m ²) | (minutes) | | |
| 0.003-10 ²¹ | 83 | 90 | - | Instantaneous* | | |
| 0.1-10 | - | 0.73/ f | - | 6** | | |
| 1.1-10 | 87/ f ^{0.5} | - | - | 6** | | |
| 10-20 | 27.46 | 0.0728 | 2 | 6 | | |
| 20-48 | $58.07/f^{0.25}$ | $0.1540/f^{0.25}$ | 8.944/ f ^{0.5} | 6 | | |
| 48-300 | 22.06 | 0.05852 | 1.291 | 6 | | |
| 300-6000 | $3.142 f^{0.3417}$ | $0.008335 f^{0.3417}$ | $0.02619 f^{0.6834}$ | 6 | | |
| 6000-15000 | 61.4 | 0.163 | 10 | 6 | | |
| 15000-150000 | 61.4 | 0.163 | 10 | $616000/f^{1.2}$ | | |
| 150000-300000 | $0.158 f^{0.5}$ | $4.21 \ge 10^{-4} f^{0.5}$ | 6.67 x 10 ⁻⁵ f | $616000/f^{1.2}$ | | |
| Note: <i>f</i> is frequency in MHz. *Based on nerve stimulation (NS). | | | | | | |
| ** Based on specific absorption rate (SAR). | | | | | | |

1.1 Test Procedure

The EUT was measured in a radiated fashion. The RF output power was measured using a resolution bandwidth which encompassed the entire emission bandwidth. The data obtained was adjusted for equipment losses and converted from a field strength reading to a power reading using the provisions of RSS-Gen 4.6.

1.2 Results:

RSS-102 Issue 5 Exposure Limit at 2.48 GHz = 5.47 W/m²

Maximum EIRP measured at 2480 MHz -8.66 dBm or 0.136 mW

Power Density = $EIRP/(4*pi*20^2)$

Power Density = $0.0000271 \text{ mW/cm}^2$

Power Density = 0.000271 W/m^2

The calculated maximum power density at 20 cm distance is less than the limit for general population / uncontrolled exposure. The device has also met the higher FCC RF exposure limits.

Report Number: 102172761BOX-001b

| Test Personnel: | Vathana Ven | Test Date: | 09/22/2012, 08/27/2015 |
|----------------------------------|-----------------------|-----------------------|------------------------|
| Supervising/Reviewing | | | |
| Engineer: | | | |
| (Where Applicable) | N/A | | |
| | FCC Part 15 Subpart C | Test Levels: | See tables |
| Product Standard: | 15.247; IC RSS-247 | | |
| Input Voltage: | 120VAC/60Hz | | |
| Pretest Verification w/ | | Ambient Temperature: | 24, 22 °C |
| Ambient Signals or BB Source: | Ambient | Relative Humidity: | 49, 41 % |
| | | Atmospheric Pressure: | 1009, 1006 mbars |

Deviations, Additions, or Exclusions: None

7 6 dB Bandwidth & 99% Power Bandwidth

7.1 Method

Tests are performed in accordance with FCC Part 15 Subpart C Section 15.247, *KDB 558074*, ANSI C63.10, and RSS-247.

TEST SITE: 10m ALSE

The 10m ALSE is 13m (Length) x 21m (Depth) x 10m (Height) with the effective size in terms of space from the tips of the absorber is 12m (Length) x 20m (Depth) x 8.5m (Height). This chamber achieves broadband performance using a unique arrangement of hybrid and ferrite tile absorber. This chamber has a built in 3m diameter turntable (Embedded type). The metal structure of the table makes electrical connection around the entire circumference of the turntable to the ground plane with a metal brush type connection. The turntable is located on one end of the chamber and the antennas are mounted 3 and 10 meters away at the other end of the chamber on the adjustable an Antenna Mast. The antenna mast is a non-conductive bore sighted type with remote control of antenna height and polarization. The Antenna Mast and the turntable can be remotely controlled through the controller located in the adjacent Control room. A wooden table 80 cm high is used for table-top equipment.

7.2 Test Equipment Used:

| Asset | Description | Manufacturer | Model | Serial | Cal Date | Cal Due |
|----------|--|-------------------|------------|------------|------------|------------|
| | | | | PE80529A61 | | |
| DAV004' | Weather Station | Davis Instruments | 7400 | A | 10/06/2014 | 10/06/2015 |
| 145128' | EMI Receiver (20 Hz - 40 Ghz) | Rohde & Schwarz | ESIB 40 | 839283/001 | 03/14/2015 | 03/14/2016 |
| ETS001' | 1-18GHz DRG Horn Antenna | ETS-Lindgren | 3117 | 00143259 | 01/14/2015 | 01/14/2016 |
| | | | 3m Track B | | | |
| 145-416' | Cables 145-400 145-402 145-404 145-408 | Huber + Suhner | cables | multiple | 10/04/2014 | 10/04/2015 |

Software Utilized:

| Name | Manufacturer | Version |
|------|--------------|---------|
| None | | |


7.3 Results:

The 99% power bandwidth, or 6 dB bandwidth, must not be less than 500 kHz. The sample tested was found to Comply.

| Channel | 6 dB Bandwidth | 99% Power Bandwidth |
|-----------------------|----------------|---------------------|
| Channel 11 (2405 MHz) | 1.488 MHz | 3.151 MHz |
| Channel 18 (2440 MHz) | 1.507 MHz | 2.975 MHz |
| Channel 26 (2480 MHz) | 1.527 MHz | 2.975 MHz |


Plots were taken using an RBW of ~1-5% of the measured emission bandwidth, per KDB 558074 and IC RSS-Gen 6.6.


7.4 Setup Photographs:



Intertek


7.5 Plots/Data:






Channel 18 (2440 MHz) 6 dB Bandwidth


Issued: 09/04/2015



Channel 26 (2480 MHz) 6 dB Bandwidth




Channel 11 (2405 MHz) 99% Power Bandwidth



Channel 18 (2440 MHz) 99% Power Bandwidth

Intertek

Report Number: 102172761BOX-001b



Intertek

Deviations, Additions, or Exclusions: None

Issued: 09/04/2015

8 Peak Power Spectral Density

8.1 Method

Tests are performed in accordance with FCC Part 15 Subpart C Section 15.247, *KDB 558074*, ANSI C63.4:2013, and RSS-247.

TEST SITE: 10m ALSE

The 10m ALSE is 13m (Length) x 21m (Depth) x 10m (Height) with the effective size in terms of space from the tips of the absorber is 12m (Length) x 20m (Depth) x 8.5m (Height). This chamber achieves broadband performance using a unique arrangement of hybrid and ferrite tile absorber. This chamber has a built in 3m diameter turntable (Embedded type). The metal structure of the table makes electrical connection around the entire circumference of the turntable to the ground plane with a metal brush type connection. The turntable is located on one end of the chamber and the antennas are mounted 3 and 10 meters away at the other end of the chamber on the adjustable an Antenna Mast. The antenna mast is a non-conductive bore sighted type with remote control of antenna height and polarization. The Antenna Mast and the turntable can be remotely controlled through the controller located in the adjacent Control room. A wooden table 80 cm high is used for table-top equipment.

Measurement Uncertainty

For radiated emissions, U_{lab} (3.5 dB at 3m and 3.5 dB at 10m below 1 GHz, and 4.2 dB at 3m above 1 GHz) < U_{CISPR} (5.2 dB), which is the reference value in CISPR 16-4-2 Table 1, hence the compliance of the product is only based on the measured value, and no measurement uncertainty correction is required, based on CISPR 22 and CISPR 11 (for 2006 and later revisions) Clause 11.

Sample Calculation

The field strength is calculated by adding the Antenna Factor and Cable Factor, and subtracting the Amplifier Gain (if any) from the measured reading. The basic equation with a sample calculation is as follows:

| CF - AG |
|---|
| FS = Field Strength in $dB\mu V/m$ |
| RA = Receiver Amplitude (including preamplifier) in $dB\mu V$ |
| CF = Cable Attenuation Factor in dB |
| AF = Antenna Factor in dB |
| AG = Amplifier Gain in dB |
| |

In the following table(s), the reading shown on the data table reflects the preamplifier gain. An example for the calculations in the following table is as follows.

Assume a receiver reading of 52.0 dB μ V is obtained. The antenna factor of 7.4 dB and cable factor of 1.6 dB is added. The amplifier gain of 29 dB is subtracted, giving a field strength of 32 dB μ V/m. This value in dB μ V/m was converted to its corresponding level in μ V/m.

RA = 52.0 dB μ V AF = 7.4 dB/m CF = 1.6 dB AG = 29.0 dB FS = 32 dB μ V/m

To convert from $dB\mu V$ to μV or mV the following was used:

UF = $10^{(NF/20)}$ where UF = Net Reading in μ V NF = Net Reading in dB μ V

Example:

FS = RA + AF + CF - AG = 52.0 + 7.4 + 1.6 - 29.0 = 32.0 UF = $10^{(32 \text{ dB}\mu\text{V}/20)}$ = 39.8 $\mu\text{V/m}$

8.2 Test Equipment Used:

| Asset | Description | Manufacturer | Model | Serial | Cal Date | Cal Due |
|----------|--|-------------------|------------|------------|------------|------------|
| | | | | PE80529A61 | | |
| DAV004' | Weather Station | Davis Instruments | 7400 | A | 10/06/2014 | 10/06/2015 |
| 145128' | EMI Receiver (20 Hz - 40 Ghz) | Rohde & Schwarz | ESIB 40 | 839283/001 | 03/14/2015 | 03/14/2016 |
| ETS001' | 1-18GHz DRG Horn Antenna | ETS-Lindgren | 3117 | 00143259 | 01/14/2015 | 01/14/2016 |
| | | | 3m Track B | | | |
| 145-416' | Cables 145-400 145-402 145-404 145-408 | Huber + Suhner | cables | multiple | 10/04/2014 | 10/04/2015 |


Software Utilized:

| Name | Manufacturer | Version | | |
|--------------------|--------------|------------|--|--|
| EMI Boxborough.xls | Intertek | 08/27/2010 | | |

8.3 Results:

The sample tested was found to Comply. The peak power spectral density must not exceed 8 dBm in any 3 kHz bandwidth using the methods of KDB 558074.

8.4 Setup Photographs:



Intertek

Emissions Report for Mircom Technologies Ltd. on the NC-210

Issued: 09/04/2015

8.5 Plots/Data:

| Company: | Company: Mircom Technologies Ltd. | | | | | | Antenn | a & Cables: | HF | Bands: N, I | .F, HF, SHF |
|------------|-----------------------------------|---------------|--------------|----------------------------|----------------------------|--------------|---------------|----------------|------------------|-------------|-------------|
| Model #: | NC-210 | | | | | | Antenna: | ETS001 01 | -14-16.txt | ETS001 01 | -14-16.txt |
| Serial #: | 00309 | | | | | | Cable(s): | 145-416 3mTrkE | 3 10-04-2015.txt | NONE. | |
| Engineers: | Vathana Ve | en | | | Location: | 10M | Barometer: | DAV004 | | Filter: | NONE |
| Project #: | G10217950 | 05 | Date(s): | 08/27/15 | | | | | | | |
| Standard: | FCC Part 1 | 5C, 15.247 | | | | | Temp/Humic | lity/Pressure: | 22 deg C | 41% | 1006 mB |
| Receiver: | R&S ESI (1 | 45-128) 10-0 | 01-2014 | Limit Di | stance (m): | 3 | | | | | |
| PreAmp: | 145014 05- | -13-16.txt | | Test Di | stance (m): | 3 | | | | | |
| F | PreAmp Use | ed? (Y or N): | Ν | Voltage/ | Frequency: | Battery | powered | Freque | ncy Range: | Funda | mental |
| | Net = Rea | iding (dBuV/r | n) + Antenn | a Factor (dl | 31/m) + Cat | ole Loss (dB | s) - Preamp | Factor (dB) | - Distance F | actor (dB) | |
| Peak: F | PK Quasi-P | eak: QP Av | erage: AVG | RMS: RMS | S; NF = Nois | se Floor, RB | = Restricte | d Band; Bar | ndwidth den | oted as RB | W/VBW |
| | Ant. | | | Antenna | Cable | Pre-amp | Distance | | | | |
| Detector | Pol. | Frequency | Reading | Factor | Loss | Factor | Factor | Net | Limit | Margin | Bandwidth |
| Туре | (V/H) | MHz | dB(uV) | dB(1/m) | dB | dB | dB | dB(uV/m) | dB(uV/m) | dB | |
| Peak | Power Spe | ctral Density | , normalized | from 100kl | Hz to 3 kHz | using Band | width Corre | ction Factor | 10LOG(3/1 | 00 kHz)=-1 | 5.2 dB |
| | Note: EIRP | Obtained by | applying th | e path loss | correction for | or a 3m test | distance, E | (dBuV/m)@: | 3m - 95.22 : | = dBm EIRF |) |
| | | | Cł | <mark>-111 - 2405</mark> N | <mark>1Hz, No pre</mark> ∙ | -amp, Typic | al Orientatio | n | | | |
| PK | Н | 2405.000 | 28.20 | 31.97 | 5.92 | 0.00 | 0.00 | -44.33 | 8.00 | -52.33 | 3/10kHz |
| РК | V | 2405.000 | 24.85 | 31.97 | 5.92 | 0.00 | 0.00 | -47.68 | 8.00 | -55.68 | 3/10kHz |
| | | | C | H18 - 2440N | /Hz, No pre | -amp, Typic | al Orientatio | on | | | |
| PK | Н | 2440.000 | 34.71 | 32.11 | 5.98 | 0.00 | 0.00 | -37.62 | 8.00 | -45.62 | 3/10kHz |
| PK | V | 2440.000 | 31.53 | 32.11 | 5.98 | 0.00 | 0.00 | -40.80 | 8.00 | -48.80 | 3/10kHz |
| | | | C | H26 - 2480N | /Hz, No pre | -amp, Typic | al Orientatio | on | | | |
| PK | Н | 2480.000 | 35.88 | 32.26 | 6.06 | 0.00 | 0.00 | -36.22 | 8.00 | -44.22 | 3/10kHz |
| РК | V | 2480.000 | 35.71 | 32.26 | 6.06 | 0.00 | 0.00 | -36.39 | 8.00 | -44.39 | 3/10kHz |

Intertek

Radiated Emissions

| Test Personnel: | Vathana Ven |
|------------------------------------|-----------------------|
| Supervising/Reviewing Engineer: | |
| (Where Applicable) | N/A |
| | FCC Part 15 Subpart C |
| Product Standard: | 15.247; IC RSS-247 |
| Input Voltage: | 120VAC/60Hz |
| Pretest Verification w/ | |
| Ambient Signals or | |
| BB Source: | Ambient |

| Test Levels: | See section 8.3 |
|--|-----------------|
| Ambient Temperature: Relative Humidity: | |
| Atmospheric Pressure: | 1006 mbars |

Test Date: 08/27/2015

Deviations, Additions, or Exclusions: None

FCC IC

9 Band Edge Compliance

9.1 Method

Tests are performed in accordance with FCC Part 15 Subpart C Section 15.247, *KDB* 558074, ANSI C63.4:2013, and RSS-247.

TEST SITE: 10m ALSE

The 10m ALSE is 13m (Length) x 21m (Depth) x 10m (Height) with the effective size in terms of space from the tips of the absorber is 12m (Length) x 20m (Depth) x 8.5m (Height). This chamber achieves broadband performance using a unique arrangement of hybrid and ferrite tile absorber. This chamber has a built in 3m diameter turntable (Embedded type). The metal structure of the table makes electrical connection around the entire circumference of the turntable to the ground plane with a metal brush type connection. The turntable is located on one end of the chamber and the antennas are mounted 3 and 10 meters away at the other end of the chamber on the adjustable an Antenna Mast. The antenna mast is a non-conductive bore sighted type with remote control of antenna height and polarization. The Antenna Mast and the turntable can be remotely controlled through the controller located in the adjacent Control room. A wooden table 80 cm high is used for table-top equipment.

Measurement Uncertainty

For radiated emissions, U_{lab} (3.5 dB at 3m and 3.5 dB at 10m below 1 GHz, and 4.2 dB at 3m above 1 GHz) < U_{CISPR} (5.2 dB), which is the reference value in CISPR 16-4-2 Table 1, hence the compliance of the product is only based on the measured value, and no measurement uncertainty correction is required, based on CISPR 22 and CISPR 11 (for 2006 and later revisions) Clause 11.

Sample Calculation

The field strength is calculated by adding the Antenna Factor and Cable Factor, and subtracting the Amplifier Gain (if any) from the measured reading. The basic equation with a sample calculation is as follows:

| CF - AG |
|---|
| FS = Field Strength in $dB\mu V/m$ |
| RA = Receiver Amplitude (including preamplifier) in $dB\mu V$ |
| CF = Cable Attenuation Factor in dB |
| AF = Antenna Factor in dB |
| AG = Amplifier Gain in dB |
| |

In the following table(s), the reading shown on the data table reflects the preamplifier gain. An example for the calculations in the following table is as follows.

Assume a receiver reading of 52.0 dB μ V is obtained. The antenna factor of 7.4 dB and cable factor of 1.6 dB is added. The amplifier gain of 29 dB is subtracted, giving a field strength of 32 dB μ V/m. This value in dB μ V/m was converted to its corresponding level in μ V/m.

RA = 52.0 dB μ V AF = 7.4 dB/m CF = 1.6 dB AG = 29.0 dB FS = 32 dB μ V/m

To convert from $dB\mu V$ to μV or mV the following was used:

UF = $10^{(NF/20)}$ where UF = Net Reading in μ V NF = Net Reading in dB μ V

Example:

FS = RA + AF + CF - AG = 52.0 + 7.4 + 1.6 - 29.0 = 32.0 UF = $10^{(32 \text{ dB}\mu\text{V}/20)}$ = 39.8 $\mu\text{V/m}$

9.2 Test Equipment Used:

| Asset | Description | Manufacturer | Model | Serial | Cal Date | Cal Due |
|----------|--|-------------------|------------|------------|------------|------------|
| DAV001 | Weather Station | Davis Instruments | 7400 | PE80519A61 | 08/28/2012 | 08/28/2014 |
| 145128' | EMI Receiver 40 GHz (20 Hz - 40 Ghz) | Rohde & Schwarz | ESI | 8392831001 | 08/23/2011 | 09/23/2012 |
| | | | 3m Track B | | | |
| 145-416' | Cables 145-400 145-402 145-404 145-408 | Huber + Suhner | cables | multiple | 09/04/2011 | 10/04/2012 |
| HORN2' | HORN ANTENNA | EMCO | 3115 | 9602-4675 | 10/24/2011 | 10/24/2012 |

Software Utilized:


| Name | Manufacturer | Version |
|--------------------|--------------|------------|
| EMI Boxborough.xls | Intertek | 08/27/2010 |

9.3 Results:

Spurious emissions at the band edges must be at least 20 dB lower than the fundamental field strength when measured with a 100 kHz bandwidth, without the need to be below the general limits of FCC Part 15 Section 15.209 and of RSS-Gen 7.2.5 Table 5. Emissions in restricted bands must meet the general limits of FCC Part 15 Section 15.209 and of RSS-Gen 7.2.5 Table 5.


The sample tested was found to Comply.

9.4 Setup Photographs:




Intertek

9.5 Plots/Data:



Lower Band Edge Compliance, 31.51 dB down



Report Number: 102172761BOX-001b

| Company: | Mircom | | | | | | Antenna | a & Cables: | SHF | Bands: N, I | LF, HF, SHF |
|------------|--------------|----------------|--------------|--------------|--------------|--------------|--------------|----------------|------------------|-------------|----------------|
| Model #: | NC-210 | | | | | | Antenna: | HORN2 V3m | 10-24-2012.txt | HORN2 H3m | 10-24-2012.txt |
| Serial #: | 0006 | | | | | | Cable(s): | 145-416 3mTrkE | 3 09-04-2012.txt | | |
| Engineers: | Vathana Ve | en | | | Location: | 10m Chamber | Barometer: | DAV001 | | Filter: | |
| Project #: | G1008761 | 15 | Date(s): | 09/21/12 | | | | | | | |
| Standard: | FCC Part 1 | 5 Subpart C | 15.247 | | | | Temp/Humid | lity/Pressure: | 24C | 49% | 1009mbar |
| Receiver: | R&S ESI (1 | 45-128) 09-2 | 23-2012 | Limit Di | stance (m): | 3 | | | | | |
| PreAmp: | PRE145014 | 12-16-2012.txt | | Test Di | stance (m): | 3 | | | | | |
| F | PreAmp Use | ed? (Y or N): | Ν | Voltage/ | Frequency: | 120VA | C/60Hz | Freque | ncy Range: | See Fr | equency |
| | Net = Rea | ding (dBuV/ı | n) + Antenn | a Factor (dl | B1/m) + Cat | ole Loss (dB |) - Preamp | Factor (dB) | - Distance F | actor (dB) | |
| Peak: I | PK Quasi-P | eak: QP Av | erage: AVG | RMS: RMS | S; NF = Nois | e Floor, RB | = Restricte | d Band; Bar | ndwidth den | oted as RB | W/VBW |
| | Ant. | | | Antenna | Cable | Pre-amp | Distance | | | | |
| Detector | Pol. | Frequency | Reading | Factor | Loss | Factor | Factor | Net | Limit | Margin | Bandwidth |
| Туре | (V/H) | MHz | dB(uV) | dB(1/m) | dB | dB | dB | dB(uV/m) | dB(uV/m) | dB | |
| Not | e: Power int | egrated acro | ss 1 MHz ba | andwidth; dl | Bm reading | converted to | o dBuv insid | e the receiv | er using dB | m + 107 = c | dBuV |
| | | No | ote: Upper B | and Edge C | Compliance, | Integrated t | o 1 MHz RB | W Equivale | ent | | |
| PK | Н | 2484.000 | 25.10 | 28.56 | 6.04 | 0.00 | 0.00 | 59.69 | 74.00 | -14.31 | 500kHz/3MHz |
| | | 2.0.000 | == | | | | | | | | |

| Test Demonstra | Vathana Ven |
|-------------------------|----------------------------|
| Test Personnel: | Vathana Ven 🛀 |
| Supervising/Reviewing | |
| Engineer: | |
| (Where Applicable) | N/A |
| | FCC Part 15 Subpart C |
| Product Standard: | 15.247; IC RSS-210 Annex 8 |
| Input Voltage: | 120VAC/60Hz |
| Pretest Verification w/ | |
| Ambient Signals or | |
| BB Source: | Ambient |

Test Date: 09/18/2012, 09/21/2012

Test Levels: See section 7.3

Ambient Temperature: 23, 25 °C Relative Humidity: 47, 50 % Atmospheric Pressure: 999. 1014 mbars

Deviations, Additions, or Exclusions: None

10 Transmitter Radiated Spurious Emissions

10.1 Method

Tests are performed in accordance with FCC Part 15 Subpart C Section 15.247, *KDB 558074*, ANSI C63.4:2013, and RSS-247.

TEST SITE: 10m ALSE

The 10m ALSE is 13m (Length) x 21m (Depth) x 10m (Height) with the effective size in terms of space from the tips of the absorber is 12m (Length) x 20m (Depth) x 8.5m (Height). This chamber achieves broadband performance using a unique arrangement of hybrid and ferrite tile absorber. This chamber has a built in 3m diameter turntable (Embedded type). The metal structure of the table makes electrical connection around the entire circumference of the turntable to the ground plane with a metal brush type connection. The turntable is located on one end of the chamber and the antennas are mounted 3 and 10 meters away at the other end of the chamber on the adjustable an Antenna Mast. The antenna mast is a non-conductive bore sighted type with remote control of antenna height and polarization. The Antenna Mast and the turntable can be remotely controlled through the controller located in the adjacent Control room. A wooden table 80 cm high is used for table-top equipment.

Measurement Uncertainty

For radiated emissions, U_{lab} (3.5 dB at 3m and 3.5 dB at 10m below 1 GHz, and 4.2 dB at 3m above 1

GHz) < U_{CISPR} (5.2 dB), which is the reference value in CISPR 16-4-2 Table 1, hence the compliance of the product is only based on the measured value, and no measurement uncertainty correction is required, based on CISPR 22 and CISPR 11 (for 2006 and later revisions) Clause 11.

Sample Calculation

The field strength is calculated by adding the Antenna Factor and Cable Factor, and subtracting the Amplifier Gain (if any) from the measured reading. The basic equation with a sample calculation is as follows:

| FS = RA + AF + | · CF - AG |
|----------------|---|
| Where | FS = Field Strength in $dB\mu V/m$ |
| | RA = Receiver Amplitude (including preamplifier) in $dB\mu V$ |
| | CF = Cable Attenuation Factor in dB |
| | AF = Antenna Factor in dB |
| | AG = Amplifier Gain in dB |
| | |

In the following table(s), the reading shown on the data table reflects the preamplifier gain. An example for the calculations in the following table is as follows.

Assume a receiver reading of 52.0 dB μ V is obtained. The antenna factor of 7.4 dB and cable factor of 1.6 dB is added. The amplifier gain of 29 dB is subtracted, giving a field strength of 32 dB μ V/m. This value in dB μ V/m was converted to its corresponding level in μ V/m.

RA = 52.0 dB μ V AF = 7.4 dB/m CF = 1.6 dB AG = 29.0 dB FS = 32 dB μ V/m

To convert from $dB\mu V$ to μV or mV the following was used:

UF = $10^{(NF/20)}$ where UF = Net Reading in μ V NF = Net Reading in dB μ V

Example:

FS = RA + AF + CF - AG = 52.0 + 7.4 + 1.6 - 29.0 = 32.0 UF = $10^{(32 \text{ dB}\mu\text{V}/20)}$ = 39.8 $\mu\text{V/m}$

10.2 Test Equipment Used:

| Asset | Description | Manufacturer | Model | Serial | Cal Date | Cal Due |
|----------|--|---------------------|-----------------------|-------------|------------|------------|
| DAV001 | Weather Station | Davis Instruments | 7400 | PE80519A61 | 08/28/2012 | 08/28/2014 |
| '145128 | EMI Receiver 40 GHz (20 Hz - 40 Ghz) | Rohde & Schwarz | ESI | 8392831001 | 08/23/2011 | 09/23/2012 |
| 'ROS001 | Spectrum Analyzer 20Hz - 40 GHz | Rohde & Schwartz | FSEK-30 | 100225 | 02/10/2012 | 02/10/2013 |
| 'REA004 | 3GHz High Pass Filter | Reactel, Inc | 7HSX- 3G/18G-S11 | 06-1 | 11/30/2011 | 11/30/2012 |
| 'REA006 | 18GHz High Pass Filter | Reactel, Inc | 7HS- 18G/40G K11 | (06)1 | 08/08/2012 | 08/08/2013 |
| '145-410 | Cables 145-400 145-403 145-405 145-406 145-407 | Huber + Suhner | 10m Track A Cables | multiple | 09/04/2011 | 10/04/2012 |
| '145-416 | Cables 145-400 145-402 145-404 145-408 | Huber + Suhner | 3m Track B cables | multiple | 09/04/2011 | 10/04/2012 |
| 'CBL030 | High Frequency Cable 40GHz | Megaphase | TM40 K1K1 80 | CBL030 | 02/08/2012 | 02/08/2013 |
| 'MEG005 | High Frequency Cable | Megaphase | TM40-K1K1- 197 | 8148601-001 | 02/07/2012 | 02/07/2013 |
| 'PRE8 | PREAMPLFIER 1- 40 GHz | MITEQ | NSP4000-NF | 507145 | 01/26/2012 | 01/26/2013 |
| ·145003 | Preamplifier (150 KHz to 1.3 GHz) | Hewlett Packard | 8447D | 2443A04077 | 10/04/2011 | 10/04/2012 |
| '145014 | Preamplifier (1 GHz to 26.5 GHz) | Hewlett Packard | 8449B | 3008A00232 | 12/16/2011 | 12/16/2012 |
| '145034 | BiLog Antenna (30 MHz to 1GHz) | Schaffner Chase EMC | CBL6111C | 2564 | 02/07/2012 | 02/07/2013 |
| 'HORN2 | HORN ANTENNA | EMCO | 3115 | 9602-4675 | 10/24/2011 | 10/24/2012 |
| 'EMC04 | ANTENNA, RIDGED GUIDE, 18-40 GHZ | EMCO | 3116 | 2090 | 02/08/2012 | 02/08/2013 |

Intertek

Tested 08/28/2015

| Asset | Description | Manufacturer | Model | Serial | Cal Date | Cal Due |
|---------------------|--|-------------------|-------------------|-------------|------------|------------|
| DAV004' | Weather Station | Davis Instruments | 7400 | PE80529A61A | 10/06/2014 | 10/06/2015 |
| 145128' | EMI Receiver (20 Hz - 40 Ghz) | Rohde & Schwarz | ESIB 40 | 839283/001 | 03/14/2015 | 03/14/2016 |
| ROS001' | Spectrum Analyzer 20Hz - 40 GHz | Rohde & Schwartz | FSEK-30 | 100225 | 06/04/2015 | 06/04/2016 |
| REA004' | 3GHz High Pass Filter | Reactel, Inc | 7HSX-3G/18G-S11 | 06-1 | 12/30/2013 | 12/30/2015 |
| REA006' | 18GHz High Pass Filter | Reactel, Inc | 7HS-18G/40G K11 | (06)1 | 08/28/2014 | 08/28/2016 |
| 145-416' | Cables 145-400 145-402 145-404 145-408 | Huber + Suhner | 3m Track B cables | multiple | 10/04/2014 | 10/04/2015 |
| CBLHF2012 -2M-2' | 2m 9kHz-40GHz Coaxial Cable - SET2 | Huber & Suhner | SF102 | 252675002 | 02/05/2015 | 02/05/2016 |
| CBLHF2012 -5M-2' | 5m 9kHz-40GHz Coaxial Cable - SET2 | Huber & Suhner | SF102 | 252676002 | 02/05/2015 | 02/05/2016 |
| PRE9' | 100MHz-40GHz Preamp | MITEQ | NSP4000-NFG | 1260417 | 09/06/2013 | 09/06/2014 |
| 145014' | Preamplifier (1 GHz to 26.5 GHz) | Hewlett Packard | 8449B | 3008A00232 | 05/13/2015 | 05/13/2016 |
| ETS001' | 1-18GHz DRG Horn Antenna | ETS-Lindgren | 3117 | 00143259 | 01/14/2015 | 01/14/2016 |
| EMC04' | ANTENNA, RIDGED GUIDE, 18-40 GHZ | EMCO | 3116 | 2090 | 04/07/2015 | 04/07/2016 |

Software Utilized:

| Name | Name Manufacturer | |
|------|-------------------|-----------------|
| C5 | Teseq | Build 5.26.00.3 |

| Name | Manufacturer | Version |
|--------------------|--------------|------------|
| EMI Boxborough.xls | Intertek | 08/27/2010 |

10.3 Results:

The sample tested was found to Comply.


FCC Part 15.247(d) & RSS-247 Section 5.5 – Non Restricted Band Radiated Spurious/Harmonics Limits

In any 100 kHz bandwidth outside the frequency band , the radio frequency power that is produced by the intentional radiator shall be at least 20 dB below that in the 100 kHz bandwidth within the band that contains the highest level of the desired power, based on either an RF conducted or a radiated measurement. Attenuation below the general limits specified in §15.209(a) and RSS-Gen Section 6.13 Table 4 is not required. In addition, radiated emissions which fall in the restricted bands, as defined in 15.205(a) and RSS-Gen Section 8.10, must also comply with the radiated emission limits specified in 15.209(a) and IC RSS-Gen Section 6.13.

FCC Part 15.209(a) & RSS-247 Section 5.5 & RSS-Gen Section 8.10 – Restricted Band Radiated Spurious/Harmonics Limits

| Frequency | Fiel | Test Distance | |
|-----------|------|---------------|----------|
| (MHz) | μV/m | dBµV/m | (meters) |
| 30–88 | 100 | 40.00 | 3 |
| 88–216 | 150 | 43.52 | 3 |
| 216–960 | 200 | 46.02 | 3 |
| Above 960 | 500 | 53.98 | 3 |

10.4 Setup Photographs:




Intertek


30-1000MHz

Intertek

Report Number: 102172761BOX-001b



1-18GHz



Intertek

18-25GHz Hand scans

10.5 Plots/Data:


Spurious Emissions 30-1000MHz

Test Information User Entry Radiated - FCC15 Class B @ 10m Mircom (IgeaCare_G100357410_Beacon) 1006mB, CH11_Tx mode Test Details Test: Project: Test Notes: Temperature: Humidity: 25 deg C 38% Vathana Ven 17 Sep 2012 22 : 39 Tested by: Test Started:

Additional Information

Prescan Emission Graph


•



| Frequency | Level | AF | PA+CL | Limit | Margin | Hor (), | Azimuth (deg) | Mast Height | RBW |
|-----------------|----------|--------|---------|----------|----------|-----------|---------------|-------------|-------|
| (Hz) | (dBuV/m) | AF | FATUL | (dBuV/m) | (dBuV/m) | Ver () | (Deg) | (m) | (Hz) |
| 255.656112261 M | 9.58 | 13.579 | -24.138 | 35.540 | -25.96 | | 158 | 1.75 | 120 k |
| 121.775550651 M | 8.80 | 11.378 | -25.073 | 33.040 | -24.24 | | 321 | 3.93 | 120 k |
| 967.682164625 M | 25.13 | 24.907 | -22.386 | 43.540 | -18.41 | | 134 | 3.29 | 120 k |
| 539.157314379 M | 19.06 | 21.831 | -23.979 | 35.540 | -16.48 | | 321 | 1.04 | 120 k |
| 32.515030397 M | 13.52 | 17.691 | -26.106 | 29.540 | -16.02 | | 1 | 1.67 | 120 k |
| 30.608416834 M | 14.38 | 18.674 | -26.113 | 29.540 | -15.16 | | 1 | 1.87 | 120 k |
| | | | | | | | | | |

Issued: 09/04/2015

Azimuth Plots




All Polarities


Azimuth (Degrees)

Turntable Plot (32.515030397 MHz)

Level (dBuV/m)



Height Plot (30.608416834 MHz) 3.5 3 2.5 2 1.5 Height (m) 1 0 20 40 Level (dBuV/m) 60 80




All Polarities

Azimuth (Degrees)

4


Intertek


Intertek




All Polarities

Azimuth (Degrees)








All Polarities

Issued: 09/04/2015

Height Plot (539.157314379 MHz)

4




All Polarities


Azimuth (Degrees)


Intertek



Level (dBuV/m)








All Polarities

Issued: 09/04/2015

Test Information Test Details Test: Project: Test Notes: Temperature: Humidity: Tested by: Test Started:

User Entry Radiated - FCC15 Class B @ 10m Mircom (IgeaCare_G100357410_Beacon) 1006mB, CH18_Tx mode 25 deg C 38% Vathana Ven 17 Sep 2012 23 : 16

Prescan Emission Graph



Swept Peak Data

Swept Quasi Peak Data

Swept Average Data

Intertek

Measured Peak Value

Measured Quasi Peak Value

Measured Average Value

• Maximum Value of Mast and Turntable

Emissions Test Data Trace²· Measured Ouasi Peak


| Tracez. Measureu | Quasi Peak | | | |
|-------------------|-------------------|----|-------|----------------|
| Frequency (Hz) | Level (dBuV/m) | AF | PA+CL | Limit (dBu) |

| Frequency (Hz) | Level (dBuV/m) | AF | PA+CL | Limit (dBuV/m) | Margin (dBuV/m) | Hor (), Ver () | Azimuth (deg) (Deg) | Mast Height (m) | RBW (Hz) |
|-------------------|-------------------|--------|---------|-------------------|--------------------|-----------------------|------------------------|--------------------|-------------|
| | | 40.045 | 04.440 | | | | | | |
| 271.363727343 M | 9.27 | 13.245 | -24.112 | 35.540 | -26.27 | | 360 | 1.46 | 120 k |
| 34.866332283 M | 12.29 | 16.567 | -26.098 | 29.540 | -17.25 | | 169 | 4.00 | 120 k |
| 545.449299076 M | 18.88 | 21.637 | -23.974 | 35.540 | -16.66 | Í | 106 | 2.19 | 120 k |
| 32.156913996 M | 13.73 | 17.906 | -26.107 | 29.540 | -15.81 | | 181 | 1.05 | 120 k |
| 844.028456846 M | 22.32 | 23.303 | -23.036 | 35.540 | -13.22 | 1 | 93 | 3.09 | 120 k |
| 958.995391012 M | 24.65 | 24.560 | -22.406 | 35.540 | -10.89 | | 103 | 4.00 | 120 k |

Additional Information

Issued: 09/04/2015

Azimuth Plots





All Polarities


Azimuth (Degrees)

Turntable Plot (34.866332283 MHz)

Level (dBuV/m)








All Polarities

Azimuth (Degrees)


Intertek

Intertek





All Polarities


Azimuth (Degrees)



Level (dBuV/m)









All Polarities

Intertek





All Polarities

Azimuth (Degrees)



90





All Polarities

135

Azimuth (Degrees)


45

Issued: 09/04/2015

Test Information Test Details Test: Project: Test Notes: Temperature: Humidity: Tested by: Test Started:

User Entry Radiated - FCC15 Class B @ 10m Mircom (IgeaCare_G100357410_Beacon) 1006mB, CH26_Tx mode 25 deg C 38% Vathana Ven 17 Sep 2012 23 : 53

Prescan Emission Graph



Swept Peak Data

Swept Quasi Peak Data

Swept Average Data

Intertek

Measured Peak Value

Measured Quasi Peak Value

Measured Average Value

Maximum Value of Mast and Turntable

Emissions Test Data


| Trace2: | Measured | Quasi | Peak |
|---------|----------|-------|------|
|---------|----------|-------|------|

| Frequency | Level | AF | PA+CL | Limit | Margin | Hor (), Ver () | Azimuth (deg) | Mast Height | RBW |
|-----------------|----------|--------|---------|----------|----------|---------------------|---------------|-------------|-------|
| (Hz) | (dBuV/m) | ~ | FAIGL | (dBuV/m) | (dBuV/m) | 1101 (), Vei () | (Deg) | (m) | (Hz) |
| 260.027454451 M | 10.25 | 14.100 | -24.131 | 35.540 | -25.29 | | 0 | 1.64 | 120 k |
| 435.34168322 M | 14.00 | 17.093 | -23.921 | 35.540 | -21.54 | | 186 | 2.29 | 120 k |
| 964.846292489 M | 24.90 | 24.794 | -22.393 | 43.540 | -18.64 | | 14 | 3.73 | 120 k |
| 543.01883793 M | 19.05 | 21.819 | -23.976 | 35.540 | -16.49 | | 256 | 2.04 | 120 k |
| 31.356913996 M | 14.08 | 18.257 | -26.110 | 29.540 | -15.46 | | 291 | 2.66 | 120 k |
| 844.102605255 M | 22.33 | 23.310 | -23.036 | 35.540 | -13.21 | i i | 360 | 3.83 | 120 k |

Additional Information

Issued: 09/04/2015

Azimuth Plots




All Polarities

Azimuth (Degrees)


Intertek

Turntable Plot (260.027454451 MHz)

Level (dBuV/m)



Height Plot (31.356913996 MHz) 3.5 3 2.5 2 1.5 Height (m) 0 20 40 Level (dBuV/m) 60 80




All Polarities

Azimuth (Degrees)


4

Intertek







Azimuth (Degrees)



90






All Polarities

135

Azimuth (Degrees)


45

Intertek





All Polarities

Azimuth (Degrees)



90





All Polarities

Harmo

Tx Spurious Emissions above 1GHz Radiated Emissions

Intertek

| Model, #. NC-210 Anterna: ETS0101-14-16.bit. ETS011-14-16.bit. ETS011-14-16.bit. ETS011-14-16.bit. ETS0101-14-16.bit. ETS011-14-16.bit. ETS011-14-16.bit. ETS01 | | | chnologies L | td. | | | | | a & Cables: | | | LF, HF, SHF | | |
|--|---|-----|--------------|--------------|-----------|---------------------------------------|-------|-------------|----------------|------------------|--------|--------------|-------------|----|
| Englness: Vathana Ven Projecit #: (20179955) Date(s): 08/2713 Standard: FCC Part 152, 15.247 International fields of the second secon | | | | | | | | | | | | | | |
| Piced E Distance: Count of the second of t | | | on | | | Location: | 10M | . , | | 5 10-04-2015.txt | | | | |
| Standard: FCC Part 162, 15,247 Temp14umidty/Pressure: 22 deg C 41% 1006 mB PreAmp: 145014 06-13-16.kt Test Distance (m): 3 Test Distance (m): 3 Test Distance (m): 3 PreAmp: 145014 06-13-16.kt Test Distance (m): 3 Test Distance (m): 3 Test Distance (m): 3 PreAmp: 145014 06-13-16.kt Test Distance (m): 3 Test Distance (m): 3 Test Distance (m): 3 PreAmp: 145014 06-13-16.kt Test Distance (m): 3 Test Distance (m): 3 Test Distance (m): 3 Type PreAmp: 145014 06-13-16.kt Test Distance (m): 3 Test Distance (m): 3 Test Distance (m): 3 Type Path Reading, Glaumanna test Distance (m): 400 (m) | • | | | Date(s): | 08/27/15 | Lucation. | | Darometer. | DAV004 | | | NLA004 | | |
| Receive: R&S ESI (145-128) 10-01-2014 Limit Distance (m): 3 PreAmp: 14501405-13-16.bit Test Distance (m): 3 PreAmp: 14501405-13-16.bit Test Distance (m): 3 Frequency Range: 1-25 GHz Note 1 Note 1 <t< td=""><td>-</td><td></td><td></td><td>Date(3).</td><td>00/21/10</td><td></td><td></td><td>Temn/Humic</td><td>hitu/Droccuro:</td><td>22 deg C</td><td>11%</td><td>1006 mB</td><td></td><td></td></t<> | - | | | Date(3). | 00/21/10 | | | Temn/Humic | hitu/Droccuro: | 22 deg C | 11% | 1006 mB | | |
| PreAmp: 145014 Distance (m): 3 Preamp Used? (V or N): Y Y Otage/Frequency: Battery powered Frequency Range: 1.25 GHz Net = Reading (GUV/m) + Anterna Factor (GB /m) + Cable Loos (GB) - Preamp Factor (GB) - Distance Eactor (GB) - 1.25 GHz Detector Pol. Frequency Reading Frequency RB Frequency RB Eactor Eactor <t< td=""><td></td><td></td><td>,</td><td>11-2014</td><td>Limit Di</td><td>istance (m):</td><td>3</td><td>rempiriumic</td><td>nty/r ressure.</td><td>22 deg 0</td><td>4170</td><td>1000 1110</td><td></td><td></td></t<> | | | , | 11-2014 | Limit Di | istance (m): | 3 | rempiriumic | nty/r ressure. | 22 deg 0 | 4170 | 1000 1110 | | |
| PreAmp Used? Y Voltage/Frequency. Battery powered Frequency Range: 1.25 GHz Net = Reading (dBU/m) + Antenna Factor (dBT) Peak: PK Quasi-Peak: QP Average: AVG RMS: RMS; NF = Noise Floor, RB = Restricted Band, Bandwidth denoted as RBW/VBW Immediate and the set of the se | | | , | 51-2014 | | . , | | | | | | | | |
| Net Readring (dBU/m) + Antemna Cable Preame Factor (dB) Detector Pick Frequency Reading Factor Factor Net Limit Margin Bandwidth Detector Pol. Frequency Reading Factor Loss Factor Net Limit Margin Bandwidth Type (VI) MHz B(U/m) Bl Bl <td>•</td> <td></td> <td></td> <td>Y</td> <td></td> <td>• • •</td> <td></td> <td>nowered</td> <td>Freque</td> <td>ncy Range.</td> <td>1-25</td> <td>GH7</td> <td></td> <td></td> | • | | | Y | | • • • | | nowered | Freque | ncy Range. | 1-25 | GH7 | | |
| Peak: PK Quasi-Peak: QP Average: AVG RMS: RMS: NF = Noise Floor. RB = Restricted Band; Bandwidth denoted as RBW/VBW Detector Pol. Frequency Reading Fractor Loss Factor Net Limit Margin Bandwidth Type (V/H) MHz dB(1/M) dB dB dB dB(1/M) dB B C </td <td></td> <td>•</td> <td>· · ·</td> <td></td> <td>•</td> <td></td> <td></td> <td>•</td> <td></td> <td>, ,</td> <td></td> <td>0112</td> <td></td> <td></td> | | • | · · · | | • | | | • | | , , | | 0112 | | |
| Ant: Detector Productor Reading (Factor Pype Anterna (Mit) Cable (Mit) Distance (Mit) Net (Mit) Limit (Margin (Margin) Bandwidth (Margin) FCC IC Note: Spurious Emissions Reference: (ViH) Mit2 Spurious Emissions Reference: (Mit) Note: Spurious Emissions Reference: (Mit) Note: Spurious Emissions Reference: (Mit) Note: Spurious Emissions Reference: (Mit) Note: Spurious Chilling Note: Sp | Peak I | | | | | | | | | | | W/VBW | | |
| Detector Pol. Frequency HH Feading B(H/m) Factor B(B(H/m) Factor B(B) Factor B(B) Factor B(B) Net B(B) Imit B(B) Margin B(B) Bandwidth B(H/m) FCC IC Note: Spurious Emissions Reference. Fundamental frequencies (modulated) at 3 meters with no pre-amp. Typical Orientation Typical Orientation Typical Orientation PK H 2405.000 36.02 31.97 5.92 0.00 0.00 77.44 - - 100/300 H/z PK H 2406.000 40.76 32.11 5.98 0.00 0.00 78.85 - - 100/300 H/z PK H 2440.000 40.76 32.21 5.98 0.00 0.00 78.85 - - 100/300 H/z PK V 2440.000 40.74 32.28 6.06 0.00 0.00 78.86 - - 100/300 H/z PK H 2480.000 12.31 45.19 8.65 31.62 0.00 47.30 | | 1 | | olugo. / tro | 1 | · · · · · · · · · · · · · · · · · · · | 1 | 1 | | | | | T | |
| Type (V/H) MHz dB(UV) | Detector | | Frequency | Reading | | | | | Net | l imit | Margin | Bandwidth | | |
| PK H 2480.000 41.12 2406504 28.93 0.00 77.44 - - 100/300 kHz PK V 2405.000 39.55 31.97 5.52 0.00 0.00 77.44 - - 100/300 kHz PK V 2405.000 30.62 31.97 5.52 0.00 0.00 77.94 - - 100/300 kHz PK H 2440.000 40.76 32.11 5.98 0.00 0.00 78.36 - - 100/300 kHz PK V 2440.000 41.17 32.11 5.98 0.00 0.00 78.36 - - 100/300 kHz PK H 2480.000 41.24 32.26 6.06 0.00 0.00 78.36 - - 100/300 kHz PK H 4810.000 12.13 34.19 8.65 31.62 0.00 42.73 57.44 -14.71 100/300 kHz Noise Floor Noise Floor | | | | U | | | | | | | - | Danathan | FCC | IC |
| CH11 - 2405MHz, No pre-amp, Typical Orientation PK H 2405.000 39.55 31.97 5.92 0.00 0.00 77.44 - 100/300 Hz PK V 2405.000 36.02 31.97 5.92 0.00 0.00 77.44 - 100/300 Hz PK V 2440.000 41.17 32.11 5.98 0.00 0.00 78.85 - 100/300 Hz PK V 2440.000 41.17 32.11 5.98 0.00 0.00 78.85 - 100/300 Hz PK V 2440.000 40.04 32.26 6.06 0.00 0.00 78.66 - 100/300 Hz PK V 2480.000 31.34 19 8.65 31.62 0.00 42.53 74.00 -25.47 1/3MHz Noise Floor PK H 4810.000 37.31 3.419 8.65 31.62 0.00 42.73 57.44 1.99.51 100/300Hz Nois | .,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,, | | | . , | , | | | | () | () | | | | |
| PK H 2405.000 39.55 31.97 5.92 0.00 77.44 - - 100300 Hz PK V 2405.000 36.02 31.97 5.92 0.00 73.91 - - 100300 Hz PK H 2440.000 40.76 32.11 5.98 0.00 0.00 78.35 - - 100300 Hz PK H 2440.000 41.77 32.11 5.98 0.00 0.00 78.36 - - 100300 Hz CH26 24800MHz, No pre-smp, Typical Orientation - 100300 Hz - - 100300 Hz PK H 4810.000 37.31 34.19 8.65 31.62 0.00 42.53 57.40 -30.65 1/3MHz Noise Floor PK H 7215.000 27.10 35.68 11.02 31.08 0.00 42.73 57.44 -1.47.11 100/300Hz Noise Floor PK H 12025.000 9.58 <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>-</td> <td>o mai no pre</td> <td>o ump</td> <td></td> <td></td> <td></td> | | | | | | | | | - | o mai no pre | o ump | | | |
| PK V 2405.000 36.02 31.97 5.92 0.00 73.91 - - 100300 kHz PK H 2440.000 40.76 32.11 5.98 0.00 0.00 78.85 - - 100300 kHz PK V 2440.000 41.17 32.11 5.98 0.00 0.00 78.85 - - 100300 kHz PK V 2440.000 41.24 22.26 6.06 0.00 79.86 - - 100300 kHz PK V 2480.000 40.04 32.26 6.06 0.00 2.85 - - 100300 kHz PK H 4810.000 37.31 34.19 8.65 31.62 0.00 23.35 54.00 -30.65 1/3/MHz Noise Floor PK H 7215.000 27.10 35.68 11.02 31.62 0.00 47.49 57.44 -49.51 100/300kHz Noise Floor Noise Floor | PK | н | 2405.000 | - | <u> </u> | - | 1 | 1 | 1 | - | - | 100/300 kHz | | |
| PK H 2440.000 40.76 32.11 5.98 0.00 0.00 78.85 - - 100/300 kHz PK H 2440.000 41.77 32.11 5.98 0.00 79.26 - - 100/300 kHz PK H 2480.000 41.24 32.26 6.06 0.00 79.56 - - 100/300 kHz PK H 2480.000 40.22.6 6.06 0.00 79.56 - - 100/300 kHz PK H 4810.000 37.31 34.19 8.65 31.62 0.00 48.53 74.00 -25.47 1/3MHz Noise Floor PK H 4810.000 12.13 34.19 8.65 31.62 0.00 47.39 57.44 -9.51 100/300kHz Noise Floor PK H 12025.000 24.76 38.81 14.93 24.91 0.00 63.58 74.40 -9.52 100/300kHz Noise Floor Noise Floor | | | | | | | | | | - | - | | + | |
| PK H 2440.000 40.76 32.11 5.98 0.00 0.00 79.26 - - 100/300 Hz PK V 2440.000 41.17 32.11 5.98 0.00 0.00 79.26 - - 100/300 Hz PK H 2480.000 41.24 32.26 6.06 0.00 0.00 79.56 - - 100/300 Hz PK V 2480.000 40.04 32.26 6.06 0.00 0.00 78.56 - - 100/300 Hz PK H 4810.000 37.31 34.19 8.65 31.62 0.00 23.5 54.00 -30.65 1/3MHz Noise Floor PK H 7215.000 27.10 35.68 10.02 35.8 74.00 -10.42 1/3MHz Noise Floor PK H 12025.000 24.76 38.81 14.93 24.91 0.00 63.58 74.00 -1.42 1/3MHz Noise Floor | | . · | | | | | | | | | 1 | 100,000 1012 | | |
| PK V 2440.000 41.17 32.11 5.98 0.00 0.00 79.26 - - 100/300 kHz PK H 2480.000 41.17 32.26 6.06 0.00 0.00 79.56 - - 100/300 kHz PK V 2480.000 40.04 32.26 6.06 0.00 0.00 78.36 - - 100/300 kHz PK H 4810.000 17.31 34.19 8.65 31.62 0.00 23.35 54.00 -30.65 1/3MHz Noise Floor PK H 7215.000 27.10 35.68 11.02 31.08 0.00 42.73 57.44 -14.71 100/300kHz Noise Floor PK H 7225.000 34.76 38.81 14.93 24.91 0.00 63.58 74.40 -16.60 1/3MHz Noise Floor PK H 142025.000 35.84 31.62 0.00 54.12 57.44 -1.56 | PK | н | 2440.000 | | | | | 1 | | - | - | 100/300 kHz | | |
| CH26 - 2480MHz, No pre-amp, Typical Orientation PK H 2480.000 41.24 32.26 6.06 0.00 0.00 79.56 - - 100/300 kHz PK V 2480.000 40.04 32.26 6.06 0.00 0.00 78.36 - - 100/300 kHz CH11 - 2405MHz, Spurious Emissions from 1-18GHz, REA004 CH11 - 2405MHz Spurious Emissions from 1-18GHz, REA004 - - 100/300 kHz Noise Floor PK H 4810.000 12.13 34.19 8.65 31.62 0.00 23.35 55.400 -30.651 1/31Hz Noise Floor PK H 7215.000 27.10 35.68 11.02 31.08 0.00 42.73 57.44 -14.71 100/300kHz Noise Floor PK H 19225.000 37.66 38.81 14.93 24.91 0.00 38.40 54.00 -15.60 1/3MHz Noise Floor PK H 14830.000 25.93 39.30 < | | | | | | | | | | - | | | ł | |
| PK H 2480.000 41.24 32.26 6.06 0.00 79.56 - - 100/300 kHz PK V 2480.000 40.04 32.26 6.06 0.00 79.56 - - 100/300 kHz PK V 2480.000 37.31 34.19 8.65 31.62 0.00 48.53 74.00 -25.47 1/3MHz Noise Floor PK H 4810.000 12.13 34.19 8.65 31.62 0.00 42.73 57.44 -14.71 100/300kHz Noise Floor PK H 9620.000 26.49 36.69 12.78 28.47 0.00 43.49 -10.42 1/3MHz Noise Floor AVG H 12025.000 34.76 38.81 14.93 24.91 0.00 58.40 -15.60 1/3MHz Noise Floor AVG H 14205.000 25.93 39.30 15.12 26.24 0.00 54.12 57.44 -3.32 100 | | - | | | | | | | | | | 1 | | |
| PK V 2480.000 40.04 32.26 6.06 0.00 78.36 - - 100/300 kHz PK H 4810.000 37.31 34.19 8.65 31.62 0.00 23.55 54.00 -30.65 1/3MHz Noise Floor PK H 4810.000 27.10 35.68 11.02 31.08 0.00 42.73 57.44 -14.71 100/300kHz Noise Floor PK H 7205.000 26.49 36.69 12.78 28.47 0.00 47.49 57.44 -9.95 100/300kHz Noise Floor PK H 12025.000 3.476 38.81 14.93 24.91 0.00 63.58 74.00 -15.60 1/3MHz Noise Floor PK H 14430.000 25.93 39.30 15.12 26.24 0.00 54.86 57.44 -1.56 10/300kHz Noise Floor PK H 1480.000 35.84 34.16 8.75 31.60 | PK | н | 2480.000 | | 1 | | 1 1 1 | | 1 | - | - | 100/300 kHz | | |
| CH11 - 2405MHz, Spurious Emissions from 1-18GHz, REA004 PK H 4810.000 37.31 34.19 8.65 31.62 0.00 48.53 74.00 -25.47 1/3MHz Noise Floor AVG H 4810.000 12.13 34.19 8.65 31.62 0.00 23.35 54.00 -30.65 1/3MHz Noise Floor PK H 7215.000 27.10 35.68 11.02 31.08 0.00 42.73 57.44 -19.71 100/300kHz Noise Floor PK H 9620.000 26.49 38.69 12.78 28.47 0.00 47.49 57.44 -19.95 100/300kHz Noise Floor PK H 12025.000 9.58 38.81 14.93 24.91 0.00 38.40 54.00 -10.42 1/3MHz Noise Floor PK H 16835.000 23.00 41.41 18.22 26.75 0.00 54.12 57.44 -15.61 100/300kHz Noise Floor | | | | | | | | | | | | | + | |
| PK H 4810.000 37.31 34.19 8.65 31.62 0.00 48.53 74.00 -25.47 1/3MHz Noise Floor PK H 4810.000 12.13 34.19 8.65 31.62 0.00 23.35 54.00 -30.65 1/3MHz Noise Floor PK H 721.00 35.68 11.02 31.08 0.00 42.73 57.44 -14.71 100/300kHz Noise Floor PK H 9620.000 26.49 36.69 12.78 28.47 0.00 47.49 57.44 -9.95 100/300kHz Noise Floor AVG H 12025.000 34.76 38.81 14.93 24.91 0.00 58.48 74.40 -1.56 1/3MHz Noise Floor PK H 14830.000 23.00 41.41 18.22 26.75 0.00 55.88 57.44 -1.56 100/300kHz Noise Floor PK H 4880.000 10.66 34.16 8 | | | | | | | | | | | | | | |
| AVG H 4810.000 12.13 34.19 8.65 31.62 0.00 23.35 54.00 -30.65 1/3MHz Noise Floor PK H 7215.000 27.10 35.68 11.02 31.08 0.00 42.73 57.44 -14.71 100/300kHz Noise Floor PK H 9620.000 26.49 36.69 12.78 28.47 0.00 47.49 57.44 -9.95 100/300kHz Noise Floor AVG H 12025.000 9.58 38.81 14.93 24.91 0.00 38.40 54.00 -15.60 1/3MHz Noise Floor PK H 14630.000 25.93 39.30 15.12 26.24 0.00 54.12 57.44 -3.32 100/300kHz Noise Floor PK H 16835.000 35.64 34.16 8.75 31.60 0.00 47.14 74.00 -26.86 1/3MHz Noise Floor AVG H 4880.000 10.66 | РК | н | 4810.000 | | | | | 1 | | 74.00 | -25.47 | 1/3MHz | Noise Floor | |
| PK H 7215.000 27.10 35.68 11.02 31.08 0.00 42.73 57.44 -14.71 100/300kHz Noise Floor PK H 9620.000 26.49 36.69 12.78 28.47 0.00 47.49 57.44 -9.95 100/300kHz Noise Floor PK H 12025.000 9.58 38.81 14.93 24.91 0.00 63.58 74.00 -10.42 1/3MHz Noise Floor PK H 12025.000 9.58 38.81 14.93 24.91 0.00 58.47 4.00 1.560 1/3MHz Noise Floor PK H 16835.000 23.00 41.41 18.22 26.75 0.00 55.88 57.44 -1.56 100/300kHz Noise Floor OK H 4880.000 10.66 34.16 8.75 31.60 0.00 21.96 54.00 -32.04 1/3MHz Noise Floor PK H 7320.000 11.72 3 | | | | | | | | | | | | | + | |
| PK H 9620.000 26.49 36.69 12.78 28.47 0.00 47.49 57.44 -9.95 100/300kH2 Noise Floor PK H 12025.000 34.76 38.81 14.93 24.91 0.00 63.58 74.00 -10.42 1/3MHz Noise Floor AVG H 12025.000 9.58 38.81 14.93 24.91 0.00 38.40 54.00 -15.60 1/3MHz Noise Floor PK H 14430.000 25.93 39.30 15.12 26.24 0.00 54.12 57.44 -3.32 100/300kH2 Noise Floor PK H 16835.000 35.84 34.16 8.75 31.60 0.00 47.14 74.00 -26.86 1/3MHz Noise Floor AVG H 4880.000 10.66 34.16 8.75 31.60 0.00 27.38 54.00 -32.04 1/3MHz Noise Floor AVG H 7320.000 11.72 <td< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>1</td><td></td><td></td><td></td><td></td><td>+</td><td></td></td<> | | | | | | | | 1 | | | | | + | |
| PK H 12025.000 34.76 38.81 14.93 24.91 0.00 63.58 74.00 -10.42 1/3MHz Noise Floor AVG H 12025.000 9.58 38.81 14.93 24.91 0.00 38.40 54.00 -15.60 1/3MHz Noise Floor PK H 14430.000 25.93 39.30 15.12 26.24 0.00 54.12 57.44 -3.32 100/300kHz Noise Floor PK H 16835.000 23.00 41.41 18.22 26.75 0.00 55.88 57.44 -1.56 100/300kHz Noise Floor Noise Floor CH18 - 2440MHz, Spurious Emissions from 1-18GHz, REA004 Noise Floor Noise Floor Noise Floor Noise Floor AVG H 4880.000 10.66 34.16 8.75 31.60 0.00 27.38 54.00 -26.62 1/3MHz Noise Floor AVG H 7320.000 11.72 35.61 11.10 31.05 0.00 | | | | | | | | 1 | | | | | ł | |
| AVG H 12025.000 9.58 38.81 14.93 24.91 0.00 38.40 54.00 -15.60 1/3MHz Noise Floor PK H 14430.000 25.93 39.30 15.12 26.24 0.00 54.12 57.44 -3.32 100/300kHz Noise Floor PK H 18830.000 23.00 41.41 18.22 26.75 0.00 55.88 57.44 -1.56 100/300kHz Noise Floor VG H 4880.000 35.84 34.16 8.75 31.60 0.00 47.14 74.00 -26.86 1/3MHz Noise Floor AVG H 4880.000 10.66 34.16 8.75 31.60 0.00 27.38 54.00 -32.04 1/3MHz Noise Floor AVG H 7320.000 11.72 35.61 11.10 31.05 0.00 27.38 54.00 -24.62 1/3MHz Noise Floor PK H 9760.000 24.70 | | | | | | | | | | | | | + | |
| PK H 14430.000 25.93 39.30 15.12 26.24 0.00 54.12 57.44 -3.32 100/300kHz Noise Floor PK H 16835.000 23.00 41.41 18.22 26.75 0.00 55.88 57.44 -1.56 100/300kHz Noise Floor PK H 4880.000 35.84 34.16 8.75 31.60 0.00 47.14 74.00 -26.86 1/3MHz Noise Floor AVG H 4880.000 10.66 34.16 8.75 31.60 0.00 21.96 54.00 -32.04 1/3MHz Noise Floor NVG H 7320.000 11.72 35.61 11.10 31.05 0.00 27.38 54.00 -26.62 1/3MHz Noise Floor PK H 9760.000 24.70 36.85 13.11 28.26 0.00 46.40 58.85 -12.45 100/300kHz Noise Floor PK H 12200.000 10.72 | | | | | | | | | | | | 1 | • | |
| PK H 16835.000 23.00 41.41 18.22 26.75 0.00 55.88 57.44 -1.56 100/300kHz Noise Floor PK H 4880.000 35.84 34.16 8.75 31.60 0.00 47.14 74.00 -26.86 1/3MHz Noise Floor AVG H 4880.000 10.66 34.16 8.75 31.60 0.00 21.96 54.00 -32.04 1/3MHz Noise Floor PK H 7320.000 36.90 35.61 11.10 31.05 0.00 27.38 54.00 -26.62 1/3MHz Noise Floor AVG H 9760.000 24.70 36.85 13.11 28.26 0.00 46.40 58.85 -12.45 10/300kHz Noise Floor PK H 12200.000 10.72 38.96 14.80 25.01 0.00 39.47 54.00 -14.53 1/3MHz Noise Floor PK H 14640.000 24.30 | | | | | | | | | | | | | ł | |
| CH18 - 2440MHz, Spurious Emissions from 1-18GHz, REA004 Noise Floor PK H 4880.000 35.84 34.16 8.75 31.60 0.00 47.14 74.00 -26.86 1/3MHz Noise Floor AVG H 4880.000 10.66 34.16 8.75 31.60 0.00 21.96 54.00 -32.04 1/3MHz Noise Floor PK H 7320.000 36.90 35.61 11.10 31.05 0.00 27.38 54.00 -21.44 1/3MHz Noise Floor AVG H 7320.000 11.72 35.61 11.10 31.05 0.00 27.38 54.00 -26.62 1/3MHz Noise Floor PK H 9760.000 24.70 36.85 13.11 28.26 0.00 46.40 58.85 -12.45 100/30kHz Noise Floor PK H 12200.000 10.72 38.96 14.80 25.01 0.00 39.47 54.00 -14.53 1/3MHz | | | | | | | | | | | | | + | |
| PK H 4880.000 35.84 34.16 8.75 31.60 0.00 47.14 74.00 -26.86 1/3MHz Noise Floor AVG H 4880.000 10.66 34.16 8.75 31.60 0.00 21.96 54.00 -32.04 1/3MHz Noise Floor PK H 7320.000 36.90 35.61 11.10 31.05 0.00 27.38 54.00 -21.44 1/3MHz Noise Floor AVG H 7320.000 11.72 35.61 11.10 31.05 0.00 27.38 54.00 -26.62 1/3MHz Noise Floor PK H 9760.000 24.70 36.85 13.11 28.26 0.00 46.40 58.85 -12.45 100/300kHz Noise Floor AVG H 12200.000 10.72 38.96 14.80 25.01 0.00 52.83 58.85 -6.02 100/300kHz Noise Floor PK H 14640.000 24.30 <td< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>1</td><td>ł</td><td></td></td<> | | | | | | | | | | | | 1 | ł | |
| AVG H 4880.000 10.66 34.16 8.75 31.60 0.00 21.96 54.00 -32.04 1/3MHz Noise Floor PK H 7320.000 36.90 35.61 11.10 31.05 0.00 52.56 74.00 -21.44 1/3MHz Noise Floor AVG H 7320.000 11.72 35.61 11.10 31.05 0.00 27.38 54.00 -26.62 1/3MHz Noise Floor PK H 9760.000 24.70 36.85 13.11 28.26 0.00 46.40 58.85 -12.45 100/300kHz Noise Floor PK H 12200.000 10.72 38.96 14.80 25.01 0.00 39.47 54.00 -14.53 1/3MHz Noise Floor AVG H 14640.000 24.30 39.64 15.25 26.35 0.00 52.83 58.85 -6.02 100/300kHz Noise Floor PK H 14640.000 23.00 < | РК | н | 4880.000 | | · · · · · | r - | 1 | 1 | 1 | 74.00 | -26.86 | 1/3MHz | ł | |
| PK H 7320.000 36.90 35.61 11.10 31.05 0.00 52.56 74.00 -21.44 1/3MHz Noise Floor AVG H 7320.000 11.72 35.61 11.10 31.05 0.00 27.38 54.00 -26.62 1/3MHz Noise Floor PK H 9760.000 24.70 36.85 13.11 28.26 0.00 46.40 58.85 -12.45 100/300kHz Noise Floor PK H 12200.000 35.90 38.96 14.80 25.01 0.00 64.65 74.00 -9.35 1/3MHz Noise Floor AVG H 12200.000 10.72 38.96 14.80 25.01 0.00 39.47 54.00 -14.53 1/3MHz Noise Floor PK H 14640.000 24.30 39.64 15.25 26.35 0.00 57.09 58.85 -1.76 100/300kHz Noise Floor PK H 1708.000 36.96 <t< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>ł</td><td></td></t<> | | | | | | | | | | | | | ł | |
| AVG H 7320.000 11.72 35.61 11.10 31.05 0.00 27.38 54.00 -26.62 1/3MHz Noise Floor PK H 9760.000 24.70 36.85 13.11 28.26 0.00 46.40 58.85 -12.45 100/300kHz Noise Floor PK H 12200.000 35.90 38.96 14.80 25.01 0.00 64.65 74.00 -9.35 1/3MHz Noise Floor AVG H 12200.000 10.72 38.96 14.80 25.01 0.00 39.47 54.00 -14.53 1/3MHz Noise Floor PK H 14640.000 24.30 39.64 15.25 26.35 0.00 57.09 58.85 -1.76 100/300kHz Noise Floor PK H 17080.000 36.96 34.24 8.86 31.58 0.00 23.29 54.00 -30.71 1/3MHz Noise Floor AVG H 4960.000 11.78 < | | | | | | | | 1 | | | | | ł | |
| PK H 9760.000 24.70 36.85 13.11 28.26 0.00 46.40 58.85 -12.45 100/300kHz Noise Floor PK H 12200.000 35.90 38.96 14.80 25.01 0.00 64.65 74.00 -9.35 1/3MHz Noise Floor AVG H 12200.000 10.72 38.96 14.80 25.01 0.00 39.47 54.00 -14.53 1/3MHz Noise Floor PK H 14640.000 24.30 39.64 15.25 26.35 0.00 52.83 58.85 -6.02 100/300kHz Noise Floor PK H 17080.000 23.00 41.73 19.00 26.64 0.00 57.09 58.85 -1.76 100/300kHz Noise Floor VCH26 - 2480MHz, Spurious Emissions from 1-18GHz, REA004 1/3MHz Noise Floor Noise Floor AVG H 4960.000 11.78 34.24 8.86 31.58 0.00 23.29 | | | | | | | | | | | | | ł | |
| PK H 12200.000 35.90 38.96 14.80 25.01 0.00 64.65 74.00 -9.35 1/3MHz Noise Floor AVG H 12200.000 10.72 38.96 14.80 25.01 0.00 39.47 54.00 -14.53 1/3MHz Noise Floor PK H 14640.000 24.30 39.64 15.25 26.35 0.00 52.83 58.85 -6.02 100/300kHz Noise Floor PK H 17080.000 23.00 41.73 19.00 26.64 0.00 57.09 58.85 -1.76 100/300kHz Noise Floor CH26 - 2480MHz, Spurious Emissions from 1-18GHz, REA004 PK H 4960.000 36.96 34.24 8.86 31.58 0.00 48.47 74.00 -25.53 1/3MHz Noise Floor AVG H 4960.000 11.78 34.24 8.86 31.58 0.00 23.29 54.00 -30.71 1/3MHz Noise Floor < | | | | | | | | | | | | | + | |
| AVG H 12200.000 10.72 38.96 14.80 25.01 0.00 39.47 54.00 -14.53 1/3MHz Noise Floor PK H 14640.000 24.30 39.64 15.25 26.35 0.00 52.83 58.85 -6.02 100/300kHz Noise Floor PK H 17080.000 23.00 41.73 19.00 26.64 0.00 57.09 58.85 -1.76 100/300kHz Noise Floor CH26 - 2480MHz, Spurious Emissions from 1-18GHz, REA004 PK H 4960.000 36.96 34.24 8.86 31.58 0.00 48.47 74.00 -25.53 1/3MHz Noise Floor AVG H 4960.000 11.78 34.24 8.86 31.58 0.00 23.29 54.00 -30.71 1/3MHz Noise Floor AVG H 7440.000 37.74 35.63 11.19 31.03 0.00 28.35 54.00 -25.65 1/3MHz Noise Floor | | | | | | | | | | | | | t | |
| PK H 14640.000 24.30 39.64 15.25 26.35 0.00 52.83 58.85 -6.02 100/300kHz Noise Floor PK H 17080.000 23.00 41.73 19.00 26.64 0.00 57.09 58.85 -1.76 100/300kHz Noise Floor CH26 - 2480MHz, Spurious Emissions from 1-18GHz, REA004 PK H 4960.000 36.96 34.24 8.86 31.58 0.00 48.47 74.00 -25.53 1/3MHz Noise Floor AVG H 4960.000 11.78 34.24 8.86 31.58 0.00 23.29 54.00 -30.71 1/3MHz Noise Floor AVG H 7440.000 37.74 35.63 11.19 31.03 0.00 28.35 54.00 -25.65 1/3MHz Noise Floor AVG H 7440.000 12.56 35.63 11.19 31.03 0.00 28.35 54.00 -25.65 1/3MHz Noise Floor < | | н | | | | | | 0.00 | | | | | + | |
| PK H 17080.000 23.00 41.73 19.00 26.64 0.00 57.09 58.85 -1.76 100/300kHz Noise Floor CH26 - 2480MHz, Spurious Emissions from 1-18GHz, REA004 PK H 4960.000 36.96 34.24 8.86 31.58 0.00 48.47 74.00 -25.53 1/3MHz Noise Floor AVG H 4960.000 11.78 34.24 8.86 31.58 0.00 23.29 54.00 -30.71 1/3MHz Noise Floor PK H 7440.000 37.74 35.63 11.19 31.03 0.00 28.35 54.00 -25.65 1/3MHz Noise Floor AVG H 7440.000 12.56 35.63 11.19 31.03 0.00 28.35 54.00 -25.65 1/3MHz Noise Floor AVG H 7440.000 12.56 35.63 11.19 28.02 0.00 48.94 58.85 -9.91 100/300kHz Noise Floor <t< td=""><td></td><td></td><td>14640.000</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>+</td><td></td></t<> | | | 14640.000 | | | | | | | | | | + | |
| CH26 - 2480MHz, Spurious Emissions from 1-18GHz, REA004 PK H 4960.000 36.96 34.24 8.86 31.58 0.00 48.47 74.00 -25.53 1/3MHz Noise Floor AVG H 4960.000 11.78 34.24 8.86 31.58 0.00 23.29 54.00 -30.71 1/3MHz Noise Floor PK H 7440.000 37.74 35.63 11.19 31.03 0.00 53.53 74.00 -20.47 1/3MHz Noise Floor AVG H 7440.000 12.56 35.63 11.19 31.03 0.00 28.35 54.00 -25.65 1/3MHz Noise Floor AVG H 7440.000 12.56 35.63 11.19 31.03 0.00 28.35 54.00 -25.65 1/3MHz Noise Floor PK H 9920.000 26.46 37.01 13.49 28.02 0.00 48.94 58.85 -9.91 100/300kHz Noise Floor | | Н | 17080.000 | | 41.73 | | | 0.00 | | | | - | ł | |
| PK H 4960.000 36.96 34.24 8.86 31.58 0.00 48.47 74.00 -25.53 1/3MHz Noise Floor AVG H 4960.000 11.78 34.24 8.86 31.58 0.00 23.29 54.00 -30.71 1/3MHz Noise Floor PK H 7440.000 37.74 35.63 11.19 31.03 0.00 53.53 74.00 -20.47 1/3MHz Noise Floor AVG H 7440.000 12.56 35.63 11.19 31.03 0.00 28.35 54.00 -25.65 1/3MHz Noise Floor AVG H 7440.000 12.56 35.63 11.19 31.03 0.00 28.35 54.00 -25.65 1/3MHz Noise Floor PK H 9920.000 26.46 37.01 13.49 28.02 0.00 48.94 58.85 -9.91 100/300kHz Noise Floor PK H 12400.000 36.30 38.9 | | | | | | | | | | | | | | |
| AVG H 4960.000 11.78 34.24 8.86 31.58 0.00 23.29 54.00 -30.71 1/3MHz Noise Floor PK H 7440.000 37.74 35.63 11.19 31.03 0.00 53.53 74.00 -20.47 1/3MHz Noise Floor AVG H 7440.000 12.56 35.63 11.19 31.03 0.00 28.35 54.00 -20.47 1/3MHz Noise Floor PK H 9920.000 26.46 37.01 13.49 28.02 0.00 48.94 58.85 -9.91 100/300kHz Noise Floor PK H 12400.000 36.30 38.99 14.65 25.12 0.00 64.82 74.00 -9.18 1/3MHz Noise Floor AVG H 12400.000 11.12 38.99 14.65 25.12 0.00 39.64 54.00 -14.36 1/3MHz Noise Floor AVG H 12400.000 11.12 3 | РК | Н | 4960.000 | | T | 1 | | 1 | 1 | 74.00 | -25.53 | 1/3MHz | Noise Floor | |
| PK H 7440.000 37.74 35.63 11.19 31.03 0.00 53.53 74.00 -20.47 1/3MHz Noise Floor AVG H 7440.000 12.56 35.63 11.19 31.03 0.00 28.35 54.00 -20.47 1/3MHz Noise Floor PK H 9920.000 26.46 37.01 13.49 28.02 0.00 48.94 58.85 -9.91 100/300kHz Noise Floor PK H 12400.000 36.30 38.99 14.65 25.12 0.00 64.82 74.00 -9.18 1/3MHz Noise Floor AVG H 12400.000 11.12 38.99 14.65 25.12 0.00 39.64 54.00 -14.36 1/3MHz Noise Floor AVG H 12400.000 11.12 38.99 14.65 25.12 0.00 39.64 54.00 -14.36 1/3MHz Noise Floor PK H 14880.000 23.00 | | | | | | | | 1 | | | | | t | |
| AVG H 7440.000 12.56 35.63 11.19 31.03 0.00 28.35 54.00 -25.65 1/3MHz Noise Floor PK H 9920.000 26.46 37.01 13.49 28.02 0.00 48.94 58.85 -9.91 100/300kHz Noise Floor PK H 12400.000 36.30 38.99 14.65 25.12 0.00 64.82 74.00 -9.18 1/3MHz Noise Floor AVG H 12400.000 11.12 38.99 14.65 25.12 0.00 39.64 54.00 -14.36 1/3MHz Noise Floor AVG H 12400.000 11.12 38.99 14.65 25.12 0.00 39.64 54.00 -14.36 1/3MHz Noise Floor PK H 14880.000 23.00 39.76 15.67 26.48 0.00 51.94 58.85 -6.91 100/300kHz Noise Floor | | | | | | | | | | | | | + | |
| PK H 9920.000 26.46 37.01 13.49 28.02 0.00 48.94 58.85 -9.91 100/300kHz Noise Floor PK H 12400.000 36.30 38.99 14.65 25.12 0.00 64.82 74.00 -9.18 1/3MHz Noise Floor AVG H 12400.000 11.12 38.99 14.65 25.12 0.00 39.64 54.00 -14.36 1/3MHz Noise Floor PK H 14880.000 23.00 39.76 15.67 26.48 0.00 51.94 58.85 -6.91 100/300kHz Noise Floor | _ | | | | 1 | 1 | | | | | | | + | |
| PK H 12400.000 36.30 38.99 14.65 25.12 0.00 64.82 74.00 -9.18 1/3MHz Noise Floor AVG H 12400.000 11.12 38.99 14.65 25.12 0.00 39.64 54.00 -14.36 1/3MHz Noise Floor PK H 14880.000 23.00 39.76 15.67 26.48 0.00 51.94 58.85 -6.91 100/300kHz Noise Floor | | | | | | | | | | | | | ł | |
| AVG H 12400.000 11.12 38.99 14.65 25.12 0.00 39.64 54.00 -14.36 1/3MHz Noise Floor PK H 14880.000 23.00 39.76 15.67 26.48 0.00 51.94 58.85 -6.91 100/300kHz Noise Floor | | | | | | | | | | | | | 1 | |
| PK H 14880.000 23.00 39.76 15.67 26.48 0.00 51.94 58.85 -6.91 100/300kHz Noise Floor | | | | | | | | | | | | | + | |
| | | | | | | | | 1 | | | | | ł | |
| | | | | | | | | | | | | | + | |

Average factor = 20*LOG((0.5511*10)/100) = 25.18 dB

Hand scans were performed from 18-25GHz at a distance of <1m, no emissions were detected above the measuring equipment noise floor.

| | | Intertek | |
|--|---|-----------------------|------------------------|
| Report Number: 102 | 2172761BOX-001b | | Issued: 09/04/2015 |
| | | | |
| Test Personnel: | Vathana Ven | Test Date: | 09/21/2012, 08/27/2015 |
| Supervising/Reviewing Engineer: (Where Applicable) | | | |
| Product Standard: | FCC Part 15 Subpart C 15.247; IC RSS-247 | Test Levels: | See tables |
| Input Voltage: Pretest Verification w/ | 120VAC/60Hz | | 24. 22.90 |
| Ambient Signals or | | Ambient Temperature: | 24, 22 °C |
| BB Source: | Ambient | Relative Humidity: | 49, 41 % |
| | | Atmospheric Pressure: | 1009, 1006 mbars |

Deviations, Additions, or Exclusions: None

11 Digital Device and Receiver Radiated Spurious Emissions

11.1 Method

Tests are performed in accordance with CFR47 FCC Part 15 Subpart B 15.109, IC RSS-Gen Section 7.1, IC ICES-003.

TEST SITE: 10m ALSE

The 10m ALSE is 13m (Length) x 21m (Depth) x 10m (Height) with the effective size in terms of space from the tips of the absorber is 12m (Length) x 20m (Depth) x 8.5m (Height). This chamber achieves broadband performance using a unique arrangement of hybrid and ferrite tile absorber. This chamber has a built in 3m diameter turntable (Embedded type). The metal structure of the table makes electrical connection around the entire circumference of the turntable to the ground plane with a metal brush type connection. The turntable is located on one end of the chamber and the antennas are mounted 3 and 10 meters away at the other end of the chamber on the adjustable an Antenna Mast. The antenna mast is a non-conductive bore sighted type with remote control of antenna height and polarization. The Antenna Mast and the turntable can be remotely controlled through the controller located in the adjacent Control room. A wooden table 80 cm high is used for table-top equipment.

Measurement Uncertainty

For radiated emissions, U_{lab} (3.5 dB at 3m and 3.5 dB at 10m below 1 GHz, and 4.2 dB at 3m above 1 GHz)

< U_{CISPR} (5.2 dB), which is the reference value in CISPR 16-4-2 Table 1, hence the compliance of the product is only based on the measured value, and no measurement uncertainty correction is required, based on CISPR 22 and CISPR 11 (for 2006 and later revisions) Clause 11.

Sample Calculation

The field strength is calculated by adding the Antenna Factor and Cable Factor, and subtracting the Amplifier Gain (if any) from the measured reading. The basic equation with a sample calculation is as follows:

| FS = RA + AF + | CF - AG |
|----------------|---|
| Where | FS = Field Strength in $dB\mu V/m$ |
| | RA = Receiver Amplitude (including preamplifier) in $dB\mu V$ |
| | CF = Cable Attenuation Factor in dB |
| | AF = Antenna Factor in dB |
| | AG = Amplifier Gain in dB |

In the following table(s), the reading shown on the data table reflects the preamplifier gain. An example for the calculations in the following table is as follows.

Assume a receiver reading of 52.0 dB μ V is obtained. The antenna factor of 7.4 dB and cable factor of 1.6 dB is added. The amplifier gain of 29 dB is subtracted, giving a field strength of 32 dB μ V/m. This value in dB μ V/m was converted to its corresponding level in μ V/m.

RA = 52.0 dB μ V AF = 7.4 dB/m CF = 1.6 dB AG = 29.0 dB FS = 32 dB μ V/m

To convert from $dB\mu V$ to μV or mV the following was used:

UF = $10^{(NF/20)}$ where UF = Net Reading in μ V NF = Net Reading in dB μ V

Example:

FS = RA + AF + CF - AG = 52.0 + 7.4 + 1.6 - 29.0 = 32.0 UF = $10^{(32 \text{ dB}\mu\text{V}/20)}$ = 39.8 $\mu\text{V/m}$

11.2 Test Equipment Used:

| Asset | Description | Manufacturer | Model | Serial | Cal Date | Cal Due |
|----------|-----------------------------------|---------------------|-------------|------------|------------|------------|
| ~145034 | BiLog Antenna (30 MHz to 1GHz) | Schaffner Chase EMC | CBL6111C | 2564 | 02/07/2012 | 02/07/2013 |
| ~145003 | Preamplifier (150 KHz to 1.3 GHz) | Hewlett Packard | 8447D | 2443A04077 | 10/04/2011 | 10/04/2012 |
| ~145 128 | EMI Test Receiver (20Hz - 40GHz) | Rohde & Schwarz | ESI | 837771/027 | 08/23/2011 | 09/23/2012 |
| | Cables 145-400 145-406 145-407 | | 10m Track A | | | |
| ~145-410 | 145-405 145-403 | Huber + Suhner | Cables | multiple | 09/04/2011 | 10/04/2012 |
| | Cables 145-400 145-408 145-402 | | 3m Track B | | | |
| ~145-416 | 145-404 | Huber + Suhner | cables | multiple | 09/04/2011 | 10/04/2012 |
| ~HORN2 | HORN ANTENNA | EMCO | 3115 | 9602-4675 | 10/24/2011 | 10/24/2012 |
| ~145 014 | Preamplifier (1 GHz to 26.5 GHz) | Hewlett Packard | 8449B | 3008A00232 | 12/16/2011 | 12/16/2012 |
| DAV001 | Weather Station | Davis Instruments | 7400 | PE80519A61 | 08/28/2012 | 08/28/2014 |

Software Utilized:


| Name | Manufacturer | Version | | | |
|------|--------------|-----------------|--|--|--|
| C5 | Teseq | Build 5.26.00.3 | | | |

11.3 Results:

Emissions must be below the general limits of FCC 15.109 and IC RSS-Gen Issue 3 December 2010 Section 6.0 Table 2.

The sample tested was found to Comply.

11.4 Setup Photographs:



Intertek

30-1000MHz

Additional Information

11.5 Plots/Data:

Rx Spurious Emissions 30-1000MHz

| Test Information | |
|------------------|-------------------------------------|
| Test Details | User Entry |
| Test: | Radiated - FCC15 Class B @ 10m |
| Project: | Mircom (IgeaCare_G100357410_Beacon) |
| Test Notes: | 1006mB, Rx mode |
| Temperature: | 25 deg C |
| Humidity: | 38% |
| Tested by: | Vathana Ven |
| Test Started: | 18 Sep 2012 00 : 34 |
| | |

Prescan Emission Graph



- Measured Quasi Peak Value
- Measured Average Value
- Maximum Value of Mast and Turntable •
- Swept Peak Data
- Swept Quasi Peak Data
- Swept Average Data


Intertek

Report Number: 102172761BOX-001b

| Emissions Test Da Trace1: Measured Frequency (Hz) 261.47114205 M 422.574148691 M 978.164328188 M 548.846693371 M 33.419639727 M 30.16993988 M | | AF 14.100 16.851 24.873 21.161 17.232 18.981 | PA+CL -24.129 -23.914 -22.361 -23.971 -26.103 -26.114 | Limit (dBuV/m) 35.540 35.540 43.540 35.540 29.540 29.540 | Margin (dBuV/m) | Hor (), Ver () | Azimuth (deg) (Deg) 158 213 192 63 178 360 | Mast Height (m) 4.00 1.05 1.25 3.78 3.70 3.83 | RBW (Hz) 120 k 120 k 120 k 120 k 120 k 120 k |
|--|--|--|---|---|--|--|---|--|---|
| Trace2: Measured Frequency (Hz) 261.47114205 M 422.574148691 M 978.16428188 M 548.846693371 M 33.419639727 M 30.16993988 M | d Quasi Peak Level dBuV/m) 10.25 13.63 25.33 18.40 13.06 14.80 | AF 14.100 16.851 24.873 21.161 17.232 18.981 | PA+CL -24.129 -23.914 -22.361 -23.971 -26.103 -26.114 | Limit (dBuV/m) 35.540 35.540 43.540 35.540 29.540 29.540 | Margin (dBuV/m) -25.29 -21.91 -18.21 -17.14 -16.48 -14.74 | Hor (), Ver () | Azimuth (deg) (Deg) 158 213 192 63 178 360 | Mast Height (m) 4.00 1.05 1.25 3.78 3.70 3.83 | RBW (Hz) 120 k 120 k 120 k 120 k 120 k 120 k |
| Trace3: Measured Frequency (Hz) 261.47114205 M 33.419639727 M 422.574148691 M 30.16993988 M 548.846693371 M 978.164328188 M | d Average Level (dBuV/m) 4.23 6.45 6.92 8.67 11.73 18.77 | AF 14.100 17.232 16.851 18.981 21.161 24.873 | PA+CL -24.129 -26.103 -23.914 -26.114 -23.971 -22.361 | Limit (dBuV/m) | Margin (dBuV/m) | Hor (), Ver () | Azimuth (deg) (Deg) 158 178 213 360 63 192 | Mast Height (m) 4.00 3.70 1.05 3.83 3.78 1.25 | RBW (Hz) 120 k 120 k 120 k 120 k 120 k 120 k |

Issued: 09/04/2015

Azimuth Plots




All Polarities

Azimuth (Degrees)

Intertek


Turntable Plot (33.419639727 MHz)

Level (dBuV/m)



4 Height Plot (30.1693988 MHz) 3.5 2.5 2 1.5 1.4 Polarties Level (BL/Vm)

Turntable Plots




All Polarities

Issued: 09/04/2015

Height Plot (261.47114205 MHz)

4


3.5




All Polarities


Azimuth (Degrees)


Intertek



Level (dBuV/m)








All Polarities

Intertek





All Polarities

Azimuth (Degrees)




Level (dBuV/m)





Height Plot (548.846693371 MHz)

4



All Polarities

Issued: 09/04/2015


Rx Spurious Emissions 1-13GHz

Intertek

| Test Information | |
|------------------|-------------------------------------|
| Test Details | User Entry |
| Test: | Radiated - FCC15 Class B @ 3m |
| Project: | Mircom (IgeaCare_G100357410_Beacon) |
| Test Notes: | 1000mB, Rx mode |
| Temperature: | 24 deg C |
| Humidity: | 24% |
| Tested by: | Vathana Ven |
| Test Started: | 22 Sep 2012 17 : 51 |

Additional Information

Prescan Emission Graph



Measured Peak Value

Measured Quasi Peak Value

Measured Average Value

Maximum Value of Mast and Turntable

- Swept Peak Data
- __ Swept Quasi Peak Data
- ___ Swept Average Data


Intertek

Report Number: 102172761BOX-001b

| Emissions Test [| Data | | | | | | | | |
|------------------------------------|----------------------------|------------------|--------------------|-----------------------------|------------------------------|----------------------------|------------------------------|----------------------------|--------------------|
| Trace1: Measure | ed Peak | | | | | | | | |
| Frequency (Hz) 1.061583166 G | Level (dBuV/m) 37.76 | AF 24.825 | PA+CL -30.224 | Limit (dBuV/m) 74.000 | Margin (dBuV/m) -36.24 | Hor (), Ver () I | Azimuth (deg) (Deg) 60 | Mast Height (m) 1.56 | RBW (Hz) 1 M |
| 1.734462258 G | 41.83 | 26.867 | -28.596 | 74.000 | -32.17 | i i | 84 | 3.40 | 1 M |
| 5.219271877 G | 56.33 | 33.691 | -20.517 | 74.000 | -17.67 | i | 288 | 1.80 | 1 M |
| 5.25239145 G | 57.73 | 33.720 | -19.428 | 74.000 | -16.27 | | 137 | 1.93 | 1 M |
| 10.657768871 G | 59.69 | 38.339 | -19.973 | 74.000 | -14.31 | | 181 | 2.88 | 1 M |
| 6.748223113 G 11.915330661 G | 59.85 60.64 | 35.074 39.569 | -24.477 -20.365 | 74.000 74.000 | -14.15 -13.36 | | 88 0 | 1.34 1.69 | 1 M 1 M |
| 12.385490982 G | 60.76 | 38.955 | -20.303 | 74.000 | -13.24 | | 147 | 3.84 | 1 M |
| Trace3: Measure | ed Average | | | Limit | Marcin | | Arimuth (Jac) | Mastllsight | RBW |
| Frequency (Hz) | (dBuV/m) | AF | PA+CL | (dBuV/m) | Margin (dBuV/m) | Hor (), Ver () | Azimuth (deg) (Deg) | Mast Height (m) | (Hz) |
| 1.061583166 G | 24.45 ´ | 24.825 | -30.224 | 54.000 | -29.55 | | 60 | 1.56 | 1 M |
| 1.734462258 G | 28.41 | 26.867 | -28.596 | 54.000 | -25.59 | 1 | 84 | 3.40 | 1 M |
| 5.219271877 G 5.25239145 G | 42.73 43.53 | 33.691 33.720 | -20.517 -19.428 | 54.000 54.000 | -11.27 -10.47 | 1 | 288 137 | 1.80 1.93 | 1 M 1 M |
| 10.657768871 G | 46.06 | 38.339 | -19.973 | 54.000 | -7.94 | | 181 | 2.88 | 1 M |
| 6.748223113 G | 46.47 | 35.074 | -24.477 | 54.000 | -7.53 | I | 88 | 1.34 | 1 M |
| 12.385490982 G | 46.82 | 38.955 | -20.722 | 54.000 | -7.18 | 1 | 147 | 3.84 | 1 M |
| 11.915330661 G | 47.08 | 39.569 | -20.365 | 54.000 | -6.92 | I | 0 | 1.69 | 1 M |

Issued: 09/04/2015

Azimuth Plots





All Polarities

Azimuth (Degrees)


Turntable Plot (1.734462258 GHz)

Level (dBuV/m)





Turntable Plots




All Polarities

Azimuth (Degrees)

Intertek


Issued: 09/04/2015




All Polarities


Azimuth (Degrees)


Intertek



Level (dBuV/m)








All Polarities

Issued: 09/04/2015

Height Plot (6.748223113 GHz)

4




All Polarities


Azimuth (Degrees)


Intertek



Level (dBuV/m)








All Polarities


Issued: 09/04/2015



All Polarities

Azimuth (Degrees)


Intertek




Azimuth (Degrees)

| Test Personnel: | Vathana Ven |
|------------------------------------|---------------------------|
| Supervising/Reviewing Engineer: | |
| (Where Applicable) | |
| | FCC Part 15 Subpart B; IC |
| | RSS-247, IC RSS-Gen, IC |
| Product Standard: | ICES-003 |
| Input Voltage: | 120VAC/60Hz |
| Pretest Verification w/ | |
| Ambient Signals or | |
| BB Source: | Ambient |

Deviations, Additions, or Exclusions: None





| Test Date: | 09/18/2012, 09/22/2012 | | |
|--|------------------------|--|--|
| Test Levels: | Class B | | |
| Ambient Temperature: Relative Humidity: | 25, 24 °C 38, 24 % | | |
| Atmospheric Pressure: | 1005, 1000 mbars | | |

12 AC Mains Conducted Emissions

12.1 Method

Tests are performed in accordance with CFR47 FCC Part 15:2012 Subpart B Section 15:207 IC RSS-Gen Issue 4 November, 7:2.2.

TEST SITE: AMAP (Bump Out)

The EMC Lab has two Semi-anechoic Chambers and one Shielded Chamber. AC Mains Power is available at 120, 230, and 277 Single Phase; 208, 400, and 480 3-Phase. Large reference ground-planes are installed in the general lab area to facilitate EMC work not requiring a shielded environment.

The AMAP Building and Lab includes general lab space that can be used for testing where a shielded/enclosed environment is not required.

Measurement Uncertainty

For conducted emissions, U_{lab} (3.1 dB in worst case) < U_{CISPR} (3.6 dB), which is the reference value in CISPR 16-4-2 Table 1, hence the compliance of the product is only based on the measured value, and no measurement uncertainty correction is required, based on CISPR 22 and CISPR 11 (for 2006 and later revisions) Clause 11.

Sample Calculations

The following is how net line-conducted readings were determined:

NF = RF + LF + CF + AF

Where NF = Net Reading in $dB\mu V$ RF = Reading from receiver in $dB\mu V$ LF = LISN or ISN Correction Factor in dB CF = Cable Correction Factor in dB AF = Attenuator Loss Factor in dB

To convert from $dB\mu V$ to μV or mV the following was used:

UF = $10^{(NF/20)}$ where UF = Net Reading in μ V NF = Net Reading in dB μ V

Example:

NF = RF + LF + CF + AF = 28.5 + 0.2 + 0.4 + 20.0 = 49.1 dB μ V UF = 10^(49.1 dB μ V / 20) = 285.1 μ V/m

12.2 Test Equipment Used:

| Asset | Description | Manufacturer | Model | Serial | Cal Date | Cal Due |
|--------|--------------------------------|-------------------|-------------------|------------|------------|------------|
| Ros002 | 9kHz to 3GHz EMI Test Receiver | Rohde & Schwartz | ESCI 1166.5950K03 | 100067 | 06/13/2012 | 06/13/2013 |
| Ds26a | Attenuator, 20dB | Mini Circuits | 20dB, 50 ohm | DS26A | 10/04/2011 | 10/04/2012 |
| Ds23a | Attenuator, 20dB | Mini Circuits | 20dB, 50 ohm | DS23A | 09/15/2010 | 09/15/2011 |
| 145015 | LISN: 50 Ohm/50 microHenry | Solar Electronics | 9252-50-R-24-BNC | 971617 | 02/06/2012 | 02/06/2013 |
| Dav001 | Weather Station | Davis Instruments | 7400 | PE80519A61 | 08/28/2012 | 08/28/2014 |

Software Utilized:

| Name | Manufacturer | Version |
|------|--------------|------------|
| C5 | Teseq | 5.26.46.46 |

12.3 Results:

The sample tested was found to Comply.

12.4 Setup Photographs:




12.5 Plots/Data:

| Test Information |
|------------------|
| Test Details |
| Test: |
| Project: |
| Test Notes: |
| Temperature: |
| Humidity: |
| Tested by: |
| Test Started: |

User Entry LISN - FCC15 Class B Mircom (IgeaCare_G100357410_Beacon) 1000mB, 120VAC/60Hz, Tx mode 24 deg C 24% Vathana Ven 22 Sep 2012 19:08

Prescan Emission Graph



- Measured Peak Value
- Measured Quasi Peak Value
- Measured Average Value
- Maximum Value of Mast and Turntable

Emissions Test Data Trace²: Measured Quasi Peak

| Tracez: Measure | ed Quasi Peak | | | | | | | |
|-----------------|---------------|-------|--------|-------------|--------------|---------|---------|------|
| Frequency(Hz) | Level(dBuV) | TF | PA+CL | Limit(dBuV) | Margin(dBuV) | RBW(Hz) | Comment | LINE |
| 201.0 k | 23.08 | 0.120 | 20.868 | 63.569 | -40.49 | 9 k | | L1 |
| 174.0 k | 24.80 | 0.123 | 20.863 | 64.767 | -39.97 | 9 k | | L1 |
| 237.0 k | 23.02 | 0.113 | 20.874 | 62.201 | -39.18 | 9 k | | L1 |
| 558.0 k | 21.02 | 0.104 | 20.915 | 56.000 | -34.98 | 9 k | | L1 |
| 7.926 M | 25.17 | 0.169 | 21.530 | 60.000 | -34.83 | 9 k | | N |
| 549.0 k | 21.93 | 0.104 | 20.914 | 56.000 | -34.07 | 9 k | | N |
| 9.666 M | 28.97 | 0.187 | 21.614 | 60.000 | -31.03 | 9 k | | L1 |
| 27.28395 M | 29.28 | 0.651 | 22.349 | 60.000 | -30.72 | 9 k | | L1 |
| | | | | | | | | |

_

Swept Peak Data Swept Quasi Peak Data

____ Swept Average Data

| Trace3: Measure | ed Average | | | | | | | |
|-----------------|-------------|-------|--------|-------------|--------------|---------|---------|------|
| Frequency(Hz) | Level(dBuV) | TF | PA+CL | Limit(dBuV) | Margin(dBuV) | RBW(Hz) | Comment | LINE |
| 201.0 k | 19.64 | 0.120 | 20.868 | 53.569 | -33.93 | 9 k | | L1 |
| 174.0 k | 21.42 | 0.123 | 20.863 | 54.767 | -33.35 | 9 k | | L1 |
| 237.0 k | 19.57 | 0.113 | 20.874 | 52.201 | -32.64 | 9 k | | L1 |
| 27.28395 M | 18.71 | 0.651 | 22.349 | 50.000 | -31.29 | 9 k | | L1 |
| 7.926 M | 20.59 | 0.169 | 21.530 | 50.000 | -29.41 | 9 k | | N |
| 558.0 k | 17.27 | 0.104 | 20.915 | 46.000 | -28.73 | 9 k | | L1 |
| 549.0 k | 17.36 | 0.104 | 20.914 | 46.000 | -28.64 | 9 k | | N |
| 9.666 M | 26.40 | 0.187 | 21.614 | 50.000 | -23.60 | 9 k | | L1 |

Additional Information


Issued: 09/04/2015

Test Information Test Details Test: Project: Test Notes: Temperature: Humidity: Tested by: Test Started:

User Entry LISN - FCC15 Class B IgeaCare_G100357410_Beacon 1000mB, 120VAC/60Hz, Rx mode 24 deg C 24% Vathana Ven 22 Sep 2012 19 : 33

Additional Information

Prescan Emission Graph



Intertek

- Measured Peak Value
- Measured Quasi Peak Value
- Measured Average Value
- Maximum Value of Mast and Turntable

Emissions Test Data

| LIIISSIONS LESU | Data | | | | | | | |
|-----------------|---------------|-------|--------|-------------|--------------|---------|---------|------|
| Trace2: Measur | ed Quasi Peak | | | | | | | |
| Frequency(Hz) | Level(dBuV) | TF | PA+CL | Limit(dBuV) | Margin(dBuV) | RBW(Hz) | Comment | LINE |
| 201.0 k | 23.64 | 0.120 | 20.868 | 63.569 | -39.93 | 9 k | | L1 |
| 231.0 k | 23.53 | 0.114 | 20.873 | 62.414 | -38.89 | 9 k | | L1 |
| 174.0 k | 27.48 | 0.123 | 20.863 | 64.767 | -37.29 | 9 k | | L1 |
| 15.606 M | 24.04 | 0.420 | 21.890 | 60.000 | -35.96 | 9 k | | N |
| 456.0 k | 21.44 | 0.102 | 20.902 | 56.765 | -35.32 | 9 k | | L1 |
| 9.654 M | 32.79 | 0.187 | 21.613 | 60.000 | -27.21 | 9 k | | N |
| 8.718 M | 36.62 | 0.177 | 21.568 | 60.000 | -23.38 | 9 k | | N |
| 537.0 k | 33.23 | 0.103 | 20.913 | 56.000 | -22.77 | 9 k | | N |
| | | | | | | | | |

Swept Peak Data

____ Swept Average Data

Swept Quasi Peak Data

| Trace3: Measure | ed Average | | | | | | | |
|-----------------|-------------|-------|--------|-------------|--------------|---------|---------|------|
| Frequency(Hz) | Level(dBuV) | TF | PA+CL | Limit(dBuV) | Margin(dBuV) | RBW(Hz) | Comment | LINE |
| 201.0 k | 20.21 | 0.120 | 20.868 | 53.569 | -33.36 | 9 k | | L1 |
| 174.0 k | 21.83 | 0.123 | 20.863 | 54.767 | -32.94 | 9 k | | L1 |
| 231.0 k | 20.10 | 0.114 | 20.873 | 52.414 | -32.31 | 9 k | | L1 |
| 15.606 M | 20.28 | 0.420 | 21.890 | 50.000 | -29.72 | 9 k | | N |
| 456.0 k | 17.52 | 0.102 | 20.902 | 46.765 | -29.24 | 9 k | | L1 |
| 537.0 k | 18.45 | 0.103 | 20.913 | 46.000 | -27.55 | 9 k | | N |
| 9.654 M | 30.72 | 0.187 | 21.613 | 50.000 | -19.28 | 9 k | | N |
| 8.718 M | 32.79 | 0.177 | 21.568 | 50.000 | -17.21 | 9 k | | N |

| | | Intertek | |
|--|--|-----------------------|--------------------|
| Report Number: 102 | 2172761BOX-001b | | Issued: 09/04/2015 |
| | | | |
| Test Personnel: | Vathana Ven | Test Date: | 09/22/2012 |
| Supervising/Reviewing Engineer: (Where Applicable) | | | |
| · · · · · · | FCC Part 15 Subpart B; IC RSS-210, IC RSS-Gen, IC | - Test Levels: | Class B |
| Product Standard: | ICES-003 120VAC/60Hz | _ | |
| Input Voltage: Pretest Verification w/ | | Ambient Temperature: | 24 °C |
| Ambient Signals or BB Source: | Ambient | Relative Humidity: | 24 % |
| | | Atmospheric Pressure: | 1000 mbars |

Deviations, Additions, or Exclusions: None

12 Revision History

| Revision Level | Date | Report Number | Prepared By | Reviewed By | Notes |
|-------------------|------------|-------------------|----------------|----------------|---|
| 0 | 09/27/2012 | 100876115BOX-001 | VHV | NNA | Original issue |
| 1 | 03/25/2015 | 100876115BOX-001a | VFV | | Company name and model number changed |
| 2 | 09/04/2015 | 102172761BOX-001b | VFV | | Added data above 1 GHz |
| | | | | | |
| | | | | | |