





# HAC RF TEST REPORT

## No. I20Z62284-SEM01

For

TCL Communication Ltd.

HSUPA/HSDPA/UMTS 7 Bands/GSM Quad Bands/LTE 13 bands mobile phone

Model Name: T782P

With

Hardware Version: 03

Software Version: 5EID

#### FCC ID: 2ACCJN051

### **Results Summary: M Category = M4**

#### Issued Date: 2021-1-21

#### Note:

The test results in this test report relate only to the devices specified in this report. This report shall not be reproduced except in full without the written approval of CTTL.

The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the U.S.Government.

Test Laboratory:

#### CTTL, Telecommunication Technology Labs, CAICT

No. 51, Xueyuan Road, Haidian District, Beijing, P. R. China 100191. Tel:+86(0)10-62304633-2512, Fax:+86(0)10-62304633-2504

Email: <u>cttl\_terminals@caict.ac.cn</u>, website: <u>www.caict.ac.cn</u>





## **REPORT HISTORY**

Report Number	r Revision Issue Date Desc		Description
I20Z62284-SEM01	Rev.0	2021-1-21	Initial creation of test report





## TABLE OF CONTENT

1 TEST LABORATORY	. 5
1.1 Testing Location	5
1.2 Testing Environment	
01.3 PROJECT DATA	
1.4 Signature	5
2 CLIENT INFORMATION	. 6
2.1 Applicant Information	6
2.2 MANUFACTURER INFORMATION	6
3 EQUIPMENT UNDER TEST (EUT) AND ANCILLARY EQUIPMENT (AE)	. 7
3.1 About EUT	
3.2 INTERNAL IDENTIFICATION OF EUT USED DURING THE TEST	
3.3 INTERNAL IDENTIFICATION OF AE USED DURING THE TEST	
3.4 AIR INTERFACES / BANDS INDICATING OPERATING MODES	8
4 MAXIMUM OUTPUT POWER	. 9
	40
5 REFERENCE DOCUMENTS	10
5.1 Reference Documents for testing	10
6 OPERATIONAL CONDITIONS DURING TEST	11
6.1 HAC MEASUREMENT SET-UP	11
6.2 PROBE SPECIFICATION	
6.3Test Arch Phantom & Phone Positioner	
6.4ROBOTIC SYSTEM SPECIFICATIONS	13
7 EUT ARRANGEMENT	14
7.1 WD RF EMISSION MEASUREMENTS REFERENCE AND PLANE	14
8 SYSTEM VALIDATION	15
8.1 VALIDATION PROCEDURE	15
8.2 VALIDATION RESULT	15
9 EVALUATION OF MIF	16
9.1 Introduction	16
9.2 MIF MEASUREMENT WITH THE AIA	17
9.3 TEST EQUIPMENT FOR THE MIF MEASUREMENT	17
9.4 Test signal validation	
9.5 DUT MIF RESULTS	18
10 EVALUATION FOR LOW-POWER EXEMPTION	19
10.1 Product testing threshold	19
10.2 CONDUCTED POWER	
10.3 CONCLUSION	20



## CAICT No.I20Z62284-SEM01

1 RF TEST PROCEDUERES
2 MEASUREMENT RESULTS (E-FIELD)
3 ANSIC 63.19-2011 LIMITS
4 MEASUREMENT UNCERTAINTY
5 MAIN TEST INSTRUMENTS
6 CONCLUSION
NNEX A TEST LAYOUT
NNEX B TEST PLOTS
NNEX C SYSTEM VALIDATION RESULT
NNEX D PROBE CALIBRATION CERTIFICATE
NNEX E DIPOLE CALIBRATION CERTIFICATE 44





## **1 Test Laboratory**

#### **1.1 Testing Location**

CompanyName:	CTTL(Shouxiang)	
Address:	No. 51 Shouxiang Science Building, Xueyuan Road, Haidian District,	
	Beijing, P. R. China100191	

#### **1.2 Testing Environment**

Temperature:	18°C~25°C,			
Relative humidity: 30%~ 70%				
Ground system resistance: $< 0.5 \Omega$				
Ambient noise is checked and found very low and in compliance with requirement of standards.				
Reflection of surrounding objects is minimized and in compliance with requirement of standards.				

#### 01.3 Project Data

Project Leader:	Qi Dianyuan
Test Engineer:	Lin Hao
Testing Start Date:	January 13, 2021
Testing End Date:	January 15, 2021

#### 1.4 Signature

Lin Xiaojun (Prepared this test report)

Qi Dianyuan (Reviewed this test report)

うう ress

Lu Bingsong Deputy Director of the laboratory (Approved this test report)





## **2** Client Information

### 2.1 Applicant Information

Company Name:	TCL Communication Ltd.
Address/Post:	5/F, Building 22E, 22 Science Park East Avenue, Hong Kong Science
	Park, Shatin, NT, Hong Kong
Contact Person:	Gong Zhizhou
Contact Email:	zhizhou.gong@tcl.com
Telephone:	0086-755-36611722
Fax	0086-755-36612000-81722

#### 2.2 Manufacturer Information

Company Name:	TCL Communication Ltd.		
Address/Post:	5/F, Building 22E, 22 Science Park East Avenue, Hong Kong Science		
	Park, Shatin, NT, Hong Kong		
Contact Person:	Gong Zhizhou		
Contact Email:	zhizhou.gong@tcl.com		
Telephone:	0086-755-36611722		
Fax	0086-755-36612000-81722		





## **3** Equipment Under Test (EUT) and Ancillary Equipment (AE)

#### 3.1 About EUT

Description:	HSUPA/HSDPA/UMTS 7 Bands/GSM Quad Bands/LTE 13 bands mobile
	phone
Model name:	T782P
Operating mode(s):	GSM850/900/1800/1900, WCDMAB1/B2/B4/B5/B6/B8, BT, Wi-Fi, LTE Band1/2/3/4/5/7/8/12/13/18/19/26/66

#### **3.2 Internal Identification of EUT used during the test**

EUT ID*	IMEI	HW Version	SW Version
EUT1	352430520005037	03	5EID

\*EUT ID: is used to identify the test sample in the lab internally.

Note: It is performed to test HAC with the EUT1

#### 3.3 Internal Identification of AE used during the test

AE ID*	Description	Model	SN	Manufacturer	
AE1	Battery	TLp043D1	/	BYD	

\*AE ID: is used to identify the test sample in the lab internally.





Air-interface	Band(MHz)	Туре	C63.19/tested	Simultaneous Transmissio ns	Name of Voice Service
GSM	850	VO	Vee		
GSIM	1900	VÜ	Yes		CMRS Voice
GPRS/EDGE	850	DT	Yes	BT, WLAN	
GFR3/EDGE	1900	וט	Tes		Google duo
	850				
WCDMA	1700	VO	Yes		CMRS Voice
(UMTS)	1900			BT, WLAN	
	HSPA	DT	Yes		Google duo
	Band2/7/12/13/26/		Yes	BT, WLAN	VoLTE, Google
LTE FDD	66	V/D			duo
вт	2450	DT	NA	GSM,WCDM	NA
ы	2450 DT	וט	NA	A,LTE	NA
WLAN	2450	V/D	Yes	GSM,WCDM	VoWiFi, Google
	2430 V/D	165	A,LTE	duo	
WLAN	5G	V/D	Yes	GSM,WCDM	VoWiFi, Google
	5G V/D		163	A,LTE	duo

#### 3.4 Air Interfaces / Bands Indicating Operating Modes

NA: Not Applicable VO: Voice Only V/D: CMRS and IP Voice Service over Digital Transport DT: Digital Transport

\* HAC Rating was not based on concurrent voice and data modes, Non current mode was found to represent worst case rating for both M and T rating

Note1 = No Associated T-Coil measurement has been made in accordance with 285076 D02 T-Coil testing for CMRS IP





## 4 Maximum Output Power

GSM		Conducted Power (dBm)			
850MHz	Channel 251(848.8MHz)	Channel 190(836.6MHz)	Channel 128(824.2MHz)		
Voice	33.5	33.5	33.5		
EDGE	29	29	29		
GSM		Conducted Power(dBm)			
1900MHz	Channel 810(1909.8MHz)	Channel 661(1880MHz)	Channel 512(1850.2MHz)		
Voice	30	30	30		
EDGE	24.5	24.5	24.5		
WCDMA		Conducted Power (dBm)			
850MHz	Channel 4233(846.6MHz)	Channel 4182(836.4MHz)	Channel 4132(826.4MHz)		
RMC	23.8	23.8	23.8		
HSPA	23.8	23.8	23.8		
		Conducted Power (dBm)			
WCDMA 1700MHz	Channel 1513 (1752.6MHz)	Channel 1412 (1732.4MHz)	Channel 1312 (1712.4MHz)		
RMC	23.8	23.8	23.8		
HSPA	23.8	23.8	23.8		
		Conducted Power (dBm)			
WCDMA 1900MHz	Channel 9538(1907.6MHz)	Channel 9400(1880MHz)	Channel 9262(1852.4MHz)		
RMC	23.8	23.8	23.8		
HSPA	23.8	23.8	23.8		
		Conducted Power (dBm)			
LTE Band2	Channel 19100(1900MHz)	Channel 18900(1880MHz)	Channel18700(1860MHz)		
QPSK	23.8	23.8	23.8		
16QAM	22.8	22.8	22.8		
64QAM	21.8	21.8	21.8		
		Conducted Power (dBm)			
LTE Band7	Channel 21350(2560MHz)	Channel 21100(2535MHz)	Channel20850(2510MHz)		
QPSK	24.5	24.5	24.5		
16QAM	23.5	23.5	23.5		
64QAM	22.5	22.5	22.5		
		Conducted Power (dBm)			
LTE Band12	Channel 23130(711MHz)	Channel 23095(707.5MHz)	Channel23060(704MHz)		
QPSK	23.5	23.5	23.5		
16QAM	22.5	22.5	22.5		
64QAM	21.5	21.5	21.5		
Conducted Power (dBm)					
LTE Band13	Channel 23230(782MHz)				
QPSK		23.5			

©Copyright. All rights reserved by CTTL.





LTE Band26	Channel 26965(841.5MHz)	Channel 26865(831.5MHz)	Channel 26775(822.5MHz)		
QPSK	23.8	23.8	23.8		
16QAM	22.8	22.8	22.8		
64QAM	21.8	21.8	21.8		
		Conducted Power (dBm)			
LTE Band66	Channel	Channel	Charges (422072)(4720MU-)		
	132572(1770MHz)	132322(1745MHz)	Channel 133072(1720MHz)		
QPSK	23.8	23.8	23.8		
16QAM	22.8	22.8	22.8		
64QAM	21.8	21.8	21.8		
	Conducted Power (dBm)				
2.4GHz	Channel 11 (2462MHz)	Channel 6 (2437MHz)	Channel 1 (2412MHz)		
802.11b	18.5	18.5	18.5		
0.4011	Conducted Power (dBm)				
2.4GHz 802.11g	Channel 11 (2462MHz)	Channel 6 (2437MHz)	Channel 1 (2412MHz)		
	18.5	18.5	18.5		
5011		Tune up (dBm)	1		
5GHz	Channel 149 (5745MHz)	Channel 157 (5785MHz)	Channel 165 (5825MHz)		
802.11a	17	17	17		

### **5** Reference Documents

#### **5.1 Reference Documents for testing**

The following document listed in this section is referred for testing.

Reference	Title	Version	
ANSI C63.19-2011	American National Standard for Methods of Measurement of	2011	
	Compatibility between Wireless Communication Devices and	Edition	
	Hearing Aids		
FCC 47 CFR §20.19	Hearing Aid Compatible Mobile Headsets		
		Edition	
KDB 285076 D01	Equipment Authorization Guidance for Hearing Aid Compatibility	v05r01	






## **6 OPERATIONAL CONDITIONS DURING TEST**

#### 6.1 HAC MEASUREMENT SET-UP

These measurements are performed using the DASY5 NEO automated dosimetric assessment system. It is made by Schmid & Partner Engineering AG (SPEAG) in Zurich, Switzerland. It consists of high precision robotics system (Stäubli), robot controller, Intel Core2 computer, near-field probe, probe alignment sensor. The robot is a six-axis industrial robot performing precise movements. A cell controller system contains the power supply, robot controller, teach pendant (Joystick), and remote control, is used to drive the robot motors. The PC consists of the HP Intel Core21.86 GHz computer with Windows XP system and HAC Measurement Software DASY5 NEO, A/D interface card, monitor, mouse, and keyboard. The Stäubli Robot is connected to the cell controller to allow software manipulation of the robot. A data acquisition electronic (DAE)circuit performs the signal amplification, signal multiplexing, AD-conversion, offset measurements, mechanical surface detection, collision detection, etc. is connected to the Electro-optical coupler (EOC). The EOC performs the conversion from the optical into digital electric signal of the DAE and transfers data to the PC plug-in card.





The DAE4 consists of a highly sensitive electrometer-grade preamplifier with auto-zeroing, a channel and gain-switching multiplexer, a fast 16 bit AD-converter and a command decoder and control logic unit. Transmission to the PC-card is accomplished through an optical downlink for data and status information and an optical uplink for commands and clock lines. The mechanical probe mounting device includes two different sensor systems for frontal and sidewise probe contacts. They are also used for mechanical surface detection and probe collision detection. The robot uses its own controller with a built in VME-bus computer.





### 6.2 Probe Specification

#### E-Field Probe Description

Construction	One dipole parallel, two dipoles normal to probe axis	
	Built-in shielding against static charges	
	PEEK enclosure material	E
Calibration	In air from 100 MHz to 3.0 GHz (absolute accuracy ±6.0%, k=2)	
-		[ER3DV6]
Frequency	40 MHz to > 6 GHz (can be extended to < 20 MHz)	
	Linearity: ± 0.2 dB (100 MHz to 3 GHz)	
Directivity	± 0.2 dB in air (rotation around probe axis)	
	± 0.4 dB in air (rotation normal to probe axis)	
Dynamic Range	2 V/m to > 1000 V/m; Linearity: ± 0.2 dB	
Dimensions	Overall length: 330 mm (Tip: 16 mm)	
	Tip diameter: 8 mm (Body: 12 mm)	
	Distance from probe tip to dipole centers: 2.5 mm	
Application	General near-field measurements up to 6 GHz	
	Field component measurements	
	Fast automatic scanning in phantoms	





#### 6.3Test Arch Phantom & Phone Positioner

The Test Arch phantom should be positioned horizontally on a stable surface. Reference markings on the Phantom allow the complete setup of all predefined phantom positions and measurement grids by manually teaching three points in the robot. It enables easy and well defined positioning of the phone and validation dipoles as well as simple teaching of the robot (Dimensions:  $370 \times 370 \times 370 \text{ mm}$ ).

The Phone Positioner supports accurate and reliable positioning of any phone with effect on near field < $\pm$ 0.5 dB.




Fig. 2 HAC Phantom & Device Holder

#### 6.4 Robotic System Specifications

#### **Specifications**

Positioner: Stäubli Unimation Corp. Robot Model: RX160L Repeatability: ±0.02 mm No. of Axis: 6 Data Acquisition Electronic (DAE) System Cell Controller Processor: Intel Core2 Clock Speed: 1.86GHz Operating System: Windows XP Data Converter Features:Signal Amplifier, multiplexer, A/D converter, and control logic Software: DASY5 software Connecting Lines: Optical downlink for data and status info. Optical uplink for commands and clock





## 7 EUT ARRANGEMENT

#### 7.1 WD RF Emission Measurements Reference and Plane

Figure 4 illustrates the references and reference plane that shall be used in the WD emissions measurement.

- The grid is 5 cm by 5 cm area that is divided into 9 evenly sized blocks or sub-grids.
- The grid is centered on the audio frequency output transducer of the WD (speaker or T-coil).

The grid is located by reference to a reference plane. This reference plane is the planar area that contains the highest point in the area of the WD that normally rests against the user's ear
The measurement plane is located parallel to the reference plane and 15 mm from it, out from the phone. The grid is located in the measurement plane.




Fig. 3 WD reference and plane for RF emission measurements





### **8 SYSTEM VALIDATION**

#### 8.1 Validation Procedure

Place a dipole antenna meeting the requirements given in ANSI C63.19 in the position normally occupied by the WD. The dipole antenna serves as a known source for an electrical output. Position the E-field probes so that:

•The probes and their cables are parallel to the coaxial feed of the dipole antenna

•The probe cables and the coaxial feed of the dipole antenna approach the measurement area from opposite directions

• The center point of the probe element(s) are 15 mm from the closest surface of the dipole elements.




Fig. 4 Dipole Validation Setup

#### 8.2 Validation Result

	E-Field Scan						
Mode	Frequency (MHz)	Input Power (mW)	Measured <sup>1</sup> Value(dBV/m)	Target <sup>2</sup> Value(dBV/m)	Deviation <sup>3</sup> (%)	Limit⁴ (%)	
CW	835	100	40.60	40.64	-0.46	±25	
CW	1880	100	38.97	38.87	1.16	±25	
CW	2450	100	38.75	38.67	0.81	±25	

Notes:

1. Please refer to the attachment for detailed measurement data and plot.

2. Target value is provided by SPEAD in the calibration certificate of specific dipoles.

3. Deviation (%) = 100 \* (Measured value minus Target value) divided by Target value.

4. ANSI C63.19 requires values within  $\pm$  25% are acceptable, of which 12% is deviation and 13% is measurement uncertainty. Values independently validated for the dipole actually used in the measurements should be used, when available.





## 9 Evaluation of MIF

#### 9.1 Introduction

The MIF (Modulation Interference Factor) is used to classify E-field emission to determine Hearing Aid Compatibility (HAC). It scales the power-averaged signal to the RF audio interference level and is characteristic to a modulation scheme. The HAC standard preferred "indirect" measurement method is based on average field measurement with separate scaling by the MIF. With an Audio Interference Analyzer (AIA) designed by SPEAG specifically for the MIF measurement, these values have been verified by practical measurements on an RF signal modulated with each of the waveforms. The resulting deviations from the simulated values are within the requirements

of the HAC standard.

The AIA (Audio Interference Analyzer) is an USB powered electronic sensor to evaluate signals in the frequency range 698MHz - 6 GHz. It contains RMS detector and audio frequency circuits for sampling of the RF envelope.




Fig. 5 AIA Front View





#### 9.2 MIF measurement with the AIA

The MIF is measured with the AIA as follows:

- 1. Connect the AIA via USB to the DASY5 PC and verify the configuration settings.
- 2. Couple the RF signal to be evaluated to an AIA via cable or antenna.
- 3. Generate a MIF measurement job for the unknown signal and select the measurement port and timing settings.
- 4. Document the results via the post processor in a report.

#### 9.3 Test equipment for the MIF measurement

No.	Name	Туре	Serial Number	Manufacturer
01	Signal Generator	E4438C	MY49071430	Agilent
02	AIA	SE UMS 170 CB	1029	SPEAG
03	BTS	CMW500	166370	Agilent

#### 9.4 Test signal validation

The signal generator (E4438C) is used to generate a 1GHz signal with different modulation in the below table based on the ANSI C63.19-2011. The measured MIF with AIA are compared with the target values given in ANSI C63.19-2011 table D.3, D.4 and D5.

Pulse modulation	Target MIF	Measured MIF	Deviation
0.5ms pulse, 1000Hz repetition rate	-0.9 dB	-0.9 dB	0 dB
1ms pulse, 100Hz repetition rate	+3.9 dB	+3.7 dB	0.2 dB
0.1ms pulse, 100Hz repetition rate	+10.1 dB	+10.0 dB	0.1 dB
10ms pulse, 10Hz repetition rate	+1.6 dB	+1.7 dB	0.1 dB
Sine-wave modulation	Target MIF	Measured MIF	Deviation
1 kHz, 80% AM	-1.2 dB	-1.3 dB	0.1 dB
1 kHz, 10% AM	-9.1 dB	-9.0 dB	0.1 dB
1 kHz, 1% AM	-19.1 dB	-18.9 dB	0.2 dB
100 Hz, 10% AM	-16.1 dB	-16.0 dB	0.1 dB
10 kHz, 10% AM	-21.5 dB	-21.6 dB	0.1 dB
Transmission protocol	Target MIF	Measured MIF	Deviation
GSM; full-rate version 2; speech codec/handset low	+3.5 dB	+3.47 dB	0.03 dB
WCDMA; speech; speech codec low; AMR 12.2 kb/s	-20.0 dB	-19.8 dB	0.2 dB
CDMA; speech; SO3; RC3; full frame rate; 8kEVRC	-19.0 dB	-19.1 dB	0.1 dB
CDMA; speech; SO3; RC1; 1/8 <sup>th</sup> frame rate; 8kEVRC	+3.3 dB	+3.44 dB	0.14 dB





#### 9.5 DUT MIF results

Based on the KDB285076D01v05, the handset can also use the MIF values predetermined by the test equipment manufacturer. MIF values applied in this test report were provided by the HAC equipment provider of SPEAG, and the worst values for all air interface are listed below to be determine the Low-power Exemption.

Typical MIF levels in ANSI C63.19-2011				
Transmission protocol	Modulation interference			
	factor			
GSM-FDD (TDMA, GMSK)	+3.63 dB			
EDGE-FDD (TDMA, 8PSK, TN 0-1)	+1.23dB			
EDGE-FDD (TDMA, 8PSK, TN 0-1-2)	-0.52dB			
EDGE-FDD (TDMA, 8PSK, TN 0-1-2-3)	-1.82dB			
UMTS-FDD(WCDMA, AMR)	-25.43dB			
UMTS-FDD (HSPA)	-20.75dB			
LTE-FDD (SC-FDMA, 1RB, 20MHz, QPSK)	-15.63 dB			
LTE-FDD (SC-FDMA, 1RB, 20MHz, 16QAM)	-9.76 dB			
LTE-FDD (SC-FDMA, 1RB, 20MHz, 64QAM)	-9.93 dB			
IEEE 802.11b WiFi 2.4 GHz (DSSS, 1 Mbps)	-5.90 dB			
IEEE 802.11b WiFi 2.4 GHz (DSSS, 2 Mbps)	-5.17 dB			
IEEE 802.11b WiFi 2.4 GHz (DSSS, 5.5 Mbps)	-3.37 dB			
IEEE 802.11b WiFi 2.4 GHz (DSSS, 11 Mbps)	-2.02 dB			
IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 6 Mbps)	-0.36dB			
IEEE 802.11n (HT Greenfield, 6.5 Mbps, BPSK)	-15.80 dB			
IEEE 802.11a/h WiFi 5 GHz (OFDM, 6 Mbps)	-5.82 dB			
IEEE 802.11ac WiFi (20MHz, MCS0, 99pc duty cycle)	-12.23dB			





### 10 Evaluation for low-power exemption

#### **10.1 Product testing threshold**

There are two methods for exempting an RF air interface technology from testing. The first method requires evaluation of the MIF for the worst-case operating mode. An RF air interface technology of a device is exempt from testing when its average antenna input power plus its MIF is  $\leq$  17 dBm for any of its operating modes. The second method does not require determination of the MIF. The RF emissions testing exemption shall be applied to an RF air interface technology in a device whose peak antenna input power, averaged over intervals  $\leq$  50  $\mu$  s20, is  $\leq$  23 dBm. An RF air interface technology that is exempted from testing by either method shall be rated as M4.

The first method is used to be exempt from testing for the RF air interface technology in this report.

Band	Average power (dBm)	MIF (dB)	Sum (dBm)	C63.19 Tested
GSM 850 - Voice	33.5	3.63	37.13	Yes
GSM 850 - EDGE	29	-1.82	27.18	Yes*
GSM 1900 - Voice	30	3.63	33.63	Yes
GSM 1900 - EDGE	24.5	-1.82	22.68	Yes*
WCDMA 850 - RMC	23.8	-25.43	-1.63	No
WCDMA 850 - HSPA	23.8	-20.75	3.05	No
WCDMA 1700 - RMC	23.8	-25.43	-1.63	No
WCDMA 1700 - HSPA	23.8	-20.75	3.05	No
WCDMA 1900 - RMC	23.8	-25.43	-1.63	No
WCDMA 1900 - HSPA	23.8	-20.75	3.05	No
LTE Band 2 QPSK	23.8	-15.63	8.17	No
LTE Band 7 QPSK	24.5	-15.63	8.87	No
LTE Band 12 QPSK	23.5	-15.63	7.87	No
LTE Band 13 QPSK	23.5	-15.63	7.87	No
LTE Band 26 QPSK	23.8	-15.63	8.17	No
LTE Band 66 QPSK	23.8	-15.63	8.17	No
LTE Band 2 16QAM	22.8	-9.76	13.04	No
LTE Band 7 16QAM	23.5	-9.76	13.74	No
LTE Band 12 16QAM	22.5	-9.76	12.74	No
LTE Band 13 16QAM	22.5	-9.76	12.74	No
LTE Band 26 16QAM	22.8	-9.76	13.04	No
LTE Band 66 16QAM	22.8	-9.76	13.04	No
LTE Band 2 64QAM	21.8	-9.93	11.87	No
LTE Band 7 64QAM	22.5	-9.93	12.57	No
LTE Band 12 64QAM	21.5	-9.93	11.57	No

#### 10.2 Conducted power

©Copyright. All rights reserved by CTTL.





LTE Band 13 64QAM	21.5	-9.93	11.57	No
LTE Band 26 64QAM	21.8	-9.93	11.87	No
LTE Band 66 64QAM	21.8	-9.93	11.87	No
WiFi-2.4G 11b	18.5	-2.02	16.48	No
WiFi-2.4G 11g	18.5	-0.36	18.14	Yes
WiFi-5G	17	-5.82	11.18	No

\*Note: For GSM bands, EDGE modes were not evaluated as Voice modes were found to the worstcase modes for the GSM air interface.

#### 10.3 Conclusion

According to the above table, the sums of average power and MIF for WCDMA, LTE FDD and WiFi5G are less than 17dBm. So it is measured for GSM and WiFi2.4G. The WCDMA, LTE FDD and WiFi5G are exempt from testing and rated as M4.





## 11 RF TEST PROCEDUERES

#### The evaluation was performed with the following procedure:

- 1) Confirm proper operation of the field probe, probe measurement system and other instrumentation and the positioning system.
- 2) Position the WD in its intended test position. The gauge block can simplify this positioning.
- 3) Configure the WD normal operation for maximum rated RF output power, at the desired channel and other operating parameters (e.g., test mode), as intended for the test.
- 4) The center sub-grid shall centered on the center of the T-Coil mode axial measurement point or the acoustic output, as appropriate. Locate the field probe at the initial test position in the50 mm by 50 mm grid, which is contained in the measurement plane. If the field alignment method is used, align the probe for maximum field reception.
- 5) Record the reading.
- 6) Scan the entire 50 mm by 50 mm region in equally spaced increments and record the reading at each measurement point. The distance between measurement points shall be sufficient to assure the identification of the maximum reading.
- 7) Identify the five contiguous sub-grids around the center sub-grid whose maximum reading is the lowest of all available choices. This eliminates the three sub-grids with the maximum readings. Thus, the six areas to be used to determine the WD's highest emissions are identified.
- 8) Identify the maximum field reading within the non-excluded sub-grids identified in Step 7)
- 9) Evaluate the MIF and add to the maximum steady-state rms field-strength reading to obtain the RF audio interference level..
- 10) Compare this RF audio interference level with the categories and record the resulting WD category rating.





Frec	luency	Measured	Dower Drift (dD)	Cotosony		
MHz	Channel	Value(dBV/m)	Power Drift (dB)	Category		
		GSM 8	50			
848.8	251	34.39	-0.02	<b>M4</b> (see Fig B.1)		
836.6	190	34.24	0.06	M4		
824.2	128	33.92	0.02	M4		
		<b>GSM</b> 19	00			
1909.8	810	23.56	0.05	M4 (see Fig B.2)		
1880	661	23.27	-0.02	M4		
1850.2	512	22.69	0.17	M4		
	WiFi2.4G 11g					
2462	11	26.20	0.02	M4		
2437	6	25.72	-0.03	M4		
2412	1	27.08	0.06	<b>M4</b> (see Fig B.3)		

## 12 Measurement Results (E-Field)

## 13 ANSIC 63.19-2011 LIMITS

#### WD RF audio interference level categories in logarithmic units

Emission categories	< 960 MHz E	-field emissions
Category M1	50 to 55	dB (V/m)
Category M2	45 to 50	dB (V/m)
Category M3	40 to 45	dB (V/m)
Category M4	< 40	dB (V/m)
Emission categories	> 960 MHz E-field emissions	
Category M1	40 to 45	dB (V/m)
Category M2	35 to 40	dB (V/m)
Category M3	30 to 35	dB (V/m)
Category M4	< 30	dB (V/m)





## **14 MEASUREMENT UNCERTAINTY**

No.	Error source	Туре	Uncertainty Value(%)	Prob. Dist.	k	CiE	Standard Uncertainty (%) <sub><i>u</i><sub>i</sub><sup>+</sup></sub> (%)E	Degree of freedom V <sub>eff</sub> or <i>v</i> i
Meas	urement System			1	I			
1	Probe Calibration	В	5.	Ν	1	1	5.1	∞
2	Axial Isotropy	В	4.7	R	$\sqrt{3}$	1	2.7	∞
3	Sensor Displacement	В	16.5	R	$\sqrt{3}$	1	9.5	∞
4	Boundary Effects	В	2.4	R	$\sqrt{3}$	1	1.4	∞
5	Linearity	В	4.7	R	$\sqrt{3}$	1	2.7	ø
6	Scaling to Peak Envelope Power	В	2.0	R	$\sqrt{3}$	1	1.2	×
7	System Detection Limit	В	1.0	R	$\sqrt{3}$	1	0.6	∞
8	Readout Electronics	В	0.3	Ν	1	1	0.3	∞
9	Response Time	В	0.8	R	$\sqrt{3}$	1	0.5	∞
10	Integration Time	В	2.6	R	$\sqrt{3}$	1	1.5	×
11	RF Ambient Conditions	В	3.0	R	$\sqrt{3}$	1	1.7	∞
12	RF Reflections	В	12.0	R	$\sqrt{3}$	1	6.9	×
13	Probe Positioner	В	1.2	R	$\sqrt{3}$	1	0.7	×
14	Probe Positioning	А	4.7	R	$\sqrt{3}$	1	2.7	×
15	Extra. And Interpolation	В	1.0	R	$\sqrt{3}$	1	0.6	ø
Test	Test Sample Related							
16	Device Positioning Vertical	В	4.7	R	$\sqrt{3}$	1	2.7	ø
17	Device Positioning Lateral	В	1.0	R	$\sqrt{3}$	1	0.6	ø
18	Device Holder and Phantom	В	2.4	R	$\sqrt{3}$	1	1.4	ø
19	Power Drift	В	5.0	R	$\sqrt{3}$	1	2.9	ø





20	AIA measurement	В	12	R	$\sqrt{3}$	1	6.9	∞
Pha	Phantom and Setup related							
21	Phantom Thickness	В	2.4	R	$\sqrt{3}$	1	1.4	×
Com	Combined standard uncertainty(%) 16.2							
	nded uncertainty idence interval of 95 %)	ı	$u_e = 2u_c$	Ν	k=:	2	32.4	

### **15 MAIN TEST INSTRUMENTS**

#### Table 1: List of Main Instruments

No.	Name	Туре	Serial Number	Calibration Date	Valid Period
01	Signal Generator	E4438C	MY49071430	February 25, 2020	One Year
02	Power meter	NRP2	106276	May 10, 0000	
03	Power sensor	NRP6A	101368	May 12, 2020	One year
04	Amplifier	60S1G4	0331848	No Calibration Requested	
05	E-Field Probe	EF3DV3	4060	May 29, 2020	One year
06	DAE	SPEAG DAE4	1555	August 25, 2020	One year
07	HAC Dipole	CD835V3	1023	August 18, 2020	One year
08	HAC Dipole	CD1880V3	1018	August 18, 2020	One year
09	HAC Dipole	CD2450V3	1021	August 18, 2020	One year
10	BTS	CMW500	166370	June 28, 2020	One year
11	AIA	SE UMS 170 CB	1029	No Calibration Re	quested

### **16 CONCLUSION**


The HAC measurement indicates that the EUT complies with the HAC limits of the ANSIC63.19-2011. The total M-rating is **M4.** 

\*\*\*END OF REPORT BODY\*\*\*





## ANNEX A TEST LAYOUT



Picture A1:HAC RF System Layout





## ANNEX B TEST PLOTS

HAC RF E-Field GSM 850 High Date: 2021-1-13 Electronics: DAE4 Sn1555 Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup> Ambient Temperature: 22.0°C Communication System: GSM 850; Frequency: 848.8 MHz; Duty Cycle: 1:8.3 Probe: EF3DV3 - SN4060;ConvF(1, 1, 1)

E Scan - ER3DV6 - 2011: 15 mm from Probe Center to the Device

3/Hearing Aid Compatibility Test (101x101x1): Interpolated grid:

dx=0.5000 mm, dy=0.5000 mm Device Reference Point: 0, 0, -6.3 mm Reference Value = 42.81 V/m; Power Drift = -0.02 dB Applied MIF = 3.51 dB RF audio interference level = 34.39 dBV/m

#### Emission category: M4

MIF SCa	lieu E	lieiu			
Grid 1	M4	Grid 2	M4	Grid 3	M4
33. 75	dBV/m	34. 07	dBV/m	33. 23	dBV/m
Grid 4	M4	Grid 5	M4	Grid 6	M4
33. 96	dBV/m	34. 39	dBV/m	33. 76	dBV/m
Grid 7	M4	Grid 8	M4	Grid 9	M4
34. 41	dBV/m	34. 63	dBV/m	33.86	dBV/m








Fig B.1 HAC RF E-Field GSM 850 High





### HAC RF E-Field GSM 1900 High Date: 2021-1-14 Electronics: DAE4 Sn1555 Medium: Air Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$ ; $\rho = 1000$ kg/m<sup>3</sup> Ambient Temperature: 22.0°C Communication System: PCS 1900; Frequency: 1909.8 MHz; Duty Cycle: 1:8.3 Probe: EF3DV3 - SN4060;ConvF(1, 1, 1)

E Scan - ER3DV6 - 2011: 15 mm from Probe Center to the Device 2

2/Hearing Aid Compatibility Test (101x101x1): Interpolated grid:

dx=0.5000 mm, dy=0.5000 mm Device Reference Point: 0, 0, -6.3 mm Reference Value = 3.159 V/m; Power Drift = 0.05 dB Applied MIF = 3.51 dB RF audio interference level = 23.56 dBV/m

Emission category: M4

Grid 1 <b>M4</b>	Grid 2 <b>M4</b>	Grid 3 <b>M4</b>
23.36 dBV/m	23.56 dBV/m	22.57 dBV/m
Grid 4 <b>M4</b>	Grid 5 <b>M4</b>	Grid 6 <b>M4</b>
19.97 dBV/m	19.97 dBV/m	19.26 dBV/m
Grid 7 <b>M4</b>	Grid 8 <b>M4</b>	Grid 9 <b>M4</b>
25.44 dBV/m	25.37 dBV/m	23.09 dBV/m








Fig B.2 HAC RF E-Field GSM 1900 High





### HAC RF E-Field WiFI2.4G 11g Date: 2021-1-15 Electronics: DAE4 Sn1555 Medium: Air Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$ ; $\rho = 1000$ kg/m<sup>3</sup> Ambient Temperature: 22.0°C Communication System: WiFi2.4G; Frequency: 2412 MHz; Duty Cycle: 1:1 Probe: EF3DV3 - SN4060;ConvF(1, 1, 1)

#### E Scan - ER3DV6 - 2011: 15 mm from Probe Center to the

#### Device/Hearing Aid Compatibility Test (101x101x1): Interpolated

grid: dx=0.5000 mm, dy=0.5000 mm Device Reference Point: 0, 0, -6.3 mm Reference Value = 23.71 V/m; Power Drift = 0.06 dB Applied MIF = 0.29 dB RF audio interference level = 27.08 dBV/m

#### Emission category: M4

Grid 1 <b>M4</b>	Grid 2 <b>M4</b>	Grid 3 <b>M4</b>
22.16 dBV/m	24.83 dBV/m	24.81 dBV/m
Grid 4 <b>M4</b>	Grid 5 <b>M4</b>	Grid 6 <b>M4</b>
24.82 dBV/m	27.08 dBV/m	26.99 dBV/m
Grid 7 <b>M4</b>	Grid 8 <b>M4</b>	Grid 9 <b>M4</b>
28.04 dBV/m	29.1 dBV/m	28.6 dBV/m

MIF scaled E-field








Fig B.3 HAC RF E-Field WiFi2.4G 11g







## ANNEX C SYSTEM VALIDATION RESULT

E SCAN of Dipole 835 MHz Date: 2021-1-13 Electronics: DAE4 Sn1555 Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\varepsilon r = 1$ ;  $\rho = 1000$  kg/m3 Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1 Probe: EF3DV3 - SN4060;ConvF(1, 1, 1) E Scan - measurement distance from the probe sensor center to CD835 Dipole = 15mm/Hearing Aid Compatibility Test (41x361x1): Interpolated grid: dx=0.5000 mm, dy=0.5000 mm Device Reference Point: 0, 0, -6.3 mm Reference Value = 131.5 V/m; Power Drift = 0.05 dB Applied MIF = 0.00 dB RF audio interference level = 40.6 dBV/m Emission category: M3

Grid 1 <b>M3</b>	Grid 2 <b>M3</b>	Grid 3 <b>M3</b>
40.15 dBV/m	40.6 dBV/m	40.74 dBV/m
Grid 4 <b>M4</b>	Grid 5 M4	Grid 6 <b>M4</b>
35.42 dBV/m	35.14 dBV/m	35.14 dBV/m
Grid 7 <b>M3</b>	Grid 8 <b>M3</b>	Grid 9 <b>M3</b>
40.35 dBV/m	40.78 dBV/m	40.66 dBV/m










#### E SCAN of Dipole 1880 MHz Date: 2021-1-14

Electronics: DAE4 Sn1555 Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\varepsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup> Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1 Probe: EF3DV3 - SN4060;ConvF(1, 1, 1) **E Scan - measurement distance from the probe sensor center to CD1880 Dipole = 15mm/Hearing Aid Compatibility Test (41x181x1):** Interpolated grid: dx=0.5000 mm, dy=0.5000 mm Device Reference Point: 0, 0, -6.3 mm Reference Value = 150.6 V/m; Power Drift = 0.04 dB Applied MIF = 0.00 dB RF audio interference level = 38.97 dBV/m **Emission category: M2** 

Grid 1 <b>M2</b>	Grid 2 <b>M2</b>	Grid 3 <b>M2</b>
38.66 dBV/m	38.97 dBV/m	39.05 dBV/m
Grid 4 <b>M2</b>	Grid 5 M2	Grid 6 <b>M2</b>
36.07 dBV/m	36.09 dBV/m	36.17 dBV/m
Grid 7 <b>M2</b>	Grid 8 <b>M2</b>	Grid 9 <b>M2</b>
38.68 dBV/m	39.02 dBV/m	38.99 dBV/m



 $0 \ dB = 38.97 \ dBV/m$ 





#### E SCAN of Dipole 2450 MHz Date: 2021-1-15

Electronics: DAE4 Sn1555 Medium: Air Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup> Communication System: CW; Frequency: 2450 MHz; Duty Cycle: 1:1 Probe: EF3DV3 - SN4060;ConvF(1, 1, 1) **E Scan - measurement distance from the probe sensor center to CD2450 Dipole = 15mm** /**Hearing Aid Compatibility Test (41x181x1):** Interpolated grid: dx=0.5000 mm, dy=0.5000

mm

Device Reference Point: 0, 0, -6.3 mm


Reference Value = 79.98 V/m; Power Drift = 0.02 dB

Applied MIF = 0.00 dB

RF audio interference level = 38.74 dBV/m

#### **Emission category: M2**

Grid 1 <b>M2</b>	Grid 2 <b>M2</b>	Grid 3 <b>M2</b>
39.06 dBV/m	39.09 dBV/m	38.78 dBV/m
Grid 4 <b>M2</b>	Grid 5 M2	Grid 6 <b>M2</b>
38.71 dBV/m	38.74 dBV/m	38.41 dBV/m
Grid 7 <b>M2</b>	Grid 8 <b>M2</b>	Grid 9 <b>M2</b>
38.18 dBV/m	38.37 dBV/m	38.22 dBV/m







## ANNEX D PROBE CALIBRATION CERTIFICATE

	tation Service (SAS)	Acc	reditation No.: SCS 0108
ccredited by the Swiss Accredit he Swiss Accreditation Servi			
lultilateral Agreement for the	recognition of calibration co	ertificates	
lient CTTL (Auden)		Certificate No:	EF3-4060_May20
CALIBRATION	CERTIFICATE		
Dbject	EF3DV3- SN:4060	)	
	A A A A A A A A		
Calibration procedure(s)	QA CAL-02.v9, QA	A CAL-25.V/ lure for E-field probes optimized for	or close pear field
	evaluations in air	lute for E-field probes optimized in	of close field field
Calibration date:	May 29, 2020		
Jailbration date.	Way 23, 2020		
This calibration certificate docur	ments the traceability to nation	nal standards, which realize the physical units	of measurements (SI).
		bability are given on the following pages and a	
The medadicine no and the and			
	1.1	,	
All calibrations have been cond		facility: environment temperature (22 ± 3)°C a	
	ucted in the closed laboratory		
	ucted in the closed laboratory		
	ucted in the closed laboratory		
All calibrations have been cond Calibration Equipment used (Ma Primary Standards	ucted in the closed laboratory	facility: environment temperature (22 ± 3)°C a	and humidity < 70%.
Calibration Equipment used (Ma Primary Standards Power meter NRP	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778	facility: environment temperature (22 ± 3)°C a Cal Date (Certificate No.) 01-Apr-20 (No. 217-03100/03101)	and humidity < 70%. Scheduled Calibration Apr-21
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91	Ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244	facility: environment temperature (22 ± 3)°C a Cal Date (Certificate No.) 01-Apr-20 (No. 217-03100/03101) 01-Apr-20 (No. 217-03100)	And humidity < 70%. Scheduled Calibration Apr-21 Apr-21
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91	Uncted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245	facility: environment temperature (22 ± 3)°C a Cal Date (Certificate No.) 01-Apr-20 (No. 217-03100/03101) 01-Apr-20 (No. 217-03100) 01-Apr-20 (No. 217-03101)	And humidity < 70%. Scheduled Calibration Apr-21 Apr-21 Apr-21
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator	UCTE din the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x)	facility: environment temperature (22 ± 3)°C a Cal Date (Certificate No.) 01-Apr-20 (No. 217-03100/03101) 01-Apr-20 (No. 217-03100) 01-Apr-20 (No. 217-03101) 31-Mar-20 (No. 217-03106)	And humidity < 70%. Scheduled Calibration Apr-21 Apr-21 Apr-21 Apr-21 Apr-21
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x) SN: 789	facility: environment temperature (22 ± 3)°C a Cal Date (Certificate No.) 01-Apr-20 (No. 217-03100/03101) 01-Apr-20 (No. 217-03100) 01-Apr-20 (No. 217-03101) 31-Mar-20 (No. 217-03106) 27-Dec-19 (No. DAE4-789_Dec19)	And humidity < 70%. Scheduled Calibration Apr-21 Apr-21 Apr-21 Apr-21 Dec-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator	UCTE din the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x)	facility: environment temperature (22 ± 3)°C a Cal Date (Certificate No.) 01-Apr-20 (No. 217-03100/03101) 01-Apr-20 (No. 217-03100) 01-Apr-20 (No. 217-03101) 31-Mar-20 (No. 217-03106)	And humidity < 70%. Scheduled Calibration Apr-21 Apr-21 Apr-21 Apr-21 Apr-21
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x) SN: 789	Cal Date (Certificate No.)           01-Apr-20 (No. 217-03100)/03101)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03101)           31-Mar-20 (No. 217-03106)           27-Dec-19 (No. DAE4-789_Dec19)	And humidity < 70%. Scheduled Calibration Apr-21 Apr-21 Apr-21 Apr-21 Dec-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x) SN: 789 SN: 2328	Cal Date (Certificate No.)           01-Apr-20 (No. 217-03100/03101)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03101)           31-Mar-20 (No. 217-03106)           27-Dec-19 (No. DAE4-789_Dec19)           05-Oct-19 (No. ER3-2328_Oct19)	Apr-21 Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6 Secondary Standards Power meter E4419B	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x) SN: 789 SN: 2328 ID	facility: environment temperature (22 ± 3)°C a Cal Date (Certificate No.) 01-Apr-20 (No. 217-03100/03101) 01-Apr-20 (No. 217-03100) 01-Apr-20 (No. 217-03100) 01-Apr-20 (No. 217-03106) 27-Dec-19 (No. DAE4-789_Dec19) 05-Oct-19 (No. ER3-2328_Oct19) Check Date (in house)	Apr-21 Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20 Scheduled Check
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6 Secondary Standards	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x) SN: 789 SN: 2328 ID SN: GB41293874	Cal Date (Certificate No.)           01-Apr-20 (No. 217-03100/03101)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03101)           31-Mar-20 (No. 217-03106)           27-Dec-19 (No. DAE4-789_Dec19)           05-Oct-19 (No. ER3-2328_Oct19)           Check Date (in house)           06-Apr-16 (in house check Jun-18)	Apr-21 Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20 Scheduled Check In house check: Jun-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6 Secondary Standards Power meter E4419B Power sensor E4412A	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x) SN: 789 SN: 2328 ID SN: GB41293874 SN: MY41498087	Cal Date (Certificate No.)           01-Apr-20 (No. 217-03100/03101)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03101)           31-Mar-20 (No. 217-03106)           27-Dec-19 (No. DAE4-789_Dec19)           05-Oct-19 (No. ER3-2328_Oct19)           Check Date (in house)           06-Apr-16 (in house check Jun-18)           06-Apr-16 (in house check Jun-18)	Apr-21 Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20 Oct-20 Scheduled Check In house check: Jun-20 In house check: Jun-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6 Secondary Standards Power meter E44198 Power sensor E4412A Power sensor E4412A RF generator HP 8648C	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: C22552 (20x) SN: 789 SN: 2328 ID SN: GB41293874 SN: MY41498087 SN: 000110210	facility: environment temperature (22 ± 3)°C a         Cal Date (Certificate No.)         01-Apr-20 (No. 217-03100/03101)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03101)         31-Mar-20 (No. 217-03106)         27-Dec-19 (No. DAE4-789_Dec19)         05-Oct-19 (No. ER3-2328_Oct19)         Check Date (in house)         06-Apr-16 (in house check Jun-18)         06-Apr-16 (in house check Jun-18)	Apr-21 Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20 Oct-20 Scheduled Check In house check: Jun-20 In house check: Jun-20 In house check: Jun-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6 Secondary Standards Power meter E4419B Power sensor E4412A Power sensor E4412A	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x) SN: 2328 ID SN: GB41293874 SN: MY41498087 SN: 000110210 SN: US3642U01700 SN: US3642U01700 SN: US41080477	Cal Date (Certificate No.)           01-Apr-20 (No. 217-03100/03101)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03101)           31-Mar-20 (No. 217-03106)           27-Dec-19 (No. DAE4-789_Dec19)           05-Oct-19 (No. ER3-2328_Oct19)           06-Apr-16 (in house)           06-Apr-16 (in house check Jun-18)           06-Apr-16 (in house check Jun-18)           06-Apr-16 (in house check Jun-18)           04-Aug-99 (in house check Jun-18)           31-Mar-14 (in house check Oct-19)	Apr-21 Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20 Oct-20 Scheduled Check In house check: Jun-20 In house check: Jun-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6 Secondary Standards Power meter E4419B Power sensor E4412A Power sensor E4412A RF generator HP 8648C Network Analyzer E8358A	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x) SN: 789 SN: 2328 ID SN: GB41293874 SN: MY41498087 SN: 000110210 SN: US3642U01700 SN: US3642U01700 SN: US41080477 Name	facility: environment temperature (22 ± 3)°C a         Cal Date (Certificate No.)         01-Apr-20 (No. 217-03100/03101)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03106)         27-Dec-19 (No. DAE4-789_Dec19)         05-Oct-19 (No. ER3-2328_Oct19)         05-Oct-19 (No. ER3-2328_Oct19)         06-Apr-16 (in house)         06-Apr-16 (in house check Jun-18)         06-Apr-16 (in house check Jun-18)         04-Aug-99 (in house check Jun-18)         31-Mar-14 (in house check Oct-19)	And humidity < 70%. Scheduled Calibration Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20 Oct-20 Scheduled Check In house check: Jun-20 In house check: Jun-20 In house check: Jun-20 In house check: Jun-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6 Secondary Standards Power meter E4419B Power sensor E4412A Power sensor E4412A RF generator HP 8648C Network Analyzer E8358A	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x) SN: 2328 ID SN: GB41293874 SN: MY41498087 SN: 000110210 SN: US3642U01700 SN: US3642U01700 SN: US41080477	Cal Date (Certificate No.)           01-Apr-20 (No. 217-03100/03101)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03100)           01-Apr-20 (No. 217-03101)           31-Mar-20 (No. 217-03106)           27-Dec-19 (No. DAE4-789_Dec19)           05-Oct-19 (No. ER3-2328_Oct19)           06-Apr-16 (in house)           06-Apr-16 (in house check Jun-18)           06-Apr-16 (in house check Jun-18)           06-Apr-16 (in house check Jun-18)           04-Aug-99 (in house check Jun-18)           31-Mar-14 (in house check Oct-19)	Apr-21 Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20 Oct-20 Scheduled Check In house check: Jun-20 In house check: Jun-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6 Secondary Standards Power meter E44198 Power sensor E4412A Power sensor E4412A RF generator HP 8648C	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x) SN: 789 SN: 2328 ID SN: GB41293874 SN: MY41498087 SN: 000110210 SN: US3642U01700 SN: US3642U01700 SN: US41080477 Name	facility: environment temperature (22 ± 3)°C a         Cal Date (Certificate No.)         01-Apr-20 (No. 217-03100/03101)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03106)         27-Dec-19 (No. DAE4-789_Dec19)         05-Oct-19 (No. ER3-2328_Oct19)         05-Oct-19 (No. ER3-2328_Oct19)         06-Apr-16 (in house)         06-Apr-16 (in house check Jun-18)         06-Apr-16 (in house check Jun-18)         04-Aug-99 (in house check Jun-18)         31-Mar-14 (in house check Oct-19)	Apr-21 Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20 Oct-20 Scheduled Check In house check: Jun-20 In house check: Jun-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6 Secondary Standards Power meter E44198 Power sensor E4412A RF generator HP 8648C Network Analyzer E8358A Calibrated by:	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: C22552 (20x) SN: 789 SN: 2328 ID SN: GB41293874 SN: WY41498087 SN: 000110210 SN: US3642U01700 SN: US3642U01700 SN: US3642U01700 SN: US41080477 Name Michael Weber	facility: environment temperature (22 ± 3)°C a         Cal Date (Certificate No.)         01-Apr-20 (No. 217-03100/03101)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03101)         31-Mar-20 (No. 217-03106)         27-Dec-19 (No. DAE4-789_Dec19)         05-Oct-19 (No. ER3-2328_Oct19)         Check Date (in house)         06-Apr-16 (in house check Jun-18)         06-Apr-16 (in house check Jun-18)         04-Aug-99 (in house check Jun-18)         31-Mar-14 (in house check Oct-19)         Function         Laboratory Technician	Apr-21 Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20 Oct-20 Scheduled Check In house check: Jun-20 In house check: Jun-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6 Secondary Standards Power meter E4419B Power sensor E4412A Power sensor E4412A RF generator HP 8648C Network Analyzer E8358A	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: CC2552 (20x) SN: 789 SN: 2328 ID SN: GB41293874 SN: MY41498087 SN: 000110210 SN: US3642U01700 SN: US3642U01700 SN: US41080477 Name	facility: environment temperature (22 ± 3)°C a         Cal Date (Certificate No.)         01-Apr-20 (No. 217-03100/03101)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03106)         27-Dec-19 (No. DAE4-789_Dec19)         05-Oct-19 (No. ER3-2328_Oct19)         05-Oct-19 (No. ER3-2328_Oct19)         06-Apr-16 (in house)         06-Apr-16 (in house check Jun-18)         06-Apr-16 (in house check Jun-18)         06-Apr-16 (in house check Jun-18)         04-Aug-99 (in house check Jun-18)         31-Mar-14 (in house check Oct-19)	Apr-21 Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20 Oct-20 Scheduled Check In house check: Jun-20 In house check: Oct-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6 Secondary Standards Power meter E44198 Power sensor E4412A RF generator HP 8648C Network Analyzer E8358A Calibrated by:	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: C22552 (20x) SN: 789 SN: 2328 ID SN: GB41293874 SN: WY41498087 SN: 000110210 SN: US3642U01700 SN: US3642U01700 SN: US3642U01700 SN: US41080477 Name Michael Weber	facility: environment temperature (22 ± 3)°C a         Cal Date (Certificate No.)         01-Apr-20 (No. 217-03100/03101)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03101)         31-Mar-20 (No. 217-03106)         27-Dec-19 (No. DAE4-789_Dec19)         05-Oct-19 (No. ER3-2328_Oct19)         Check Date (in house)         06-Apr-16 (in house check Jun-18)         06-Apr-16 (in house check Jun-18)         04-Aug-99 (in house check Jun-18)         31-Mar-14 (in house check Oct-19)         Function         Laboratory Technician	Apr-21 Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20 Oct-20 Scheduled Check In house check: Jun-20 In house check: Oct-20
Calibration Equipment used (Ma Primary Standards Power meter NRP Power sensor NRP-Z91 Power sensor NRP-Z91 Reference 20 dB Attenuator DAE4 Reference Probe ER3DV6 Secondary Standards Power meter E44198 Power sensor E4412A RF generator HP 8648C Network Analyzer E8358A Calibrated by:	ucted in the closed laboratory &TE critical for calibration) ID SN: 104778 SN: 103244 SN: 103245 SN: C22552 (20x) SN: 789 SN: 2328 ID SN: GB41293874 SN: WY41498087 SN: 000110210 SN: US3642U01700 SN: US3642U01700 SN: US3642U01700 SN: US41080477 Name Michael Weber	facility: environment temperature (22 ± 3)°C a         Cal Date (Certificate No.)         01-Apr-20 (No. 217-03100/03101)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03100)         01-Apr-20 (No. 217-03101)         31-Mar-20 (No. 217-03106)         27-Dec-19 (No. DAE4-789_Dec19)         05-Oct-19 (No. ER3-2328_Oct19)         Check Date (in house)         06-Apr-16 (in house check Jun-18)         06-Apr-16 (in house check Jun-18)         04-Aug-99 (in house check Jun-18)         31-Mar-14 (in house check Oct-19)         Function         Laboratory Technician	Apr-21 Apr-21 Apr-21 Apr-21 Apr-21 Dec-20 Oct-20 Oct-20 Scheduled Check In house check: Jun-20 In house check: Oct-20

\_ \_ \_





#### Calibration Laboratory of Schmid & Partner **Engineering AG** Zeughausstrasse 43, 8004 Zurich, Switzerland



Schweizerischer Kalibrierdienst Service suisse d'étalonnage Servizio svizzero di taratura Swiss Calibration Service

Accreditation No.: SCS 0108

S

С

S

Accredited by the Swiss Accreditation Service (SAS) The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

#### Glossary:

Olossuly.	
NORMx,y,z	sensitivity in free space
DCP	diode compression point
CF	crest factor (1/duty_cycle) of the RF signal
A, B, C, D	modulation dependent linearization parameters
En	incident E-field orientation normal to probe axis
Ep	incident E-field orientation parallel to probe axis
Polarization $\phi$	φ rotation around probe axis
Polarization 9	9 rotation around an axis that is in the plane normal to probe axis (at measurement center),
	i.e., $9 = 0$ is normal to probe axis
Connector Angle	information used in DASY system to align probe sensor X to the robot coordinate system

#### Calibration is Performed According to the Following Standards:

- a) IEEE Std 1309-2005, "IEEE Standard for calibration of electromagnetic field sensors and probes, excluding antennas, from 9 kHz to 40 GHz", December 2005
- b) CTIA Test Plan for Hearing Aid Compatibility, Rev 3.1.1, May 2017

#### Methods Applied and Interpretation of Parameters:

- *NORMx,y,z*: Assessed for E-field polarization  $\vartheta = 0$  for XY sensors and  $\vartheta = 90$  for Z sensor (f  $\le 900$  MHz in TEM-cell; f > 1800 MHz: R22 waveguide).
- NORM(f)x,y,z = NORMx,y,z \* frequency\_response (see Frequency Response Chart). .
- DCPx, y, z: DCP are numerical linearization parameters assessed based on the data of power sweep with CW signal (no uncertainty required). DCP does not depend on frequency nor media.
- PAR: PAR is the Peak to Average Ratio that is not calibrated but determined based on the signal characteristics
- Ax,y,z; Bx,y,z; Cx,y,z; Dx,y,z; VRx,y,z: A, B, C, D are numerical linearization parameters assessed based on the data of power sweep for specific modulation signal. The parameters do not depend on frequency nor media. VR is the maximum calibration range expressed in RMS voltage across the diode.
- Spherical isotropy (3D deviation from isotropy): in a locally homogeneous field realized using an open waveguide setup.
- Sensor Offset: The sensor offset corresponds to the offset of virtual measurement center from the probe tip (on probe axis). No tolerance required.
- Connector Angle: The angle is assessed using the information gained by determining the NORMx (no uncertainty required).

Certificate No: EF3-4060\_May20

Page 2 of 21





May 29, 2020

# DASY/EASY - Parameters of Probe: EF3DV3 - SN:4060

### **Basic Calibration Parameters**

	Sensor X	Sensor Y	Sensor Z	Unc (k=2)
Norm $(\mu V/(V/m)^2)$	0.79	0.74	1.28	± 10.1 %
DCP (mV) <sup>B</sup>	95.3	97.8	96.5	

#### Calibration results for Frequency Response (30 MHz - 6 GHz)

Frequency MHz	Target E-Field V/m	Measured E-field (En)	Deviation E-normal	Measured E-field (Ep)	Deviation E-normal	Unc (k=2) %
		V/m	in %	V/m	in %	
30	77.2	77.3	0.1%	77.3	0.1%	± 5.1 %
100	77.3	78.2	1.2%	78.5	1.5%	± 5.1 %
450	77.1	78.1	1.2%	78.2	1.4%	± 5.1 %
600	77.2	77.7	0.6%	77.7	0.7%	± 5.1 %
750	77.3	77.4	0.3%	77.4	0.3%	± 5.1 %
1800	140.3	138.3	-2.8%	139.2	-2.1%	± 5.1 %
2000	133.0	131.4	-2.7%	131.4	-2.7%	± 5.1 %
2200	125.1	123.5	-3.3%	124.5	-2.5%	± 5.1 %
2500	123.7	122.4	-2.5%	123.2	-1.8%	± 5.1 %
3000	78.9	75.8	-4.6%	76.7	-3.4%	± 5.1 %
3500	250.5	247.6	-3.3%	243.6	-4.8%	± 5.1 %
3700	244.2	239.8	-3.9%	237.6	-4.8%	± 5.1 %
5200	50.8	51.3	1.1%	51.7	1.8%	± 5.1 %
5200	49.7	49.4	-0.6%	48.2	-3.1%	± 5.1 %
5800	48.9	48.6	-0.6%	49.7	1.7%	± 5.1 %

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.

<sup>B</sup> Numerical linearization parameter: uncertainty not required.
 <sup>E</sup> Uncertainty is determined using the max. deviation from linear response applying rectangular distribution and is expressed for the square of the field value.

Certificate No: EF3-4060\_May20

Page 3 of 21





May 29, 2020

## DASY/EASY - Parameters of Probe: EF3DV3 - SN:4060

#### Calibration Results for Modulation Response

UID	Communication System Name		A dB	B dBõV	С	D dB	VR mV	Max dev.	Max Unc <sup>E</sup> (k=2)
0	CW	X	0.00	0.00	1.00	0.00	125.9	± 3.5 %	±4.7 %
		Y	0.00	0.00	1.00		166.9		
		Z	0.00	0.00	1.00	1	128.4	1	
10352-	Pulse Waveform (200Hz, 10%)	X	2.22	64.12	8.85	10.00	60.0	± 2.9 %	±9.6 %
AAA		Y	3.72	69.58	11.72	]	60.0	]	
		Z	2.68	66.15	10.03	1	60.0	1	
10353-	Pulse Waveform (200Hz, 20%)	X	1.05	61.61	6.69	6.99	80.0	± 1.0 %	±9.6 %
AAA	, , , , , , , , , , , , , , , , , , ,	Y	2.73	69.71	10.89	1	80.0	]	
		Z	1.39	64.06	8.17	1	80.0	1	
10354-	Pulse Waveform (200Hz, 40%)	X	0.64	61.95	5.93	3.98	95.0	± 0.8 %	±9.6 %
AAA		Y	20.00	88.10	15.51		95.0	]	
		Z	1.00	65.44	7.85	1	95.0	1	
10355-	Pulse Waveform (200Hz, 60%)	X	0.66	64.74	6.65	2.22	120.0	± 1.0 %	± 9.6 %
AAA		Y	20.00	93.78	17.20		120.0		
		Z	20.00	84.41	12.55	1	120.0	]	
10387-	QPSK Waveform, 1 MHz	X	1.98	70.59	17.17	1.00	150.0	± 1.9 %	± 9.6 %
AAA		Y	1.94	69.99	16.92	1	150.0	1	
		Z	2.02	71.47	17.51	1	150.0	1	
10388-	QPSK Waveform, 10 MHz	X	2.54	70.83	17.55	0.00	150.0	± 1.1 %	± 9.6 %
AAA		Y	2.51	70.47	17.33		150.0	1	
		Z	2.43	70.41	17.43	1	150.0		
10396-	64-QAM Waveform, 100 kHz	X	2.34	69.66	19.06	3.01	150.0	± 1.1 %	± 9.6 %
AAA		Y	2.49	70.33	19.41	1	150.0	]	
		Z	2.09	67.16	17.82	1	150.0		
10399-	64-QAM Waveform, 40 MHz	X	3.51	67.32	16.24	0.00	150.0	± 1.0 %	± 9.6 %
AAA		Y	3.62	67.78	16.40		150.0		
		Z	3.52	67.45	16.34		150.0		
10414-	WLAN CCDF, 64-QAM, 40MHz	X	4.74	65.60	15.79	0.00	150.0	± 2.0 %	± 9.6 %
AAA		Y	4.72	65.49	15.68		150.0		
		Z	4.73	65.70	15.88		150.0		

Note: For details on UID parameters see Appendix

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.

<sup>B</sup> Numerical linearization parameter: uncertainty not required. <sup>E</sup> Uncertainty is determined using the max. deviation from linear response applying rectangular distribution and is expressed for the square of the field value.

Certificate No: EF3-4060\_May20

Page 4 of 21





May 29, 2020

## DASY/EASY - Parameters of Probe: EF3DV3 - SN:4060

### **Sensor Frequency Model Parameters**

	Sensor X	Sensor Y	Sensor Z
Frequency Corr. (LF)	0.20	0.19	4.60
Frequency Corr. (HF)	2.82	2.82	2.82

#### Sensor Model Parameters

	C1 fF	C2 fF	α V <sup>-1</sup>	T1 ms.V <sup>-2</sup>	T2 ms.V <sup>-1</sup>	T3 ms	T4 V <sup>-2</sup>	T5 V <sup>-1</sup>	Т6
Х	39.4	262.85	37.46	5.11	0.07	4.93	0.89	0.00	1.00
Y	40.3	265.26	36.67	6.10	0.00	4.98	1.07	0.00	1.00
Z	37.4	250.57	37.84	4.63	0.03	4.97	0.00	0.14	1.00

## **Other Probe Parameters**

Sensor Arrangement	Rectangular
Connector Angle (°)	-35
Mechanical Surface Detection Mode	enabled
Optical Surface Detection Mode	disabled
Probe Overall Length	337 mm
Probe Body Diameter	12 mm
Tip Length	25 mm
Tip Diameter	4 mm
Probe Tip to Sensor X Calibration Point	1.5 mm
Probe Tip to Sensor Y Calibration Point	1.5 mm
Probe Tip to Sensor Z Calibration Point	1.5 mm


Certificate No: EF3-4060\_May20

Page 5 of 21





May 29, 2020



## Receiving Pattern ( $\phi$ ), $\vartheta = 0^{\circ}$


Certificate No: EF3-4060\_May20

Page 6 of 21







May 29, 2020



## Receiving Pattern ( $\phi$ ), $\vartheta = 0^{\circ}$



## Receiving Pattern ( $\phi$ ), $\vartheta$ = 90°



Uncertainty of Axial Isotropy Assessment: ± 0.5% (k=2)

Certificate No: EF3-4060\_May20


Page 7 of 21





May 29, 2020






Certificate No: EF3-4060\_May20

Page 8 of 21





May 29, 2020



Uncertainty of Spherical Isotropy Assessment: ± 2.6% (k=2)

Certificate No: EF3-4060\_May20

Page 9 of 21





# ANNEX E DIPOLE CALIBRATION CERTIFICATE

ient CTTL-BJ (Auden)	-	ertificates	
the state of the s			: CD835V3-1023_Aug20
CALIBRATION CI	ERTIFICATE		
Object	CD835V3 - SN: 1	023	
Calibration procedure(s)	QA CAL-20.v7 Calibration Proce	dure for Validation Sources in air	r
Calibration date:	August 18, 2020		
All calibrations have been conducte Calibration Equipment used (M&TE		y facility: environment temperature (22 $\pm$ 3)°C	C and humidity < 70%.
Primary Standards	ID#	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	01-Apr-20 (No. 217-03100/03101)	Apr-21
Power sensor NRP-Z91	SN: 103244	01-Apr-20 (No. 217-03100)	Apr-21
Power sensor NRP-Z91	SN: 103245	01-Apr-20 (No. 217-03101)	Apr-21
Reference 20 dB Attenuator	SN: BH9394 (20k)	31-Mar-20 (No. 217-03106)	Apr-21
Type-N mismatch combination	SN: 310982 / 06327	31-Mar-20 (No. 217-03104)	Apr-21
Probe EF3DV3	SN: 4013	31-Dec-19 (No. EF3-4013_Dec19)	Dec-20
DAE4	SN: 781	27-Dec-19 (No. DAE4-781_Dec19)	Dec-20
Secondary Standards	ID #	Check Date (in house)	Scheduled Check
Power meter Agilent 4419B	SN: GB42420191	09-Oct-09 (in house check Oct-17)	In house check: Oct-20
Power sensor HP E4412A	SN: US38485102	05-Jan-10 (in house check Oct-17)	In house check: Oct-20
Power sensor HP 8482A	SN: US37295597	09-Oct-09 (in house check Oct-17)	In house check: Oct-20
RF generator R&S SMT-06 Network Analyzer Agilent E8358A	SN: 837633/005 SN: US41080477	10-Jan-19 (in house check Jan-19) 31-Mar-14 (in house check Oct-19)	In house check: Oct-20 In house check: Oct-20
Network Analyzer Aglient E0350A		Function	Signature
Network Analyzer Agrent 20000A	Name		S.D.M.
	Name Leif Klysner	Laboratory Technician	Les Man
Calibrated by:		Laboratory Technician Technical Manager	Sel Man
Calibrated by:	Leif Klysner		def Man





### Calibration Laboratory of

Schmid & Partner Engineering AG Zeughausstrasse 43, 8004 Zurich, Switzerland



Schweizerischer Kalibrierdienst S С S

Service suisse d'étalonnage Servizio svizzero di taratura Swiss Calibration Service

Accreditation No.: SCS 0108

Accredited by the Swiss Accreditation Service (SAS)

The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

#### References

ANSI-C63.19-2011 [1]

American National Standard, Methods of Measurement of Compatibility between Wireless Communications Devices and Hearing Aids.

### Methods Applied and Interpretation of Parameters:

- Coordinate System: y-axis is in the direction of the dipole arms. z-axis is from the basis of the antenna (mounted on the table) towards its feed point between the two dipole arms. x-axis is normal to the other axes. In coincidence with the standards [1], the measurement planes (probe sensor center) are selected to be at a distance of 15 mm above the top metal edge of the dipole arms.
- Measurement Conditions: Further details are available from the hardcopies at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated. The forward power to the dipole connector is set with a calibrated power meter connected and monitored with an auxiliary power meter connected to a directional coupler. While the dipole under test is connected, the forward power is adjusted to the same level.
- Antenna Positioning: The dipole is mounted on a HAC Test Arch phantom using the matching dipole positioner with the arms horizontal and the feeding cable coming from the floor. The measurements are performed in a shielded room with absorbers around the setup to reduce the reflections. It is verified before the mounting of the dipole under the Test Arch phantom, that its arms are perfectly in a line. It is installed on the HAC dipole positioner with its arms parallel below the dielectric reference wire and able to move elastically in vertical direction without changing its relative position to the top center of the Test Arch phantom. The vertical distance to the probe is adjusted after dipole mounting with a DASY5 Surface Check job. Before the measurement, the distance between phantom surface and probe tip is verified. The proper measurement distance is selected by choosing the matching section of the HAC Test Arch phantom with the proper device reference point (upper surface of the dipole) and the matching grid reference point (tip of the probe) considering the probe sensor offset. The vertical distance to the probe is essential for the accuracy.
- Feed Point Impedance and Return Loss: These parameters are measured using a Vector Network Analyzer. The impedance is specified at the SMA connector of the dipole. The influence of reflections was eliminating by applying the averaging function while moving the dipole in the air, at least 70cm away from any obstacles.
- E-field distribution: E field is measured in the x-y-plane with an isotropic E-field probe with 100 mW forward power to the antenna feed point. In accordance with [1], the scan area is 20mm wide, its length exceeds the dipole arm length (180 or 90mm). The sensor center is 15 mm (in z) above the metal top of the dipole arms. Two 3D maxima are available near the end of the dipole arms. Assuming the dipole arms are perfectly in one line, the average of these two maxima (in subgrid 2 and subgrid 8) is determined to compensate for any nonparallelity to the measurement plane as well as the sensor displacement. The E-field value stated as calibration value represents the maximum of the interpolated 3D-E-field, in the plane above the dipole surface.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Certificate No: CD835V3-1023 Aug20

Page 2 of 5





### **Measurement Conditions**

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.4
Phantom	HAC Test Arch	
Distance Dipole Top - Probe Center	15 mm	
Scan resolution	dx, dy = 5 mm	
Frequency	835 MHz ± 1 MHz	2723
Input power drift	< 0.05 dB	

### Maximum Field values at 835 MHz

E-field 15 mm above dipole surface	condition	Interpolated maximum
Maximum measured above high end	100 mW input power	107.7 V/m = 40.64 dBV/m
Maximum measured above low end	100 mW input power	107.3 V/m = 40.61 dBV/m
Averaged maximum above arm	100 mW input power	107.5 V/m ± 12.8 % (k=2)

## Appendix (Additional assessments outside the scope of SCS 0108)

### **Antenna Parameters**

Frequency	Return Loss	Impedance
800 MHz	17.1 dB	41.3 Ω - 9.5 jΩ
835 MHz	24.9 dB	52.8 Ω + 5.2 jΩ
880 MHz	16.5 dB	62.0 Ω - 11.9 jΩ
900 MHz	16.5 dB	53.1 Ω - 15.3 jΩ
945 MHz	25.4 dB	46.2 Ω + 3.5 jΩ

#### 3.2 Antenna Design and Handling

The calibration dipole has a symmetric geometry with a built-in two stub matching network, which leads to the enhanced bandwidth.

The dipole is built of standard semirigid coaxial cable. The internal matching line is open ended. The antenna is therefore open for DC signals.

Do not apply force to dipole arms, as they are liable to bend. The soldered connections near the feedpoint may be damaged. After excessive mechanical stress or overheating, check the impedance characteristics to ensure that the internal matching network is not affected.

After long term use with 40W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

Certificate No: CD835V3-1023\_Aug20

Page 3 of 5





## Impedance Measurement Plot

ile <u>V</u> iew	Channel	Sw <u>e</u> ep	Calibration	Trace	<u>S</u> cale	M <u>a</u> rker	S <u>v</u> stem	Window	Help		Sec. 2
10.00 5.00	dB S11								1:	800.000000 MHz 835.000000 MHz	-17.083 dB
0.00									3:	835.000000 MHz 880.000000 MHz	21.880 d8 -16.480 d8
								-	-4.	900.00000 MH2	-16.507 88
-5.00		1			-			1	5	345 000800 MHz	-25 407 dB
-10.00		-				1					
-15.00 🔉						1					
-20.00			1.			À	100				
						12	1.	1/			
-25.00							-	<u>×</u>			
-30.00		-						5			
-35.00			-								
40.00	Ch1Avg=	20									
UNT: SI	art 335.000 h	MHZ								Chan	
-										Stop	1.33500 GHz
									1:	800.000000 MHz	
					K	6		<u>}</u>		800.000000 MHz 21.000 pF	41.325 0 -3.4734 0
					12	<	R		1: ≥2:	800.000000 MHz 21.000 pF 835.000000 MHz	41.325 G -8.4734 G 52.791 G
					(1)	Ś	R			800.000000 MHz 21.000 pF 835.000000 MHz 982.35 pH	41.325 0 -8.4734 0 52.791 0 5.1539 0
					Å	K	R		>2:	800.000000 MHz 21.000 pF 835.000000 MHz 982.35 pH 860.00000 MHz 15.191 pF	41.325 0 -8.4734 0 52.791 0 5.1539 0 61.976 0
					Ő.	X			>2:	800.000000 MHz 21.000 pF 835.00000 MHz 962.35 pH 880.000000 MHz 15.191 pF 900.000000 MHz	41.325 0 -3.4734 0 52.791 0 5.1539 0 61.976 0 -11.905 0 53.135 0
					Å	X			> 2: 3: 4:	800.000000 MHz 21.000 pF 835.000000 MHz 982.35 pH 880.000000 MHz 15.191 pF 900.000000 MHz 11.581 pF	41.325 G -9.4734 G 52.791 G 5.1539 G 61.976 G -11.905 G 53.135 G -15.269 G
					4				>2: 3:	800.000000 MHz 21.000 pF 835.000000 MHz 982.35 pH 880.000000 MHz 15.191 pF 900.000000 MHz 11.581 pF 945.000000 MHz	41.325 ( -9.4734 ( 52.791 ( 5.1539 ( 61.976 ( -11.905 ( 53.135 ( -15.269 ( 46.243 (
					<u> </u>	X			> 2: 3: 4:	800.000000 MHz 21.000 pF 835.000000 MHz 982.35 pH 880.000000 MHz 15.191 pF 900.000000 MHz 11.581 pF	41.325 ( -9.4734 ( 52.791 ( 5.1539 ( 61.976 ( -11.905 ( 53.135 ( -15.269 ( 46.243 (
						XX			> 2: 3: 4:	800.000000 MHz 21.000 pF 835.000000 MHz 982.35 pH 880.000000 MHz 15.191 pF 900.000000 MHz 11.581 pF 945.000000 MHz	41.325 G -9.4734 G 52.791 G 5.1539 G 61.976 G -11.905 G 53.135 G -15.269 G 46.243 G
						X			> 2: 3: 4:	800.000000 MHz 21.000 pF 835.000000 MHz 982.35 pH 880.000000 MHz 15.191 pF 900.000000 MHz 11.581 pF 945.000000 MHz	41.325 ( -9.4734 ( 52.791 ( 5.1539 ( 61.976 ( -11.905 ( 53.135 ( -15.269 ( 46.243 (
						X			> 2: 3: 4:	800.000000 MHz 21.000 pF 835.000000 MHz 982.35 pH 880.000000 MHz 15.191 pF 900.000000 MHz 11.581 pF 945.000000 MHz	41.325 G -9.4734 G 52.791 G 5.1539 G 61.976 G -11.905 G 53.135 G -15.269 G 46.243 G
	Ch 1 Avg =								> 2: 3: 4:	800.00000 MHz 21.000 pF 835.000000 MHz 982.35 pH 880.00000 MHz 15.191 pF 900.000000 MHz 11.581 pF 945.000000 MHz 597.63 pH	41.325 0 -3.4734 0 52.791 0 5.1539 0 61.376 0 -11.905 0 53.135 0 -15.269 0 46.243 0 3.5485 0
Ch1: St	Ch 1 Avg = art 335.000 h		_						> 2: 3: 4:	800.00000 MHz 21.000 pF 835.000000 MHz 982.35 pH 880.00000 MHz 15.191 pF 900.000000 MHz 11.581 pF 945.000000 MHz 597.63 pH	1.33500 GH: 41.325 G -9.4734 G 5.1536 G -11.305 G -11.305 G -15.263 G 46.243 G 3.5485 G

Certificate No: CD835V3-1023\_Aug20

Page 4 of 5





#### **DASY5 E-field Result**

Date: 18.08.2020

Test Laboratory: SPEAG Lab2

## DUT: HAC-Dipole 835 MHz; Type: CD835V3; Serial: CD835V3 - SN: 1023

 $\begin{array}{l} \mbox{Communication System: UID 0 - CW ; Frequency: 835 MHz} \\ \mbox{Medium parameters used: } \sigma = 0 \ S/m, \ \epsilon_r = 1; \ \rho = 0 \ kg/m^3 \\ \mbox{Phantom section: } RF \ Section \\ \mbox{Measurement Standard: } DASY5 \ (IEEE/IEC/ANSI \ C63.19-2011) \\ \end{array}$ 

DASY52 Configuration:


- Probe: EF3DV3 SN4013; ConvF(1, 1, 1) @ 835 MHz; Calibrated: 31.12.2019
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn781; Calibrated: 27.12.2019
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA; Serial: 1070
- DASY52 52.10.4(1527); SEMCAD X 14.6.14(7483)

Dipole E-Field measurement @ 835MHz/E-Scan - 835MHz d=15mm/Hearing Aid Compatibility Test (41x361x1): Interpolated grid: dx=0.5000 mm, dy=0.5000 mm Device Reference Point: 0, 0, -6.3 mm

Reference Value = 128.0 V/m; Power Drift = -0.02 dBApplied MIF = 0.00 dBRF audio interference level = 40.64 dBV/mEmission category: M3

MIF scaled E-field

Grid 1 <b>M3</b>	Grid 2 M3	Grid 3 M3
40.19 dBV/m	40.64 dBV/m	40.62 dBV/m
Grid 4 <b>M4</b>	Grid 5 M4	Grid 6 M4
35.3 dBV/m	35.62 dBV/m	35.6 dBV/m
Grid 7 M3	Grid 8 M3	Grid 9 M3
40.33 dBV/m	40.61 dBV/m	40.55 dBV/m



Certificate No: CD835V3-1023 Aug20

Page 5 of 5





Schweizerischer Kalibrierdienst

Service suisse d'étalonnage

S

## Dipole 1880 MHz

**Calibration Laboratory of** 

Schmid & Partner

С ac-MR **Engineering AG** Servizio svizzero di taratura S Zeughausstrasse 43, 8004 Zurich, Switzerland Swiss Calibration Service Accredited by the Swiss Accreditation Service (SAS) Accreditation No.: SCS 0108 The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates Client CTTL-BJ (Auden) Certificate No: CD1880V3-1018\_Aug20 **CALIBRATION CERTIFICATE** Object CD1880V3 - SN: 1018 QA CAL-20.v7 Calibration procedure(s) Calibration Procedure for Validation Sources in air August 18, 2020 Calibration date: This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate. All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%. Calibration Equipment used (M&TE critical for calibration) Primary Standards ID # Cal Date (Certificate No.) Scheduled Calibration Power meter NRP SN: 104778 01-Apr-20 (No. 217-03100/03101) Apr-21 Power sensor NRP-Z91 SN: 103244 01-Apr-20 (No. 217-03100) Apr-21 Power sensor NRP-791 SN: 103245 01-Apr-20 (No. 217-03101) Apr-21 Reference 20 dB Attenuator SN: BH9394 (20k) 31-Mar-20 (No. 217-03106) Apr-21 Type-N mismatch combination SN: 310982 / 06327 31-Mar-20 (No. 217-03104) Apr-21 Probe EF3DV3 SN: 4013 31-Dec-19 (No. EF3-4013 Dec19) Dec-20 DAE4 SN: 781 27-Dec-19 (No. DAE4-781\_Dec19) Dec-20 Secondary Standards ID # Check Date (in house) Scheduled Check Power meter Agilent 4419B SN: GB42420191 09-Oct-09 (in house check Oct-17) In house check: Oct-20 Power sensor HP E4412A SN: US38485102 05-Jan-10 (in house check Oct-17) In house check: Oct-20 Power sensor HP 8482A SN: US37295597 09-Oct-09 (in house check Oct-17) In house check: Oct-20 RF generator R&S SMT-06 SN: 837633/005 10-Jan-19 (in house check Jan-19) In house check: Oct-20 Network Analyzer Agilent E8358A SN: US41080477 31-Mar-14 (in house check Oct-19) In house check: Oct-20 Name Function Signature Calibrated by: Leif Klysner Laboratory Technician Approved by: Katja Pokovic Technical Manager Issued: August 18, 2020 This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

Certificate No: CD1880V3-1018\_Aug20

Page 1 of 5