

Assembled in Canada / Assemblé au Canada

OTODATA
Battery Operated Wireless Remote
Tank Level Monitor

MODEL # TM5040

SERIAL #

20000003



Install according to manual GRA- 0089- EN_001

Battery rated 3.6Vdc/19Ah



Class I, Div 2, Groups C & D, T3
Class I, Zone 2, Group IIB T3
- 40°C ≤ Ta ≤ + 60°C

HVIN: C024 v2
FCC ID: 2ADQFM T4ADS
IC: 12649A- M T4ADS

Apparatus also contains:
FCC ID: XMR202007BG95M6
IC: 10224A- 202007BG95M6

This device provides non- incendeive circuits to cable sensor assembly P/N :

Ce dispositif comporte des circuits non- incendiaires à l'ensemble du capteur filaire no. de pièce :
ACDH45 OR/OU HE- LEAD- CIRC- 6 OR/OU HE- LEAD- CIRC- 6- RA OR/OU DH- LEAD- CIRC- 6

Potential Electrostatic Charging Hazard. See Instructions.

Danger Potentiel De Charges Électrostatiques - Voir Instructions.

VA00

Facility D

Label Rev 0 / Q4- 23