

Moment Inc

MPE ASSESSMENT REPORT

Report Type:

FCC MPE assessment report

Model:

810-01040

REPORT NUMBER:

221200414SHA-003

ISSUE DATE:

January 03, 2023

DOCUMENT CONTROL NUMBER:

TTRFFCCMPE-01_V1 © 2018 Intertek



Applicant: Moment Inc
Address of Applicant: 55 South Atlantic Street Suite 204, Seattle, United States

Manufacturer: Moment Inc
Address of Manufacturer: 55 South Atlantic Street Suite 204, Seattle, United States


Factory: Zhongshan Zen Factory Ltd.
Address of Factory: 6th.Industrial Area, Nanlang Town, Zhongshan City,
Guangdong, China

FCC ID: 2AEZQ810-01040

SUMMARY:

The equipment complies with the requirements according to the following standard(s) or Specification:

FCC PART 1 SECTION 1.1310

PREPARED BY:**REVIEWED BY:**

Project Engineer
Justin Wu

Reviewer
Wakeyou Wang

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Revision History

Report No.	Version	Description	Issued Date
221200414SHA-003	Rev. 01	Initial issue of report	January 03, 2023

1 GENERAL INFORMATION

1.1 Description of Equipment Under Test (EUT)

Product name:	LAB22 Magnetic Phone Stand with Dual Wireless Charging
Type/Model:	810-01040
Description of EUT:	LAB22 Magnetic Phone Stand with Dual Wireless Charging
Rating:	Input: DC12V/1.67A Output:12.5W
Category of EUT:	Class B
EUT type:	<input checked="" type="checkbox"/> Table top <input type="checkbox"/> Floor standing
Operating Frequency range:	127.8 kHz
Antenna Type:	Coil antenna
Sample received date:	November 24, 2022
Date of test:	December 2, 2022 to December 2, 2022

1.2 Description of Test Facility

Name:	Intertek Testing Services Shanghai
Address:	Building 86, No. 1198 Qinzhou Road (North), Shanghai 200233, P.R. China
Telephone:	86 21 61278200
Telefax:	86 21 54262353

The test facility is recognized, certified, or accredited by these organizations:	CNAS Accreditation Lab Registration No. CNAS L0139
	FCC Accredited Lab Designation Number: CN1175
	IC Registration Lab CAB identifier.: CN0051
	VCCI Registration Lab Registration No.: R-14243, G-10845, C-14723, T-12252
	A2LA Accreditation Lab Certificate Number: 3309.02

All tests were sub-contracted.

Shenzhen UnionTrust Quality and Technology Co., Ltd.

Address: Unit D/E of 9/F and 16/F, Block A, Building 6, Baoneng Science and Technology Park, Longhua District, Shenzhen, China 518109

Telephone: +86 (0) 755 2823 0888

Fax: +86 (0) 755 2823 0886

All tests were sub-contracted at Shenzhen UnionTrust Quality and Technology Co., Ltd, and conducted by Kieron Luo

Reviewed and approved by Wakeyou Wang from Intertek Testing Services Shanghai.

The test facility is recognized, certified, or accredited by the following organizations:

CNAS-Lab Code: L9069

The measuring equipment utilized to perform the tests documented in this report has been calibrated once a year or in accordance with the manufacturer's recommendations, and is traceable under the ISO/IEC/EN 17025 to international or national standards. Equipment has been calibrated by accredited calibration laboratories.

IC-Registration No.: 21600-1

TEST REPORT

The 3m Semi-anechoic chamber of Shenzhen UnionTrust Quality and Technology Co., Ltd. has been registered by Certification and Engineering Bureau of Industry Canada for radio equipment testing with Registration No.: 21600-1.

A2LA-Lab Certificate No.: 4312.01

Shenzhen UnionTrust Quality and Technology Co., Ltd. has been accredited by A2LA for technical competence in the field of electrical testing, and proved to be in compliance with ISO/IEC 17025: 2005 General Requirements for the Competence of Testing and Calibration Laboratories and any additional program requirements in the identified field of testing.

FCC Accredited Lab.

Designation Number: CN1194

Test Firm Registration Number: 259480

2 TEST SPECIFICATIONS

2.1 Standards or specification

FCC PART 1 SECTION 1.1310

KDB 680106 D01 RF Exposure Wireless Charging App v03

2.2 Mode of operation during the test

Within this test report, EUT was tested under all modes and tested under its rating voltage and frequency. Other voltage and frequency are specified if used. The test mode is as follows:

Test Mode 1: Wireless charging mode with Mobile phone (7.5W)

Test Mode 2: Wireless charging mode with watch(5W)

Test Mode 3: Wireless charging mode with Mobile phone (7.5W) + Wireless charging mode with watch(5W)

Test Mode 4: Standby

2.3 Test peripherals list

Item No	Description	Band and Model	S/No	rating
1	Mobile phone	Apple, iphone12	N/A	15W
2	Adapter	BULL, GNV-AU1652	N/A	AC100-240V 50/60Hz 1.5A
3	Apple watches	Apple, WR-50M	N/A	5W

2.4 Support Cable list

Item No	Description	Length (m)	Cable Type
1	Type-C Cable	1.5	NA

2.5 Record of climatic conditions

Test Item	Temperature (°C)	Relative Humidity (%)	Pressure (kPa)
RF Exposure	26.5	56	101.8

2.6 Instrument list

Test Equipment List						
Used	Equipment	Manufacturer	Model No.	Serial Number	Cal. date (mm dd, yyyy)	Cal. Due date (mm dd, yyyy)
<input checked="" type="checkbox"/>	Probe	STT	EHP-50F	SZ186-04	July 21, 2022	July 20, 2023
<input checked="" type="checkbox"/>	Probe holder	STT	TR-01	N/A	N/A	N/A
<input checked="" type="checkbox"/>	Optical fiber line	STT	L=5M	N/A	N/A	N/A

2.7 Measurement uncertainty

The measurement uncertainty represents an expanded uncertainty expressed at approximately the 95% confidence level using a coverage factor of k=2.

Measurement	Expanded Uncertainty (k=2)
Electromagnetic field (9kHz-30MHz)	±5%
Magnetic field measurement (9kHz-30MHz)	±7%

3 MPE Assessment

Test result: Pass

3.1 MPE Assessment Limit

According to 47 CFR §1.1310, system operating under the provisions of this section shall be operating in a manner that the public is not exposed to radio frequency energy level in excess limit for maximum permissible exposure.

Limits for Occupational / Controlled Exposure

Frequency range (MHz)	Electric Field Strength (E) (V/m)	Magnetic Field Strength (H) (A/m)	Power Density (S) (mW/cm ²)	Averaging Times E ² , H ² or S (minutes)
0.3-3.0	614	1.63	(100)*	6
3.0-30	1842/f	4.89/f	(900/f)*	6
30-300	61.4	0.163	1.0	6
300-1500	/	/	F/300	6
1500-100000	/	/	5	6

Limits for General Population/Uncontrolled Exposure

Frequency range (MHz)	Electric Field Strength (E) (V/m)	Magnetic Field Strength (H) (A/m)	Power Density (S) (mW/cm ²)	Averaging Times E ² , H ² or S (minutes)
0.3-1.34	614	1.63	*100	30
1.34-30	824/f	2.19/f	*180/f ²	30
30-300	27.5	0.073	0.2	30
300-1,500	/	/	f/1500	30
1,500-100,000	/	/	1.0	30

Note: f = frequency in MHz: * = Plane-wave equivalents power density.

3.2 Testing Procedure


Enabled the EUT to transmit and receive data continue

- The field strength of both E-field and H-field was measured at 15 cm surrounding the device and 20 cm above the top surface using the equipment list above for determining compliance with the MPE requirements of FCC Part 1.1310.
- The RF power density was measured with the battery at 3 different charge conditions: battery at less than 1 % , battery at 50% charger, battery at 99% charger.
- Maximum E-field and H-field measurements were made 15cm from each side of the EUT. Along the side of the EUT and still 15cm away from the edge of the EU T, the field probes were positioned at the location where there is maximum field strength. The maximum E-field and H-field is reported below.
- This device uses a wireless charging circuit for power transfer operating at the frequency of X

TEST REPORT

kHz. Thus, the 300 kHz limits were used: E-field Limit = 614 (V/m); H-field limit = 1.63 (A/m).

3.3 Test setup



Note

The RF exposure test is performed in the shield room

The test distance is between the edge of the charger and the geometric center of probe

The aggregate at 15 cm surrounding the device and 20 cm above the top surface from all simultaneous transmitting coils are demonstrated.

3.4 TEST DATA

Worst case Test Mode 3

Test result of E-Field Strength

Test Position	Test distance (cm)	Test result (V/m)			Limit (V/m)	Result (Pass/Fail)
		<1% Battery status	<50% Battery status	<99% Battery status		
A: Right	15	4.8707	4.1591	3.1265	614	Pass
B: Left	15	5.4275	4.6345	3.4839	614	Pass
C: Front	15	4.7031	4.0164	3.0189	614	Pass
D: Back	15	5.8101	4.9612	3.7295	614	Pass
E: Top	20	3.2775	2.7987	2.1038	614	Pass
F: Bottom	15	1.8682	1.5953	1.1992	614	Pass

TEST REPORT

Test result of Magnetic Field Strength

Test Position	Test distance (cm)	Test result (A/m)			Limit (A/m)	Result (Pass/Fail)
		<1% Battery status	<50% Battery status	<99% Battery status		
A: Right	15	0.0778	0.0664	0.0499	1.63	Pass
B: Left	15	0.0411	0.0351	0.0264	1.63	Pass
C: Front	15	0.0299	0.0255	0.0192	1.63	Pass
D: Back	15	0.0402	0.0343	0.0258	1.63	Pass
E: Top	20	0.0093	0.0079	0.0069	1.63	Pass
F: Bottom	15	0.0063	0.0054	0.0042	1.63	Pass

Note:

1. Test with 15cm distance from the center of the probe(s) to the edge of the device, 20 cm for top (Position E) test
2. All simultaneous transmitting coils are demonstrated to be less than 50% of the MPE limit.
3. All possible modes of operation were investigated, only the worst-case test data reported.

TEST REPORT

Equipment Approval Considerations

Requirements of section 5 of KDB680106 D01 RF Exposure Wireless Charging App v03	Yes/No	Description
Power transfer frequency is less than 1 MHz.	Yes	The device operates in the frequency 127.8kHz
Output power from each primary coil is less than or equal to 15 watts.	Yes	The maximum output power of the primary coil is 7.5W
The system may consist of more than one source primary coils, charging one or more clients. If more than one primary coil is present, the coil pairs may be powered on at the same time.	Yes	The transmission system consists of two coils, it can work simultaneously.
Client device is placed directly in contact with the transmitter.	Yes	Client device is placed directly in contact with the transmitter
Mobile exposure conditions only (portable exposure conditions are not covered by this exclusion).	Yes	Product is not a portable device.
The aggregate H-field strengths anywhere at or beyond 15 cm surrounding the device, and 20 cm away from the surface from all coils that by design can simultaneously transmit, and while those coils are simultaneously energized, are demonstrated to be less than 50% of the applicable MPE limit.	Yes	See the test data in section 2.4 of this report

TEST REPORT**Appendix I: Photograph of test setup**

See test photos attached in Appendix 1 for the actual connections between Product and support equipment.

Appendix II: Photograph of equipment under test

Refer to Appendix 2 for EUT external and internal photos.

***** END *****