

Appendix B

Detailed Test Results

LTE Band 2 for Limbs
LTE Band 4 for Limbs
LTE Band 5 for Limbs
LTE Band 7 for Limbs
LTE Band 12 for Limbs
LTE Band 13 for Limbs
LTE Band 14 for Limbs
LTE Band 25 for Limbs
LTE Band 26 for Limbs
LTE Band 30 for Limbs
LTE Band 41 for Limbs
LTE Band 48 for Limbs
LTE Band 66 for Limbs
LTE Band 71 for Limbs
WIFI 2.4G for Limbs
WIFI 5G for Limbs



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

GL-XE2000 LTE Band 2 20M QPSK 1RB50 19100CH Back side 15mm**GL-XE2000**

Communication System: Band 2; Frequency: 1900.000

Medium: Head Simulating Liquid. Medium parameters used: $f=1900.000$ MHz; $\sigma=1.36$ S/m; $\epsilon_r=40.3$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(7.82, 7.76, 7.85); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (90.0 mm x 240.0 mm): Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 1.16 W/kg; SAR (10g) = 0.671 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 8.0 mm x 8.0 mm x 5.0 mm

Power Drift = 0.03 dB

SAR (1g) = 1.22 W/kg; SAR (10g) = 0.738 W/kg;



GL-XE2000 LTE Band 4 20M QPSK 1RB50 20175CH Back side 15mm**GL-XE2000**

Communication System: Band 4; Frequency: 1732.500

Medium: Head Simulating Liquid. Medium parameters used: $f=1732.500$ MHz; $\sigma=1.33$ S/m; $\epsilon_r=40.4$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(8.11, 8.04, 8.17); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (90.0 mm x 240.0 mm): Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 1.39 W/kg; SAR (10g) = 0.827 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 8.0 mm x 8.0 mm x 5.0 mm

Power Drift = -0.01 dB

SAR (1g) = 1.41 W/kg; SAR (10g) = 0.880 W/kg;



GL-XE2000 LTE Band 5 10M QPSK 1RB0 20525CH Front side 15mm**GL-XE2000**

Communication System: Band 5; Frequency: 836.500

Medium: Head Simulating Liquid. Medium parameters used: $f=836.500$ MHz; $\sigma=0.912$ S/m; $\epsilon_r=43.3$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(9.3, 9.34, 9.27); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (90.0 mm x 240.0 mm): Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 0.726 W/kg; SAR (10g) = 0.497 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 8.0 mm x 8.0 mm x 5.0 mm

Power Drift = 0.02 dB

SAR (1g) = 0.758 W/kg; SAR (10g) = 0.534 W/kg;



GL-XE2000 LTE Band 7 20M QPSK 1RB99 21100CH Back side 15mm**GL-XE2000**

Communication System: Band 7; Frequency: 2535.000

Medium: Head Simulating Liquid. Medium parameters used: $f=2535.000$ MHz; $\sigma=1.89$ S/m; $\epsilon_r=39.9$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(7.31, 7.23, 7.33); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (96.0 mm x 240.0 mm): Measurement Grid: 12.0 mm x 12.0 mm

SAR (1g) = 0.897 W/kg; SAR (10g) = 0.452 W/kg;

Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm): Measurement Grid: 5.0 mm x 5.0 mm x 5.0 mm

Power Drift = 0.01 dB

SAR (1g) = 0.932 W/kg; SAR (10g) = 0.490 W/kg;



GL-XE2000 LTE Band 12 10M QPSK 1RB0 23060CH Back side 15mm**GL-XE2000**

Communication System: Band 12; Frequency: 704.000

Medium: Head Simulating Liquid. Medium parameters used: $f = 704.000$ MHz; $\sigma = 0.825$ S/m; $\epsilon_r = 44.1$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(9.75, 9.68, 9.67); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (90.0 mm x 240.0 mm): Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 0.807 W/kg; SAR (10g) = 0.555 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 8.0 mm x 8.0 mm x 5.0 mm

Power Drift = 0.02 dB

SAR (1g) = 0.816 W/kg; SAR (10g) = 0.574 W/kg;



GL-XE2000 LTE Band 13 10M QPSK 1RB25 23230CH Back side 15mm**GL-XE2000**

Communication System: Band 13; Frequency: 782.000

Medium: Head Simulating Liquid. Medium parameters used: $f = 782.000$ MHz; $\sigma = 0.875$ S/m; $\epsilon_r = 43.7$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(9.75, 9.68, 9.67); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (90.0 mm x 240.0 mm): Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 0.761 W/kg; SAR (10g) = 0.522 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 8.0 mm x 8.0 mm x 5.0 mm

Power Drift = -0.02 dB

SAR (1g) = 0.776 W/kg; SAR (10g) = 0.548 W/kg;



GL-XE2000 LTE Band 14 10M QPSK 1RB0 23330CH Back side 15mm**GL-XE2000**

Communication System: Band 14; Frequency: 793.000

Medium: Head Simulating Liquid. Medium parameters used: $f = 793.000$ MHz; $\sigma = 0.881$ S/m; $\epsilon_r = 43.6$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(9.75, 9.68, 9.67); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (90.0 mm x 240.0 mm): Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 0.776 W/kg; SAR (10g) = 0.527 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 8.0 mm x 8.0 mm x 5.0 mm

Power Drift = -0.02 dB

SAR (1g) = 0.796 W/kg; SAR (10g) = 0.559 W/kg;



GL-XE2000 LTE Band 25 20M QPSK 1RB50 26365CH Back side 15mm**GL-XE2000**

Communication System: Band 25; Frequency: 1882.500

Medium: Head Simulating Liquid. Medium parameters used: $f=1882.500$ MHz; $\sigma=1.36$ S/m; $\epsilon_r=40.3$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(7.82, 7.76, 7.85); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (90.0 mm x 240.0 mm): Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 1.01 W/kg; SAR (10g) = 0.579 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 8.0 mm x 8.0 mm x 5.0 mm

Power Drift = 0.00 dB

SAR (1g) = 1.05 W/kg; SAR (10g) = 0.638 W/kg;



GL-XE2000 LTE Band 26 15M QPSK 1RB0 26765CH Front side 15mm**GL-XE2000**

Communication System: Band 26; Frequency: 821.500

Medium: Head Simulating Liquid. Medium parameters used: $f=821.500$ MHz; $\sigma=0.901$ S/m; $\epsilon_r=43.4$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(9.3, 9.34, 9.27); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (90.0 mm x 240.0 mm): Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 0.736 W/kg; SAR (10g) = 0.499 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 8.0 mm x 8.0 mm x 5.0 mm

Power Drift = -0.03 dB

SAR (1g) = 0.757 W/kg; SAR (10g) = 0.533 W/kg;



GL-XE2000 LTE Band 30 10M QPSK 1RB0 27710CH Back side 15mm**GL-XE2000**

Communication System: Band 30; Frequency: 2310.000

Medium: Head Simulating Liquid. Medium parameters used: $f=2310.000$ MHz; $\sigma=1.65$ S/m; $\epsilon_r=40.6$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(7.56, 7.47, 7.57); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (96.0 mm x 240.0 mm): Measurement Grid: 12.0 mm x 12.0 mm

SAR (1g) = 0.996 W/kg; SAR (10g) = 0.529 W/kg;

Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm): Measurement Grid: 5.0 mm x 5.0 mm x 5.0 mm

Power Drift = -0.01 dB

SAR (1g) = 1.04 W/kg; SAR (10g) = 0.580 W/kg;



GL-XE2000 LTE Band 41 20M QPSK 1RB0 41055CH Back side 15mm**GL-XE2000**

Communication System: Band 41; Frequency: 2636.500

Medium: Head Simulating Liquid. Medium parameters used: $f = 2636.500$ MHz; $\sigma = 2.00$ S/m; $\epsilon_r = 39.5$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(7.31, 7.23, 7.33); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (96.0 mm x 240.0 mm): Measurement Grid: 12.0 mm x 12.0 mm

SAR (1g) = 0.788 W/kg; SAR (10g) = 0.395 W/kg;

Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm): Measurement Grid: 5.0 mm x 5.0 mm x 5.0 mm

Power Drift = -0.04 dB

SAR (1g) = 0.815 W/kg; SAR (10g) = 0.425 W/kg;



GL-XE2000 LTE Band 48 20M QPSK 1RB0 56640CH Back side side 15mm**GL-XE2000**

Communication System: Band 48; Frequency: 3690.000

Medium: Head Simulating Liquid. Medium parameters used: $f=3690.000$ MHz; $\sigma=3.04$ S/m; $\epsilon_r=37.1$

DASY8 Configuration:

- Probe: EX3DV4 - SN7636; ConvF(6.99, 6.99, 6.99); Calibrated: 2024-07-17
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (96.0 mm x 240.0 mm): Measurement Grid: 12.0 mm x 12.0 mm

SAR (1g) = 0.435 W/kg; SAR (10g) = 0.199 W/kg;

Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm): Measurement Grid: 5.0 mm x 5.0 mm x 5.0 mm

Power Drift = 0.02 dB

SAR (1g) = 0.446 W/kg; SAR (10g) = 0.202 W/kg;



GL-XE2000 LTE Band 66 20M QPSK 1RB99 132322CH Back side 15mm**GL-XE2000**

Communication System: Band 66; Frequency: 1745.000

Medium: Head Simulating Liquid. Medium parameters used: $f=1745.000$ MHz; $\sigma=1.34$ S/m; $\epsilon_r=40.4$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(8.11, 8.04, 8.17); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (90.0 mm x 240.0 mm): Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 1.16 W/kg; SAR (10g) = 0.688 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 8.0 mm x 8.0 mm x 5.0 mm

Power Drift = -0.03 dB

SAR (1g) = 1.20 W/kg; SAR (10g) = 0.749 W/kg;



GL-XE2000 LTE Band 71 20M QPSK 1RB50 133322CH Front side 15mm**GL-XE2000**

Communication System: Band 71; Frequency: 683.000

Medium: Head Simulating Liquid. Medium parameters used: $f=683.000$ MHz; $\sigma=0.812$ S/m; $\epsilon_r=44.3$

DASY8 Configuration:

- Probe: EX3DV4 - SN7838; ConvF(9.75, 9.68, 9.67); Calibrated: 2023-09-11
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1803; Calibrated: 2024-08-08
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (90.0 mm x 240.0 mm): Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 0.631 W/kg; SAR (10g) = 0.435 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 8.0 mm x 8.0 mm x 5.0 mm

Power Drift = -0.02 dB

SAR (1g) = 0.644 W/kg; SAR (10g) = 0.456 W/kg;



GL-XE2000 WIFI 2.4G 802.11nHT40 6CH Front side 15mm-MIMO**GL-XE2000**

Communication System: WLAN 2.4GHz; Frequency: 2437.000

Medium: Head Simulating Liquid. Medium parameters used: $f=2437.000$ MHz; $\sigma=1.79$ S/m; $\epsilon_r=40.5$

DASY8 Configuration:

- Probe: EX3DV4 - SN7636; ConvF(7.95, 7.95, 7.95); Calibrated: 2024-07-17
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1267; Calibrated: 2024-01-03
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2156
- Measurement Software: cDASY8 V16.2.4.2524


Area Scan (144.0 mm x 168.0 mm): Measurement Grid: 12.0 mm x 12.0 mm

SAR (1g) = 0.826 W/kg; SAR (10g) = 0.460 W/kg;

Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm): Measurement Grid: 5.0 mm x 5.0 mm x 5.0 mm

Power Drift = -0.02 dB

SAR (1g) = 0.841 W/kg; SAR (10g) = 0.49 W/kg;



GL-XE2000 WIFI 5G 802.11ac VHT80 155CH Front side 15mm-MIMO**GL-XE2000**

Communication System: WLAN 5GHz; Frequency: 5775.000

Medium: Head Simulating Liquid. Medium parameters used: $f= 5775.000$ MHz; $\sigma= 5.51$ S/m; $\epsilon_r = 35.7$

DASY8 Configuration:

- Probe: EX3DV4 - SN7636; ConvF(5.16, 5.16, 5.16); Calibrated: 2024-07-17
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1267; Calibrated: 2024-01-03
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2156
- Measurement Software: cDASY8 V16.2.4.2524

Area Scan (140.0 mm x 180.0 mm): Measurement Grid: 10.0 mm x 10.0 mm

SAR (1g) = 1.68 W/kg; SAR (10g) = 0.724 W/kg;

Zoom Scan (24.0 mm x 24.0 mm x 22.0 mm): Measurement Grid: 4.0 mm x 4.0 mm x 2.0 mm

Power Drift = -0.06 dB

SAR (1g) = 1.67 W/kg; SAR (10g) = 0.74 W/kg;

