

## System Check\_Head\_13MHz

**DUT: CLA13 - SN:1020**

Communication System: ; Frequency: 13.000

Medium: HSL. Medium parameters used:  $f= 13.000$  MHz;  $\sigma= 0.757$  S/m;  $\epsilon_r = 53.7$

Ambient Temperature: 23.4°C; Liquid Temperature: 22.8°C

DASY6 Configuration:

- Probe: EX3DV4 - SN7764; ConvF(15.05, 15.05, 15.05); Calibrated: 2023-10-05
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1650; Calibrated: 2023-09-13
- Phantom: ELI V8.0 (20deg probe tilt); Serial: 2134
- Measurement Software: cDASY6 V6.6.0.13926

**Area Scan (40.0 mm x 90.0 mm):** Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 0.136 W/kg; SAR (10g) = 0.098 W/kg;

**Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm):** Measurement Grid: 6.0 mm x 6.0 mm x 5.0 mm

Power Drift = 0.04 dB

SAR (1g) = 0.135 W/kg; SAR (10g) = 0.091 W/kg;

