

**Wi-Fi 5G U-NII-1&2A 11a Left Mode Middle 5mm**

Date/Time: 2023/2/14

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 5200$  MHz;  $\sigma = 4.688$  S/m;  $\epsilon_r = 35.754$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature: 21.4°C      Liquid Temperature: 20.3°C

Communication System: 5G-U-NII-1 5GHz;   Frequency: 5200 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(5.7, 5.7, 5.7) @ 5200 MHz

**Wi-Fi 5G U-NII-1&2A 11a Left Mode Middle 5mm/Area Scan (7x11x1):**

Measurement grid: dx=10mm, dy=10mm

Maximum value of SAR (measured) = 1.43 W/kg

**Wi-Fi 5G U-NII-1&2A 11a Left Mode Middle 5mm/Zoom Scan (7x7x7)/Cube 0:**

Measurement grid: dx=4mm, dy=4mm, dz=2mm

Reference Value = 15.34 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 2.73 W/kg

SAR(1 g) = 0.681 W/kg; SAR(10 g) = 0.236 W/kg

Maximum of SAR (measured) = 1.53 W/kg




Figure A.2-27 Wi-Fi 5G U-NII-1&amp;2A 11a Left Mode Middle 5mm

**Wi-Fi 5G U-NII-1&2A Left Mode High 0mm**

Date/Time: 2023/2/14

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 5180 \text{ MHz}$ ;  $\sigma = 4.665 \text{ S/m}$ ;  $\epsilon_r = 35.797$ ;  $\rho = 1000 \text{ kg/m}^3$ Ambient Temperature:  $21.4^\circ\text{C}$  Liquid Temperature:  $20.3^\circ\text{C}$ 

Communication System: 5G-U-NII-1 5GHz; Frequency: 5180 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(5.7, 5.7, 5.7) @ 5180 MHz

**Wi-Fi 5G U-NII-1&2A Left Mode High 0mm/Area Scan (7x17x1):**Measurement grid:  $dx=10\text{mm}$ ,  $dy=10\text{mm}$ 

Maximum value of SAR (measured) = 2.19 W/kg

**Wi-Fi 5G U-NII-1&2A Left Mode High 0mm/Zoom Scan (7x7x7)/Cube 0:**Measurement grid:  $dx=4\text{mm}$ ,  $dy=4\text{mm}$ ,  $dz=2\text{mm}$ 

Reference Value = 26.99 V/m; Power Drift = 0.09 dB

Peak SAR (extrapolated) = 6.22 W/kg

SAR(1 g) = 1.48 W/kg; SAR(10 g) = 0.446 W/kg

Maximum of SAR (measured) = 3.72 W/kg




Figure A.2-28 Wi-Fi 5G U-NII-1&amp;2A Left Mode High 0mm

**Wi-Fi 5G U-NII-2C 11a Left Mode High 5mm**

Date/Time: 2023/2/14

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 5700 \text{ MHz}$ ;  $\sigma = 5.272 \text{ S/m}$ ;  $\epsilon_r = 34.731$ ;  $\rho = 1000 \text{ kg/m}^3$ Ambient Temperature:  $21.4^\circ\text{C}$  Liquid Temperature:  $20.3^\circ\text{C}$ 

Communication System: 5G-U-NII-2C 5GHz; Frequency: 5700 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(5.13, 5.13, 5.13) @ 5700 MHz

**Wi-Fi 5G U-NII-2C 11a Left Mode High 5mm/Area Scan (7x17x1):**Measurement grid:  $dx=10\text{mm}$ ,  $dy=10\text{mm}$ 

Maximum value of SAR (measured) = 1.14 W/kg

**Wi-Fi 5G U-NII-2C 11a Left Mode High 5mm/Zoom Scan (7x7x7)/Cube 0:**Measurement grid:  $dx=4\text{mm}$ ,  $dy=4\text{mm}$ ,  $dz=4\text{mm}$ 

Reference Value = 13.65 V/m; Power Drift = 0.04 dB

Peak SAR (extrapolated) = 2.68 W/kg

SAR(1 g) = 0.595 W/kg; SAR(10 g) = 0.194 W/kg

Maximum of SAR (measured) = 1.45 W/kg




Figure A.2-29 Wi-Fi 5G U-NII-2C 11a Left Mode High 5mm

**Wi-Fi 5G U-NII-2C 11a Left Mode High 0mm**

Date/Time: 2023/2/14

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 5700 \text{ MHz}$ ;  $\sigma = 5.272 \text{ S/m}$ ;  $\epsilon_r = 34.731$ ;  $\rho = 1000 \text{ kg/m}^3$ Ambient Temperature:  $21.4^\circ\text{C}$  Liquid Temperature:  $20.3^\circ\text{C}$ 

Communication System: 5G-U-NII-2C 5GHz; Frequency: 5700 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(5.13, 5.13, 5.13) @ 5700 MHz

**Wi-Fi 5G U-NII-2C 11a Left Mode High 0mm/Area Scan (7x17x1):**Measurement grid:  $dx=10\text{mm}$ ,  $dy=10\text{mm}$ 

Maximum value of SAR (measured) = 2.30 W/kg

**Wi-Fi 5G U-NII-2C 11a Left Mode High 0mm/Zoom Scan (7x7x7)/Cube 0:**Measurement grid:  $dx=4\text{mm}$ ,  $dy=4\text{mm}$ ,  $dz=2\text{mm}$ 

Reference Value = 18.40 V/m; Power Drift = 0.03 dB

Peak SAR (extrapolated) = 7.07 W/kg

SAR(1 g) = 1.41 W/kg; SAR(10 g) = 0.376 W/kg

Maximum of SAR (measured) = 3.80 W/kg




Figure A.2-30 Wi-Fi 5G U-NII-2C 11a Left Mode High 0mm

**Wi-Fi 5G U-NII-3 11a Left Mode High 5mm**

Date/Time: 2023/2/15

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 5825$  MHz;  $\sigma = 5.412$  S/m;  $\epsilon_r = 34.499$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature: 21.4°C      Liquid Temperature: 20.3°C

Communication System: 5G-U-NII-3 5GHz;   Frequency: 5825 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(5.17, 5.17, 5.17) @ 5825 MHz

**Wi-Fi 5G U-NII-3 11a Left Mode High 5mm/Area Scan (7x17x1):**

Measurement grid: dx=10mm, dy=10mm

Maximum value of SAR (measured) = 1.50 W/kg

**Wi-Fi 5G U-NII-3 11a Left Mode High 5mm/Zoom Scan (7x7x7)/Cube 0:**

Measurement grid: dx=4mm, dy=4mm, dz=2mm

Reference Value = 13.32 V/m; Power Drift = 0.04 dB

Peak SAR (extrapolated) = 3.56 W/kg

SAR(1 g) = 0.762 W/kg; SAR(10 g) = 0.248 W/kg

Maximum of SAR (measured) = 1.92 W/kg




Figure A.2-31 Wi-Fi 5G U-NII-3 11a Left Mode High 5mm

**Wi-Fi 5G U-NII-3 11a Left Mode High 0mm**

Date/Time: 2023/2/15

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 5825 \text{ MHz}$ ;  $\sigma = 5.412 \text{ S/m}$ ;  $\epsilon_r = 34.499$ ;  $\rho = 1000 \text{ kg/m}^3$ Ambient Temperature:  $21.4^\circ\text{C}$  Liquid Temperature:  $20.3^\circ\text{C}$ 

Communication System: 5G-U-NII-3 5GHz; Frequency: 5825 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(5.17, 5.17, 5.17) @ 5825 MHz

**Wi-Fi 5G U-NII-3 11a Left Mode High 0mm/Area Scan (7x11x1):**Measurement grid:  $dx=10\text{mm}$ ,  $dy=10\text{mm}$ 

Maximum value of SAR (measured) = 3.03 W/kg

**Wi-Fi 5G U-NII-3 11a Left Mode High 0mm/Zoom Scan (7x7x7)/Cube 0:**Measurement grid:  $dx=4\text{mm}$ ,  $dy=4\text{mm}$ ,  $dz=2\text{mm}$ 

Reference Value = 18.55 V/m; Power Drift = 0.04 dB

Peak SAR (extrapolated) = 8.71 W/kg

SAR(1 g) = 1.69 W/kg; SAR(10 g) = 0.453 W/kg

Maximum of SAR (measured) = 4.70 W/kg




Figure A.2-32 Wi-Fi 5G U-NII-3 11a Left Mode High 0mm

## A.2 System Check Graph Results

### Head 750MHz

Date/Time: 2023/2/10

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 750 \text{ MHz}$ ;  $\sigma = 0.898 \text{ S/m}$ ;  $\epsilon_r = 42.846$ ;  $\rho = 1000 \text{ kg/m}^3$

Ambient Temperature:  $21.4^\circ\text{C}$  Liquid Temperature:  $20.2^\circ\text{C}$

Communication System: CW 900MHz; Frequency: 750 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(10.9, 10.9, 10.9) @ 750 MHz

#### System Check Head 750MHz/Area Scan (7x13x1):

Measurement grid:  $dx=15\text{mm}$ ,  $dy=15\text{mm}$

Maximum value of SAR (measured) = 2.39 W/kg

#### System Check Head 750MHz/Zoom Scan (7x7x7) (5x5x7)/Cube 0:

Measurement grid:  $dx=8\text{mm}$ ,  $dy=8\text{mm}$ ,  $dz=5\text{mm}$

Reference Value = 56.83 V/m; Power Drift = -0.09 dB

Peak SAR (extrapolated) = 3.11 W/kg

SAR(1 g) = 2.02 W/kg; SAR(10 g) = 1.34 W/kg

Maximum value of SAR (measured) = 2.72 W/kg




Figure A.2-1 Head 750MHz

**Head 835MHz**

Date/Time: 2023/2/10

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 835$  MHz;  $\sigma = 0.927$  S/m;  $\epsilon_r = 42.519$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature: 21.4°C      Liquid Temperature: 20.2°C

Communication System: CW 900MHz;   Frequency: 835 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(10.55, 10.55, 10.55) @ 835 MHz

**System Check Head 835MHz/Area Scan (7x13x1):**

Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (measured) = 2.86 W/kg

**System Check Head 835MHz/Zoom Scan (7x7x7) (5x5x7)/Cube 0:**

Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 63.11 V/m; Power Drift = -0.03 dB

Peak SAR (extrapolated) = 3.85 W/kg

SAR(1 g) = 2.43 W/kg; SAR(10 g) = 1.57 W/kg

Maximum value of SAR (measured) = 3.33 W/kg




Figure A.2-2 Head 835MHz

**Head 1750MHz**

Date/Time: 2023/2/11

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 1750 \text{ MHz}$ ;  $\sigma = 1.324 \text{ S/m}$ ;  $\epsilon_r = 38.81$ ;  $\rho = 1000 \text{ kg/m}^3$ Ambient Temperature:  $21.2^\circ\text{C}$  Liquid Temperature:  $20.0^\circ\text{C}$ 

Communication System: CW 1900MHz; Frequency: 1750 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(8.9, 8.9, 8.9) @ 1750 MHz

**System Check Head 1750MHz/Area Scan (8x7x1):**Measurement grid:  $dx=15\text{mm}$ ,  $dy=15\text{mm}$ 

Maximum value of SAR (measured) = 10.8 W/kg

**System Check Head 1750MHz/Zoom Scan (7x7x7) (7x7x7)/Cube 0:**Measurement grid:  $dx=8\text{mm}$ ,  $dy=8\text{mm}$ ,  $dz=5\text{mm}$ 

Reference Value = 99.41 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 16.6 W/kg

SAR(1 g) = 8.94 W/kg; SAR(10 g) = 4.75 W/kg

Maximum value of SAR (measured) = 13.8 W/kg




Figure A.2-3 Head 1750MHz

**Head 1900MHz**

Date/Time: 2023/2/12

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 1900 \text{ MHz}$ ;  $\sigma = 1.428 \text{ S/m}$ ;  $\epsilon_r = 38.937$ ;  $\rho = 1000 \text{ kg/m}^3$ Ambient Temperature:  $21.2^\circ\text{C}$  Liquid Temperature:  $20.0^\circ\text{C}$ 

Communication System: CW 1900MHz; Frequency: 1900 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(8.6, 8.6, 8.6) @ 1900 MHz

**System Check Head 1900MHz/Area Scan (8x7x1):**Measurement grid:  $dx=15\text{mm}$ ,  $dy=15\text{mm}$ 

Maximum value of SAR (measured) = 11.9 W/kg

**System Check Head 1900MHz/Zoom Scan (7x7x7) (7x7x7)/Cube 0:**Measurement grid:  $dx=8\text{mm}$ ,  $dy=8\text{mm}$ ,  $dz=5\text{mm}$ 

Reference Value = 102.5 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 18.9 W/kg

SAR(1 g) = 9.95 W/kg; SAR(10 g) = 5.14 W/kg

Maximum value of SAR (measured) = 15.6 W/kg




Figure A.2-4 Head 1900MHz

**Head 2450MHz**

Date/Time: 2023/2/13

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 2450$  MHz;  $\sigma = 1.815$  S/m;  $\epsilon_r = 38.554$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature: 21.4°C      Liquid Temperature: 20.1°C

Communication System: CW 2500MHz; Frequency: 2450 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(7.96, 7.96, 7.96) @ 2450 MHz

**System Check Head 2450MHz/Area Scan (8x8x1):**

Measurement grid: dx=12mm, dy=12mm

Maximum value of SAR (measured) = 19.3 W/kg

**System Check Head 2450MHz/Zoom Scan (7x7x7)/Cube 0:**

Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 113.3 V/m; Power Drift = -0.02 dB

Peak SAR (extrapolated) = 27.5 W/kg

SAR(1 g) = 13.1 W/kg; SAR(10 g) = 6.09 W/kg

Maximum value of SAR (measured) = 22.2 W/kg




Figure A.2-5 Head 2450MHz

**Head 2600MHz**

Date/Time: 2023/2/13

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 2600 \text{ MHz}$ ;  $\sigma = 1.936 \text{ S/m}$ ;  $\epsilon_r = 38.289$ ;  $\rho = 1000 \text{ kg/m}^3$ 

Ambient Temperature: 21.4°C      Liquid Temperature: 20.1°C

Communication System: CW 2450MHz; Frequency: 2600 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(7.73, 7.73, 7.73) @ 2600 MHz

**System Check Head 2600MHz/Area Scan (8x8x1):**Measurement grid:  $dx=12\text{mm}$ ,  $dy=12\text{mm}$ 

Maximum value of SAR (measured) = 20.2 W/kg

**System Check Head 2600MHz/Zoom Scan (7x7x7)/Cube 0:**Measurement grid:  $dx=5\text{mm}$ ,  $dy=5\text{mm}$ ,  $dz=5\text{mm}$ 

Reference Value = 111.5 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 29.2 W/kg

SAR(1 g) = 13.8 W/kg; SAR(10 g) = 6.2 W/kg

Maximum value of SAR (measured) = 23.3 W/kg




Figure A.2-6 Head 2600MHz

**Head 5200MHz**

Date/Time: 2023/2/14

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 5200 \text{ MHz}$ ;  $\sigma = 4.688 \text{ S/m}$ ;  $\epsilon_r = 35.754$ ;  $\rho = 1000 \text{ kg/m}^3$ 

Ambient Temperature: 21.0°C      Liquid Temperature: 20.0°C

Communication System: CW 5GHz;   Frequency: 5200 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(5.7, 5.7, 5.7) @ 5200 MHz

**System Cheek Head 5200MHz/Area Scan (10x10x1):**Measurement grid:  $dx=10\text{mm}$ ,  $dy=10\text{mm}$ 

Maximum value of SAR (measured) = 14.0 W/kg

**System Cheek Head 5200MHz/Zoom Scan (7x7x7)/Cube 0:**Measurement grid:  $dx=4\text{mm}$ ,  $dy=4\text{mm}$ ,  $dz=2\text{mm}$ 

Reference Value = 62.58 V/m; Power Drift = 0.04 dB

Peak SAR (extrapolated) = 30.3 W/kg

SAR(1 g) = 7.53 W/kg; SAR(10 g) = 2.16 W/kg

Maximum of SAR (measured) = 18.8 W/kg




Figure A.2-7 Head 5200MHz

**Head 5600MHz**

Date/Time: 2023/2/14

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 5600$  MHz;  $\sigma = 5.153$  S/m;  $\epsilon_r = 34.938$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Ambient Temperature: 21.0°C      Liquid Temperature: 20.0°C

Communication System: CW 5GHz;   Frequency: 5600 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7633ConvF(5.13, 5.13, 5.13) @ 5600 MHz

**System Check Head 5600MHz/Area Scan (10x10x1):**

Measurement grid: dx=10mm, dy=10mm

Maximum value of SAR (measured) = 16.0 W/kg

**System Check Head 5600MHz/Zoom Scan (7x7x7)/Cube 0:**

Measurement grid: dx=4mm, dy=4mm, dz=2mm

Reference Value = 66.99 V/m; Power Drift = 0.03 dB

Peak SAR (extrapolated) = 38.2 W/kg

SAR(1 g) = 8.34 W/kg; SAR(10 g) = 2.36 W/kg

Maximum of SAR (measured) = 21.9 W/kg




Figure A.2-8 Head 5600MHz

**Head 5800MHz**

Date/Time: 2023/2/15

Electronics: DAE4 Sn1244

Medium parameters used:  $f = 5800 \text{ MHz}$ ;  $\sigma = 5.383 \text{ S/m}$ ;  $\epsilon_r = 34.549$ ;  $\rho = 1000 \text{ kg/m}^3$ Ambient Temperature:  $21.4^\circ\text{C}$  Liquid Temperature:  $20.1^\circ\text{C}$ 

Communication System: CW 5G; Frequency: 5800 MHz; Duty Cycle: 1:1

Probe: EX3DV4 - SN7401ConvF(5.17, 5.17, 5.17) @ 5800 MHz

**System Check Head 5800MHz/Area Scan (10x10x1):**Measurement grid:  $dx=10\text{mm}$ ,  $dy=10\text{mm}$ 

Maximum value of SAR (measured) = 17.0 W/kg

**System Check Head 5800MHz/Zoom Scan (4x4x1.4mm, graded), dist=1.4mm (7x7x7)/Cube 0:**Measurement grid:  $dx=4\text{mm}$ ,  $dy=4\text{mm}$ ,  $dz=2\text{mm}$ 

Reference Value = 62.71 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 34.8 W/kg

SAR(1 g) = 7.61 W/kg; SAR(10 g) = 2.16 W/kg

Maximum value of SAR (measured) = 20.2 W/kg




Figure A.2-9 Head 5800MHz

## Annex B: Calibration Certificate



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2512 Fax: +86-10-62304633-2504  
E-mail: cttl@chinattl.com Http://www.chinattl.cn



Client : 3in

Certificate No: Z22-60063

## CALIBRATION CERTIFICATE

Object DAE4 - SN: 1244

Calibration Procedure(s) FF-Z11-002-01  
Calibration Procedure for the Data Acquisition Electronics  
(DAEx)


Calibration date: March 09, 2022

This calibration Certificate documents the traceability to national standards, which realize the physical units of measurements(SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature( $22\pm3$ )°C and humidity<70%.

## Calibration Equipment used (M&amp;TE critical for calibration)

Primary Standards	ID #	Cal Date(Calibrated by, Certificate No.)	Scheduled Calibration
Process Calibrator 753	1971018	15-Jun-21 (CTTL, No.J21X04465)	Jun-22

Calibrated by:	Name	Function	Signature
	Yu Zongying	SAR Test Engineer	
Reviewed by:	Lin Hao	SAR Test Engineer	
Approved by:	Qi Dianyuan	SAR Project Leader	

Issued: March 11, 2022

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

Certificate No: Z22-60063

Page 1 of 3



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2512 Fax: +86-10-62304633-2504  
E-mail: ctll@chinattl.com Http://www.chinattl.cn

**Glossary:**

- DAE data acquisition electronics  
Connector angle information used in DASY system to align probe sensor X to the robot coordinate system.

**Methods Applied and Interpretation of Parameters:**

- *DC Voltage Measurement*: Calibration Factor assessed for use in DASY system by comparison with a calibrated instrument traceable to national standards. The figure given corresponds to the full scale range of the voltmeter in the respective range.
- *Connector angle*: The angle of the connector is assessed measuring the angle mechanically by a tool inserted. Uncertainty is not required.
- The report provide only calibration results for DAE, it does not contain other performance test results.

Certificate No: Z22-60063

Page 2 of 3



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2512 Fax: +86-10-62304633-2504  
E-mail: ctfl@chinattl.com Http://www.chinattl.cn

#### DC Voltage Measurement

A/D - Converter Resolution nominal

High Range: 1LSB =  $6.1\mu V$ , full range = -100...+300 mV

Low Range: 1LSB =  $61nV$ , full range = -1.....+3mV

DASY measurement parameters: Auto Zero Time: 3 sec; Measuring time: 3 sec

Calibration Factors	X	Y	Z
High Range	$403.832 \pm 0.15\% (k=2)$	$403.556 \pm 0.15\% (k=2)$	$404.475 \pm 0.15\% (k=2)$
Low Range	$3.95285 \pm 0.7\% (k=2)$	$3.96959 \pm 0.7\% (k=2)$	$3.97877 \pm 0.7\% (k=2)$

#### Connector Angle

Connector Angle to be used in DASY system	$23.5^\circ \pm 1^\circ$
---	--------------------------

Certificate No: Z22-60063

Page 3 of 3



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2512 Fax: +86-10-62304633-2504  
E-mail: cttl@chinattl.com [Http://www.chinattl.cn](http://www.chinattl.cn)


Client **3in**
**Certificate No: Z22-60064**

## CALIBRATION CERTIFICATE

Object EX3DV4 - SN : 7633

Calibration Procedure(s) FF-Z11-004-02  
Calibration Procedures for Dosimetric E-field Probes


Calibration date: March 31, 2022

This calibration Certificate documents the traceability to national standards, which realize the physical units of measurements(SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature( $22\pm3$ )°C and humidity<70%.

### Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date(Calibrated by, Certificate No.)	Scheduled Calibration
Power Meter NRP2	101919	15-Jun-21(CTTL, No.J21X04466)	Jun-22
Power sensor NRP-Z91	101547	15-Jun-21(CTTL, No.J21X04466)	Jun-22
Power sensor NRP-Z91	101548	15-Jun-21(CTTL, No.J21X04466)	Jun-22
Reference 10dBAttenuator	18N50W-10dB	20-Jan-21(CTTL, No.J21X00486)	Jan-23
Reference 20dBAttenuator	18N50W-20dB	20-Jan-21(CTTL, No.J21X00485)	Jan-23
Reference Probe EX3DV4	SN 7307	26-May-21(SPEAG, No.EX3-7307_May21)	May-22
Reference Probe EX3DV4	SN 7464	26-Jan-22(SPEAG, No.EX3-7464_Jan22)	Jan-23
DAE4	SN 1555	20-Aug-21(SPEAG, No.DAE4-1555_Aug21/2)	Aug-22
Secondary Standards	ID #	Cal Date(Calibrated by, Certificate No.)	Scheduled Calibration
SignalGenerator MG3700A	6201052605	16-Jun-21(CTTL, No.J21X04467)	Jun-22
Network Analyzer E5071C	MY46110673	14-Jan-22(CTTL, No.J22X00406)	Jan-23

Name	Function	Signature
Calibrated by: Yu Zongying	SAR Test Engineer	
Reviewed by: Lin Hao	SAR Test Engineer	
Approved by: Qi Dianyuan	SAR Project Leader	

Issued: April 06, 2022

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

Certificate No: Z22-60064

Page 1 of 9



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2512 Fax: +86-10-62304633-2504  
E-mail: ctll@chinattl.com [Http://www.chinattl.cn](http://www.chinattl.cn)

**Glossary:**

TSL	tissue simulating liquid
NORMx,y,z	sensitivity in free space
ConvF	sensitivity in TSL / NORMx,y,z
DCP	diode compression point
CF	crest factor (1/duty_cycle) of the RF signal
A,B,C,D	modulation dependent linearization parameters
Polarization $\Phi$	$\Phi$ rotation around probe axis
Polarization $\theta$	$\theta$ rotation around an axis that is in the plane normal to probe axis (at measurement center), i $\theta=0$ is normal to probe axis
Connector Angle	information used in DASY system to align probe sensor X to the robot coordinate system

**Calibration is Performed According to the Following Standards:**

- a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- b) IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- c) IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- d) KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

**Methods Applied and Interpretation of Parameters:**

- $NORMx,y,z$ : Assessed for E-field polarization  $\theta=0$  ( $f \leq 900$ MHz in TEM-cell;  $f > 1800$ MHz: waveguide).  $NORMx,y,z$  are only intermediate values, i.e., the uncertainties of  $NORMx,y,z$  does not effect the  $E^2$ -field uncertainty inside TSL (see below ConvF).
- $NORM(f)x,y,z = NORMx,y,z * frequency\_response$  (see Frequency Response Chart). This linearization is implemented in DASY4 software versions later than 4.2. The uncertainty of the frequency response is included in the stated uncertainty of ConvF.
- $DCPx,y,z$ : DCP are numerical linearization parameters assessed based on the data of power sweep (no uncertainty required). DCP does not depend on frequency nor media.
- PAR: PAR is the Peak to Average Ratio that is not calibrated but determined based on the signal characteristics.
- $Ax,y,z; Bx,y,z; Cx,y,z; VRx,y,z; A, B, C$  are numerical linearization parameters assessed based on the data of power sweep for specific modulation signal. The parameters do not depend on frequency nor media. VR is the maximum calibration range expressed in RMS voltage across the diode.
- *ConvF and Boundary Effect Parameters*: Assessed in flat phantom using E-field (or Temperature Transfer Standard for  $f \leq 800$ MHz) and inside waveguide using analytical field distributions based on power measurements for  $f > 800$ MHz. The same setups are used for assessment of the parameters applied for boundary compensation (alpha, depth) of which typical uncertainty values are given. These parameters are used in DASY4 software to improve probe accuracy close to the boundary. The sensitivity in TSL corresponds to  $NORMx,y,z * ConvF$  whereby the uncertainty corresponds to that given for ConvF. A frequency dependent ConvF is used in DASY version 4.4 and higher which allows extending the validity from  $\pm 50$ MHz to  $\pm 100$ MHz.
- *Spherical isotropy (3D deviation from isotropy)*: in a field of low gradients realized using a flat phantom exposed by a patch antenna.
- *Sensor Offset*: The sensor offset corresponds to the offset of virtual measurement center from the probe tip (on probe axis). No tolerance required.
- *Connector Angle*: The angle is assessed using the information gained by determining the  $NORMx$  (no uncertainty required).

Certificate No:Z22-60064

Page 2 of 9



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2512 Fax: +86-10-62304633-2504  
E-mail: [cttl@chinattl.com](mailto:cttl@chinattl.com) [Http://www.chinattl.cn](http://www.chinattl.cn)



## DASY/EASY – Parameters of Probe: EX3DV4 – SN:7633

### Basic Calibration Parameters

	Sensor X	Sensor Y	Sensor Z	Unc (k=2)
Norm( $\mu\text{V}/(\text{V}/\text{m})^2$ ) <sup>A</sup>	0.66	0.65	0.68	±10.0%
DCP(mV) <sup>B</sup>	111.2	112.3	113.8	

### Modulation Calibration Parameters

UID	Communication System Name	A dB	B dB/ $\mu\text{V}$	C	D dB	VR mV	Unc <sup>E</sup> (k=2)
0	CW	X	0.0	0.0	1.0	0.00	214.3
		Y	0.0	0.0	1.0		212.4
		Z	0.0	0.0	1.0		221.3

The reported uncertainty of measurement is stated as the standard uncertainty of Measurement multiplied by the coverage factor k=2, which for a normal distribution Corresponds to a coverage probability of approximately 95%.

<sup>A</sup> The uncertainties of Norm X, Y, Z do not affect the E<sup>2</sup>-field uncertainty inside TSL (see Page 4).

<sup>B</sup> Numerical linearization parameter: uncertainty not required.

<sup>E</sup> Uncertainty is determined using the max. deviation from linear response applying rectangular distribution and is expressed for the square of the field value.

Certificate No:Z22-60064

Page 3 of 9



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2512 Fax: +86-10-62304633-2504  
E-mail: [cttl@chinattl.com](mailto:cttl@chinattl.com) [Http://www.chinattl.cn](http://www.chinattl.cn)



## DASY/EASY – Parameters of Probe: EX3DV4 – SN:7633

### Calibration Parameter Determined in Head Tissue Simulating Media

f [MHz] <sup>C</sup>	Relative Permittivity <sup>F</sup>	Conductivity (S/m) <sup>F</sup>	ConvF X	ConvF Y	ConvF Z	Alpha <sup>G</sup>	Depth <sup>G</sup> (mm)	Unct. (k=2)
750	41.9	0.89	10.90	10.90	10.90	0.14	1.44	±12.1%
835	41.5	0.90	10.55	10.55	10.55	0.13	1.59	±12.1%
900	41.5	0.97	10.53	10.53	10.53	0.15	1.38	±12.1%
1750	40.1	1.37	8.90	8.90	8.90	0.30	0.86	±12.1%
1900	40.0	1.40	8.60	8.60	8.60	0.26	0.98	±12.1%
2000	40.0	1.40	8.63	8.63	8.63	0.23	1.08	±12.1%
2300	39.5	1.67	8.20	8.20	8.20	0.55	0.72	±12.1%
2450	39.2	1.80	7.96	7.96	7.96	0.58	0.71	±12.1%
2600	39.0	1.96	7.73	7.73	7.73	0.65	0.67	±12.1%
3300	38.2	2.71	7.42	7.42	7.42	0.41	0.98	±13.3%
3500	37.9	2.91	7.20	7.20	7.20	0.41	0.95	±13.3%
3700	37.7	3.12	6.83	6.83	6.83	0.44	1.01	±13.3%
3900	37.5	3.32	6.85	6.85	6.85	0.35	1.33	±13.3%
4100	37.2	3.53	6.73	6.73	6.73	0.40	1.15	±13.3%
4200	37.1	3.63	6.65	6.65	6.65	0.35	1.35	±13.3%
4400	36.9	3.84	6.55	6.55	6.55	0.35	1.35	±13.3%
4600	36.7	4.04	6.41	6.41	6.41	0.45	1.25	±13.3%
4800	36.4	4.25	6.37	6.37	6.37	0.40	1.40	±13.3%
4950	36.3	4.40	6.06	6.06	6.06	0.40	1.40	±13.3%
5250	35.9	4.71	5.70	5.70	5.70	0.50	1.20	±13.3%
5600	35.5	5.07	5.13	5.13	5.13	0.50	1.30	±13.3%
5750	35.4	5.22	5.17	5.17	5.17	0.50	1.30	±13.3%

<sup>C</sup> Frequency validity above 300 MHz of ±100MHz only applies for DASY v4.4 and higher (Page 2), else it is restricted to ±50MHz. The uncertainty is the RSS of ConvF uncertainty at calibration frequency and the uncertainty for the indicated frequency band. Frequency validity below 300 MHz is ± 10, 25, 40, 50 and 70 MHz for ConvF assessments at 30, 64, 128, 150 and 220 MHz respectively. Above 5 GHz frequency validity can be extended to ± 110 MHz.

<sup>F</sup> At frequency below 3 GHz, the validity of tissue parameters ( $\epsilon$  and  $\sigma$ ) can be relaxed to ±10% if liquid compensation formula is applied to measured SAR values. At frequencies above 3 GHz, the validity of tissue parameters ( $\epsilon$  and  $\sigma$ ) is restricted to ±5%. The uncertainty is the RSS of the ConvF uncertainty for indicated target tissue parameters.

<sup>G</sup> Alpha/Depth are determined during calibration. SPEAG warrants that the remaining deviation due to the boundary effect after compensation is always less than ± 1% for frequencies below 3 GHz and below ± 2% for the frequencies between 3-6 GHz at any distance larger than half the probe tip diameter from the boundary.

Certificate No:Z22-60064

Page 4 of 9




In Collaboration with  
**s p e a g**  
CALIBRATION LABORATORY



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2512 Fax: +86-10-62304633-2504  
E-mail: [ttl@chinattl.com](mailto:ttl@chinattl.com) [Http://www.chinattl.cn](http://www.chinattl.cn)

## Frequency Response of E-Field (TEM-Cell: ifi110 EXX, Waveguide: R22)



Uncertainty of Frequency Response of E-field:  $\pm 7.4\%$  ( $k=2$ )

Certificate No:Z22-60064

Page 5 of 9




In Collaboration with  
**s p e a g**  
 CALIBRATION LABORATORY





Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
 Tel: +86-10-62304633-2512 Fax: +86-10-62304633-2504  
 E-mail: [cttl@chinattl.com](mailto:cttl@chinattl.com) [Http://www.chinattl.cn](http://www.chinattl.cn)

### Receiving Pattern ( $\Phi$ ), $\theta=0^\circ$

f=600 MHz, TEM




f=1800 MHz, R22



Uncertainty of Axial Isotropy Assessment:  $\pm 1.2\% (k=2)$


Certificate No:Z22-60064

Page 6 of 9



Certificate No:Z22-60064

Page 7 of 9




Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2512 Fax: +86-10-62304633-2504  
E-mail: [cttl@chinattl.com](mailto:cttl@chinattl.com) [Http://www.chinattl.cn](http://www.chinattl.cn)




## Conversion Factor Assessment

$f=750 \text{ MHz}, \text{WGLS R9(H\_convF)}$        $f=1750 \text{ MHz}, \text{WGLS R22(H\_convF)}$



## Deviation from Isotropy in Liquid



Uncertainty of Spherical Isotropy Assessment:  $\pm 3.2\% (k=2)$

Certificate No:Z22-60064

Page 8 of 9



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2512 Fax: +86-10-62304633-2504  
E-mail: [cttl@chinattl.com](mailto:cttl@chinattl.com) [Http://www.chinattl.cn](http://www.chinattl.cn)



## DASY/EASY – Parameters of Probe: EX3DV4 – SN:7633

### Other Probe Parameters

Sensor Arrangement	Triangular
Connector Angle (°)	26.4
Mechanical Surface Detection Mode	enabled
Optical Surface Detection Mode	disable
Probe Overall Length	337mm
Probe Body Diameter	10mm
Tip Length	9mm
Tip Diameter	2.5mm
Probe Tip to Sensor X Calibration Point	1mm
Probe Tip to Sensor Y Calibration Point	1mm
Probe Tip to Sensor Z Calibration Point	1mm
Recommended Measurement Distance from Surface	1.4mm

Certificate No:Z22-60064

Page 9 of 9



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191  
Tel: +86-10-62304633-2117  
E-mail: ems@caict.ac.cn  
<http://www.caict.ac.cn>



Client 3in

Certificate No: Z22-60398

## CALIBRATION CERTIFICATE

Object D750V3 - SN: 1144

Calibration Procedure(s) FF-Z11-003-01  
Calibration Procedures for dipole validation kits


Calibration date: September 16, 2022

This calibration Certificate documents the traceability to national standards, which realize the physical units of measurements (SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22±3)°C and humidity<70%.

Calibration Equipment used (M&amp;TE critical for calibration)

Primary Standards	ID #	Cal Date (Calibrated by, Certificate No.)	Scheduled Calibration
Power Meter NRP2	106277	24-Sep-21 (CTTL, No.J21X08326)	Sep-22
Power sensor NRP8S	104291	24-Sep-21 (CTTL, No.J21X08326)	Sep-22
Reference Probe EX3DV4	SN 7464	26-Jan-22(SPEAG, No.EX3-7464_Jan22)	Jan-23
DAE4	SN 1556	12-Jan-22(CTTL-SPEAG, No.Z22-60007)	Jan-23
Secondary Standards	ID #	Cal Date (Calibrated by, Certificate No.)	Scheduled Calibration
Signal Generator E4438C	MY49071430	13-Jan-22 (CTTL, No.J22X00409)	Jan-23
Network Analyzer E5071C	MY46110673	14-Jan-22 (CTTL, No.J22X00406)	Jan-23

Calibrated by:	Name	Function	Signature
Zhao Jing	SAR Test Engineer		
Reviewed by:	Lin Hao	SAR Test Engineer	
Approved by:	Qi Dianyuan	SAR Project Leader	

Issued: September 23, 2022

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2117  
E-mail: emf@caict.ac.cn <http://www.caict.ac.cn>

**Glossary:**

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORMx,y,z
N/A	not applicable or not measured

**Calibration is Performed According to the Following Standards:**

- IEC/IEEE 62209-1528, "Measurement Procedure for The Assessment of Specific Absorption Rate of Human Exposure to Radio Frequency Fields from Hand-held and Body-mounted Wireless Communication Devices- Part 1528: Human Models, Instrumentation and Procedures (Frequency range of 4 MHz to 10 GHz)", October 2020
- KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

**Additional Documentation:**

- DASY4/5 System Handbook

**Methods Applied and Interpretation of Parameters:**

- Measurement Conditions:* Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- Antenna Parameters with TSL:* The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- Feed Point Impedance and Return Loss:* These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- Electrical Delay:* One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- SAR measured:* SAR measured at the stated antenna input power.
- SAR normalized:* SAR as measured, normalized to an input power of 1 W at the antenna connector.
- SAR for nominal TSL parameters:* The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of Measurement multiplied by the coverage factor k=2, which for a normal distribution Corresponds to a coverage probability of approximately 95%.



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2117  
E-mail: emf@caict.ac.cn http://www.caict.ac.cn



#### Measurement Conditions

DASY system configuration, as far as not given on page 1.

<b>DASY Version</b>	DASY52	V52.10.4
<b>Extrapolation</b>	Advanced Extrapolation	
<b>Phantom</b>	Triple Flat Phantom 5.1C	
<b>Distance Dipole Center - TSL</b>	15 mm	with Spacer
<b>Zoom Scan Resolution</b>	dx, dy, dz = 5 mm	
<b>Frequency</b>	750 MHz ± 1 MHz	

#### Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
<b>Nominal Head TSL parameters</b>	22.0 °C	42.0	0.90 mho/m
<b>Measured Head TSL parameters</b>	(22.0 ± 0.2) °C	42.1 ± 6 %	0.91 mho/m ± 6 %
<b>Head TSL temperature change during test</b>	<1.0 °C	—	—

#### SAR result with Head TSL

<b>SAR averaged over 1 cm<sup>3</sup> (1 g) of Head TSL</b>	Condition	
SAR measured	250 mW input power	2.12 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	8.32 W/kg ± 18.8 % (k=2)
<b>SAR averaged over 10 cm<sup>3</sup> (10 g) of Head TSL</b>	Condition	
SAR measured	250 mW input power	1.40 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	5.52 W/kg ± 18.7 % (k=2)



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2117  
E-mail: emf@caict.ac.cn <http://www.caict.ac.cn>



#### Appendix (Additional assessments outside the scope of CNAS L0570)

##### Antenna Parameters with Head TSL

Impedance, transformed to feed point	52.2Ω- 2.96jΩ
Return Loss	- 28.8dB

##### General Antenna Parameters and Design

Electrical Delay (one direction)	0.942 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feed-point can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.  
No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feed-point may be damaged.

##### Additional EUT Data

Manufactured by	SPEAG
-----------------	-------



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2117  
E-mail: emf@caict.ac.cn <http://www.caict.ac.cn>

**DASY5 Validation Report for Head TSL**

Date: 2022-09-16

Test Laboratory: CTTL, Beijing, China

**DUT: Dipole 750 MHz; Type: D750V3; Serial: D750V3 - SN: 1144**

Communication System: UID 0, CW; Frequency: 750 MHz; Duty Cycle: 1:1  
Medium parameters used:  $f = 750 \text{ MHz}$ ;  $\sigma = 0.913 \text{ S/m}$ ;  $\epsilon_r = 42.07$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Right Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2007)

DASY5 Configuration:

- Probe: EX3DV4 - SN7464; ConvF(10.26, 10.26, 10.26) @ 750 MHz;  
Calibrated: 2022-01-26
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1556; Calibrated: 2022-01-12
- Phantom: MFP\_V5.1C (20deg probe tilt); Type: QD 000 P51 Cx; Serial:  
1062
- DASY5 52.10.4(1535); SEMCAD X 14.6.14(7501)

**Dipole Calibration/Zoom Scan (7x7x7) (7x7x7)/Cube 0: Measurement grid:** $dx=5\text{mm}, dy=5\text{mm}, dz=5\text{mm}$ 

Reference Value = 54.98 V/m; Power Drift = -0.01 dB


Peak SAR (extrapolated) = 3.15 W/kg

**SAR(1 g) = 2.12 W/kg; SAR(10 g) = 1.4 W/kg**

Smallest distance from peaks to all points 3 dB below = 22.7 mm

Ratio of SAR at M2 to SAR at M1 = 66.8%

Maximum value of SAR (measured) = 2.81 W/kg



Certificate No: Z22-60398


Page 5 of 6



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191, China  
Tel: +86-10-62304633-2117  
E-mail: emf@caict.ac.cn http://www.caict.ac.cn



### Impedance Measurement Plot for Head TSL



Certificate No: Z22-60398

Page 6 of 6



Add: No.52 HuaYuanBei Road, Haidian District, Beijing, 100191  
Tel: +86-10-62304633-2117  
E-mail: emf@caict.ac.cn http://www.caict.ac.cn



Client

3in

Certificate No: Z22-60399

## CALIBRATION CERTIFICATE

Object D835V2 - SN: 4d112

Calibration Procedure(s) FF-Z11-003-01  
Calibration Procedures for dipole validation kits

Calibration date: September 21, 2022

This calibration Certificate documents the traceability to national standards, which realize the physical units of measurements (SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22±3)°C and humidity<70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Calibrated by, Certificate No.)	Scheduled Calibration
Power Meter NRP2	106277	24-Sep-21 (CTTL, No.J21X08326)	Sep-22
Power sensor NRP8S	104291	24-Sep-21 (CTTL, No.J21X08326)	Sep-22
Reference Probe EX3DV4	SN 7464	26-Jan-22(SPEAG, No.EX3-7464_Jan22)	Jan-23
DAE4	SN 1556	12-Jan-22(CTTL-SPEAG, No.Z22-60007)	Jan-23
Secondary Standards	ID #	Cal Date (Calibrated by, Certificate No.)	Scheduled Calibration
Signal Generator E4438C	MY49071430	13-Jan-22 (CTTL, No.J22X00409)	Jan-23
Network Analyzer E5071C	MY46110673	14-Jan-22 (CTTL, No.J22X00406)	Jan-23

Calibrated by:	Name	Function	Signature
Zhao Jing	SAR Test Engineer		
Reviewed by:	Lin Hao	SAR Test Engineer	
Approved by:	Qi Dianyuan	SAR Project Leader	

Issued: September 27, 2022

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.