

3020E0001

SHT. 1

THIS DOCUMENT HAS BEEN GENERATED USING ADOBE ILLUSTRATOR AND MUST ONLY BE UPDATED BY A.I.



**Honeywell**

### Touchpoint Plus Wireless

Honeywell Analytics Asia Pacific, Co., Ltd. 7F SangAm IT Tower, 434 Worldcup Buk-ro, Mapo-gu, Seoul 03922, South Korea

S/N: \_\_\_\_\_ P/N: \_\_\_\_\_

Power: 110 / 220 V ~ (AC) 50 - 60 Hz Max 150 W or 18 - 32 V = (DC) Max 150 W  
Enclosure protection: IP65

**CLASSIFIED**  
**UL** US  
E480011  
Gas Detector for use in Hazardous Locations as to Fire, Electrical Shock, Explosion Hazards Only  
Class I, Division 2, Groups A, B, C and D.  
Temp Code T4. Tamb: -10°C to +55°C  
CSA C22.2 No.152

**LISTED**  
**UL** US  
E466771  
E470577  
Programmable Controllers  
Process Control Equipment

**Warning:** EXPLOSION HAZARD – Batteries must only be changed in an area known to be non-hazardous  
De-energize the equipment before opening the enclosure

### Honeywell

QR code  
(Size: 12 x 12mm )

Power: 110 / 220 V ~ (AC) 50 - 60 Hz Max 150 W or 18 - 32 V = (DC) Max 150 W  
Enclosure protection: IP65

**CLASSIFIED**  
**UL** US  
E480011  
Gas Detector for use in Hazardous Locations as to Fire, Electrical Shock, Explosion Hazards Only  
Class I, Division 2, Groups A, B, C and D.  
Temp Code T4. Tamb: -10°C to +55°C  
CSA C22.2 No.152

**LISTED**  
**UL** US  
E466771  
E470577  
Programmable Controllers  
Process Control Equipment

**Warning:** EXPLOSION HAZARD – Batteries must only be changed in an area known to be non-hazardous  
De-energize the equipment before opening the enclosure

(SCALE 1:1)

### Touchpoint Plus Wireless

Honeywell Analytics Asia Pacific, Co., Ltd. 7F SangAm IT Tower, 434 Worldcup Buk-ro, Mapo-gu, Seoul 03922, South Korea

S/N: \_\_\_\_\_ P/N: \_\_\_\_\_

Power: 110 / 220 V ~ (AC) 50 - 60 Hz Max 150 W or 18 - 32 V = (DC) Max 150 W  
Enclosure protection: IP65

**CLASSIFIED**  
**UL** US  
E480011  
Gas Detector for use in Hazardous Locations as to Fire, Electrical Shock, Explosion Hazards Only  
Class I, Division 2, Groups A, B, C and D.  
Temp Code T4. Tamb: -10°C to +55°C  
CSA C22.2 No.152

**LISTED**  
**UL** US  
E466771  
E470577  
Programmable Controllers  
Process Control Equipment

**Warning:** EXPLOSION HAZARD – Batteries must only be changed in an area known to be non-hazardous  
De-energize the equipment before opening the enclosure

### Honeywell

QR code  
(Size: 12 x 12mm )

Power: 110 / 220 V ~ (AC) 50 - 60 Hz Max 150 W or 18 - 32 V = (DC) Max 150 W  
Enclosure protection: IP65

**CLASSIFIED**  
**UL** US  
E480011  
Gas Detector for use in Hazardous Locations as to Fire, Electrical Shock, Explosion Hazards Only  
Class I, Division 2, Groups A, B, C and D.  
Temp Code T4. Tamb: -10°C to +55°C  
CSA C22.2 No.152

**LISTED**  
**UL** US  
E466771  
E470577  
Programmable Controllers  
Process Control Equipment

**Warning:** EXPLOSION HAZARD – Batteries must only be changed in an area known to be non-hazardous  
De-energize the equipment before opening the enclosure

(SCALE 1:1)

Note:


1. Color

Silver: Background

Black: Font

**A. SERIAL NUMBER EXAMPLE:**

S/N : SIIPPPYYWWNNNN



THIS ITEM FORMS PART OF A CERTIFIED PRODUCT  
NO MODIFICATION PERMITTED WITHOUT  
REFERENCE TO CERTIFICATION DEPARTMENT

THIS DRAWING IS CONFIDENTIAL. IT IS THE PROPERTY OF HONEYWELL ANALYTICS LTD AND MUST NOT BE REPRODUCED EITHER WHOLLY OR PARTLY. ALL RIGHTS IN RESPECT OF PATENTS, DESIGNS AND COPYRIGHT ARE RESERVED.

	FINISH	REFERENCE PARTNUMBER	SCALE NTS	DRAWING Jinkyung Lim	07/SEP/18
			ISSUE	TPPLW Unit Label Artwork	
			DATE		
			CHANGE	3020E0001	
			NEW DRAWING		
			APPROVED BY	SHT. 1	OF 1
			Jeffery L.		

## Touchpoint Plus Wireless – Label position

