



High-Bay Emergency LED Driver

- Universal Voltage: 100-347V~
- For wiring to the LED Driver's input
- High voltage output 170VDC
- Aux output: 12VDC, 0.2A
- Built-in integrated junction box

Output Wattage: 40W constant powerSelf-Diagnostic


- CEC Title20 compliance
- Remote control distance up to 98ft
- IP 65

General Specifications

Input Voltage / Frequency	100-347V~, 50/60Hz			
Input Current	0.2A Max.			
Input Power	12W Max.			
Load Input Power	320W Max. when using 0-10V dimming; 40W Max. when 0-10V dimming is not used.			
	The luminaire driver power at min. dimming needs to be less than the EM power 40W.			
	Please test the compatibility of the FHSHB-347-40W-D with the intended luminaire before installation			
Output Type	Non-Class 2			
Uout	180V			
Output Power	40W			
Output Voltage	170VDC			
Vaux	12VDC, 0. 2A			
Number of Output Channels	1Channel			
Input Surge Protection	Line - Neutral 3kV, Line & Neutral - Ground 3kV			
Protections	Output Open Protection			
	Output Overload Protection			
	Output Short Circuit Protection			
	Output Temperature Protection			
Emergency Mode	90 Minutes Min			
RFI/EMI	FCC Part15A			
Ambient Operating Temperature Rang	0°C To 50°C (32°F To 122°F)			
Sound Rating	Α			
Battery Type	Lithium			
Battery Voltage	18V			
Pack Capacity	5000mAh			
Battery Rating	90Wh			
Battery Recharge Time	24 Hours			
Battery Discharge Time	Min 1.5 Hours			
Remote Control Distance	98' (30m) Max.			
Remote Controller Battery Model	23A			
Remote Controller Battery Voltage	12V			
Remote Controller Battery Quantity	<u>1pc</u>			
Application Environment	Wet			
Service Life	50,000 hours			
Warranty	5 years			
Standard	UL924, CSA C22.2 No.141			
	CEC, Title 20, UN 38.3			
	RoHS, IP65			







 Fulham Co. Inc.: 12705 South Van Ness Ave., Hawthorne, CA 90250 Tel.: 1-323-779-2980 Fax.: 1-323-754-9060.
 order@fulham.com
 www.fulham.com


 Specifications subject to change without notice.
 Page 2 of 10
 2023-959 Rev B





Installation Diagram

*Note: This product is not compatible with all luminaires, please conduct a compatibility test before use.




(4) Integrated Junction Box Cover

(9) Charge Indicator & Test Switch



Accessories






1x pcs of remote control 1x pcs of Antenna 2x pcs of connectors for wire diameter 0.118-0.248" (3-6.3mm) 2x pcs of connectors for wire diameter 0.196-0.393" (5-10mm)





Wiring Diagram

Note: 0-10V dimming on luminaire driver is needed and must be connected to FHSHB-347-40W-D if the luminaire power is over 40W. **Note:** This product is not compatible with all luminaires, please conduct a compatibility test before use.



 Fulham Co. Inc.: 12705 South Van Ness Ave., Hawthorne, CA 90250 Tel.: 1-323-779-2980 Fax.: 1-323-754-9060.
 order@fulham.com
 www.fulham.com

 Specifications subject to change without notice.
 Page 5 of 10
 2023-959 Rev B





Self-Diagnostic Instructions / Operation

The emergency LED driver will conduct a self-test for thirty(30) seconds every thirty(30) days; and a ninety(90) minutes self-test every 12 months. After every self-test, the LED indicator light will indicate a status signal. Check indicator status chart below to diagnose the status signal.

Test Switch Indicator Status

Mode	Test Switch on EM Driver	Wireless Remote	Indicator Status	Comment & Solutions			
AC MODE (1)	NO Press	NO Press	ON(no flashing)	Emergency led driver is charging			
AC MODE (2)	Press once	Press "Button A" once	2s ON and 2s OFF (slow flashing)	Emergency led driver is conducting a 30s short-term emergency test. After 30 seconds, it will automatically restore to normal charging mode			
AC MODE (3)	Press twice (2s) in sequence	Press "Button B" once	2s ON and 2s OFF (slow_flashing)	Emergency led driver is conducting a long-term emergency test until battery is fully discharged			
EMERGENCY MODE	NO Press	NO Press	2s ON and 2s OFF (slow_flashing)	Emergency led driver is conducting a long-term emergency test until battery is fully discharged			
ABNORMAL	When flashes (50ms) ON and (50ms) OFF fast or goes off, the emergency backup pack is abnormal. Contact the manufacturer.						
WARNING A Note: Battery shall be disconnected before installation, maintenance, storage or shipping							

EM Test:

Press the test button on EM driver or on the remote control to enter EM mode in normal AC powered.

Turn OFF EM Output:

Press test button on EM driver or on the remote control once during EMERGENCY MODE (NO AC Power) to turn off EM output. This is useful for producte environment to turn off the EM output once a luminaire has completed functionality testing.

Remote Control

One remote control can control with multiple FHSHB-347-40W-D emergency drivers, there's no need to pair, the control can work within the max. distance.

Max. control distance 98ft *

During AC mode: Press "Button A" once for a 30s short-term emergency test; Press "Button B" once for a long-term emergency test until the battery is fully discharged. During Emergency mode (no AC power): Press "Button A" or "Button B" to turn off the emergency output.

* NOTE: The max. remote control distance could be limited by different environments.



 Fulham Co. Inc.: 12705 South Van Ness Ave., Hawthorne, CA 90250 Tel.: 1-323-779-2980 Fax.: 1-323-754-9060.
 order@fulham.com
 www.fulham.com

 Specifications subject to change without notice.
 Page 6 of 10
 2023-959 Rev B







III IMPORTANT SAFEGUARDS III

WHEN USING ELECTRICAL EQUIPMENT, BASIC SAFETY PRECAUTION SHOULD ALWAYS BE FOLLOWED, INCLUDING THE FOLLOWING

READ AND FOLLOW ALL SAFETY INSTRUCTION

- 1. CAUTION- This FHSHB provides more than one power supply output source. To reduce the risk of electrical shock, disconnect both normal and emergency source by turning o the A.C. branch circuit.
- 2. CAUTION- Servicing of this equipment should be performed by qualified personnel only.
- 3. CAUTION- Do not attempt to service the battery. A sealed, no-maitenence battery is used that is not field replaceable. Replace the entire unit when necessary.
- CAUTION- The use of accessory equipment not recommended by the manufacturer may cause an unsafe condition, void warranty, and result in non-compliance with UL specifications.
- 5. CAUTION- The FHSHB requires an un-switched AC power source of 100-347VAC ,50/60Hz. Installer must confirm that fixtures input voltage. covered 120VAC before installation. It will supply power under an output voltage of 170VDC in emergency mode for at least 90 minutes.
- 6. CAUTION- Battery pack should be charged for 24 hours every 6 months during storage.
- 7. Battery in this unit may not be fully charged. After electricity is connected to the unit for at least 24 hours, then normal operation of this unit should take effect.
- 8. For use in 0°C minimum, 50°C maximum ambient temperatures. Suitable for use in wet locations and plenum spaces.
- 9. Flexible mental conduit is optional, depend on installation environment.
- 10. The FHSHB should be mounted in locations and at heights where it will not readily be subjected to tampering by unauthorized personnel.
- 11. Do not use this equipment for anything other than its intended use. Equipment only use for LED Lighting emergency backup.
- 12. Do not mount near gas or electric heaters. Do not let power supply cords touch hot surfaces.
- 13. Do not make or leave any other open holes in the wiring enclosure or electrical component enclosure during installation.
- 14. This fixture is for use with grounded, UL Listed, this model can use in wet location. Not for use in heated air outlets or hazardous locations.
- 15. The emergency driver have battery inside, forbidden for insulation voltage(I/P-O/P) test.
- 16. Equipment should be mounted in locations and at heights where it will not be subjected to tampering by unauthorized personnel.
- 17. The equipment is intended for ordinary locations and for permanent installation into one or more Listed emergency luminaires.
- 18. Suitable for minimum 10W LED lamp.
- 19. Maximum installation height: 28.5 feet.
- Changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.
 This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.
- This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:
 - -Reorient or relocate the receiving antenna.
 - -Increase the separation between the equipment and receiver.
 - —Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
 —Consult the dealer or an experienced radio/TV technician for help.

LUMEN OUTPUT DURING EMERGENCY OPERATION

The luminaire rated data and maximum mounting height can be found as follows:

- 1. Determine the fixture efficacy under normal AC operation, based on fixture manufacturer published data in lumens per watt (LM/W).
- 2. Reference DLC QPL (www.designlights.org) and Energy Star QPL (www.energystar.gov) for rated data on fixture efficacy.
- If fixture is not found on DLC or Energy Star Qualified Product List , contact fixture manufacturer.

3. Multiply *fixture LM/W* by *rated output power of emergency pack* Example 'model FHSHB347-40W-D' is $40 \text{ W} \times 100 \text{ LM/W} = 4000 \text{ Lumens}$ This product has been designed and tested to compatible with most of led drivers in the market. However, compatibility cannot guaranteed

with all current and future LED drivers or fixtures. So compatibility testing of the end-use system is suggested. Please contact the factory with any questions.

Caution: Before Installation, Make Certain The A.C. Power is Off !

STEP 1: ASSEMBLING NOTICE

- > Select a suitable location on the hangable device.
- > The Maximum weight of lighting fixture should be less than 20kg.
- > Turn off the AC power before installing.
- > Assembling the EM backup with the Safety Rope with the chain link connector.
- > Please use waterproof connectors in position AC input wire interface and Dimming wire interface for application in wet location.

SAVE THESE INSTRUCTIONS

 Fulham Co. Inc.: 12705 South Van Ness Ave., Hawthorne, CA 90250 Tel.: 1-323-779-2980 Fax.: 1-323-754-9060.
 order@fulham.com
 www.fulham.com

 Specifications subject to change without notice.
 Page 7 of 10
 2023-959 Rev B





INSTALLATION MANUAL

!!! IMPORTANT SAFEGUARDS !!!

WHEN USING ELECTRICAL EQUIPMENT, BASIC SAFETY PRECAUTION SHOULD ALWAYS BE FOLLOWED, INCLUDING THE FOLLOWING

STEP 2: INSTALLING

> Install the ring M10 Hanging Ring Bolt to the EM backup and fix it with screw.

- > Install the M10 Hanging Hook Bolt to the EM backup and fix it with screw.
- > Install the UFO high bay to the Hanging Hook of EM backup and tighten the screws.

STEP 3: WIRING

- > Before wiring, make sure safety rope is securely locked and make sure all the screws are tight.
- > Open the cover of junction box.
- > Select the appropriate wiring diagram to connect the emergency driver to the AC driver. For other diagrams, consult the manufacturer.
- > The voltage input to the dimmable wires (DIM+, DIM-) of emergency LED driver must less than 20Vdc.
- > Using wire nuts to cover un-used wires and make sure all connections are in accordance with the NEC and any local regulations.

STEP 4: TESTING

- > After wiring is complete, apply A.C. power. Check if the indicator light lights or not , which will indicate the battery's charging situation.
- > The battery in this unit may not be fully charged. A short-term discharge test may be conducted after the EMUFO has been charging for 1 hour.

Charge for 24 hours before conducting a long-term discharge test.

SAVE THESE INSTRUCTIONS

Fulham Co. Inc.: 12705 South Van Ness Ave., Hawthorne, CA 90250 Tel.: 1-323-779-2980 Fax.: 1-323-754-9060. order@fulham.com Specifications subject to change without notice.





Guidelines

Grounding

• The Emergency Driver must be grounded by means of the grounding wire.

Over temperature protection

• The Fulham Hotspot LED drivers are protected against thermal overload. If the temperature limit is exceeded, the output current is reduced.

Load

• Fulham High-Bay Emergency LED drivers are designed to connect to normal LED driver's input.

Short-circuit protection

 In case of a short circuit the LED driver switches to protection mode. After the removal of the short-circuit the LED driver will recover automatically.

No-load Operation

• In no-load operation the output voltage will not exceed the specified open circuit output voltage.

Hot Swapping

• This driver does not support hot swapping.

Remote Mounting

• Up to 15ft with 18AWG. Contact Fulham for higher remoute distance.

Battery Maintenance

• In order to maintain proper operation and warranty coverage, the battery must be recharged once per year prior to installation.


Warranty

• Reference Fulham's limited Warranty: https://cdn.fulham.com/PDFs/Limited-Warranty.pdf





Part Number Matrix




Product Image:



Packaging

Master Carton



OUTER DIMENSION								
L		W		Н				
14.96" (380mm)		14.96"(380mm)		9.84" (250mm)				
Net Weight	Gross Weight		QL	QUANTITY				
21.61lbs. (9.8kg.)	23.15lbs. (10.5kg)		4pcs.					