

Prüfbericht - Nr.:		ULR-TC568819300000029F 001		Seite 1 von 20 <i>Page 1 of 20</i>	
<i>Test Report No.:</i>					
Auftraggeber: <i>Client:</i>		Hill-rom Services Private Limited 1 Yishun Avenue 7, Singapore 768923			
Gegenstand der Prüfung: <i>Test item:</i>		Airway clearance device			
Bezeichnung: <i>Identification:</i>		POPT1	Serien-Nr.: <i>Serial No.</i>		U044OP0050
Wareneingangs-Nr.: <i>Receipt No.:</i>		166120073	Eingangsdatum: <i>Date of receipt:</i>		01-04-2019
Prüfort: <i>Testing location:</i>		Refer Page 5 of 20 for Test site details			
Prüfgrundlage: <i>Test specification:</i>		FCC Part 15 Subpart C - 15.225 & ANSI C63.10-2013			
Prüfergebnis: <i>Test Result:</i>		Der Prüfgegenstand entspricht oben genannter Prüfgrundlage(n). <i>The test items passed the test specification(s).</i>			
Prüflaboratorium: <i>Testing Laboratory:</i>		TÜV Rheinland (India) Pvt. Ltd. 27/B, 2nd Cross, Electronic City , Phase 1 Bangalore – 560 100, FCC Test Site Registration no.: 496599			
geprüft / tested by:		kontrolliert / reviewed by:			
08.04.2019	Pramod Sharma R Engineer		25.06.2019	Mahammadgouse Kaladagi Senior Engineer	
Datum <i>Date</i>	Name/Stellung <i>Name/Position</i>	Unterschrift <i>Signature</i>	Datum <i>Date</i>	Name/Stellung <i>Name/Position</i>	Unterschrift <i>Signature</i>
Sonstiges / Other Aspects:		FCC ID: 2AJKO-OPTIMUS			
Abkürzungen:		Abbreviations:			
P(ass) = entspricht Prüfgrundlage		P(ass) = passed			
F(ail) = entspricht nicht Prüfgrundlage		F(ail) = failed			
N/A = nicht anwendbar		N/A = not applicable			
N/T = nicht getestet		N/T = not tested			
Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens. <i>This test report relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any safety mark on this or similar products.</i>					

TÜV Rheinland (India) Pvt.Ltd., 27/B, 2nd Cross, Electronic City , Phase 1 Bangalore – 560 100, Karnataka
Tel : +91- 80- 46498110/8000Fax: +91 - 80- 46498042

Prüfbericht - Nr.:
Test Report No.:

ULR-TC568819300000029F 001

Seite 2 von 20
Page 2 of 20

Test Summary

Test Item	FCC Clause	Result	Remarks
Frequency tolerance	FCC part 15 Subpart C Section 15.225 (e)	Pass	-
Radiated Spurious Emission & Field Strength Measurement within the band 13.110-14.010 MHz	FCC part 15 Subpart C Section 15.225 (a,b,c,d) / (15.209)	Pass	-

Discipline: Electronics Testing
Group: EMC Test Facility

Product Variants:

Variant	Model Number	Modes available
1	POPT1	Maximus™ System
2	PSC1	Synclara™ Cough System
3	PVL1	Volara™ Cough System

Note:

1. Model POPT1 is the highest configuration where it has both synclara and volara modes available , hence the testing is carried out on this model.
2. Measurements were performed as the procedure mentioned in ANSI C63.10-2013

Table of Contents

1	GENERAL REMARKS.....	4
1.1	Complimentary Materials	4
2	TEST SITES.....	5
2.1	Testing Facilities	5
2.2	List of Test and Measurement Instruments	5
3	GENERAL PRODUCT INFORMATION	6
3.1	Product Function and Intended Use	6
3.2	Ratings and System Details	7
3.3	Measurement Uncertainty:.....	7
4	TEST SET-UP AND OPERATION MODE.....	8
4.1	Principle of Configuration Selection.....	8
4.2	Test Operation and Test Software.....	8
4.3	Special Accessories and Auxiliary Equipment.....	8
4.4	Countermeasures to achieve EMC Compliance	8
4.5	Test modes – data rates and modulations	8
5	TEST METHODOLOGY.....	9
5.1	Radiated Emission Test.....	9
5.1.1	Test Setup Configuration.....	9
6	TEST RESULTS.....	11
6.1	Frequency tolerance.....	11
6.2	Radiated Spurious Emission & Field Strength Measurement within the band 13.110-14.010 MHz.....	14
6.1	Conducted Spurious Emission Test on AC Power Line.....	17
7	LIST OF TABLES	20
8	LIST OF TEST PLOTS	20

1 GENERAL REMARKS

1.1 Complimentary Materials

All attachments are integral part of this test report. This applies especially to the following items.

1. TEST SETUP PHOTOS
- 2: EUT EXTERNAL PHOTOS
- 3: EUT INTERNAL PHOTOS
- 4: FCC LABEL AND LABEL LOCATION
- 5: BLOCK DIAGRAM
- 6: SPECIFICATION OF EUT
- 7: SCHEMATIC DIAGRAM
- 8: BILL OF MATERIAL
- 9: USER MANUAL

2 TEST SITES

2.1 Testing Facilities

TÜV Rheinland (India) Pvt.Ltd.,
27/B, 2nd Cross,
Electronic City , Phase 1
Bangalore – 560 100,

TUV Rheinland (India) Private Limited
108 , Beside ISBR Business School,
Electronic city Phase I
Bangalore - 560 100.

2.2 List of Test and Measurement Instruments

Table 1: List of test and measurement instruments

Equipment	Manufacturer	Model Name	Serial Number	Calibration Due Date	Periodicity	Used for Test Items
Signal Analyzer	Rohde & Schwarz	FSV7	101644	29-12-2019	Yearly	Antenna Port Measurements
Environmental Chamber	Envisys	EM80-40H	ET/022/14-15	21-05-2020	Yearly	
EMI Test Receiver	Rohde & Schwarz	ESU 40	100288	11-10-2019	Yearly	Radiated Spurious Emission
Active loop antenna	Frankonia	LAX-10	LAX-10-800	15-01-2020	Yearly	
Biconical Antenna	Schwarzbeck mess-elektronik	VHBB-9124 / BBA-9106	9124-656	16-01-2020	Yearly	
Log-Periodic Antenna	Schwarzbeck mess-elektronik	VUSLP-9111B	9111B-111	17-01-2020	Yearly	
Broadband Horn Antenna	Frankonia	HAX-18	HAX18-802	17-05-2019	Yearly	
Semi Anechoic Chamber	Frankonia	-	-	-	-	AC Power line conducted emission
EMI Receiver	Rohde & Schwarz	ESR7	101133	16-01-2020	Yearly	
LISN	Rohde & Schwarz	ENV 216	100022	18-10-2019	Yearly	
Pulse Limiter	Rohde & Schwarz	ESH3-Z2	100811	09-08-2019	Yearly	

3 GENERAL PRODUCT INFORMATION

3.1 Product Function and Intended Use

The **Synclara™ Cough System** is intended for use on patients who are unable to cough or clear secretions effectively due to reduced peak cough expiratory flow, as a result of high spinal cord injuries, neuromuscular deficits, or severe fatigue associated with intrinsic lung disease.

The **Volara™ System** is intended for the mobilization of secretions, lung expansion therapy, the treatment and prevention of pulmonary atelectasis, and has the ability to provide supplemental oxygen when used with oxygen supply.

The **Maximus™ System, when used as a Synclara™ Cough System** is indicated for, but is not limited to patients with these conditions:

- Muscular dystrophy
- Spinal muscular atrophy
- Amyotrophic lateral sclerosis
- Spinal cord injuries
- Myasthenia gravis
- Post-polio
- COPD patient with a weak and ineffective cough

The **Maximus™ System, when used as a Volara™ System** is indicated for, but is not limited to patients with these conditions:

- Difficulty in clearance of secretions
- Pulmonary atelectasis

Model differences:

The model POPT1 (Maximus™ System) provides features of both the Synclara™ System and the Volara™ System. The model PSC1 (Synclara™ System) only provides feature of Synclara™ System. It doesn't have the OLE-module. And it's identical to model POPT1 (Maximus™ System) with same rated voltage and rated power, same power supply unit, same output character, except for the circuit diagram, PCB layout and construction.

The model PVL1 (Volara™ System) only provides feature of Volara™ System. And it's identical to model POPT1 (Maximus™ System) with same rated voltage and rated power, same power supply unit, same output character, same the circuit diagram, same PCB layout and same construction.

3.2 Ratings and System Details

Table 2: Ratings and System Details

Operating Frequency Range	13.56 MHz
No. of Channel	Single Channel
Radio Protocol	Short-range devices
Modulation	Amplitude shift keying(ASK)
Number of antennas	1
Antenna Gain & Type	PCB Antenna
Supply Voltage to Product	100-240VAC/50-60Hz
Environmental conditions	Operating: +5 °C to +35 °C
Dimensions	22.3cm x 23.3cm x 27cm

3.3 Measurement Uncertainty:

Table 3: Measurement Uncertainty

Parameter	Uncertainty
RF output power, conducted	±1.5 dB
Unwanted Emissions, conducted	±3 dB
All emissions, radiated	±6 dB
Temperature	±3 °C
Supply Voltages	±3 %
Time	±5 %

4 TEST SET-UP AND OPERATION MODE

4.1 Principle of Configuration Selection

Continuous transmission was enabled upon power up of EUT.

4.2 Test Operation and Test Software

- Hardware version 1
- Software version MCB 0.0.21.0
- Software version DCB 0.0.21.0

4.3 Special Accessories and Auxiliary Equipment

1. Stand Mount
2. Foot switch

4.4 Countermeasures to achieve EMC Compliance

- None

4.5 Test modes – data rates and modulations

For Radiated spurious emissions, the tests were performed for the worst case operating mode and results are reported in this report.

Note:

EUT serial number:

Conducted measurement sample: U044OP0052

Radiated measurement sample : U044OP0050

5 TEST METHODOLOGY

5.1 Radiated Emission Test

The radiated emission measurement was performed according to the procedures in ANSI C63.10-2013. The equipment under test (EUT) was placed at the middle of the 80 cm high turntable for below 1 GHz & 1.5 m height for above 1 GHz measurement, and the EUT is 3 meters far from the measuring antenna. The turntable was rotated 360° for obtaining the maximum emission. The height of the measuring antennas was scanned between 1 m and 4 m, and the antenna rotated to repeat the measurements for both the horizontal and vertical antenna polarizations. Repeat the measurement steps until the maximum emissions were obtained. The measurement above 1000 MHz was performed by horn antenna, The measurement below 30 MHz was performed by loop antenna, Measurement from 30 MHz to 200 MHz was performed by Baloon and Biconical Antenna, and mesurement from 200 MHz to 1 GHz was performed by Log-Periodic Antenna.

The EUT was rotated around the X-, Y-, and Z-Axis and the results from worst case axis are recorded.

5.1.1 Test Setup Configuration




Figure 1: Frequency Range 9 kHz- 30 MHz




Figure 2: Frequency Range 30 MHz – 200 MHz




Figure 3: Frequency Range 200 MHz - 1GHz

6 TEST RESULTS

6.1 Frequency tolerance

Result

Pass

Test Specification	FCC part 15 Subpart C 15.225 (e)
Measurement	10KHz
Bandwidth	
Detector	Peak

Requirement	The frequency tolerance of the carrier signal shall be maintained within $\pm 0.01\%$ of the operating frequency over a temperature variation of -20 degrees to $+ 50$ degrees C at normal supply voltage, and for a variation in the primary supply voltage from 85% to 115% of the rated supply voltage at a temperature of 20 degrees C
-------------	--


Cable Loss & attenuation loss are considered in the test results

Normal Test Condition:

Temperature (Norm) = $+ 25$ °C Voltage (Vnorm) = 230 VAC RH= 62 %


Extreme Test Condition:

Temperature: Low = $+5$ °C
High = $+35$ °C




Test plot 1: Frequency tolerance

Temperature: +5 °C



Test plot 2: Frequency tolerance

Temperature: -Normal



Test plot 3: Frequency tolerance

Temperature: +35°C

6.2 Radiated Spurious Emission & Field Strength Measurement within the band 13.110-14.010 MHz

Result

Pass

Test Specification	FCC part 15 Subpart C Section 15.225 (a,b,c,d) / (15.209)
Test Method	ANSI C 63.10 - 2013
Measurement Location	Semi Anechoic Chamber
Measuring Distance	3 m
Detector	QP for frequency below 1 GHz, average for frequency above 1 GHz
Requirement	As per the limits mentioned in the below table

Table 4: Transmitter limits for Radiated emission

Frequency (MHz)	Field strength (μV/m)	Field strength (dBμV/m)	Distance of Measurement (m)
0.009 – 0.490	2400/F(kHz)	48.50 – 13.80	300*
0.490 – 1.705	24000/F(kHz)	33.80 – 23.00	30*
1.705 -30	30	29.54	30*
30-88	100	40.0	3
88-216	150	43.5	3
216-960	200	46.0	3
Above 960	500	54.0	3

Remark: * The limit shows in the table above of frequency range 0.009 – 0.490, 0.490 – 1.705 MHz and 1.705-30MHz is at 300 meter, 30 meter and 30 meter range respectively, which corresponds to 128.51 – 93.80, 73.80 – 62.96 and 69.54 dBμV/m at 3m range by extrapolation calculation and the measurement of loop antenna.

The emission limits shown in the above table are based on measurements employing a CISPR quasi-peak detector except for the frequency bands 9–90 kHz, 110–490 kHz and above 1000 MHz Radiated emission limits in these three bands are based on measurements employing an average detector.

Test Conditions:

Supply Voltage: 110 VAC, 60 Hz

Environmental conditions:

Temperature: +25 °C RH: 61.76 %

Prüfbericht - Nr.:

Test Report No.:

ULR-TC568819300000029F 001

Seite 15 von 20

Page 15 of 20

Test results:

Table 5:Tranmitter test results for frequency 9kHz to 30MHz

Polarization	Measured Frequency (MHz)	Field Strength (dBµV/m)	Limit (dBµV/m)	Margin (dB)
Parallel	0.071	21.41	110.58	-89.17
	0.092	32.68	108.33	-75.65
	0.127	33.2	105.33	-72.13
Perpendicular	0.086	30.97	108.91	-77.94
	0.128	26.31	105.46	-79.15

Table 6: Transmitter test results in the frequency band of 13.11MHz to 14.01MHz

Polarization	Frequency Range (MHz)	Measured Frequency (MHz)	Field Strength (dBµV/m)	Limit (dBµV/m)	Margin (dB)
Parallel	13.11-13.41	13.135	31.88	125.24	-93.36
	13.41-13.553	13.535	45.9	124.98	-79.08
	13.553-13.567	13.56	62.67	124.96	-62.29
	13.567-13.71	13.585	40.35	124.94	-84.59
	13.71-14.01	13.825	27.95	124.79	-96.84
Perpendicular	13.11-13.41	13.39	29.39	125.07	-95.68
	13.41-13.553	13.435	28.03	125.04	-97.01
	13.553-13.567	13.56	61.15	124.96	-63.81
	13.567-13.71	13.61	41.22	124.93	-83.71
	13.71-14.01	13.735	27.93	124.85	-96.92

Prüfbericht- Nr.:

Test Report No.:

ULR-TC568819300000029F 001

Seite 16 von 20

Page 16 of 20

Table 7:Transmitter test results for the frequency 30 MHz – 1 GHz

Table Top:

Volara Mode:

Polarization	Frequency (MHz)	Measured value (dBµV/m)	Limit (dBµV/m)	Margin (dB)
Vertical	40.676	33.67	40	-6.33
	46.88	34.09	40	-5.91
	83.992	33.55	40	-6.45
	221.36	40.12	46	-5.88
	336.02	36.73	46	-9.27
Horizontal	89.98	31.90	43.5	-11.6
	193.9	35.19	43.5	-8.31
	335.95	39.33	46	-6.67

Syncara Mode:

Polarization	Frequency (MHz)	Measured value (dBµV/m)	Limit (dBµV/m)	Margin (dB)
Vertical	42.24	21.75	40	-18.25
	81.87	22.92	40	-17.08
	163.35	16.87	43.5	-26.63
	503.9	22.64	46	-23.36
	672.11	28.46	46	-17.54
Horizontal	42.36	21.83	40	-18.17
	45.27	21.12	40	-18.88
	73.68	17.19	40	-22.81
	504.02	25.92	46	-20.08
	672.14	26.14	46	-19.86

Stand Mount:

Polarization	Frequency (MHz)	Measured value (dBµV/m)	Limit (dBµV/m)	Margin (dB)
Vertical	89.96	34.83	40	-5.17
	149.95	34.8	40	-5.2
	233.68	37.13	40	-2.87
	755.78	37.15	46	-8.85
Horizontal	89.98	32.05	43.5	-11.45
	191.55	33.81	43.5	-9.69
	238.85	44.02	46	-1.98
	335.94	38.8	46	-7.2

6.1 Conducted Spurious Emission Test on AC PowerLine

Result

Pass

Test Specification : FCC Part 15 Section 15.207
RSS-Gen Issue 4 section 8.8
Test Method : ANSI C63.10-2013
Testing Location : Screened room
Measurement Bandwidth : 9kHz
Frequency Range : 150kHz – 30MHz
Supply Voltage : 110VAC, 60Hz

Limits: FCC Part 15 section 15.207 and RSS-Gen Issue 4 section 8.8


Frequency of emission (MHz)	QP Limit (dBμV)	AV Limit (dBμV/m)
0.15 – 0.5	66 – 56*	56 – 46*
0.5 – 5	56	46
5 – 30	60	50

* Decreases with the logarithm of the frequency

Test Result

110V AC_60Hz_Line


Trace	Frequency	Level (dBµV)	Phase	Detector	Delta Limit/dB
2	686.000000000 kHz	29.49		Average	-16.51
2	214.000000000 kHz	35.79		Average	-17.26
1	214.000000000 kHz	45.12		Quasi Peak	-17.93
2	826.000000000 kHz	27.09		Average	-18.91
2	550.000000000 kHz	26.34		Average	-19.66
2	26.398000000 MHz	29.02		Average	-20.98
2	274.000000000 kHz	29.79		Average	-21.21
2	274.000000000 kHz	29.71		Average	-21.29
1	150.000000000 kHz	44.27		Quasi Peak	-21.73
1	730.000000000 kHz	34.01		Quasi Peak	-21.99
1	826.000000000 kHz	33.07		Quasi Peak	-22.93
2	13.562000000 MHz	26.76		Average	-23.24
1	542.000000000 kHz	32.59		Quasi Peak	-23.41
1	1.046000000 MHz	30.36		Quasi Peak	-25.64
1	26.222000000 MHz	32.44		Quasi Peak	-27.56
1	13.562000000 MHz	30.49		Quasi Peak	-29.51



Line: Graph

110V AC_60Hz_Neutral

Trace	Frequency	Level (dBµV)	Phase	Detector	Delta Limit/dB
2	730.000000000 kHz	30.56		Average	-15.44
2	550.000000000 kHz	26.38		Average	-19.62
1	730.000000000 kHz	35.28		Quasi Peak	-20.72
1	214.000000000 kHz	41.55		Quasi Peak	-21.50
1	826.000000000 kHz	34.31		Quasi Peak	-21.69
2	13.622000000 MHz	28.04		Average	-21.96
2	1.014000000 MHz	23.94		Average	-22.06
2	586.000000000 kHz	23.79		Average	-22.21
2	25.682000000 MHz	26.63		Average	-23.37
2	278.000000000 kHz	26.94		Average	-23.94
2	214.000000000 kHz	27.03		Average	-26.02
1	526.000000000 kHz	29.32		Quasi Peak	-26.68
1	1.190000000 MHz	28.30		Quasi Peak	-27.70
2	6.362000000 MHz	22.23		Average	-27.77
1	13.558000000 MHz	31.75		Quasi Peak	-28.25
1	26.818000000 MHz	30.78		Quasi Peak	-29.22
2	5.578000000 MHz	20.66		Average	-29.34
1	150.000000000 kHz	28.07		Quasi Peak	-37.93
1	382.000000000 kHz	20.13		Quasi Peak	-38.11
2	150.000000000 kHz	17.06		Average	-38.94



Neutral: Graph

7 LIST OF TABLES

Table 1: List of test and measurement instruments.....	5
Table 2: Ratings and System Details.....	7
Table 3: Measurement Uncertainty	7
Table 4: Transmitter limits for Radiated emission	14
Table 5: Transmitter test results for frequency 9kHz to 30MHz.....	15
Table 6: Transmitter test results in the frequency band of 13.11MHz to 14.01MHz	15
Table 7: Transmitter test results for the frequency 30 MHz – 1 GHz	16

8 LIST OF TEST PLOTS

Test plot 1: Frequency tolerance	Temperature: +5 °C	12
Test plot 2: Frequency tolerance	Temperature: -Normal.....	12
Test plot 3: Frequency tolerance	Temperature: +35°C.....	13

END OF TEST REPORT