

System Check_HSL750MHz

DUT: D750V3-1199

Communication System: CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: HSL750_231130 Medium parameters used: $f = 750$ MHz; $\sigma = 0.89$ S/m; $\epsilon_r = 42.637$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.5 °C; Liquid Temperature : 22.7°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(10.04, 10.04, 10.04) @ 750 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 31.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=250mW/Area Scan (7x8x1): Measurement grid: $dx=15$ mm, $dy=15$ mm

Maximum value of SAR (measured) = 2.76 W/kg


Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8$ mm, $dy=8$ mm, $dz=5$ mm

Reference Value = 57.23 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 3.01 W/kg

SAR(1 g) = 2.09 W/kg; SAR(10 g) = 1.43 W/kg

Maximum value of SAR (measured) = 2.71 W/kg



System Check_HSL835MHz

DUT: D835V2 - SN:4d058

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: HSL850_231125 Medium parameters used: $f = 835$ MHz; $\sigma = 0.908$ S/m; $\epsilon_r = 42.65$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.1 °C; Liquid Temperature : 22.2°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(9.76, 9.76, 9.76) @ 835 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 31.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=250mW/Area Scan (7x8x1): Measurement grid: $dx=15$ mm, $dy=15$ mm

Maximum value of SAR (measured) = 3.21 W/kg


Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8$ mm, $dy=8$ mm, $dz=5$ mm

Reference Value = 58.83 V/m; Power Drift = -0.10 dB

Peak SAR (extrapolated) = 3.73 W/kg

SAR(1 g) = 2.47 W/kg; SAR(10 g) = 1.63 W/kg

Maximum value of SAR (measured) = 3.29 W/kg



0 dB = 3.29 W/kg = 5.17 dBW/kg

System Check_HSL835MHz

DUT: D835V2 - SN:4d058

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: HSL835_231130 Medium parameters used: $f = 835$ MHz; $\sigma = 0.918$ S/m; $\epsilon_r = 42.374$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.5 °C; Liquid Temperature : 22.7°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(9.76, 9.76, 9.76) @ 835 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 31.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=250mW/Area Scan (7x8x1): Measurement grid: $dx=15$ mm, $dy=15$ mm

Maximum value of SAR (measured) = 3.17 W/kg


Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8$ mm, $dy=8$ mm, $dz=5$ mm

Reference Value = 57.87 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 3.64 W/kg

SAR(1 g) = 2.44 W/kg; SAR(10 g) = 1.63 W/kg

Maximum value of SAR (measured) = 3.24 W/kg



0 dB = 3.24 W/kg = 5.11 dBW/kg

System Check_HSL835MHz

DUT: D835V2 - SN:4d058

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: HSL835_231202 Medium parameters used: $f = 835$ MHz; $\sigma = 0.913$ S/m; $\epsilon_r = 42.374$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.1 °C; Liquid Temperature : 22.0°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(9.76, 9.76, 9.76) @ 835 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 31.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=250mW/Area Scan (7x13x1): Measurement grid: $dx=15$ mm, $dy=15$ mm

Maximum value of SAR (measured) = 3.31 W/kg


Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: $dx=5$ mm, $dy=5$ mm, $dz=5$ mm

Reference Value = 59.17 V/m; Power Drift = -0.00 dB

Peak SAR (extrapolated) = 3.82 W/kg

SAR(1 g) = 2.48 W/kg; SAR(10 g) = 1.63 W/kg

Maximum value of SAR (measured) = 3.33 W/kg



0 dB = 3.33 W/kg = 5.22 dBW/kg

System Check_HSL1800MHz

DUT: D1800V2-SN:2d156

Communication System: CW; Frequency: 1800 MHz; Duty Cycle: 1:1

Medium: HSL1800_231125 Medium parameters used: $f = 1800$ MHz; $\sigma = 1.378$ S/m; $\epsilon_r = 40.29$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.1 °C; Liquid Temperature : 22.1 °C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(8.53, 8.53, 8.53) @ 1800 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 31.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=250mW/Area Scan (7x7x1): Measurement grid: $dx=15$ mm, $dy=15$ mm

Maximum value of SAR (measured) = 13.5 W/kg


Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8$ mm, $dy=8$ mm, $dz=5$ mm

Reference Value = 96.94 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 16.6 W/kg

SAR(1 g) = 9.21 W/kg; SAR(10 g) = 4.87 W/kg

Maximum value of SAR (measured) = 14.1 W/kg



System Check_HSL1800MHz

DUT: D1800V2-SN:2d156

Communication System: CW; Frequency: 1800 MHz; Duty Cycle: 1:1

Medium: HSL1800_231130 Medium parameters used: $f = 1800$ MHz; $\sigma = 1.333$ S/m; $\epsilon_r = 40.106$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.5 °C; Liquid Temperature : 22.7°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(8.53, 8.53, 8.53) @ 1800 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 31.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=250mW/Area Scan (7x7x1): Measurement grid: $dx=15$ mm, $dy=15$ mm

Maximum value of SAR (measured) = 13.5 W/kg


Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8$ mm, $dy=8$ mm, $dz=5$ mm

Reference Value = 98.50 V/m; Power Drift = 0.01 dB

Peak SAR (extrapolated) = 16.7 W/kg

SAR(1 g) = 9.19 W/kg; SAR(10 g) = 4.86 W/kg

Maximum value of SAR (measured) = 14.0 W/kg



0 dB = 14.0 W/kg = 11.46 dBW/kg

System Check_HSL1900MHz

DUT: D1900V2-SN:5d090

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: HSL1900_231124 Medium parameters used: $f = 1900$ MHz; $\sigma = 1.46$ S/m; $\epsilon_r = 39.715$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.2 °C; Liquid Temperature : 22.3 °C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(8.29, 8.29, 8.29) @ 1900 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 31.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=250mW/Area Scan (7x7x1): Measurement grid: $dx=15$ mm, $dy=15$ mm

Maximum value of SAR (measured) = 15.4 W/kg


Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8$ mm, $dy=8$ mm, $dz=5$ mm

Reference Value = 100.0 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 18.8 W/kg

SAR(1 g) = 10.2 W/kg; SAR(10 g) = 5.28 W/kg

Maximum value of SAR (measured) = 15.8 W/kg



System Check_HSL1900MHz

DUT: D1900V2-SN:5d090

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: HSL1900_231130 Medium parameters used: $f = 1900$ MHz; $\sigma = 1.392$ S/m; $\epsilon_r = 39.942$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.5 °C; Liquid Temperature : 22.7°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(8.29, 8.29, 8.29) @ 1900 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 31.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=250mW/Area Scan (7x7x1): Measurement grid: $dx=15$ mm, $dy=15$ mm

Maximum value of SAR (measured) = 13.8 W/kg


Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8$ mm, $dy=8$ mm, $dz=5$ mm

Reference Value = 97.59 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 16.9 W/kg

SAR(1 g) = 9.55 W/kg; SAR(10 g) = 5.09 W/kg

Maximum value of SAR (measured) = 14.5 W/kg



0 dB = 14.5 W/kg = 11.61 dBW/kg

System Check_HSL1900MHz

DUT: D1900V2-SN:5d090

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: HSL1900_231202 Medium parameters used: $f = 1900$ MHz; $\sigma = 1.397$ S/m; $\epsilon_r = 39.715$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.1 °C; Liquid Temperature : 22.0°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(8.29, 8.29, 8.29) @ 1900 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 31.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=250mW/Area Scan (7x7x1): Measurement grid: $dx=15$ mm, $dy=15$ mm

Maximum value of SAR (measured) = 15.9 W/kg


Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8$ mm, $dy=8$ mm, $dz=5$ mm

Reference Value = 103.8 V/m; Power Drift = 0.00 dB

Peak SAR (extrapolated) = 18.7 W/kg

SAR(1 g) = 10.2 W/kg; SAR(10 g) = 5.32 W/kg

Maximum value of SAR (measured) = 15.9 W/kg



0 dB = 15.9 W/kg = 12.01 dBW/kg

System Check_HSL1900MHz

DUT: D1900V2-SN:5d090

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: HSL1900_231229 Medium parameters used: $f = 1900$ MHz; $\sigma = 1.416$ S/m; $\epsilon_r = 40.142$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.0 °C; Liquid Temperature : 21.9°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(8.29, 8.29, 8.29) @ 1900 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 31.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=250mW/Area Scan (7x7x1): Measurement grid: $dx=15$ mm, $dy=15$ mm

Maximum value of SAR (measured) = 14.1 W/kg


Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8$ mm, $dy=8$ mm, $dz=5$ mm

Reference Value = 97.48 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 17.1 W/kg

SAR(1 g) = 9.68 W/kg; SAR(10 g) = 5.16 W/kg

Maximum value of SAR (measured) = 14.6 W/kg



System Check_HSL2450MHz

DUT: D2450V2-SN:804

Communication System: CW; Frequency: 2450 MHz; Duty Cycle: 1:1

Medium: HSL2450_231203 Medium parameters used: $f = 2450$ MHz; $\sigma = 1.855$ S/m; $\epsilon_r =$

40.418 ; $\rho = 1000$ kg/m³

Ambient Temperature : 23.2 °C; Liquid Temperature : 22.1 °C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(7.69, 7.69, 7.69) @ 2450 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 31.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=250mW/Area Scan (8x8x1): Measurement grid: $dx=12$ mm, $dy=12$ mm

Maximum value of SAR (measured) = 18.8 W/kg


Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: $dx=5$ mm, $dy=5$ mm, $dz=5$ mm

Reference Value = 101.5 V/m; Power Drift = 0.04 dB

Peak SAR (extrapolated) = 27.2 W/kg

SAR(1 g) = 13.3 W/kg; SAR(10 g) = 6.3 W/kg

Maximum value of SAR (measured) = 21.8 W/kg



System Check_HSL2600MHz

DUT: D2600V2-SN:1171

Communication System: CW; Frequency: 2600 MHz; Duty Cycle: 1:1

Medium: HSL2600_231127 Medium parameters used: $f = 2600$ MHz; $\sigma = 1.973$ S/m; $\epsilon_r = 39.801$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.0 °C; Liquid Temperature : 21.9°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(7.39, 7.39, 7.39) @ 2600 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 31.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=250mW/Area Scan (8x8x1): Measurement grid: $dx=12$ mm, $dy=12$ mm

Maximum value of SAR (measured) = 18.1 W/kg


Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: $dx=5$ mm, $dy=5$ mm, $dz=5$ mm

Reference Value = 102.3 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 27.9 W/kg

SAR(1 g) = 13.7 W/kg; SAR(10 g) = 6.38 W/kg

Maximum value of SAR (measured) = 22.9 W/kg



System Check_HSL5250MHz

DUT: D5GHzV2-SN:1235

Communication System: CW; Frequency: 5250 MHz; Duty Cycle: 1:1

Medium: HSL5G_231210 Medium parameters used: $f = 5250$ MHz; $\sigma = 4.61$ S/m; $\epsilon_r = 35.777$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.4 °C; Liquid Temperature : 21.8°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(5.07, 5.07, 5.07) @ 5250 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 23.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=100mW/Area Scan (10x10x1): Measurement grid: $dx=10$ mm, $dy=10$ mm

Maximum value of SAR (measured) = 13.8 W/kg


Pin=100mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: $dx=4$ mm, $dy=4$ mm, $dz=1.4$ mm

Reference Value = 61.58 V/m; Power Drift = -0.09 dB

Peak SAR (extrapolated) = 30.0 W/kg

SAR(1 g) = 8.19 W/kg; SAR(10 g) = 2.41 W/kg

Maximum value of SAR (measured) = 19.6 W/kg



System Check_HSL5250MHz

DUT: D5GHzV2-SN:1235

Communication System: CW; Frequency: 5250 MHz; Duty Cycle: 1:1

Medium: HSL5G_240102 Medium parameters used: $f = 5250$ MHz; $\sigma = 4.645$ S/m; $\epsilon_r = 35.897$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.1 °C; Liquid Temperature : 21.9°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(5.07, 5.07, 5.07) @ 5250 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 23.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=100mW/Area Scan (10x10x1): Measurement grid: $dx=10$ mm, $dy=10$ mm

Maximum value of SAR (measured) = 13.9 W/kg


Pin=100mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: $dx=4$ mm, $dy=4$ mm, $dz=1.4$ mm

Reference Value = 61.58 V/m; Power Drift = -0.09 dB

Peak SAR (extrapolated) = 30.3 W/kg

SAR(1 g) = 8.25 W/kg; SAR(10 g) = 2.43 W/kg

Maximum value of SAR (measured) = 19.7 W/kg



System Check_HSL5600MHz

DUT: D5GHzV2-SN:1235

Communication System: CW; Frequency: 5600 MHz; Duty Cycle: 1:1

Medium: HSL5G_231210 Medium parameters used: $f = 5600$ MHz; $\sigma = 4.975$ S/m; $\epsilon_r = 35.127$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.4 °C; Liquid Temperature : 21.8°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(4.72, 4.72, 4.72) @ 5600 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 23.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=100mW/Area Scan (10x10x1): Measurement grid: $dx=10$ mm, $dy=10$ mm

Maximum value of SAR (measured) = 14.7 W/kg


Pin=100mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: $dx=4$ mm, $dy=4$ mm, $dz=1.4$ mm

Reference Value = 60.85 V/m; Power Drift = -0.12 dB

Peak SAR (extrapolated) = 33.4 W/kg

SAR(1 g) = 8.38 W/kg; SAR(10 g) = 2.45 W/kg

Maximum value of SAR (measured) = 20.6 W/kg



0 dB = 20.6 W/kg = 13.14 dBW/kg

System Check_HSL5600MHz

DUT: D5GHzV2-SN:1235

Communication System: CW; Frequency: 5600 MHz; Duty Cycle: 1:1

Medium: HSL5G_240102 Medium parameters used: $f = 5600$ MHz; $\sigma = 5.012$ S/m; $\epsilon_r = 35.246$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.1 °C; Liquid Temperature : 21.9°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(4.72, 4.72, 4.72) @ 5600 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 23.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=100mW/Area Scan (10x10x1): Measurement grid: $dx=10$ mm, $dy=10$ mm

Maximum value of SAR (measured) = 14.8 W/kg


Pin=100mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: $dx=4$ mm, $dy=4$ mm, $dz=1.4$ mm

Reference Value = 60.85 V/m; Power Drift = -0.12 dB

Peak SAR (extrapolated) = 33.7 W/kg

SAR(1 g) = 8.45 W/kg; SAR(10 g) = 2.47 W/kg

Maximum value of SAR (measured) = 20.8 W/kg



System Check_HSL5750MHz

DUT: D5GHzV2-SN:1235

Communication System: CW; Frequency: 5750 MHz; Duty Cycle: 1:1

Medium: HSL5G_231210 Medium parameters used: $f = 5750$ MHz; $\sigma = 5.132$ S/m; $\epsilon_r = 34.873$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.4 °C; Liquid Temperature : 21.8°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(4.8, 4.8, 4.8) @ 5750 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 23.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=100mW/Area Scan (10x10x1): Measurement grid: $dx=10$ mm, $dy=10$ mm

Maximum value of SAR (measured) = 14.2 W/kg


Pin=100mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: $dx=4$ mm, $dy=4$ mm, $dz=1.4$ mm

Reference Value = 68.27 V/m; Power Drift = -0.17 dB

Peak SAR (extrapolated) = 33.8 W/kg

SAR(1 g) = 7.99 W/kg; SAR(10 g) = 2.39 W/kg

Maximum value of SAR (measured) = 20.4 W/kg



System Check_HSL5750MHz

DUT: D5GHzV2-SN:1235

Communication System: CW; Frequency: 5750 MHz; Duty Cycle: 1:1

Medium: HSL5G_240102 Medium parameters used: $f = 5750$ MHz; $\sigma = 5.17$ S/m; $\epsilon_r = 34.993$; $\rho = 1000$ kg/m³

Ambient Temperature : 23.1 °C; Liquid Temperature : 21.9°C

DASY Configuration:

- Electronics: DAE4 Sn855; Calibrated: 2023/4/25
- Probe: EX3DV4 - SN7400; ConvF(4.8, 4.8, 4.8) @ 5750 MHz; Calibrated: 2023/4/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = -9.0, 23.0$
- Phantom: Right_Twin-SAM V4.0 (20deg probe tilt); Type: QD 000 P40 CC; Serial: TP-1467
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Pin=100mW/Area Scan (10x10x1): Measurement grid: $dx=10$ mm, $dy=10$ mm

Maximum value of SAR (measured) = 14.3 W/kg

Pin=100mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: $dx=4$ mm, $dy=4$ mm, $dz=1.4$ mm

Reference Value = 68.27 V/m; Power Drift = -0.17 dB

Peak SAR (extrapolated) = 34.1 W/kg

SAR(1 g) = 8.05 W/kg; SAR(10 g) = 2.41 W/kg

Maximum value of SAR (measured) = 20.5 W/kg

