

## Justification for Re-use of radio test results

We, **Honeywell (Beijing) Technology Solutions Lab Co., Ltd.**, believe that the conducted signal tests in the original test reports for model CPO-PC400-W can be re-used for the current model IO-10MIXR-NWE, as the following reason:

They use the same RF module WM-BAC-BM-25.

The difference between them is that the design of Smart IO (IO-10MIXR-WE) to integrate with RF module WM-BAC-BM-25 for wireless function as part of circuit on main board, with differentiate electrical functional design and different PCB layout on both main board and base board to implement analog/digital output and input signal detects and monitors, hence to act as advanced wireless field device.

According to KDB 484596 D01, This change not affects RF characteristics and the two models are electrically identical in conducted signal. As for radiated items, we re-test them.

FCC Part	Reference ID	Report No.	Justification of re-use
15.247,	FCC ID: 2ARTN-00001,	SRTC2018-9004(F)-18102401(D) SRTC2018-9004(F)-18102401(E) SRTC2018-9004(F)-18102401(F) SRTC2018-9004(F)-18102401(G)	See above
RSS-247	IC: 24552-00001	SRTC2018-9004(I)-18102401(D) SRTC2018-9004(I)-18102401(E) SRTC2018-9004(I)-18102401(F) SRTC2018-9004(I)-18102401(G)	

John Zhang  
2020.11.16