


### **GENERAL INFORMATION**

FCCID: 2AS3B-TRIKLORAME

### 1.1. Product description




Specialist in water treatment analysis, control & management



# **TRIKLORAME**

TRICHLORAMINE IN THE AIR: A REAL HEALTH PROBLEM



### TRICHLORAMINE IN THE AIR


Trichloramine belongs to the Chloramine family and is developping during the combination of chlorine products used for disinfection of water and nitrogen pollution made by organic derivatives (sweat, saliva, urine, bacteria, sun cream, animal or plant debris, sap...)

Trichloramine is a highly volatile substance, irritating for breathing system, eyes and skin, recognized as occupational diseases in «Occupational Asthmas and Rhinitis» category (French decree 2003-110 of 11/02/2003)

### **CURRENT REGULATIONS**

- · Analysis requirement for swimming pools equipped with a UV dechlorinator (DGS: EA4 2008-65 du 22/02/2008)
- $\boldsymbol{\cdot}$  Obligation to prevent and analyze occupational risks according to the labor code
- $\cdot$  Table of occupational diseases, category « rhinitis and asthma » decree 2003-110 of 11/02/2003)
- $\cdot$  ANSES (National Agency for food, environment and work safety) recommends to integrate to the sanitary control the monitoring of trichloramine in the air with a limit value of 0.3 mg/m

### A REAL HEALTH PROBLEM



of consulted master swimmers suffer from eye irritation\*

 $<sup>^{\</sup>circ}$  pools with a trichloramine in the air level between 0,22- 0,50 mg/m  $^{3}$ 



## **TRIKLORAME**

NEW PORTABLE MEASUREMENT OF TRICHLORAMINE IN THE AIR

For 10 years SYCLOPE Electronique collaborates with the INRS (National Institute of Research and Security) on the problem of trichloramine in the air measurement in order to propose a reliable tool for determining the exposure

Recognizing the importance of health problems caused by trichloramine in the air, these two entities decided to optimize the existing analysis equipment by making a new one simpler in use, faster in its execution, more reliable and effective. This new portable measurement tool, TRIKLORAME, determines the level of trichloramine in the air in a clear and simplified way in order to implement the preventive or corrective actions necessary to better protect the exposed persons.





### **ADVANTAGES**

- Simplified portable measurement of trichloramine in the air Faster and more efficient measurement requiring little manipulations
- · The most accurate self-checking and prevention system of
- Total autonomy in controlling trichloramine levels
   No chemicals to handle
- · Clear and precise display in mg/m³
- · Optimum measurement quality
- · Patented by the INRS

**IMPORTANT: A REGULAR FOLLOW-UP OF** TRICHLORAMINE IN THE AIR LEVEL

### PREVENTION AND CORRECTIVE ACTIONS

- 1- Specific and regular measures to respond to an immediate problem (following a complaint from a master swimmer or users...) with a return to action within 1h
- 2- Occupational Exposure Limit Value with a measurement over 8h
- 3- Mapping risk areas of the pool to implement prevention





# **TRIKLORAME**

NEW PORTABLE MEASUREMENT OF TRICHLORAMINE IN THE AIR



### **COMPOSITIONS**

- Portable measuring device of trichloramine
   Sampling device
   Sampling pellets
   Using tools
   Non-chemical reagent



Contained in a suitcase Possibility of 20 samples





Rue du Bruscos - 64230 SAUVAGNON - France Tét. +33 (0)5 59 33 70 36 / Fax +33 (0)5 59 33 70 37 syclope@syclope.fr / www.syclope.fr



### **LCIE SUD EST**

Laboratoire de Moirans Z.I. Centr'Alp 170, Rue de Chatagnon 38430 MOIRANS - FRANCE


1.2. Tested System Details

### **Equipment under test (EUT):**

- EUT 1 : TRIKLORAME
- EUT 2 : DOSIMETER
- Serial Number of the EUT 1 : 190301623
- Serial Number of the EUT 2 : 190301653
- Model under test of the EUT1: PCC0029
- Model under test of the EUT1: CHM0072







Equipment Under Test 2: DOSIMETER

### Power supply:

During all the tests, EUT is supplied by V<sub>nom</sub>: 3 VDC and 3,6VDC For measurement with different voltage, it will be presented in test method.

Name	Туре	Rating	Reference / Sn	Comments
Supply1	□ AC □ DC ☑ Battery	3VDC	-	EUT1
Supply2	□ AC □ DC ☑ Battery	3,6VDC	-	EUT2



### LCIE SUD EST Laboratoire de Moirans Z.I. Centr'Alp

170, Rue de Chatagnon 38430 MOIRANS - FRANCE

Inputs/outputs - Cable:

Access			Declared <3m	Shielded	Under test	Comments
		(m) Ione	<b>\3111</b>		test	
	None					

Auxiliary equipment used during test:

Туре	FCC Id	Reference	Sn	Comments	
None					

#### 1.1. EUT CONFIGURATION – RUNNING MODE

Hardware information					
Highest internal frequency (PLL, Quartz, Clock, Microprocessor):	F <sub>Highest</sub> :	16	MHz		
Firmware (if applicable):	V. :	1.0			
Software (if applicable):  V.:  Not appl		plicable			

### Configuration n°1:

Based on firmware V1.0, the software has been modified to make continuous measurements with an operating cycle of less than 3s.

A resistance of 39K +/- 1% is soldered between the 2 terminals of the contacts which connect the measurement vial to the device in real case. This resistance is there to simulate the measurement vial.

### 1.3. Test Methodology

Both conducted and radiated testing were performed according to the procedures in ANSI C63.4 or/and ANSI C63.10, FCC Part 15 SubPart 15B.

Radiated testing was performed at an antenna to EUT distance of 10 meters. During testing, all equipment's and cables were moved relative to each other in order to identify the worst case set-up.

### 1.4. Test facility

Tests have been performed: January 22, 2019 to January 24, 2019

This test facility has been fully described in a report and accepted by FCC as compliant with the radiated and AC line conducted test site criteria in ANSI C63.4 or/and ANSI C63.10.

This test facility has also been accredited by COFRAC (French accreditation authority for European Union test lab accreditation organization) according to NF EN ISO/IEC 17025, as compliant with test site criteria and competence in 47 CFR Part 15/ANSI C63.4 and EN55032/CISPR32 norms for 89/336/EEC European EMC Directive application. All pertinent data for this test facility remains unchanged.