

20221205_SystemPerformanceCheck-D1750V2_SN 1180

Frequency: 1750 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C
 Medium parameters used: $f = 1750$ MHz; $\sigma = 1.334$ S/m; $\epsilon_r = 40.294$; $\rho = 1000$ kg/m³

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1667; Calibrated: 2022-04-27
- Probe: EX3DV4 - SN7314; ConvF(8.39, 8.39, 8.39) @ 1750 MHz; Calibrated: 2022-05-31
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (20deg probe tilt); Type: QD 000 P40 CD; Serial: 1751

Head/1750MHz, Pin=100mW/Area Scan (7x7x1): Measurement grid: dx=15mm, dy=15mm
 Maximum value of SAR (measured) = 5.07 W/kg


Head/1750MHz, Pin=100mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 58.16 V/m; Power Drift = -0.13 dB

Peak SAR (extrapolated) = 6.08 W/kg

SAR(1 g) = 3.29 W/kg; SAR(10 g) = 1.78 W/kg

Maximum value of SAR (measured) = 5.07 W/kg



0 dB = 5.07 W/kg = 7.05 dBW/kg

20221219_SystemPerformanceCheck-D1750V2_SN 1125

Frequency: 1750 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C

Medium parameters used: $f = 1750$ MHz; $\sigma = 1.341$ S/m; $\epsilon_r = 39.789$; $\rho = 1000$ kg/m³

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1667; Calibrated: 2022-04-27
- Probe: EX3DV4 - SN7314; ConvF(8.39, 8.39, 8.39) @ 1750 MHz; Calibrated: 2022-05-31
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (20deg probe tilt); Type: QD 000 P40 CD; Serial: 1751

Head/1750MHz, Pin=100 mW/Area Scan (7x7x1): Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (measured) = 5.48 W/kg

Head/1750MHz, Pin=100 mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm,


dz=5mm

Reference Value = 58.93 V/m; Power Drift = -0.02 dB

Peak SAR (extrapolated) = 6.40 W/kg

SAR(1 g) = 3.48 W/kg; SAR(10 g) = 1.85 W/kg

Maximum value of SAR (measured) = 5.39 W/kg



0 dB = 5.39 W/kg = 7.32 dBW/kg

20230102_SystemPerformanceCheck-D1900V2_SN 5d199

Frequency: 1900 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C

Medium parameters used: $f = 1900$ MHz; $\sigma = 1.416$ S/m; $\epsilon_r = 41.002$; $\rho = 1000$ kg/m³

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1667; Calibrated: 2022-04-27
- Probe: EX3DV4 - SN7314; ConvF(8.08, 8.08, 8.08) @ 1900 MHz; Calibrated: 2022-05-31
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (20deg probe tilt); Type: QD 000 P40 CD; Serial: 1751

Head/1900MHz, Pin=100 mW/Area Scan (7x7x1): Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (measured) = 5.91 W/kg

Head/1900MHz, Pin=100 mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm,


dz=5mm

Reference Value = 60.12 V/m; Power Drift = -0.05 dB

Peak SAR (extrapolated) = 7.17 W/kg

SAR(1 g) = 3.72 W/kg; SAR(10 g) = 1.91 W/kg

Maximum value of SAR (measured) = 5.94 W/kg



0 dB = 5.94 W/kg = 7.74 dBW/kg

20230117_SystemPerformanceCheck-D3500V2_SN 1121

Frequency: 3500 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C

Medium parameters used: $f = 3500$ MHz; $\sigma = 2.866$ S/m; $\epsilon_r = 37.514$; $\rho = 1000$ kg/m³

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1667; Calibrated: 2022-04-27
- Probe: EX3DV4 - SN7376; ConvF(7.22, 7.22, 7.22) @ 3500 MHz; Calibrated: 2022-07-27
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (20deg probe tilt); Type: QD 000 P40 CD; Serial: 1751

Head/3500MHz, Pin=100mW/Area Scan (6x7x1): Measurement grid: dx=12mm, dy=12mm

Maximum value of SAR (measured) = 8.89 W/kg

Head/3500MHz, Pin=100mW/Zoom Scan (7x7x8)/Cube 0: Measurement grid: dx=5mm, dy=5mm,


dz=1.4mm

Reference Value = 65.65 V/m; Power Drift = -0.00 dB

Peak SAR (extrapolated) = 14.7 W/kg

SAR(1 g) = 6.23 W/kg; SAR(10 g) = 2.42 W/kg

Maximum value of SAR (measured) = 11.6 W/kg



0 dB = 11.6 W/kg = 10.64 dBW/kg

20230117_SystemPerformanceCheck-D3700V2_SN 1036

Frequency: 3700 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C

Medium parameters used: $f = 3700$ MHz; $\sigma = 3.088$ S/m; $\epsilon_r = 36.923$; $\rho = 1000$ kg/m³

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1667; Calibrated: 2022-04-27
- Probe: EX3DV4 - SN7376; ConvF(7.05, 7.05, 7.05) @ 3700 MHz; Calibrated: 2022-07-27
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (20deg probe tilt); Type: QD 000 P40 CD; Serial: 1751

Head/3700MHz, Pin=100mW/Area Scan (5x7x1): Measurement grid: dx=12mm, dy=12mm

Maximum value of SAR (measured) = 11.7 W/kg

Head/3700MHz, Pin=100mW/Zoom Scan (7x7x8)/Cube 0: Measurement grid: dx=5mm, dy=5mm,


dz=1.4mm

Reference Value = 65.68 V/m; Power Drift = -0.04 dB

Peak SAR (extrapolated) = 15.5 W/kg

SAR(1 g) = 6.26 W/kg; SAR(10 g) = 2.36 W/kg

Maximum value of SAR (measured) = 11.9 W/kg



0 dB = 11.9 W/kg = 10.76 dBW/kg

20230119_SystemPerformanceCheck-D1900V2_SN 5d190

Frequency: 1900 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C

Medium parameters used: $f = 1900$ MHz; $\sigma = 1.409$ S/m; $\epsilon_r = 39.919$; $\rho = 1000$ kg/m³

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1343; Calibrated: 2022-08-18
- Probe: EX3DV4 - SN7545; ConvF(8.02, 8.02, 8.02) @ 1900 MHz; Calibrated: 2022-08-19
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: SAM (20deg probe tilt) with CRP v5.0(Right); Type: QD000P40CD; Serial: TP:xxxx

Head/1900MHz, Pin=100 mW/Area Scan (7x7x1): Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (measured) = 5.43 W/kg

Head/1900MHz, Pin=100 mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm,


dz=5mm

Reference Value = 57.97 V/m; Power Drift = 0.05 dB

Peak SAR (extrapolated) = 7.39 W/kg

SAR(1 g) = 3.91 W/kg; SAR(10 g) = 2.03 W/kg

Maximum value of SAR (measured) = 6.16 W/kg



0 dB = 6.16 W/kg = 7.90 dBW/kg

20221207_SystemPerformancecheck-D2600V2_SN 1178

Frequency: 2600 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C
Medium parameters used: $f = 2600$ MHz; $\sigma = 1.933$ S/m; $\epsilon_r = 40.445$; $\rho = 1000$ kg/m³

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1671; Calibrated: 2022-05-31
- Probe: EX3DV4 - SN7645; ConvF(6.73, 6.73, 6.73) @ 2600 MHz; Calibrated: 2022-11-15
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (Right); Type: QD 000 P40 CD; Serial: 1855

Head/2600MHz, Pin=100mW/Area Scan (6x8x1): Measurement grid: dx=12mm, dy=12mm
Maximum value of SAR (measured) = 8.21 W/kg


Head/2600MHz, Pin=100mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 57.70 V/m; Power Drift = -0.03 dB

Peak SAR (extrapolated) = 11.3 W/kg

SAR(1 g) = 5.23 W/kg; SAR(10 g) = 2.34 W/kg

Maximum value of SAR (measured) = 9.04 W/kg



0 dB = 9.04 W/kg = 9.56 dBW/kg

20230115_SystemPerformanceCheck-D3900V2_SN1069

Frequency: 3900 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C

Medium parameters used: $f = 3900$ MHz; $\sigma = 3.377$ S/m; $\epsilon_r = 36.844$; $\rho = 1000$ kg/m³

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1671; Calibrated: 2022-05-31
- Probe: EX3DV4 - SN7645; ConvF(5.69, 5.69, 5.69) @ 3900 MHz; Calibrated: 2022-11-15
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (Right); Type: QD 000 P40 CD; Serial: 1855

Head/3900MHz, Pin=100mW/Area Scan (5x7x1): Measurement grid: dx=12mm, dy=12mm

Maximum value of SAR (measured) = 9.19 W/kg

Head/3900MHz, Pin=100mW/Zoom Scan (7x7x8)/Cube 0: Measurement grid: dx=5mm, dy=5mm,


dz=1.4mm

Reference Value = 59.84 V/m; Power Drift = 0.09 dB

Peak SAR (extrapolated) = 16.3 W/kg

SAR(1 g) = 6.4 W/kg; SAR(10 g) = 2.34 W/kg

Maximum value of SAR (measured) = 12.3 W/kg



0 dB = 12.3 W/kg = 10.90 dBW/kg

20221222_SystemPerformanceCheck-D1900V2_SN 5d190

Frequency: 1900 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C
 Medium parameters used: $f = 1900$ MHz; $\sigma = 1.438$ S/m; $\epsilon_r = 40.933$; $\rho = 1000$ kg/m³

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1447; Calibrated: 2022-03-25
- Probe: EX3DV4 - SN7330; ConvF(8.73, 8.73, 8.73) @ 1900 MHz; Calibrated: 2022-01-28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Left_Twin-SAM V8.0 (30deg probe tilt)221014; Type: QD 000 P41 Ax; Serial: xxxx

Head/1900MHz, Pin=100mW/Area Scan (7x7x1): Measurement grid: dx=15mm, dy=15mm
 Maximum value of SAR (measured) = 5.70 W/kg


Head/1900MHz, Pin=100mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 58.34 V/m; Power Drift = 0.04 dB

Peak SAR (extrapolated) = 6.95 W/kg

SAR(1 g) = 3.68 W/kg; SAR(10 g) = 1.92 W/kg

Maximum value of SAR (measured) = 5.80 W/kg



0 dB = 5.80 W/kg = 7.63 dBW/kg

20230103_SystemPerformancecheck-D2300V2_SN 1115

Frequency: 2300 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C

Medium parameters used: $f = 2300$ MHz; $\sigma = 1.706$ S/m; $\epsilon_r = 39.423$; $\rho = 1000$ kg/m³

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1447; Calibrated: 2022-03-25
- Probe: EX3DV4 - SN7330; ConvF(8.31, 8.31, 8.31) @ 2300 MHz; Calibrated: 2022-01-28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Left_Twin-SAM V8.0 (30deg probe tilt)221014; Type: QD 000 P41 Ax; Serial: xxxx

Head/2300MHz, Pin=100mW/Area Scan (6x8x1): Measurement grid: dx=12mm, dy=12mm

Maximum value of SAR (measured) = 6.59 W/kg

Head/2300MHz, Pin=100mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm,


dz=5mm

Reference Value = 58.08 V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 9.19 W/kg

SAR(1 g) = 4.52 W/kg; SAR(10 g) = 2.18 W/kg

Maximum value of SAR (measured) = 7.42 W/kg



0 dB = 7.42 W/kg = 8.70 dBW/kg

20230110_SystemPerformancecheck-D2600V2_SN 1097

Frequency: 2600 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C

Medium parameters used: $f = 2600$ MHz; $\sigma = 1.982$ S/m; $\epsilon_r = 37.309$; $\rho = 1000$ kg/m³

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1447; Calibrated: 2022-03-25
- Probe: EX3DV4 - SN7651; ConvF(7.48, 7.48, 7.48) @ 2600 MHz; Calibrated: 2022-05-30
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Left_Twin-SAM V8.0 (30deg probe tilt)221014; Type: QD 000 P41 Ax; Serial: xxxx

Head/2600MHz, Pin=100 mW/Area Scan (6x8x1): Measurement grid: dx=12mm, dy=12mm

Maximum value of SAR (measured) = 7.85 W/kg

Head/2600MHz, Pin=100 mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm,


dz=5mm

Reference Value = 65.47 V/m; Power Drift = 0.01 dB

Peak SAR (extrapolated) = 12.7 W/kg

SAR(1 g) = 5.97 W/kg; SAR(10 g) = 2.69 W/kg

Maximum value of SAR (measured) = 10.1 W/kg



0 dB = 10.1 W/kg = 10.04 dBW/kg

20230110_SystemPerformanceCheck-D750V3_SN 1205

Frequency: 750 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C

Medium parameters used: $f = 750 \text{ MHz}$; $\sigma = 0.871 \text{ S/m}$; $\epsilon_r = 42.422$; $\rho = 1000 \text{ kg/m}^3$

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1468; Calibrated: 2022-08-18
- Probe: EX3DV4 - SN7652; ConvF(10.58, 10.58, 10.58) @ 750 MHz; Calibrated: 2022-04-28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (20deg probe tilt); Type: QD 000 P40 CD; Serial: 1751

Head/750MHz, Pin=100 mW/Area Scan (6x17x1): Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (measured) = 0.995 W/kg

Head/750MHz, Pin=100 mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm,


dz=5mm

Reference Value = 33.53 V/m; Power Drift = 0.01 dB

Peak SAR (extrapolated) = 1.20 W/kg

SAR(1 g) = 0.806 W/kg; SAR(10 g) = 0.535 W/kg

Maximum value of SAR (measured) = 1.07 W/kg



0 dB = 1.07 W/kg = 0.29 dBW/kg

20230110_SystemPerformanceCheck-D835V2_SN 4d174

Frequency: 835 MHz; Duty Cycle: 1:1; Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C

Medium parameters used: $f = 835 \text{ MHz}$; $\sigma = 0.917 \text{ S/m}$; $\epsilon_r = 42.459$; $\rho = 1000 \text{ kg/m}^3$

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Averaged Fast SAR: Polynomial fit
- Electronics: DAE4 Sn1468; Calibrated: 2022-08-18
- Probe: EX3DV4 - SN7652; ConvF(10.39, 10.39, 10.39) @ 835 MHz; Calibrated: 2022-04-28
- Sensor-Surface: 2.5mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (20deg probe tilt); Type: QD 000 P40 CD; Serial: 1751

Head/835MHz, Pin=100 mW/Area Scan (7x13x1): Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (measured) = 1.05 W/kg

Head/835MHz, Pin=100 mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm,


dz=5mm

Reference Value = 34.19 V/m; Power Drift = 0.01 dB

Peak SAR (extrapolated) = 1.33 W/kg

SAR(1 g) = 0.890 W/kg; SAR(10 g) = 0.585 W/kg

Maximum value of SAR (measured) = 1.08 W/kg



0 dB = 1.08 W/kg = 0.33 dBW/kg

Measurement Report for Device , CW, Channel 0 (2450.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	,		, 0--	2450.0, 0	8.34	1.78	40.3

Hardware Setup


Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2043	HBBL-600-10000 Charge:xxxx, 2022-Dec-26	EX3DV4 - SN7646, 2022-03-29	DAE4 Sn1494, 2022-07-18

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	40.0 x 80.0	30.0 x 30.0 x 30.0
Grid Steps [mm]	10.0 x 10.0	5.0 x 5.0 x 1.5
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	5.01	4.94
psSAR10g [W/Kg]	2.32	2.31
Power Drift [dB]	-0.00	-0.02
M2/M1 [%]		80.5
Dist 3dB Peak [mm]		9.0



Measurement Report for Device ,CW, Channel 0 (13.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	,		, 0--	13.0, 0	17.91	0.738	54.5

Hardware Setup


Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
ELI V6.0 (20deg probe tilt) - 2005	HBBL-600-10000, 2022-Dec-14	EX3DV4 - SN7313, 2022-03-02	DAE4 Sn1670, 2022-06-07

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	40.0 x 90.0	32.0 x 32.0 x 30.0
Grid Steps [mm]	10.0 x 15.0	6.0 x 6.0 x 1.5
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.057	0.054
psSAR10g [W/Kg]	0.045	0.033
Power Drift [dB]	0.01	-0.02
M2/M1 [%]		74.9
Dist 3dB Peak [mm]		15.6



Measurement Report for Device , CW, Channel 0 (5250.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	,		, 0--	5250.0, 0	5.24	4.77	36.6

Hardware Setup

Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2039	HBBL-600-10000 Charge:xxxx, 2023-Jan-02	EX3DV4 - SN7313, 2022-03-02	DAE4 Sn1670, 2022-06-07

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	40.0 x 80.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	6.71	7.31
psSAR10g [W/Kg]	1.97	2.09
Power Drift [dB]	-0.03	0.02
M2/M1 [%]		63.1
Dist 3dB Peak [mm]		7.2

