

**System Performance Check Report**

**Summary**

Dipole	Frequency [MHz]	TSL	Power [dBm]	Dev. 1g [%]	Dev. 10g [%]	Dev. Peak [%]	Iso. Error [%]
D1900V2 - SN5d199	1900.0	HSL	20.0	-6.5	-6.6	-3.4	-2.4

**Exposure Conditions**

Phantom Section, TSL	Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	10		CW, 0--	1900.0, 0	8.14	1.43	38.6

**Hardware Setup**


Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V5.0 (30deg probe tilt) - 1877	HSL1900 Charge, 2024-Jan-03	EX3DV4 - SN7651, 2023-05-30	DAE4 Sn1671, 2023-05-25

**Scans Setup**

	Area Scan	Zoom Scan
Grid Extents [mm]	40.0 x 90.0	30.0 x 30.0 x 30.0
Grid Steps [mm]	10.0 x 15.0	6.0 x 6.0 x 1.5
Sensor Surface [mm]	3.0	1.4

**Measurement Results**

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0	3.77
psSAR10g [W/Kg]	0	1.94
Power Drift [dB]	n/a	0.02



## 20240111\_SystemPerformanceCheck-D835V2\_SN 4d174


Frequency: 835 MHz; Communication System Channel Number: 0; Duty Cycle: 1:1  
 Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C  
 Medium parameters used:  $f = 835 \text{ MHz}$ ;  $\sigma = 0.936 \text{ S/m}$ ;  $\epsilon_r = 41.413$ ;  $\rho = 1000 \text{ kg/m}^3$

### DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Electronics: DAE4 Sn1494; Calibrated: 2023-07-17
- Probe: EX3DV4 - SN7314; ConvF(9.31, 9.31, 9.31) @ 835 MHz; Calibrated: 2023-05-26
- Sensor-Surface: 2.5mm (Mechanical Surface Detection)
- Phantom: SAM (20deg probe tilt) with CRP v5.0(Right); Phantom section: Flat Section ; Type: QD000P40CD
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14 (7501)

**Head/835MHz/Area Scan (7x13x1):** Measurement grid: dx=15mm, dy=15mm  
 Maximum value of SAR (measured) = 1.20 W/kg

**Head/835MHz/Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm  
 Reference Value = 33.81 V/m; Power Drift = 0.05 dB  
 Peak SAR (extrapolated) = 1.36 W/kg  
**SAR(1 g) = 0.897 W/kg; SAR(10 g) = 0.587 W/kg**  
 Smallest distance from peaks to all points 3 dB below = 21.5 mm  
 Ratio of SAR at M2 to SAR at M1 = 66.8%  
 Maximum value of SAR (measured) = 1.09 W/kg



0 dB = 1.20 W/kg = 0.80 dBW/kg

## 20240109\_SystemPerformanceCheck-D1750V2\_SN 1180

Frequency: 1750 MHz; Communication System Channel Number: 0; Duty Cycle: 1:1  
 Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C  
 Medium parameters used:  $f = 1750 \text{ MHz}$ ;  $\sigma = 1.322 \text{ S/m}$ ;  $\epsilon_r = 39.86$ ;  $\rho = 1000 \text{ kg/m}^3$

### DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Electronics: DAE4 Sn1668; Calibrated: 2023-04-26
- Probe: EX3DV4 - SN3871; ConvF(8.54, 8.07, 8.45) @ 1750 MHz; Calibrated: 2023-08-25
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (Right); Phantom section: Flat Section ; Type: QD 000 P40 CD
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14 (7501)

**Head/1750MHz/Area Scan (7x7x1):** Measurement grid:  $dx=15\text{mm}$ ,  $dy=15\text{mm}$   
 Maximum value of SAR (measured) = 3.82 W/kg

**Head/1750MHz/Zoom Scan (5x5x7)/Cube 0:** Measurement grid:  $dx=8\text{mm}$ ,  $dy=8\text{mm}$ ,  $dz=5\text{mm}$

Reference Value = 48.48 V/m; Power Drift = -0.03 dB


Peak SAR (extrapolated) = 5.57 W/kg

**SAR(1 g) = 3.39 W/kg; SAR(10 g) = 1.93 W/kg**

Smallest distance from peaks to all points 3 dB below = 11.2 mm

Ratio of SAR at M2 to SAR at M1 = 60.9%

Maximum value of SAR (measured) = 4.84 W/kg



0 dB = 3.82 W/kg = 5.82 dBW/kg

## 20240118\_SystemPerformanceCheck-D1900V2\_SN 5d190

Frequency: 1900 MHz; Communication System Channel Number: 0; Duty Cycle: 1:1  
 Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C  
 Medium parameters used:  $f = 1900$  MHz;  $\sigma = 1.366$  S/m;  $\epsilon_r = 39.762$ ;  $\rho = 1000$  kg/m<sup>3</sup>

### DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Electronics: DAE4 Sn1668; Calibrated: 2023-04-26
- Probe: EX3DV4 - SN3871; ConvF(8.31, 7.78, 8.15) @ 1900 MHz; Calibrated: 2023-08-25
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (Right); Phantom section: Flat Section ; Type: QD 000 P40 CD
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14 (7501)

**Head/1900MHz/Area Scan (6x7x1):** Measurement grid: dx=15mm, dy=15mm  
 Maximum value of SAR (measured) = 6.44 W/kg

**Head/1900MHz/Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 49.88 V/m; Power Drift = -0.00 dB


Peak SAR (extrapolated) = 6.71 W/kg

**SAR(1 g) = 3.71 W/kg; SAR(10 g) = 2 W/kg**

Smallest distance from peaks to all points 3 dB below = 10.1 mm

Ratio of SAR at M2 to SAR at M1 = 55.3%

Maximum value of SAR (measured) = 5.55 W/kg



0 dB = 6.44 W/kg = 8.09 dBW/kg

## 20240129\_SystemPerformancecheck D2450V2\_SN960

Frequency: 2450 MHz; Communication System Channel Number: 0; Duty Cycle: 1:1  
 Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C  
 Medium parameters used (interpolated):  $f = 2450$  MHz;  $\sigma = 1.818$  S/m;  $\epsilon_r = 38.708$ ;  $\rho = 1000$  kg/m<sup>3</sup>

### DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Electronics: DAE4 Sn1668; Calibrated: 2023-04-26
- Probe: EX3DV4 - SN3871; ConvF(7.74, 7.17, 7.55) @ 2450 MHz; Calibrated: 2023-08-25
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (Right); Phantom section: Flat Section ; Type: QD 000 P40 CD
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14 (7501)

**Head/2450MHz/Area Scan (6x9x1):** Measurement grid: dx=12mm, dy=12mm  
 Maximum value of SAR (measured) = 7.77 W/kg

**Head/2450MHz/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 53.92 V/m; Power Drift = 0.08 dB


Peak SAR (extrapolated) = 9.19 W/kg

**SAR(1 g) = 4.88 W/kg; SAR(10 g) = 2.39 W/kg**

Smallest distance from peaks to all points 3 dB below = 9.1 mm

Ratio of SAR at M2 to SAR at M1 = 54%

Maximum value of SAR (measured) = 7.77 W/kg



0 dB = 7.77 W/kg = 8.90 dBW/kg

**System Performance Check Report**

**Summary**

Dipole	Frequency [MHz]	TSL	Power [dBm]	Dev. 1g [%]	Dev. 10g [%]	Dev. Peak [%]	Iso. Error [%]
D835V2 - SN4d194	835.0	HSL	20.0	0.9	2.0	4.0	1.3

**Exposure Conditions**

Phantom Section, TSL	Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	15		CW, 0--	835.0, 0	8.39	0.921	41.0

**Hardware Setup**


Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 1991	HBBL-600-10000, 2024-Jan-05	EX3DV4 - SN7313, 2023-03-24	DAE4 Sn1667, 2023-04-24

**Scans Setup**

	Area Scan	Zoom Scan
Grid Extents [mm]	40.0 x 90.0	30.0 x 30.0 x 30.0
Grid Steps [mm]	10.0 x 15.0	6.0 x 6.0 x 1.5
Sensor Surface [mm]	3.0	1.4

**Measurement Results**

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.993	0.998
psSAR10g [W/Kg]	0.659	0.658
Power Drift [dB]	0.01	0.00



**System Performance Check Report**

**Summary**

Dipole	Frequency [MHz]	TSL	Power [dBm]	Dev. 1g [%]	Dev. 10g [%]	Dev. Peak [%]	Iso. Error [%]
D750V3 - SN1205	750.0	HSL	20.0	-4.0	1.1	-8.2	1.8

**Exposure Conditions**

Phantom Section, TSL	Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	15		CW, 0--	750.0, 0	9.21	0.881	42.6

**Hardware Setup**


Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 1991	HBBL-600-10000, 2024-Jan-15	EX3DV4 - SN7313, 2023-03-24	DAE4 Sn1667, 2023-04-24

**Scans Setup**

	Area Scan	Zoom Scan
Grid Extents [mm]	40.0 x 90.0	30.0 x 30.0 x 30.0
Grid Steps [mm]	10.0 x 15.0	6.0 x 6.0 x 1.5
Sensor Surface [mm]	3.0	1.4

**Measurement Results**

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.790	0.810
psSAR10g [W/Kg]	0.532	0.559
Power Drift [dB]	-0.00	-0.00



## 20240112\_SystemPerformancecheck D2600V2\_SN1178

Frequency: 2600 MHz; Communication System Channel Number: 0; Duty Cycle: 1:1  
 Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C  
 Medium parameters used:  $f = 2600 \text{ MHz}$ ;  $\sigma = 1.92 \text{ S/m}$ ;  $\epsilon_r = 39.82$ ;  $\rho = 1000 \text{ kg/m}^3$

### DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Electronics: DAE4 Sn1591; Calibrated: 2023-03-22
- Probe: EX3DV4 - SN7545; ConvF(7.2, 7.2, 7.2) @ 2600 MHz; Calibrated: 2023-08-25
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (20deg probe tilt); Phantom section: Flat Section ; Type: QD 000 P40 CD
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14 (7501)

**Head/2600MHz/Area Scan (6x9x1):** Measurement grid:  $dx=12\text{mm}$ ,  $dy=12\text{mm}$   
 Maximum value of SAR (measured) = 8.96 W/kg

**Head/2600MHz/Zoom Scan (7x7x7)/Cube 0:** Measurement grid:  $dx=5\text{mm}$ ,  $dy=5\text{mm}$ ,  $dz=5\text{mm}$

Reference Value = 64.48 V/m; Power Drift = 0.11 dB


Peak SAR (extrapolated) = 12.1 W/kg

**SAR(1 g) = 5.35 W/kg; SAR(10 g) = 2.4 W/kg**

Smallest distance from peaks to all points 3 dB below = 9 mm

Ratio of SAR at M2 to SAR at M1 = 44.9%

Maximum value of SAR (measured) = 9.25 W/kg



0 dB = 8.96 W/kg = 9.52 dBW/kg



## 20240116\_SystemPerformancecheck D2600V2\_SN1097

Frequency: 2600 MHz; Communication System Channel Number: 0; Duty Cycle: 1:1  
 Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C  
 Medium parameters used:  $f = 2600$  MHz;  $\sigma = 1.959$  S/m;  $\epsilon_r = 38.735$ ;  $\rho = 1000$  kg/m<sup>3</sup>

### DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Electronics: DAE4 Sn1591; Calibrated: 2023-03-22
- Probe: EX3DV4 - SN7545; ConvF(7.2, 7.2, 7.2) @ 2600 MHz; Calibrated: 2023-08-25
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: Twin-SAM V5.0 (20deg probe tilt); Phantom section: Flat Section ; Type: QD 000 P40 CD
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14 (7501)

**Head/2600MHz/Area Scan (6x9x1):** Measurement grid: dx=12mm, dy=12mm  
 Maximum value of SAR (measured) = 6.61 W/kg

**Head/2600MHz/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 69.36 V/m; Power Drift = -0.03 dB


Peak SAR (extrapolated) = 11.5 W/kg

**SAR(1 g) = 5.21 W/kg; SAR(10 g) = 2.35 W/kg**

Smallest distance from peaks to all points 3 dB below = 8.9 mm

Ratio of SAR at M2 to SAR at M1 = 45.6%

Maximum value of SAR (measured) = 9.05 W/kg



0 dB = 6.61 W/kg = 8.20 dBW/kg

**System Performance Check Report**

**Summary**

Dipole	Frequency [MHz]	TSL	Power [dBm]	Dev. 1g [%]	Dev. 10g [%]	Dev. Peak [%]	Iso. Error [%]
D1750V2 - SN1125	1750.0	HSL	20.0	-5.0	-4.8	-0.5	0.6

**Exposure Conditions**

Phantom Section, TSL	Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	10		CW, 0--	1750.0, 0	8.61	1.32	40.9

**Hardware Setup**


Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2043	HBBL-600-10000, 2024-Jan-22	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1343, 2023-06-30

**Scans Setup**

	Area Scan	Zoom Scan
Grid Extents [mm]	40.0 x 90.0	30.0 x 30.0 x 30.0
Grid Steps [mm]	10.0 x 15.0	6.0 x 6.0 x 1.5
Sensor Surface [mm]	3.0	1.4

**Measurement Results**

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	3.51	3.46
psSAR10g [W/Kg]	1.87	1.84
Power Drift [dB]	-0.11	-0.06



**System Performance Check Report**

**Summary**

Dipole	Frequency [MHz]	TSL	Power [dBm]	Dev. 1g [%]	Dev. 10g [%]	Dev. Peak [%]	Iso. Error [%]
CLA-13 - SN1015	13.0	HSL	20.0	2.5	1.5	n/a	1.7

**Exposure Conditions**

Phantom Section, TSL	Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	0		CW, 0--	13.0, 0	17.89	0.727	54.1

**Hardware Setup**


Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
ELI V6.0 (20deg probe tilt) - 2005	HSL750, 2024-Jan-22	EX3DV4 - SN7646, 2023-03-23	DAE4 Sn1447, 2023-03-22

**Scans Setup**

	Area Scan	Zoom Scan
Grid Extents [mm]	40.0 x 90.0	32.0 x 32.0 x 30.0
Grid Steps [mm]	10.0 x 15.0	6.0 x 6.0 x 1.5
Sensor Surface [mm]	3.0	1.4

**Measurement Results**

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.056	0.054
psSAR10g [W/Kg]	0.045	0.033
Power Drift [dB]	-0.00	-0.11



**System Performance Check Report**

**Summary**

Dipole	Frequency [MHz]	TSL	Power [dBm]	Dev. 1g [%]	Dev. 10g [%]	Dev. Peak [%]	Iso. Error [%]
D5GHzV2 - SN1325	5600.0	HSL	20.0	-7.8	-4.4	-13.9	3.0

**Exposure Conditions**

Phantom Section, TSL	Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	10		CW, 0--	5600.0, 0	5.15	5.00	34.8

**Hardware Setup**


Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2039	HBBL-600-10000, 2024-Jan-26	EX3DV4 - SN7646, 2023-03-23	DAE4 Sn1447, 2023-03-22

**Scans Setup**

	Area Scan	Zoom Scan
Grid Extents [mm]	40.0 x 80.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

**Measurement Results**

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	7.28	7.78
psSAR10g [W/Kg]	2.12	2.29
Power Drift [dB]	0.05	0.09



**System Performance Check Report**

**Summary**

Dipole	Frequency [MHz]	TSL	Power [dBm]	Dev. 1g [%]	Dev. 10g [%]	Dev. Peak [%]	Iso. Error [%]
D5GHzV2 – SN1325	5800.0	HSL	20.0	-3.0	0.8	-6.6	0.7

**Exposure Conditions**

Phantom Section, TSL	Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	10		CW, 0--	5800.0, 0	4.56	5.34	35.2

**Hardware Setup**

Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) – 2038	HBBL-600-10000, 2024-Jan-30	EX3DV4 – SN7645, 2023-09-20	DAE4 Sn1468, 2023-08-24

**Scans Setup**

	Area Scan	Zoom Scan
Grid Extents [mm]	40.0 x 80.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

**Measurement Results**

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	7.05	7.81
psSAR10g [W/Kg]	2.11	2.27
Power Drift [dB]	0.01	-0.01

