

## APPENDIX B: SYSTEM VERIFICATION

# PCTEST

**DUT: Dipole 750 MHz; Type: D750V3; Serial: 1003**

Communication System: UID 0, CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: 750 Head Medium parameters used:

$f = 750 \text{ MHz}$ ;  $\sigma = 0.923 \text{ S/m}$ ;  $\epsilon_r = 43.827$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 05/20/2021; Ambient Temp: 24.8°C; Tissue Temp: 22.7°C

Probe: EX3DV4 - SN7357; ConvF(10.18, 10.18, 10.18) @ 750 MHz; Calibrated: 4/19/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1407; Calibrated: 4/7/2021

Phantom: Front; Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 750 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x15x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.85 W/kg

**SAR(1 g) = 1.83 W/kg**

Deviation(1 g) = 4.21%



0 dB = 2.50 W/kg = 3.98 dBW/kg

# PCTEST

**DUT: Dipole 750 MHz; Type: D750V3; Serial: 1003**

Communication System: UID 0, CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: 750 Head Medium parameters used:

$f = 750 \text{ MHz}$ ;  $\sigma = 0.921 \text{ S/m}$ ;  $\epsilon_r = 41.896$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 05/25/2021; Ambient Temp: 23.8°C; Tissue Temp: 23.0°C

Probe: EX3DV4 - SN7357; ConvF(10.18, 10.18, 10.18) @ 750 MHz; Calibrated: 4/19/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1407; Calibrated: 4/7/2021

Phantom: Front; Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 750 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x15x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.59 W/kg

**SAR(1 g) = 1.66 W/kg**

Deviation(1 g) = -5.47%



0 dB = 2.26 W/kg = 3.54 dBW/kg

# PCTEST

**DUT: Dipole 750 MHz; Type: D750V3; Serial: 1003**

Communication System: UID 0, CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: 750 Head Medium parameters used:

$f = 750 \text{ MHz}$ ;  $\sigma = 0.923 \text{ S/m}$ ;  $\epsilon_r = 42.18$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 05/27/2021; Ambient Temp: 24.4°C; Tissue Temp: 23.0°C

Probe: EX3DV4 - SN7357; ConvF(10.18, 10.18, 10.18) @ 750 MHz; Calibrated: 4/19/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1407; Calibrated: 4/7/2021

Phantom: Front; Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 750 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x15x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.71 W/kg

**SAR(1 g) = 1.72 W/kg**

Deviation(1 g) = -2.05%



# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d133**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Head Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.917 \text{ S/m}$ ;  $\epsilon_r = 42.495$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 04/06/2021; Ambient Temp: 22.9°C; Tissue Temp: 20.8°C

Probe: EX3DV4 - SN7308; ConvF(10.17, 10.17, 10.17) @ 835 MHz; Calibrated: 7/31/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1450; Calibrated: 8/11/2020

Phantom: Twin-SAM V5.0; Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.96 W/kg

**SAR(1 g) = 1.87 W/kg**

Deviation(1 g) = -0.85%



# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d047**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Head Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.884 \text{ S/m}$ ;  $\epsilon_r = 41.054$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 05/27/2021; Ambient Temp: 22.9°C; Tissue Temp: 21.2°C

Probe: EX3DV4 - SN7308; ConvF(10.17, 10.17, 10.17) @ 835 MHz; Calibrated: 7/31/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1450; Calibrated: 8/11/2020

Phantom: Twin-SAM V5.0; Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.83 W/kg

**SAR(1 g) = 1.84 W/kg**

Deviation(1 g) = -2.34%



0 dB = 2.49 W/kg = 3.96 dBW/kg

# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d047**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Head Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.899 \text{ S/m}$ ;  $\epsilon_r = 42.053$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 05/30/2021; Ambient Temp: 22.0°C; Tissue Temp: 21.8°C

Probe: EX3DV4 - SN7308; ConvF(10.17, 10.17, 10.17) @ 835 MHz; Calibrated: 7/31/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1450; Calibrated: 8/11/2020

Phantom: Twin-SAM V5.0; Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.85 W/kg

**SAR(1 g) = 1.8 W/kg**

Deviation(1 g) = -4.46%



0 dB = 2.47 W/kg = 3.93 dBW/kg

# PCTEST

**DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1150**

Communication System: UID: 0, CW; Frequency: 1750.0 MHz  
Medium: 1750 Head; Medium parameters used:  
 $f = 1750.0$  MHz;  $\sigma = 1.39$  S/m;  $\epsilon_r = 41.2$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/11/2021; Ambient Temp: 22.1°C; Tissue Temp: 22.3°C

Probe: EX3DV4 - SN7526; ConvF:(7.82,7.82,7.82); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (60.0 x 90.0):** Measurement grid: dx=15.0mm, dy=15.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=6.0mm, dy=6.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 6.69 W/kg

**SAR(1 g) = 3.65 W/kg**

Deviation (1 g) = 0.00%



# PCTEST

**DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1150**

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Head Medium parameters used:

$f = 1750 \text{ MHz}$ ;  $\sigma = 1.393 \text{ S/m}$ ;  $\epsilon_r = 40.373$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 05/16/2021; Ambient Temp: 22.0°C; Tissue Temp: 21.4°C

Probe: EX3DV4 - SN7357; ConvF(8.67, 8.67, 8.67) @ 1750 MHz; Calibrated: 4/19/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1407; Calibrated: 4/7/2021

Phantom: Front; Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x9x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 6.58 W/kg

**SAR(1 g) = 3.51 W/kg**

Deviation(1 g) = -3.84%



0 dB = 5.46 W/kg = 7.37 dBW/kg

# PCTEST

**DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1150**

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Head Medium parameters used:

$f = 1750$  MHz;  $\sigma = 1.397$  S/m;  $\epsilon_r = 41.108$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 05/18/2021; Ambient Temp: 23.0°C; Tissue Temp: 22.2°C

Probe: EX3DV4 - SN7357; ConvF(8.67, 8.67, 8.67) @ 1750 MHz; Calibrated: 4/19/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1407; Calibrated: 4/7/2021

Phantom: Front; Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x9x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.14 W/kg

**SAR(1 g) = 3.82 W/kg**

Deviation(1 g) = 4.66%



0 dB = 5.93 W/kg = 7.73 dBW/kg

# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d080**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Head Medium parameters used:

$f = 1900$  MHz;  $\sigma = 1.426$  S/m;  $\epsilon_r = 38.627$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/06/2021; Ambient Temp: 23.9°C; Tissue Temp: 22.2°C

Probe: EX3DV4 - SN7571; ConvF(8.01, 8.01, 8.01) @ 1900 MHz; Calibrated: 12/11/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1533; Calibrated: 12/7/2020

Phantom: SAM 5.0 front; Type: QD000P40CD; Serial: 1648

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 8.20 W/kg

**SAR(1 g) = 4.24 W/kg**

Deviation(1 g) = 6.53%



0 dB = 6.62 W/kg = 8.21 dBW/kg

# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d080**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Head Medium parameters used:

$f = 1900$  MHz;  $\sigma = 1.451$  S/m;  $\epsilon_r = 38.157$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/08/2021; Ambient Temp: 24.9°C; Tissue Temp: 23.3°C

Probe: EX3DV4 - SN7571; ConvF(8.01, 8.01, 8.01) @ 1900 MHz; Calibrated: 12/11/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1533; Calibrated: 12/7/2020

Phantom: SAM 5.0 front; Type: QD000P40CD; Serial: 1648

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.82 W/kg

**SAR(1 g) = 4.1 W/kg**

Deviation(1 g) = 3.02%



0 dB = 6.47 W/kg = 8.11 dBW/kg

# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d149**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Head Medium parameters used:

$f = 1900$  MHz;  $\sigma = 1.428$  S/m;  $\epsilon_r = 38.076$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 05/03/2021; Ambient Temp: 23.6°C; Tissue Temp: 23.4°C

Probe: EX3DV4 - SN7571; ConvF(8.01, 8.01, 8.01) @ 1900 MHz; Calibrated: 12/11/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1533; Calibrated: 12/7/2020

Phantom: SAM 5.0 front; Type: QD000P40CD; Serial: 1648

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 8.19 W/kg

**SAR(1 g) = 4.17 W/kg**

Deviation(1 g) = 6.11%



# PCTEST

**DUT: Dipole 2300 MHz; Type: D2300V2; Serial: 1073**

Communication System: UID 0, CW; Frequency: 2300 MHz; Duty Cycle: 1:1

Medium: 2450 Head Medium parameters used:

$f = 2300$  MHz;  $\sigma = 1.696$  S/m;  $\epsilon_r = 40.348$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/25/2021; Ambient Temp: 23.1°C; Tissue Temp: 23.0°C

Probe: EX3DV4 - SN7571; ConvF(7.56, 7.56, 7.56) @ 2300 MHz; Calibrated: 12/11/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1533; Calibrated: 12/7/2020

Phantom: SAM 5.0 front; Type: QD000P40CD; Serial: 1648

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 2300 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (8x9x1):** Measurement grid: dx=12mm, dy=12mm

**Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Peak SAR (extrapolated) = 10.3 W/kg

**SAR(1 g) = 4.92 W/kg**

Deviation(1 g) = 0.00%



# PCTEST

**DUT: Dipole 2450 MHz; Type: D2450V2; Serial: 719**

Communication System: UID 0, CW; Frequency: 2450 MHz; Duty Cycle: 1:1

Medium: 2450 Head Medium parameters used:

$f = 2450 \text{ MHz}$ ;  $\sigma = 1.863 \text{ S/m}$ ;  $\epsilon_r = 39.847$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/25/2021; Ambient Temp: 23.1°C; Tissue Temp: 23.0°C

Probe: EX3DV4 - SN7571; ConvF(7.28, 7.28, 7.28) @ 2450 MHz; Calibrated: 12/11/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1533; Calibrated: 12/7/2020

Phantom: SAM 5.0 front; Type: QD000P40CD; Serial: 1648

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 2450 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (8x9x1):** Measurement grid: dx=12mm, dy=12mm

**Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Peak SAR (extrapolated) = 11.3 W/kg

**SAR(1 g) = 5.12 W/kg**

Deviation(1 g) = -0.39%



0 dB = 8.90 W/kg = 9.49 dBW/kg

# PCTEST

**DUT: Dipole 2600 MHz; Type: D2600V2; Serial: 1064**

Communication System: UID 0, CW; Frequency: 2600 MHz; Duty Cycle: 1:1

Medium: 2450 Head Medium parameters used:

$f = 2600$  MHz;  $\sigma = 2.036$  S/m;  $\epsilon_r = 39.317$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/25/2021; Ambient Temp: 23.1°C; Tissue Temp: 23.0°C

Probe: EX3DV4 - SN7571; ConvF(7.05, 7.05, 7.05) @ 2600 MHz; Calibrated: 12/11/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1533; Calibrated: 12/7/2020

Phantom: SAM 5.0 front; Type: QD000P40CD; Serial: 1648

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 2600 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (8x9x1):** Measurement grid: dx=12mm, dy=12mm

**Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Peak SAR (extrapolated) = 13.6 W/kg

**SAR(1 g) = 5.91 W/kg**

Deviation(1 g) = 1.72%



0 dB = 10.5 W/kg = 10.21 dBW/kg

# PCTEST

**DUT: Dipole 2300 MHz; Type: D2300V2; Serial: 1073**

Communication System: UID 0, CW; Frequency: 2300 MHz; Duty Cycle: 1:1

Medium: 2450 Head Medium parameters used:

$f = 2300$  MHz;  $\sigma = 1.715$  S/m;  $\epsilon_r = 40.172$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/27/2021; Ambient Temp: 23.3°C; Tissue Temp: 24.0°C

Probe: EX3DV4 - SN7571; ConvF(7.56, 7.56, 7.56) @ 2300 MHz; Calibrated: 12/11/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1533; Calibrated: 12/7/2020

Phantom: SAM 5.0 front; Type: QD000P40CD; Serial: 1648

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 2300 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (8x9x1):** Measurement grid: dx=12mm, dy=12mm

**Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Peak SAR (extrapolated) = 10.2 W/kg

**SAR(1 g) = 4.99 W/kg**

Deviation(1 g) = 1.42%



0 dB = 8.21 W/kg = 9.14 dBW/kg

# PCTEST

**DUT: Dipole 2450 MHz; Type: D2450V2; Serial: 719**

Communication System: UID 0, CW; Frequency: 2450 MHz; Duty Cycle: 1:1

Medium: 2450 Head Medium parameters used:

$f = 2450$  MHz;  $\sigma = 1.873$  S/m;  $\epsilon_r = 39.689$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/27/2021; Ambient Temp: 23.3°C; Tissue Temp: 24.0°C

Probe: EX3DV4 - SN7571; ConvF(7.28, 7.28, 7.28) @ 2450 MHz; Calibrated: 12/11/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1533; Calibrated: 12/7/2020

Phantom: SAM 5.0 front; Type: QD000P40CD; Serial: 1648

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 2450 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (8x9x1):** Measurement grid: dx=12mm, dy=12mm

**Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Peak SAR (extrapolated) = 11.3 W/kg

**SAR(1 g) = 5.43 W/kg**

Deviation(1 g) = 5.64%



0 dB = 8.97 W/kg = 9.53 dBW/kg

# PCTEST

**DUT: Dipole 2600 MHz; Type: D2600V2; Serial: 1064**

Communication System: UID: 0, CW; Frequency: 2600.0 MHz  
Medium: 2450 Head; Medium parameters used:  
 $f = 2600.0$  MHz;  $\sigma = 1.99$  S/m;  $\epsilon_r = 40.0$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/28/2021; Ambient Temp: 21.5°C; Tissue Temp: 23.1°C

Probe: EX3DV4 - SN7526; ConvF:(7.04,7.04,7.04); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2600 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 11.7 W/kg

**SAR(1 g) = 5.49 W/kg**

Deviation (1 g) = -5.51%



# PCTEST

**DUT: Dipole 2450 MHz; Type: D2450V2; Serial: 719**

Communication System: UID: 0, CW; Frequency: 2450.0 MHz  
Medium: 2450 Head; Medium parameters used:  
 $f = 2450.0$  MHz;  $\sigma = 1.86$  S/m;  $\epsilon_r = 39.7$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/29/2021; Ambient Temp: 21.9°C; Tissue Temp: 20.8°C

Probe: EX3DV4 - SN7539; ConvF:(7.43,7.43,7.43); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V8.0 (Right); Serial: 1966  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2450 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 11.3 W/kg

**SAR(1 g) = 5.39 W/kg**

Deviation (1 g) = 4.86%



# PCTEST

**DUT: Dipole 3500 MHz; Type: D3500V2; Serial: 1097**

Communication System: UID: 0, CW; Frequency: 3500.0 MHz  
Medium: 3600 Head; Medium parameters used:  
 $f = 3500.0$  MHz;  $\sigma = 2.88$  S/m;  $\epsilon_r = 38.7$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/28/2021; Ambient Temp: 23.0°C; Tissue Temp: 20.0°C

Probe: EX3DV4 - SN7539; ConvF:(6.76,6.76,6.76); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V8.0 (Right); Serial: 1966  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3500 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 16.1 W/kg

**SAR(1 g) = 6.33 W/kg**

Deviation (1 g) = -4.67%



# PCTEST

**DUT: Dipole 3700 MHz; Type: D3700V2; Serial: 1067**

Communication System: UID: 0, CW; Frequency: 3700.0 MHz  
Medium: 3600 Head; Medium parameters used:  
 $f = 3700.0$  MHz;  $\sigma = 3.07$  S/m;  $\epsilon_r = 38.4$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/28/2021; Ambient Temp: 23.0°C; Tissue Temp: 20.0°C

Probe: EX3DV4 - SN7539; ConvF:(6.55,6.55,6.55); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V8.0 (Right); Serial: 1966  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3700 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 18.9 W/kg

**SAR(1 g) = 7.06 W/kg**

Deviation (1 g) = 5.06%



# PCTEST

**DUT: Dipole 3500 MHz; Type: D3500V2; Serial: 1059**

Communication System: UID: 0, CW; Frequency: 3500.0 MHz  
Medium: 3600 Head; Medium parameters used:  
 $f = 3500.0$  MHz;  $\sigma = 2.88$  S/m;  $\epsilon_r = 38.1$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/10/2021; Ambient Temp: 22.0°C; Tissue Temp: 20.0°C

Probe: EX3DV4 - SN7539; ConvF:(6.76,6.76,6.76); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V8.0 (Right); Serial: 1966  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3500 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 16.4 W/kg

**SAR(1 g) = 6.39 W/kg**

Deviation (1 g) = 0.31%



# PCTEST

**DUT: Dipole 3700 MHz; Type: D3700V2; Serial: 1018**

Communication System: UID: 0, CW; Frequency: 3700.0 MHz  
Medium: 3600 Head; Medium parameters used:  
 $f = 3700.0$  MHz;  $\sigma = 3.07$  S/m;  $\epsilon_r = 37.7$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/10/2021; Ambient Temp: 22.0°C; Tissue Temp: 20.0°C

Probe: EX3DV4 - SN7539; ConvF:(6.55,6.55,6.55); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V8.0 (Right); Serial: 1966  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3700 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 18.1 W/kg

**SAR(1 g) = 6.81 W/kg**

Deviation (1 g) = 1.64%



# PCTEST

**DUT: Dipole 3900 MHz; Type: D3900V2; Serial: 1056**

Communication System: UID: 0, CW; Frequency: 3900.0 MHz  
Medium: 3600 Head; Medium parameters used:  
 $f = 3900.0$  MHz;  $\sigma = 3.27$  S/m;  $\epsilon_r = 37.3$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/10/2021; Ambient Temp: 22.0°C; Tissue Temp: 20.0°C

Probe: EX3DV4 - SN7539; ConvF:(6.23,6.23,6.23); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V8.0 (Right); Serial: 1966  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 19.3 W/kg

**SAR(1 g) = 7.17 W/kg**

Deviation (1 g) = 4.06%



# PCTEST

**DUT: Dipole 5250 MHz; Type: D5GHzV2; Serial: 1057**

Communication System: UID: 0, CW; Frequency: 5250.0 MHz  
Medium: 5200-5800 Head; Medium parameters used:  
 $f = 5250.0$  MHz;  $\sigma = 4.63$  S/m;  $\epsilon_r = 36.6$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/21/2021; Ambient Temp: 24.0°C; Tissue Temp: 22.7°C

Probe: EX3DV4 - SN7538; ConvF:(5.29,5.29,5.29); Calibrated: 2020-11-23  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1449; Calibrated: 2020-09-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1873  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 5250 MHz System Verification at 17.0 dBm (50 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 13.9 W/kg

**SAR(1 g) = 3.68 W/kg**

Deviation (1 g) = -7.65%



# PCTEST

**DUT: Dipole 5600 MHz; Type: D5GHzV2; Serial: 1057**

Communication System: UID: 0, CW; Frequency: 5600.0 MHz  
Medium: 5200-5800 Head; Medium parameters used:  
 $f = 5600.0$  MHz;  $\sigma = 5.04$  S/m;  $\epsilon_r = 36.0$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/21/2021; Ambient Temp: 24.0°C; Tissue Temp: 22.7°C

Probe: EX3DV4 - SN7538; ConvF:(4.63,4.63,4.63); Calibrated: 2020-11-23  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1449; Calibrated: 2020-09-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1873  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 5600 MHz System Verification at 17.0 dBm (50 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 16.9 W/kg

**SAR(1 g) = 4.15 W/kg**

Deviation (1 g) = 0.95%



# PCTEST

**DUT: Dipole 5750 MHz; Type: D5GHzV2; Serial: 1057**

Communication System: UID: 0, CW; Frequency: 5750.0 MHz  
Medium: 5200-5800 Head; Medium parameters used:  
 $f = 5750.0$  MHz;  $\sigma = 5.22$  S/m;  $\epsilon_r = 35.8$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/21/2021; Ambient Temp: 24.0°C; Tissue Temp: 22.7°C

Probe: EX3DV4 - SN7538; ConvF:(4.78,4.78,4.78); Calibrated: 2020-11-23  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1449; Calibrated: 2020-09-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1873  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## **5750 MHz System Verification at 17.0 dBm (50 mW)**


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 16.1 W/kg

**SAR(1 g) = 3.78 W/kg**

Deviation (1 g) = -5.62%



# PCTEST

**DUT: Dipole 750 MHz; Type: D750V3; Serial: 1161**

Communication System: UID 0, CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: 750 Body Medium parameters used:

$f = 750 \text{ MHz}$ ;  $\sigma = 0.984 \text{ S/m}$ ;  $\epsilon_r = 54.407$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 04/06/2021; Ambient Temp: 24.8°C; Tissue Temp: 22.7°C

Probe: EX3DV4 - SN7406; ConvF(9.66, 9.66, 9.66) @ 750 MHz; Calibrated: 6/23/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1583; Calibrated: 5/14/2020

Phantom: Front; Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 750 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x15x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.88 W/kg

**SAR(1 g) = 1.79 W/kg**

Deviation(1 g) = 6.17%



0 dB = 2.47 W/kg = 3.93 dBW/kg

# PCTEST

**DUT: Dipole 750 MHz; Type: D750V3; Serial: 1003**

Communication System: UID 0, CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: 750 Body Medium parameters used:

$f = 750 \text{ MHz}$ ;  $\sigma = 0.986 \text{ S/m}$ ;  $\epsilon_r = 53.626$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5cm

Test Date: 04/09/2021; Ambient Temp: 24.5°C; Tissue Temp: 23.0°C

Probe: EX3DV4 - SN7406; ConvF(9.66, 9.66, 9.66) @ 750 MHz; Calibrated: 6/23/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1583; Calibrated: 5/14/2020

Phantom: Front; Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 750 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x15x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.82 W/kg

**SAR(1 g) = 1.82 W/kg**

Deviation(1 g) = 5.69%



0 dB = 2.47 W/kg = 3.93 dBW/kg

# PCTEST

**DUT: Dipole 750 MHz; Type: D750V3; Serial: 1003**

Communication System: UID 0, CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: 750 Body Medium parameters used:

$f = 750 \text{ MHz}$ ;  $\sigma = 0.98 \text{ S/m}$ ;  $\epsilon_r = 53.301$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5cm

Test Date: 04/12/2021; Ambient Temp: 24.2°C; Tissue Temp: 22.9°C

Probe: EX3DV4 - SN7406; ConvF(9.66, 9.66, 9.66) @ 750 MHz; Calibrated: 6/23/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1583; Calibrated: 5/14/2020

Phantom: Front; Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 750 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x15x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.87 W/kg

**SAR(1 g) = 1.82 W/kg**

Deviation(1 g) = 5.69%



0 dB = 2.49 W/kg = 3.96 dBW/kg

# PCTEST

**DUT: Dipole 750 MHz; Type: D750V3; Serial: 1003**

Communication System: UID 0, CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: 750 Body Medium parameters used:

$f = 750 \text{ MHz}$ ;  $\sigma = 0.989 \text{ S/m}$ ;  $\epsilon_r = 54.303$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 04/14/2021; Ambient Temp: 22.8°C; Tissue Temp: 24.5°C

Probe: EX3DV4 - SN7406; ConvF(9.66, 9.66, 9.66) @ 750 MHz; Calibrated: 6/23/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1583; Calibrated: 5/14/2020

Phantom: Front; Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 750 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x15x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.88 W/kg

**SAR(1 g) = 1.79 W/kg**

Deviation(1 g) = 3.95%



0 dB = 2.46 W/kg = 3.91 dBW/kg

# PCTEST

**DUT: Dipole 750 MHz; Type: D750V3; Serial: 1003**

Communication System: UID 0, CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: 750 Body Medium parameters used:

$f = 750 \text{ MHz}$ ;  $\sigma = 0.974 \text{ S/m}$ ;  $\epsilon_r = 53.054$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5cm

Test Date: 04/20/2021; Ambient Temp: 23.8°C; Tissue Temp: 22.3°C

Probe: EX3DV4 - SN7406; ConvF(9.66, 9.66, 9.66) @ 750 MHz; Calibrated: 6/23/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1583; Calibrated: 5/14/2020

Phantom: Front; Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 750 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x15x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.96 W/kg

**SAR(1 g) = 1.83 W/kg; SAR(10 g) = 1.19 W/kg**

Deviation(1 g) = 6.27%; Deviation(10 g) = 4.94%



0 dB = 2.54 W/kg = 4.05 dBW/kg

# PCTEST

**DUT: Dipole 750 MHz; Type: D750V3; Serial: 1003**

Communication System: UID 0, CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: 750 Body Medium parameters used:

$f = 750 \text{ MHz}$ ;  $\sigma = 0.968 \text{ S/m}$ ;  $\epsilon_r = 53.69$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5cm

Test Date: 04/22/2021; Ambient Temp: 23.8°C; Tissue Temp: 22.4°C

Probe: EX3DV4 - SN7406; ConvF(9.66, 9.66, 9.66) @ 750 MHz; Calibrated: 6/23/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1583; Calibrated: 5/14/2020

Phantom: Front; Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 750 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x15x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.90 W/kg

**SAR(10 g) = 1.19 W/kg**

Deviation(10 g) = 4.94%



0 dB = 2.50 W/kg = 3.98 dBW/kg

# PCTEST

**DUT: Dipole 750 MHz; Type: D750V3; Serial: 1003**

Communication System: UID 0, CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: 750 Body Medium parameters used:

$f = 750 \text{ MHz}$ ;  $\sigma = 0.983 \text{ S/m}$ ;  $\epsilon_r = 54.697$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 05/31/2021; Ambient Temp: 23.8°C; Tissue Temp: 23.0°C

Probe: EX3DV4 - SN7357; ConvF(10.29, 10.29, 10.29) @ 750 MHz; Calibrated: 4/19/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1407; Calibrated: 4/7/2021

Phantom: Front; Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 750 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x15x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.74 W/kg

**SAR(1 g) = 1.74 W/kg**

Deviation(1 g) = 1.05%



0 dB = 2.37 W/kg = 3.75 dBW/kg

# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d133**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.953 \text{ S/m}$ ;  $\epsilon_r = 53.651$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 04/06/2021; Ambient Temp: 22.8°C; Tissue Temp: 23.0°C

Probe: EX3DV4 - SN7410; ConvF(9.73, 9.73, 9.73) @ 835 MHz; Calibrated: 7/20/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1322; Calibrated: 7/15/2020

Phantom: Twin-SAM V5.0 Left 20; Type: QD 000 P40 CD; Serial: 1715

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.91 W/kg

**SAR(1 g) = 1.99 W/kg**

Deviation(1 g) = 2.05%



0 dB = 2.62 W/kg = 4.18 dBW/kg

# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d133**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.957 \text{ S/m}$ ;  $\epsilon_r = 53.073$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 04/08/2021; Ambient Temp: 23.4°C; Tissue Temp: 22.1°C

Probe: EX3DV4 - SN7410; ConvF(9.73, 9.73, 9.73) @ 835 MHz; Calibrated: 7/20/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1322; Calibrated: 7/15/2020

Phantom: Twin-SAM V5.0 Left 20; Type: QD 000 P40 CD; Serial: 1715

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.98 W/kg

**SAR(1 g) = 2.02 W/kg; SAR(10 g) = 1.34 W/kg**

Deviation(1 g) = 3.59%; Deviation(10 g) = 4.69%



0 dB = 2.67 W/kg = 4.27 dBW/kg

# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d133**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.953 \text{ S/m}$ ;  $\epsilon_r = 52.671$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 04/11/2021; Ambient Temp: 22.0°C; Tissue Temp: 22.0°C

Probe: EX3DV4 - SN7410; ConvF(9.73, 9.73, 9.73) @ 835 MHz; Calibrated: 7/20/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1322; Calibrated: 7/15/2020

Phantom: Twin-SAM V5.0 Left 20; Type: QD 000 P40 CD; Serial: 1715

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.97 W/kg

**SAR(1 g) = 2.02 W/kg**

Deviation(1 g) = 3.59%



0 dB = 2.67 W/kg = 4.27 dBW/kg

# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d132**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.956 \text{ S/m}$ ;  $\epsilon_r = 53.949$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 04/13/2021; Ambient Temp: 24.6°C; Tissue Temp: 23.1°C

Probe: EX3DV4 - SN7410; ConvF(9.73, 9.73, 9.73) @ 835 MHz; Calibrated: 7/20/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1322; Calibrated: 7/15/2020

Phantom: Twin-SAM V5.0 Left 20; Type: QD 000 P40 CD; Serial: 1715

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 3.07 W/kg

**SAR(1 g) = 2.07 W/kg; SAR(10 g) = 1.37 W/kg**

Deviation(1 g) = 5.50%; Deviation(10 g) = 6.37%



0 dB = 2.74 W/kg = 4.38 dBW/kg

# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d133**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.954 \text{ S/m}$ ;  $\epsilon_r = 53.583$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 04/15/2021; Ambient Temp: 23.0°C; Tissue Temp: 23.2°C

Probe: EX3DV4 - SN7410; ConvF(9.73, 9.73, 9.73) @ 835 MHz; Calibrated: 7/20/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1322; Calibrated: 7/15/2020

Phantom: Twin-SAM V5.0 Left 20; Type: QD 000 P40 CD; Serial: 1715

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 3.07 W/kg

**SAR(1 g) = 2.07 W/kg; SAR(10 g) = 1.37 W/kg**

Deviation(1 g) = 6.15%; Deviation(10 g) = 7.03%



# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d133**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.945 \text{ S/m}$ ;  $\epsilon_r = 52.79$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 04/17/2021; Ambient Temp: 22.8°C; Tissue Temp: 21.5°C

Probe: EX3DV4 - SN7410; ConvF(9.73, 9.73, 9.73) @ 835 MHz; Calibrated: 7/20/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1322; Calibrated: 7/15/2020

Phantom: Twin-SAM V5.0 Left 20; Type: QD 000 P40 CD; Serial: 1715

Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.99 W/kg

**SAR(1 g) = 2.01 W/kg**

Deviation(1 g) = 3.08%



0 dB = 2.66 W/kg = 4.25 dBW/kg

# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d133**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.954 \text{ S/m}$ ;  $\epsilon_r = 53.761$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 04/19/2021; Ambient Temp: 22.0°C; Tissue Temp: 21.9°C

Probe: EX3DV4 - SN7410; ConvF(9.73, 9.73, 9.73) @ 835 MHz; Calibrated: 7/20/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1322; Calibrated: 7/15/2020

Phantom: Twin-SAM V5.0 Left 20; Type: QD 000 P40 CD; Serial: 1715

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.97 W/kg

**SAR(1 g) = 2.03 W/kg; SAR(10 g) = 1.34 W/kg**

Deviation(1 g) = 4.10%; Deviation(10 g) = 4.69%



0 dB = 2.67 W/kg = 4.27 dBW/kg

# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d133**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.944 \text{ S/m}$ ;  $\epsilon_r = 52.652$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 04/21/2021; Ambient Temp: 22.4°C; Tissue Temp: 22.3°C

Probe: EX3DV4 - SN7410; ConvF(9.73, 9.73, 9.73) @ 835 MHz; Calibrated: 7/20/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1322; Calibrated: 7/15/2020

Phantom: Twin-SAM V5.0 Left 20; Type: QD 000 P40 CD; Serial: 1715

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 3.08 W/kg

**SAR(1 g) = 2.02 W/kg**

Deviation(1 g) = 3.59%



# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d047**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.963 \text{ S/m}$ ;  $\epsilon_r = 53.137$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 04/25/2021; Ambient Temp: 18.4°C; Tissue Temp: 20.0°C

Probe: EX3DV4 - SN7308; ConvF(9.92, 9.92, 9.92) @ 835 MHz; Calibrated: 7/31/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1450; Calibrated: 8/11/2020

Phantom: Twin-SAM V5.0; Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.95 W/kg

**SAR(1 g) = 1.93 W/kg; SAR(10 g) = 1.27 W/kg**

Deviation(1 g) = 1.90%; Deviation(10 g) = 1.28%



0 dB = 2.60 W/kg = 4.15 dBW/kg

# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d047**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.961 \text{ S/m}$ ;  $\epsilon_r = 53.775$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 05/25/2021; Ambient Temp: 21.6°C; Tissue Temp: 21.9°C

Probe: EX3DV4 - SN7308; ConvF(9.92, 9.92, 9.92) @ 835 MHz; Calibrated: 7/31/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1450; Calibrated: 8/11/2020

Phantom: Twin-SAM V5.0; Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.99 W/kg

**SAR(1 g) = 1.91 W/kg**

Deviation(1 g) = 0.84%



0 dB = 2.60 W/kg = 4.15 dBW/kg

# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d047**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.963 \text{ S/m}$ ;  $\epsilon_r = 53.18$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 06/02/2021; Ambient Temp: 23.1°C; Tissue Temp: 22.2°C

Probe: EX3DV4 - SN7308; ConvF(9.92, 9.92, 9.92) @ 835 MHz; Calibrated: 7/31/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1450; Calibrated: 8/11/2020

Phantom: Twin-SAM V5.0; Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 3.23 W/kg

**SAR(1 g) = 2.04 W/kg**

Deviation(1 g) = 7.71%



0 dB = 2.78 W/kg = 4.44 dBW/kg

# PCTEST

**DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d047**

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$ ;  $\sigma = 0.958 \text{ S/m}$ ;  $\epsilon_r = 52.788$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 06/06/2021; Ambient Temp: 22.3°C; Tissue Temp: 20.0°C

Probe: EX3DV4 - SN7308; ConvF(9.92, 9.92, 9.92) @ 835 MHz; Calibrated: 7/31/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1450; Calibrated: 8/11/2020

Phantom: Twin-SAM V5.0; Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 835 MHz System Verification at 23.0 dBm (200 mW)


**Area Scan (7x14x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 3.03 W/kg

**SAR(1 g) = 1.96 W/kg**

Deviation(1 g) = 3.48%



0 dB = 2.65 W/kg = 4.23 dBW/kg

# PCTEST

**DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1148**

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Body Medium parameters used:

$f = 1750$  MHz;  $\sigma = 1.546$  S/m;  $\epsilon_r = 50.935$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/08/2021; Ambient Temp: 22.7°C; Tissue Temp: 21.4°C

Probe: EX3DV4 - SN7308; ConvF(8.2, 8.2, 8.2) @ 1750 MHz; Calibrated: 7/31/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1450; Calibrated: 8/11/2020

Phantom: Twin-SAM V5.0; Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x9x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 6.93 W/kg

**SAR(1 g) = 3.7 W/kg; SAR(10 g) = 1.94 W/kg**

Deviation(1 g) = 1.93%; Deviation(10 g) = 0.52%



0 dB = 5.78 W/kg = 7.62 dBW/kg

# PCTEST

**DUT: Dipole 1750 MHz; Type: D1765V2; Serial: 1008**

Communication System: UID: 0, CW; Frequency: 1750.0 MHz  
Medium: 1750 Body; Medium parameters used:  
 $f = 1750.0$  MHz;  $\sigma = 1.50$  S/m;  $\epsilon_r = 52.6$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/11/2021; Ambient Temp: 22.0°C; Tissue Temp: 22.0°C

Probe: EX3DV4 - SN7551; ConvF:(8.32,8.32,8.32); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1333; Calibrated: 2020-10-16  
Phantom: Twin-SAM V5.0 Right Back; Serial: 1692  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (60.0 x 90.0):** Measurement grid: dx=15.0mm, dy=15.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=6.0mm, dy=6.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 7.29 W/kg

**SAR(1 g) = 3.84 W/kg**

Deviation (1 g) = 2.67%



# PCTEST

**DUT: Dipole 1750 MHz; Type: D1765V2; Serial: 1008**

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Body Medium parameters used:

$f = 1750$  MHz;  $\sigma = 1.528$  S/m;  $\epsilon_r = 51.875$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/11/2021; Ambient Temp: 21.1°C; Tissue Temp: 21.0°C

Probe: EX3DV4 - SN7308; ConvF(8.2, 8.2, 8.2) @ 1750 MHz; Calibrated: 7/31/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1450; Calibrated: 8/11/2020

Phantom: Twin-SAM V5.0; Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x9x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.24 W/kg

**SAR(1 g) = 3.75 W/kg; SAR(10 g) = 1.95 W/kg**

Deviation(1 g) = 0.27%; Deviation(10 g) = -2.01%



0 dB = 5.88 W/kg = 7.69 dBW/kg

# PCTEST

**DUT: Dipole 1750 MHz; Type: D1765V2; Serial: 1008**

Communication System: UID: 0, CW; Frequency: 1750.0 MHz  
Medium: 1750 Body; Medium parameters used:  
 $f = 1750.0$  MHz;  $\sigma = 1.49$  S/m;  $\epsilon_r = 52.5$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/14/2021; Ambient Temp: 22.5°C; Tissue Temp: 22.9°C

Probe: EX3DV4 - SN7551; ConvF:(8.32,8.32,8.32); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1333; Calibrated: 2020-10-16  
Phantom: Twin-SAM V5.0 Right Back; Serial: 1692  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (60.0 x 90.0):** Measurement grid: dx=15.0mm, dy=15.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=6.0mm, dy=6.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 7.13 W/kg

**SAR(1 g) = 3.76 W/kg; SAR(10 g) = 1.98 W/kg**

Deviation (1 g) = 0.53%; Deviation (10 g) = -0.50%



# PCTEST

**DUT: Dipole 1750 MHz; Type: D1765V2; Serial: 1008**

Communication System: UID: 0, CW; Frequency: 1750.0 MHz  
Medium: 1750 Body; Medium parameters used:  
 $f = 1750.0$  MHz;  $\sigma = 1.49$  S/m;  $\epsilon_r = 51.6$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/19/2021; Ambient Temp: 21.5°C; Tissue Temp: 22.0°C

Probe: EX3DV4 - SN7551; ConvF:(8.32,8.32,8.32); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1333; Calibrated: 2020-10-16  
Phantom: Twin-SAM V5.0 Right Back; Serial: 1692  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (60.0 x 90.0):** Measurement grid: dx=15.0mm, dy=15.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=6.0mm, dy=6.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 7.31 W/kg

**SAR(1 g) = 3.84 W/kg**

Deviation (1 g) = 2.67%



# PCTEST

**DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1150**

Communication System: UID: 0, CW; Frequency: 1750.0 MHz  
Medium: 1750 Body; Medium parameters used:  
 $f = 1750.0$  MHz;  $\sigma = 1.50$  S/m;  $\epsilon_r = 51.2$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/21/2021; Ambient Temp: 24.0°C; Tissue Temp: 22.5°C

Probe: EX3DV4 - SN7551; ConvF:(8.32,8.32,8.32); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (All points)  
Electronics: DAE4 Sn1333; Calibrated: 2020-10-16  
Phantom: Twin-SAM V5.0 Right Back; Serial: 1692  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (60.0 x 90.0):** Measurement grid: dx=15.0mm, dy=15.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=6.0mm, dy=6.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 7.26 W/kg

**SAR(1 g) = 3.79 W/kg**

Deviation (1 g) = 3.55%



# PCTEST

**DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1150**

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Body Medium parameters used:

$f = 1750 \text{ MHz}$ ;  $\sigma = 1.495 \text{ S/m}$ ;  $\epsilon_r = 51.19$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 05/05/2021; Ambient Temp: 24.7°C; Tissue Temp: 23.91°C

Probe: EX3DV4 - SN7571; ConvF(8.09, 8.09, 8.09) @ 1750 MHz; Calibrated: 12/11/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1533; Calibrated: 12/7/2020

Phantom: SAM 5.0 front; Type: QD000P40CD; Serial: 1648

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x9x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.27 W/kg

**SAR(10 g) = 2.06 W/kg**

Deviation(10 g) = 6.19%



0 dB = 5.95 W/kg = 7.75 dBW/kg

# PCTEST

**DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1150**

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Body Medium parameters used:

$f = 1750$  MHz;  $\sigma = 1.528$  S/m;  $\epsilon_r = 51.562$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 05/10/2021; Ambient Temp: 22.7°C; Tissue Temp: 22.9°C

Probe: EX3DV4 - SN7571; ConvF(8.09, 8.09, 8.09) @ 1750 MHz; Calibrated: 12/11/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1533; Calibrated: 12/7/2020

Phantom: SAM 5.0 front; Type: QD000P40CD; Serial: 1648

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x9x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 6.92 W/kg

**SAR(1 g) = 3.73 W/kg; SAR(10 g) = 1.96 W/kg**

Deviation(1 g) = 1.91%; Deviation(10 g) = 1.03%



0 dB = 5.72 W/kg = 7.57 dBW/kg

# PCTEST

**DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1150**

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Body Medium parameters used:

$f = 1750$  MHz;  $\sigma = 1.516$  S/m;  $\epsilon_r = 51.753$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 05/15/2021; Ambient Temp: 22.3°C; Tissue Temp: 23.0°C

Probe: EX3DV4 - SN7571; ConvF(8.09, 8.09, 8.09) @ 1750 MHz; Calibrated: 12/11/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1533; Calibrated: 12/7/2020

Phantom: SAM 5.0 front; Type: QD000P40CD; Serial: 1648

Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14 (7483)

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x9x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 6.74 W/kg

**SAR(10 g) = 1.95 W/kg**

Deviation(10 g) = 0.52%



0 dB = 5.32 W/kg = 7.26 dBW/kg

# PCTEST

**DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1150**

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Body Medium parameters used:

$f = 1750 \text{ MHz}$ ;  $\sigma = 1.5 \text{ S/m}$ ;  $\epsilon_r = 51.98$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 05/20/2021; Ambient Temp: 24.0°C; Tissue Temp: 21.9°C

Probe: EX3DV4 - SN7410; ConvF(8.17, 8.17, 8.17) @ 1750 MHz; Calibrated: 7/20/2020

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1322; Calibrated: 7/15/2020

Phantom: Twin-SAM V5.0 Left 20; Type: QD 000 P40 CD; Serial: 1715

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1750 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x9x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 6.90 W/kg

**SAR(1 g) = 3.8 W/kg**

Deviation(1 g) = 3.83%



0 dB = 5.79 W/kg = 7.63 dBW/kg

# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d080**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900$  MHz;  $\sigma = 1.568$  S/m;  $\epsilon_r = 51.867$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/06/2021; Ambient Temp: 22.7°C; Tissue Temp: 22.4°C

Probe: EX3DV4 - SN3589; ConvF(6.84, 6.84, 6.84) @ 1900 MHz; Calibrated: 1/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1558; Calibrated: 1/13/2021

Phantom: Twin-SAM V5.0 (30); Type: QD 000 P40 CD; Serial: 1646

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.74 W/kg

**SAR(1 g) = 4.13 W/kg**

Deviation(1 g) = 5.36%



0 dB = 6.43 W/kg = 8.08 dBW/kg

# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d080**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900$  MHz;  $\sigma = 1.578$  S/m;  $\epsilon_r = 51.657$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/09/2021; Ambient Temp: 23.6°C; Tissue Temp: 22.3°C

Probe: EX3DV4 - SN3589; ConvF(6.84, 6.84, 6.84) @ 1900 MHz; Calibrated: 1/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1558; Calibrated: 1/13/2021

Phantom: Twin-SAM V5.0 (30); Type: QD 000 P40 CD; Serial: 1646

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.61 W/kg

**SAR(10 g) = 2.13 W/kg**

Deviation(10 g) = 3.40%



# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d080**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900$  MHz;  $\sigma = 1.577$  S/m;  $\epsilon_r = 51.666$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/11/2021; Ambient Temp: 23.6°C; Tissue Temp: 22.6°C

Probe: EX3DV4 - SN3589; ConvF(6.84, 6.84, 6.84) @ 1900 MHz; Calibrated: 1/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1558; Calibrated: 1/13/2021

Phantom: Twin-SAM V5.0 (30); Type: QD 000 P40 CD; Serial: 1646

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.59 W/kg

**SAR(1 g) = 4.11 W/kg; SAR(10 g) = 2.12 W/kg**

Deviation(1 g) = 4.85%; Deviation(10 g) = 2.91%



0 dB = 6.41 W/kg = 8.07 dBW/kg

# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d080**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900$  MHz;  $\sigma = 1.579$  S/m;  $\epsilon_r = 51.189$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/14/2021; Ambient Temp: 23.7°C; Tissue Temp: 21.9°C

Probe: EX3DV4 - SN3589; ConvF(6.84, 6.84, 6.84) @ 1900 MHz; Calibrated: 1/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1558; Calibrated: 1/13/2021

Phantom: Twin-SAM V5.0 (30); Type: QD 000 P40 CD; Serial: 1646

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.75 W/kg

**SAR(1 g) = 4.12 W/kg; SAR(10 g) = 2.12 W/kg**

Deviation(1 g) = 5.10%; Deviation(10 g) = 2.91%



0 dB = 6.46 W/kg = 8.10 dBW/kg

# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d080**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900$  MHz;  $\sigma = 1.578$  S/m;  $\epsilon_r = 52.098$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/19/2021; Ambient Temp: 23.3°C; Tissue Temp: 22.3°C

Probe: EX3DV4 - SN3589; ConvF(6.84, 6.84, 6.84) @ 1900 MHz; Calibrated: 1/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1558; Calibrated: 1/13/2021

Phantom: Twin-SAM V5.0 (30); Type: QD 000 P40 CD; Serial: 1646

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.75 W/kg

**SAR(1 g) = 4.17 W/kg**

Deviation(1 g) = 6.38%



0 dB = 6.43 W/kg = 8.08 dBW/kg

# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d080**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900$  MHz;  $\sigma = 1.578$  S/m;  $\epsilon_r = 51.307$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/21/2021; Ambient Temp: 23.4°C; Tissue Temp: 22.6°C

Probe: EX3DV4 - SN3589; ConvF(6.84, 6.84, 6.84) @ 1900 MHz; Calibrated: 1/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1558; Calibrated: 1/13/2021

Phantom: Twin-SAM V5.0 (30); Type: QD 000 P40 CD; Serial: 1646

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.81 W/kg

**SAR(1 g) = 4.15 W/kg; SAR(10 g) = 2.14 W/kg**

Deviation(1 g) = 5.87%; Deviation(10 g) = 3.88%



0 dB = 6.51 W/kg = 8.14 dBW/kg

# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d080**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900 \text{ MHz}$ ;  $\sigma = 1.58 \text{ S/m}$ ;  $\epsilon_r = 53.169$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/26/2021; Ambient Temp: 23.3°C; Tissue Temp: 21.9°C

Probe: EX3DV4 - SN3589; ConvF(6.84, 6.84, 6.84) @ 1900 MHz; Calibrated: 1/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1558; Calibrated: 1/13/2021

Phantom: Twin-SAM V5.0 (30); Type: QD 000 P40 CD; Serial: 1646

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.81 W/kg

**SAR(10 g) = 2.16 W/kg**

Deviation(10 g) = 4.85%



0 dB = 6.55 W/kg = 8.16 dBW/kg

# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d080**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900$  MHz;  $\sigma = 1.553$  S/m;  $\epsilon_r = 52.012$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 04/28/2021; Ambient Temp: 23.4°C; Tissue Temp: 22.3°C

Probe: EX3DV4 - SN3589; ConvF(6.84, 6.84, 6.84) @ 1900 MHz; Calibrated: 1/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1558; Calibrated: 1/13/2021

Phantom: Twin-SAM V5.0 (30); Type: QD 000 P40 CD; Serial: 1646

Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.41 W/kg

**SAR(1 g) = 3.97 W/kg**

Deviation(1 g) = 1.28%



0 dB = 6.19 W/kg = 7.92 dBW/kg

# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d080**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900$  MHz;  $\sigma = 1.548$  S/m;  $\epsilon_r = 51.739$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 05/02/2021; Ambient Temp: 22.0°C; Tissue Temp: 22.5°C

Probe: EX3DV4 - SN3589; ConvF(6.84, 6.84, 6.84) @ 1900 MHz; Calibrated: 1/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1558; Calibrated: 1/13/2021

Phantom: Twin-SAM V5.0 (30); Type: QD 000 P40 CD; Serial: 1646

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.85 W/kg

**SAR(1 g) = 4.09 W/kg; SAR(10 g) = 2.1 W/kg**

Deviation(1 g) = 4.34%; Deviation(10 g) = 1.94%



0 dB = 6.43 W/kg = 8.08 dBW/kg

# PCTEST

**DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d080**

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900 \text{ MHz}$ ;  $\sigma = 1.58 \text{ S/m}$ ;  $\epsilon_r = 51.212$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 06/09/2021; Ambient Temp: 23.7°C; Tissue Temp: 22.1°C

Probe: EX3DV4 - SN3589; ConvF(6.84, 6.84, 6.84) @ 1900 MHz; Calibrated: 1/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1558; Calibrated: 1/13/2021

Phantom: Twin-SAM V5.0 (30); Type: QD 000 P40 CD; Serial: 1646

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

## 1900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (7x11x1):** Measurement grid: dx=15mm, dy=15mm

**Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.12 W/kg

**SAR(1 g) = 3.75 W/kg**

Deviation(1 g) = -4.34%



0 dB = 5.90 W/kg = 7.71 dBW/kg

# PCTEST

**DUT: Dipole 2300 MHz; Type: D2300V2; Serial: 1073**

Communication System: UID: 0, CW; Frequency: 2300.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2300.0$  MHz;  $\sigma = 1.86$  S/m;  $\epsilon_r = 51.1$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/11/2021; Ambient Temp: 24.0°C; Tissue Temp: 22.3°C

Probe: EX3DV4 - SN7538; ConvF:(7.62,7.62,7.62); Calibrated: 2020-11-23  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1449; Calibrated: 2020-09-10  
Phantom: Twin-SAM V5.0 (Leftt); Serial: 1873  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2300 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 9.98 W/kg

**SAR(1 g) = 4.92 W/kg; SAR(10 g) = 2.34 W/kg**

Deviation (1 g) = 3.14%; Deviation (10 g) = 0.86%



# PCTEST

**DUT: Dipole 2450 MHz; Type: D2450V2; Serial: 797**

Communication System: UID: 0, CW; Frequency: 2450.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2450.0$  MHz;  $\sigma = 1.99$  S/m;  $\epsilon_r = 52.2$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/12/2021; Ambient Temp: 21.7°C; Tissue Temp: 23.2°C

Probe: EX3DV4 - SN7539; ConvF:(7.62,7.62,7.62); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2450 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 10.8 W/kg

**SAR(1 g) = 5.13 W/kg; SAR(10 g) = 2.37 W/kg**

Deviation (1 g) = 3.85%; Deviation (10 g) = 1.28%



# PCTEST

**DUT: Dipole 2600 MHz; Type: D2600V2; Serial: 1064**

Communication System: UID: 0, CW; Frequency: 2600.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2600.0$  MHz;  $\sigma = 2.20$  S/m;  $\epsilon_r = 51.6$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/12/2021; Ambient Temp: 21.7°C; Tissue Temp: 23.2°C

Probe: EX3DV4 - SN7539; ConvF:(7.55,7.55,7.55); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2600 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 11.9 W/kg

**SAR(1 g) = 5.39 W/kg; SAR(10 g) = 2.38 W/kg**

Deviation (1 g) = -3.06%; Deviation (10 g) = -4.80%



# PCTEST

**DUT: Dipole 2450 MHz; Type: D2450V2; Serial: 719**

Communication System: UID: 0, CW; Frequency: 2450.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2450.0$  MHz;  $\sigma = 2.03$  S/m;  $\epsilon_r = 53.1$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/14/2021; Ambient Temp: 23.4°C; Tissue Temp: 22.6°C

Probe: EX3DV4 - SN7538; ConvF:(7.44,7.44,7.44); Calibrated: 2020-11-23  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1449; Calibrated: 2020-09-10  
Phantom: Twin-SAM V5.0 (Leftt); Serial: 1873  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2450 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 11.1 W/kg

**SAR(1 g) = 5.30 W/kg; SAR(10 g) = 2.44 W/kg**

Deviation (1 g) = 4.54%; Deviation (10 g) = 2.09%



# PCTEST

**DUT: Dipole 2450 MHz; Type: D2450V2; Serial: 981**

Communication System: UID: 0, CW; Frequency: 2450.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2450.0$  MHz;  $\sigma = 1.99$  S/m;  $\epsilon_r = 51.9$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/15/2021; Ambient Temp: 20.5°C; Tissue Temp: 22.0°C

Probe: EX3DV4 - SN7539; ConvF:(7.62,7.62,7.62); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2450 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 10.9 W/kg

**SAR(1 g) = 4.98 W/kg**

Deviation (1 g) = -0.60%



# PCTEST

**DUT: Dipole 2600 MHz; Type: D2600V2; Serial: 1071**

Communication System: UID: 0, CW; Frequency: 2600.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2600.0$  MHz;  $\sigma = 2.19$  S/m;  $\epsilon_r = 51.3$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/15/2021; Ambient Temp: 20.5°C; Tissue Temp: 22.0°C

Probe: EX3DV4 - SN7539; ConvF:(7.55,7.55,7.55); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2600 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 12.7 W/kg

**SAR(1 g) = 5.54 W/kg**

Deviation (1 g) = 2.03%



# PCTEST

**DUT: Dipole 2300 MHz; Type: D2300V2; Serial: 1073**

Communication System: UID: 0, CW; Frequency: 2300.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2300.0$  MHz;  $\sigma = 1.87$  S/m;  $\epsilon_r = 52.9$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/18/2021; Ambient Temp: 24.0°C; Tissue Temp: 22.1°C

Probe: EX3DV4 - SN7538; ConvF:(7.62,7.62,7.62); Calibrated: 2020-11-23  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1449; Calibrated: 2020-09-10  
Phantom: Twin-SAM V5.0 (Leftt); Serial: 1873  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2300 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 9.52 W/kg

**SAR(1 g) = 4.73 W/kg**

Deviation (1 g) = -0.84%



# PCTEST

**DUT: Dipole 2600 MHz; Type: D2600V2; Serial: 1071**

Communication System: UID: 0, CW; Frequency: 2600.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2600.0$  MHz;  $\sigma = 2.21$  S/m;  $\epsilon_r = 51.8$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/18/2021; Ambient Temp: 22.9°C; Tissue Temp: 22.3°C

Probe: EX3DV4 - SN7539; ConvF:(7.55,7.55,7.55); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2600 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 11.9 W/kg

**SAR(1 g) = 5.30 W/kg**

Deviation (1 g) = -2.39%



# PCTEST

**DUT: Dipole 2450 MHz; Type: D2450V2; Serial: 981**

Communication System: UID: 0, CW; Frequency: 2450.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2450.0$  MHz;  $\sigma = 1.95$  S/m;  $\epsilon_r = 52.4$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/21/2021; Ambient Temp: 24.1°C; Tissue Temp: 24.5°C

Probe: EX3DV4 - SN7539; ConvF:(7.62,7.62,7.62); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2450 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 10.3 W/kg

**SAR(1 g) = 5.03 W/kg; SAR(10 g) = 2.35 W/kg**

Deviation (1 g) = 0.40%; Deviation (10 g) = -0.84%



# PCTEST

**DUT: Dipole 2600 MHz; Type: D2600V2; Serial: 1071**

Communication System: UID: 0, CW; Frequency: 2600.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2600.0$  MHz;  $\sigma = 2.16$  S/m;  $\epsilon_r = 52.0$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/21/2021; Ambient Temp: 24.1°C; Tissue Temp: 24.5°C

Probe: EX3DV4 - SN7539; ConvF:(7.55,7.55,7.55); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2600 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 11.9 W/kg

**SAR(1 g) = 5.34 W/kg; SAR(10 g) = 2.39 W/kg**

Deviation (1 g) = -1.66%; Deviation (10 g) = -0.83%



# PCTEST

**DUT: Dipole 2300.0 MHz; Type: D2300V2; Serial: 1073**

Communication System: UID: 0, CW; Frequency: 2300.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2300.0$  MHz;  $\sigma = 1.78$  S/m;  $\epsilon_r = 53.3$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/26/2021; Ambient Temp: 23.5°C; Tissue Temp: 23.6°C

Probe: EX3DV4 - SN7539; ConvF:(7.64,7.64,7.64); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2300 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 9.58 W/kg

**SAR(1 g) = 4.90 W/kg; SAR(10 g) = 2.36 W/kg**

Deviation (1 g) = 2.73%; Deviation (10 g) = 1.72%



# PCTEST

**DUT: Dipole 2450 MHz; Type: D2450V2; Serial: 981**

Communication System: UID: 0, CW; Frequency: 2450.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2450.0$  MHz;  $\sigma = 1.95$  S/m;  $\epsilon_r = 52.6$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/03/2021; Ambient Temp: 21.3°C; Tissue Temp: 23.7°C

Probe: EX3DV4 - SN7539; ConvF:(7.62,7.62,7.62); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2450 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 10.9 W/kg

**SAR(10 g) = 2.35 W/kg**

Deviation (10 g) = -0.84%



# PCTEST

**DUT: Dipole 2600 MHz; Type: D2600V2; Serial: 1071**

Communication System: UID: 0, CW; Frequency: 2600.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2600.0$  MHz;  $\sigma = 2.16$  S/m;  $\epsilon_r = 52.1$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/03/2021; Ambient Temp: 21.3°C; Tissue Temp: 23.7°C

Probe: EX3DV4 - SN7539; ConvF:(7.55,7.55,7.55); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2600 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 12.0 W/kg

**SAR(1 g) = 5.45 W/kg**

Deviation (1 g) = 0.37%



# PCTEST

**DUT: Dipole 2450 MHz; Type: D2450V2; Serial: 719**

Communication System: UID: 0, CW; Frequency: 2450.0 MHz  
Medium: 2450 Body; Medium parameters used:  
 $f = 2450.0$  MHz;  $\sigma = 2.03$  S/m;  $\epsilon_r = 51.3$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/06/2021; Ambient Temp: 22.6°C; Tissue Temp: 22.4°C

Probe: EX3DV4 - SN7538; ConvF:(7.44,7.44,7.44); Calibrated: 2020-11-23  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1449; Calibrated: 2020-09-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1873  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 2450 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (30.0 x 30.0 x 30.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 11.1 W/kg

**SAR(10 g) = 2.38 W/kg**

Deviation (10 g) = -0.42%



# PCTEST

**DUT: Dipole 3500 MHz; Type: D3500V2; Serial: 1059**

Communication System: UID: 0, CW; Frequency: 3500.0 MHz  
Medium: 3600 Body; Medium parameters used:  
 $f = 3500.0$  MHz;  $\sigma = 3.26$  S/m;  $\epsilon_r = 49.6$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/26/2021; Ambient Temp: 21.0°C; Tissue Temp: 20.0°C

Probe: EX3DV4 - SN7551; ConvF:(6.31,6.31,6.31); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1333; Calibrated: 2020-10-16  
Phantom: Twin-SAM V5.0 Right Back; Serial: 1692  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3500 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 16.6 W/kg

**SAR(1 g) = 6.67 W/kg; SAR(10 g) = 2.53 W/kg**

Deviation (1 g) = 5.87%; Deviation (10 g) = 8.58%



# PCTEST

**DUT: Dipole 3700 MHz; Type: D3700V2; Serial: 1018**

Communication System: UID: 0, CW; Frequency: 3700.0 MHz  
Medium: 3600 Body; Medium parameters used:  
 $f = 3700.0$  MHz;  $\sigma = 3.50$  S/m;  $\epsilon_r = 49.3$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/26/2021; Ambient Temp: 21.0°C; Tissue Temp: 20.0°C

Probe: EX3DV4 - SN7551; ConvF:(6.41,6.41,6.41); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1333; Calibrated: 2020-10-16  
Phantom: Twin-SAM V5.0 Right Back; Serial: 1692  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3700 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 17.3 W/kg

**SAR(1 g) = 6.68 W/kg; SAR(10 g) = 2.46 W/kg**

Deviation (1 g) = 5.20%; Deviation (10 g) = 9.33%



# PCTEST

**DUT: Dipole 3500 MHz; Type: D3500V2; Serial: 1097**

Communication System: UID: 0, CW; Frequency: 3500.0 MHz  
Medium: 3600 Body; Medium parameters used:  
 $f = 3500.0$  MHz;  $\sigma = 3.26$  S/m;  $\epsilon_r = 51.1$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/12/2021; Ambient Temp: 20.9°C; Tissue Temp: 19.6°C

Probe: EX3DV4 - SN7539; ConvF:(6.5,6.5,6.5); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3500 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 16.4 W/kg

**SAR(1 g) = 6.51 W/kg**

Deviation (1 g) = 1.40%



# PCTEST

**DUT: Dipole 3700 MHz; Type: D3700V2; Serial: 1067**

Communication System: UID: 0, CW; Frequency: 3700.0 MHz  
Medium: 3600 Body; Medium parameters used:  
 $f = 3700.0$  MHz;  $\sigma = 3.54$  S/m;  $\epsilon_r = 48.6$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/13/2021; Ambient Temp: 22.0°C; Tissue Temp: 22.0°C

Probe: EX3DV4 - SN7551; ConvF:(6.41,6.41,6.41); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1333; Calibrated: 2020-10-16  
Phantom: Twin-SAM V5.0 Right Back; Serial: 1692  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3700 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 18.7 W/kg

**SAR(1 g) = 6.89 W/kg; SAR(10 g) = 2.47 W/kg**

Deviation (1 g) = 5.67%; Deviation (10 g) = 6.01%



# PCTEST

**DUT: Dipole 3900 MHz; Type: D3900V2; Serial: 1056**

Communication System: UID: 0, CW; Frequency: 3900.0 MHz  
Medium: 3600 Body; Medium parameters used:  
 $f = 3900.0$  MHz;  $\sigma = 3.75$  S/m;  $\epsilon_r = 48.4$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/13/2021; Ambient Temp: 22.0°C; Tissue Temp: 22.0°C

Probe: EX3DV4 - SN7551; ConvF:(5.95,5.95,5.95); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1333; Calibrated: 2020-10-16  
Phantom: Twin-SAM V5.0 Right Back; Serial: 1692  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 19.8 W/kg

**SAR(1 g) = 6.84 W/kg; SAR(10 g) = 2.32 W/kg**

Deviation (1 g) = 3.17%; Deviation (10 g) = 0.87%



# PCTEST

**DUT: Dipole 3500 MHz; Type: D3500V2; Serial: 1097**

Communication System: UID: 0, CW; Frequency: 3500.0 MHz  
Medium: 3600 Body; Medium parameters used:  
 $f = 3500.0$  MHz;  $\sigma = 3.27$  S/m;  $\epsilon_r = 51.5$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/14/2021; Ambient Temp: 22.3°C; Tissue Temp: 19.8°C

Probe: EX3DV4 - SN7539; ConvF:(6.5,6.5,6.5); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3500 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 15.6 W/kg

**SAR(1 g) = 6.13 W/kg; SAR(10 g) = 2.31 W/kg**

Deviation (1 g) = -4.52%; Deviation (10 g) = -2.94%



# PCTEST

**DUT: Dipole 3700 MHz; Type: D3700V2; Serial: 1067**

Communication System: UID: 0, CW; Frequency: 3700.0 MHz  
Medium: 3600 Body; Medium parameters used:  
 $f = 3700.0$  MHz;  $\sigma = 3.50$  S/m;  $\epsilon_r = 50.5$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 06/03/2021; Ambient Temp: 23.0°C; Tissue Temp: 20.4°C

Probe: EX3DV4 - SN7539; ConvF:(6.48,6.48,6.48); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3700 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 17.3 W/kg

**SAR(1 g) = 6.67 W/kg; SAR(10 g) = 2.44 W/kg**

Deviation (1 g) = 2.30%; Deviation (10 g) = 4.72%



# PCTEST

**DUT: Dipole 3900 MHz; Type: D3900V2; Serial: 1056**

Communication System: UID: 0, CW; Frequency: 3900.0 MHz  
Medium: 3600 Body; Medium parameters used:  
 $f = 3900.0$  MHz;  $\sigma = 3.77$  S/m;  $\epsilon_r = 50.1$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 06/03/2021; Ambient Temp: 23.0°C; Tissue Temp: 20.4°C

Probe: EX3DV4 - SN7539; ConvF:(6.18,6.18,6.18); Calibrated: 2020-10-20  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10  
Phantom: Twin-SAM V5.0 (Left); Serial: 1630  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 3900 MHz System Verification at 20.0 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.4mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 17.6 W/kg

**SAR(1 g) = 6.68 W/kg; SAR(10 g) = 2.34 W/kg**

Deviation (1 g) = 0.75%; Deviation (10 g) = 1.74%



# PCTEST

**DUT: Dipole 5250 MHz; Type: D5GHzV2; Serial: 1191**

Communication System: UID: 0, CW; Frequency: 5250.0 MHz  
Medium: 5200-5800 Body; Medium parameters used:  
 $f = 5250.0$  MHz;  $\sigma = 5.40$  S/m;  $\epsilon_r = 47.7$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/13/2021; Ambient Temp: 21.5°C; Tissue Temp: 21.2°C

Probe: EX3DV4 - SN7526; ConvF:(4.55,4.55,4.55); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 5250 MHz System Verification at 17.0 dBm (50 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 14.802 W/kg

**SAR(1 g) = 3.69 W/kg**

Deviation (1 g) = -1.07%



# PCTEST

**DUT: Dipole 5600 MHz; Type: D5GHzV2; Serial: 1191**

Communication System: UID: 0, CW; Frequency: 5600.0 MHz  
Medium: 5200-5800 Body; Medium parameters used:  
 $f = 5600.0$  MHz;  $\sigma = 5.90$  S/m;  $\epsilon_r = 47.1$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/13/2021; Ambient Temp: 21.5°C; Tissue Temp: 21.2°C

Probe: EX3DV4 - SN7526; ConvF:(4.12,4.12,4.12); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 5600 MHz System Verification at 17.0 dBm (50 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 16.103 W/kg

**SAR(1 g) = 3.73 W/kg**

Deviation (1 g) = -4.48%



# PCTEST

**DUT: Dipole 5750 MHz; Type: D5GHzV2; Serial: 1191**

Communication System: UID: 0, CW; Frequency: 5750.0 MHz  
Medium: 5200-5800 Body; Medium parameters used:  
 $f = 5750.0$  MHz;  $\sigma = 6.11$  S/m;  $\epsilon_r = 46.8$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/13/2021; Ambient Temp: 21.5°C; Tissue Temp: 21.2°C

Probe: EX3DV4 - SN7526; ConvF:(4.14,4.14,4.14); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## **5750 MHz System Verification at 17.0 dBm (50 mW)**


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 15.875 W/kg

**SAR(1 g) = 3.53 W/kg**

Deviation (1 g) = -5.74%



# PCTEST

**DUT: Dipole 5250 MHz; Type: D5GHzV2; Serial: 1191**

Communication System: UID: 0, CW; Frequency: 5250.0 MHz  
Medium: 5200-5800 Body; Medium parameters used:  
 $f = 5250.0$  MHz;  $\sigma = 5.11$  S/m;  $\epsilon_r = 47.0$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/16/2021; Ambient Temp: 20.9°C; Tissue Temp: 22.2°C

Probe: EX3DV4 - SN7526; ConvF:(4.55,4.55,4.55); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 5250 MHz System Verification at 17.0 dBm (50 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=5.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 13.754 W/kg

**SAR(1 g) = 3.47 W/kg**

Deviation (1 g) = -6.97%



# PCTEST

**DUT: Dipole 5600 MHz; Type: D5GHzV2; Serial: 1191**

Communication System: UID: 0, CW; Frequency: 5600.0 MHz  
Medium: 5200-5800 Body; Medium parameters used:  
 $f = 5600.0$  MHz;  $\sigma = 5.58$  S/m;  $\epsilon_r = 46.4$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/16/2021; Ambient Temp: 20.9°C; Tissue Temp: 22.2°C

Probe: EX3DV4 - SN7526; ConvF:(4.12,4.12,4.12); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 5600 MHz System Verification at 17.0 dBm (50 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=5.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 16.497 W/kg

**SAR(1 g) = 3.79 W/kg**

Deviation (1 g) = -2.94%



# PCTEST

**DUT: Dipole 5750 MHz; Type: D5GHzV2; Serial: 1191**

Communication System: UID: 0, CW; Frequency: 5750.0 MHz  
Medium: 5200-5800 Body; Medium parameters used:  
 $f = 5750.0$  MHz;  $\sigma = 5.78$  S/m;  $\epsilon_r = 46.2$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/16/2021; Ambient Temp: 20.9°C; Tissue Temp: 22.2°C

Probe: EX3DV4 - SN7526; ConvF:(4.14,4.14,4.14); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## **5750 MHz System Verification at 17.0 dBm (50 mW)**


**Area Scan (40.0 x 80.0):** Measurement grid: dx=5.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 16.856 W/kg

**SAR(1 g) = 3.77 W/kg**

Deviation (1 g) = 0.67%



# PCTEST

**DUT: Dipole 5250 MHz; Type: D5GHzV2; Serial: 1057**

Communication System: UID: 0, CW; Frequency: 5250.0 MHz  
Medium: 5200-5800 Body; Medium parameters used:  
 $f = 5250.0$  MHz;  $\sigma = 5.38$  S/m;  $\epsilon_r = 49.9$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/19/2021; Ambient Temp: 21.9°C; Tissue Temp: 22.6°C

Probe: EX3DV4 - SN7526; ConvF:(4.55,4.55,4.55); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 5250 MHz System Verification at 17.0 dBm (50 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=5.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 15.1 W/kg

**SAR(1 g) = 3.83 W/kg; SAR(10 g) = 1.07 W/kg**

Deviation (1 g) = 3.10%; Deviation (10 g) = 3.38%



# PCTEST

**DUT: Dipole 5600 MHz; Type: D5GHzV2; Serial: 1057**

Communication System: UID: 0, CW; Frequency: 5600.0 MHz  
Medium: 5200-5800 Body; Medium parameters used:  
 $f = 5600.0$  MHz;  $\sigma = 5.89$  S/m;  $\epsilon_r = 49.3$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/19/2021; Ambient Temp: 21.9°C; Tissue Temp: 22.6°C

Probe: EX3DV4 - SN7526; ConvF:(4.12,4.12,4.12); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 5600 MHz System Verification at 17.0 dBm (50 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=5.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 17.3 W/kg

**SAR(1 g) = 4.04 W/kg; SAR(10 g) = 1.11 W/kg**

Deviation (1 g) = 4.39%; Deviation (10 g) = 3.74%



# PCTEST

**DUT: Dipole 5750 MHz; Type: D5GHzV2; Serial: 1057**

Communication System: UID: 0, CW; Frequency: 5750.0 MHz  
Medium: 5200-5800 Body; Medium parameters used:  
 $f = 5750.0$  MHz;  $\sigma = 6.11$  S/m;  $\epsilon_r = 49.0$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 04/19/2021; Ambient Temp: 21.9°C; Tissue Temp: 22.6°C

Probe: EX3DV4 - SN7526; ConvF:(4.14,4.14,4.14); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## **5750 MHz System Verification at 17.0 dBm (50 mW)**


**Area Scan (40.0 x 80.0):** Measurement grid: dx=5.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 16.6 W/kg

**SAR(1 g) = 3.77 W/kg; SAR(10 g) = 1.05 W/kg**

Deviation (1 g) = 3.57%; Deviation (10 g) = 5.00%



# PCTEST

**DUT: Dipole 5250 MHz; Type: D5GHzV2; Serial: 1191**

Communication System: UID: 0, CW; Frequency: 5250.0 MHz  
Medium: 5200-5800 Body; Medium parameters used:  
 $f = 5250.0$  MHz;  $\sigma = 5.42$  S/m;  $\epsilon_r = 48.7$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/03/2021; Ambient Temp: 20.5°C; Tissue Temp: 21.0°C

Probe: EX3DV4 - SN7526; ConvF:(4.55,4.55,4.55); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 5250 MHz System Verification at 17.0 dBm (50 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=5.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 14.9 W/kg

**SAR(10 g) = 1.04 W/kg**

Deviation (10 g) = -0.95%



# PCTEST

**DUT: Dipole 5600 MHz; Type: D5GHzV2; Serial: 1191**

Communication System: UID: 0, CW; Frequency: 5600.0 MHz  
Medium: 5200-5800 Body; Medium parameters used:  
 $f = 5600.0$  MHz;  $\sigma = 5.91$  S/m;  $\epsilon_r = 48.0$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/03/2021; Ambient Temp: 20.5°C; Tissue Temp: 21.0°C

Probe: EX3DV4 - SN7526; ConvF:(4.12,4.12,4.12); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## 5600 MHz System Verification at 17.0 dBm (50 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=5.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 16.2 W/kg

**SAR(10 g) = 1.03 W/kg**

Deviation (10 g) = -5.07%



# PCTEST

**DUT: Dipole 5750 MHz; Type: D5GHzV2; Serial: 1191**

Communication System: UID: 0, CW; Frequency: 5750.0 MHz  
Medium: 5200-5800 Body; Medium parameters used:  
 $f = 5750.0$  MHz;  $\sigma = 6.13$  S/m;  $\epsilon_r = 47.7$ ; density =  $1000$  kg/m<sup>3</sup>  
Phantom Section: Flat Section; Space: 1.0 cm

Test Date: 05/03/2021; Ambient Temp: 20.5°C; Tissue Temp: 21.0°C

Probe: EX3DV4 - SN7526; ConvF:(4.14,4.14,4.14); Calibrated: 2021-03-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18  
Phantom: Twin-SAM V5.0 (left); Serial: 1758  
Measurement SW: cDASY6 Module SAR V6.14.0.959

## **5750 MHz System Verification at 17.0 dBm (50 mW)**

**Area Scan (40.0 x 80.0):** Measurement grid: dx=5.0mm, dy=10.0mm

**Zoom Scan (22.0 x 22.0 x 22.0):** Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 15.6 W/kg

**SAR(10 g) = 0.993 W/kg**

Deviation (10 g) = -4.52%

