

Measurement Report for SM_F956U, EDGE RIGHT, WLAN 5GHz, IEEE 802.11n (HT Mixed, 40MHz, MCS0, 90pc duty cycle), Channel 54 (5270.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	EDGE RIGHT, 0.00	WLAN 5GHz	WLAN, 10599-AAD	5270.0	5.24	4.69	35.9

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2046	HBBL-600-10000	EX3DV4 - SN7313, 2024-02-21	DAE4 Sn1468, 2023-08-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	60.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	2.2 x 2.2 x 1.2
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	2.57	3.55
psSAR10g [W/Kg]	0.753	0.889
Power Drift [dB]		-0.00
M2/M1 [%]		57.9
Dist 3dB Peak [mm]		3.0



Measurement Report for SM_F956U, BACK, WLAN 5GHz, IEEE 802.11n (HT Mixed, 40MHz, MCS0, 90pc duty cycle), Channel 54 (5270.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	BACK, 10.00	WLAN 5GHz	WLAN, 10599-AAD	5270.0	5.24	4.62	35.6

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2046	HBBL-600-10000	EX3DV4 - SN7313, 2024-02-21	DAE4 Sn1468, 2023-08-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.171	0.165
psSAR10g [W/Kg]	0.067	0.062
Power Drift [dB]	-0.12	
M2/M1 [%]	68.1	
Dist 3dB Peak [mm]	8.2	



Measurement Report for SM_F956U, CHEEK, WLAN 5GHz, IEEE 802.11n (HT Mixed, 40MHz, MCS0, 90pc duty cycle), Channel 54 (5270.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
LeftHead, HSL	CHEEK, 0.00	WLAN 5GHz	WLAN, 10599-AAD	5270.0	5.24	4.62	35.6

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2046	HBBL-600-10000	EX3DV4 - SN7313, 2024-02-21	DAE4 Sn1468, 2023-08-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	2.4 x 2.4 x 1.2
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.428	0.550
psSAR10g [W/Kg]	0.129	0.141
Power Drift [dB]	-0.13	
M2/M1 [%]	68.9	
Dist 3dB Peak [mm]	3.4	



Measurement Report for SM_F956U, BACK, WLAN 5GHz, IEEE 802.11n (HT Mixed, 40MHz, MCS0, 90pc duty cycle), Channel 54 (5270.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	BACK, 10.00	WLAN 5GHz	WLAN, 10599-AAD	5270.0	5.24	4.62	35.6

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2046	HBBL-600-10000	EX3DV4 - SN7313, 2024-02-21	DAE4 Sn1468, 2023-08-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.235	0.226
psSAR10g [W/Kg]	0.091	0.086
Power Drift [dB]		-0.15
M2/M1 [%]		68.8
Dist 3dB Peak [mm]		9.0



Measurement Report for SM_F956U, EDGE RIGHT, WLAN 5GHz, IEEE 802.11n (HT Mixed, 40MHz, MCS0, 90pc duty cycle), Channel 54 (5270.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	EDGE RIGHT, 0.00	WLAN 5GHz	WLAN, 10599-AAD	5270.0	5.24	4.69	35.9

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2046	HBBL-600-10000	EX3DV4 - SN7313, 2024-02-21	DAE4 Sn1468, 2023-08-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	60.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	2.2 x 2.2 x 1.2
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	2.64	4.05
psSAR10g [W/Kg]	0.842	1.12
Power Drift [dB]		-0.03
M2/M1 [%]		56.4
Dist 3dB Peak [mm]		2.7



Measurement Report for SM_F956U, CHEEK, WLAN 5GHz, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 122 (5610.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
LeftHead, HSL	CHEEK, 0.00	WLAN 5GHz	WLAN, 10626-AAC	5610.0	4.98	5.01	35.1

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.228	0.247
psSAR10g [W/Kg]	0.076	0.073
Power Drift [dB]	0.08	
M2/M1 [%]	65.7	
Dist 3dB Peak [mm]	6.9	



Measurement Report for SM_F956U, EDGE RIGHT, WLAN 5GHz, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 122 (5610.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	EDGE RIGHT, 0.00	WLAN 5GHz	WLAN, 10626-AAC	5610.0	4.98	5.01	35.1

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	60.0 x 200.0	24.0 x 24.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	2.0 x 2.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	2.33	3.08
psSAR10g [W/Kg]	0.722	0.863
Power Drift [dB]	0.08	
M2/M1 [%]	55.3	
Dist 3dB Peak [mm]	3.0	



Measurement Report for SM_F956U, BACK, U-NII-2C < 5.65 GHz, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 122 (5610.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	BACK, 10.00	U-NII-2C < 5.65 GHz	WLAN, 10626-AAC	5610.0	4.71	4.93	36.0

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2039	HBBL-600-10000	EX3DV4 - SN7313, 2024-02-21	DAE4 Sn912, 2023-11-17

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.326	0.331
psSAR10g [W/Kg]	0.119	0.107
Power Drift [dB]		-0.12
M2/M1 [%]		62.2
Dist 3dB Peak [mm]		7.9



Measurement Report for SM_F956U, CHEEK, WLAN 5GHz, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 122 (5610.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
RightHead, HSL	CHEEK, 0.00	WLAN 5GHz	WLAN, 10626-AAC	5610.0	4.98	5.01	35.1

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.309	0.302
psSAR10g [W/Kg]	0.103	0.093
Power Drift [dB]		0.14
M2/M1 [%]		66.5
Dist 3dB Peak [mm]		6.8



Measurement Report for SM_F956U, BACK, U-NII-2C < 5.65 GHz, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 122 (5610.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	BACK, 10.00	U-NII-2C < 5.65 GHz	WLAN, 10626-AAC	5610.0	4.71	4.93	36.0

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2039	HBBL-600-10000	EX3DV4 - SN7313, 2024-02-21	DAE4 Sn912, 2023-11-17

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.445	0.441
psSAR10g [W/Kg]	0.153	0.140
Power Drift [dB]		0.12
M2/M1 [%]		64.1
Dist 3dB Peak [mm]		6.5



Measurement Report for SM_F956U, EDGE TOP, WLAN 5GHz, IEEE 802.11ac WIFI (80MHz, MCS0, 90pc duty cycle), Channel 122 (5610.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	EDGE TOP, 0.00	WLAN 5GHz	WLAN, 10626-AAC	5610.0	4.98	5.01	35.1

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	60.0 x 100.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	3.10	3.94
psSAR10g [W/Kg]	0.830	1.01
Power Drift [dB]	0.02	
M2/M1 [%]	56.7	
Dist 3dB Peak [mm]	5.4	



Measurement Report for SM_F956U, CHEEK, WLAN 5GHz, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 155 (5775.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
RightHead, HSL	CHEEK, 0.00	WLAN 5GHz	WLAN, 10626-AAC	5775.0	5.03	5.31	35.6

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.431	0.442
psSAR10g [W/Kg]	0.132	0.129
Power Drift [dB]	0.11	
M2/M1 [%]	64.7	
Dist 3dB Peak [mm]	6.4	



Measurement Report for SM_F956U, BACK, Custom Band, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 5775000 (5775.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	BACK, 10.00	Custom Band	CW, 10626-AAC	5775.0	5.03	5.31	35.6

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.184	0.207
psSAR10g [W/Kg]	0.067	0.068
Power Drift [dB]		0.06
M2/M1 [%]		61.0
Dist 3dB Peak [mm]		8.8



Measurement Report for SM_F956U, TILT, WLAN 5GHz, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 155 (5775.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
LeftHead, HSL	TILT, 0.00	WLAN 5GHz	WLAN, 10626-AAC	5775.0	5.03	5.31	35.6

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.401	0.461
psSAR10g [W/Kg]	0.103	0.103
Power Drift [dB]	0.08	
M2/M1 [%]	59.7	
Dist 3dB Peak [mm]	5.4	



Measurement Report for SM_F956U, TILT, WLAN 5GHz, IEEE 802.11 ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 155 (5775.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
RightHead, HSL	TILT, 0.00	WLAN 5GHz	WLAN, 10626-AAC	5775.0	5.03	5.31	35.6

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.259	0.284
psSAR10g [W/Kg]	0.079	0.078
Power Drift [dB]	-0.02	
M2/M1 [%]	62.7	
Dist 3dB Peak [mm]	7.2	



Measurement Report for SM_F956U, CHEEK, Custom Band, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 5855000 (5855.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
RightHead, HSL	CHEEK, 0.00	Custom Band	CW, 10626-AAC	5855.0	5.03	5.38	34.6

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.399	0.382
psSAR10g [W/Kg]	0.122	0.115
Power Drift [dB]	0.08	
M2/M1 [%]	62.8	
Dist 3dB Peak [mm]	6.4	



Measurement Report for SM_F956U, BACK, Custom Band, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 5855000 (5855.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	BACK, 10.00	Custom Band	CW, 10626-AAC	5855.0	4.67	5.14	35.8

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2039	HBBL-600-10000	EX3DV4 - SN7313, 2024-02-21	DAE4 Sn912, 2023-11-17

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.209	0.218
psSAR10g [W/Kg]	0.075	0.071
Power Drift [dB]		-0.08
M2/M1 [%]		60.3
Dist 3dB Peak [mm]		8.8



Measurement Report for SM_F956U, EDGE TOP, Custom Band, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 5855000 (5855.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	EDGE TOP, 0.00	Custom Band	CW, 10626-AAC	5855.0	5.03	5.38	34.6

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	60.0 x 100.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	2.08	2.58
psSAR10g [W/Kg]	0.587	0.689
Power Drift [dB]	0.04	
M2/M1 [%]	53.7	
Dist 3dB Peak [mm]	5.1	



Measurement Report for SM_F956U, CHEEK, Custom Band, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 5855000 (5855.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
RightHead, HSL	CHEEK, 0.00	Custom Band	CW, 10626-AAC	5855.0	5.03	5.38	34.6

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.445	0.439
psSAR10g [W/Kg]	0.144	0.133
Power Drift [dB]		0.05
M2/M1 [%]		67.6
Dist 3dB Peak [mm]		7.2



Measurement Report for SM_F956U, EDGE RIGHT, Custom Band, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 5855000 (5855.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	EDGE RIGHT, 0.00	Custom Band	CW, 10626-AAC	5855.0	5.03	5.38	34.6

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7376, 2023-07-25	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	60.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	2.1 x 2.1 x 1.2
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	1.71	3.34
psSAR10g [W/Kg]	0.568	0.839
Power Drift [dB]		0.13
M2/M1 [%]		59.8
Dist 3dB Peak [mm]		2.6



Measurement Report for SM_F956U, BACK, Custom Band, IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle), Channel 5855000 (5855.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	BACK, 10.00	Custom Band	CW, 10626-AAC	5855.0	4.67	5.14	35.8

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2039	HBBL-600-10000	EX3DV4 - SN7313, 2024-02-21	DAE4 Sn912, 2023-11-17

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	22.0 x 22.0 x 22.0
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.285	0.287
psSAR10g [W/Kg]	0.103	0.097
Power Drift [dB]	-0.13	
M2/M1 [%]	60.2	
Dist 3dB Peak [mm]	9.0	



Measurement Report for SM_F956U, TILT, ISM 2.4 GHz Band, Bluetooth Low Energy, Channel 38 (2440.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
RightHead, HSL	TILT, 0.00	ISM 2.4 GHz Band	Bluetooth, 10670-AAA	2440.0	6.96	1.81	39.5

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7645, 2023-09-20	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	30.0 x 30.0 x 30.0
Grid Steps [mm]	10.0 x 10.0	5.0 x 5.0 x 1.5
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.229	0.236
psSAR10g [W/Kg]	0.104	0.108
Power Drift [dB]		-0.07
M2/M1 [%]		79.7
Dist 3dB Peak [mm]		7.7



Measurement Report for SM_F956U, EDGE TOP, ISM 2.4 GHz Band, Bluetooth Low Energy, Channel 38 (2440.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	EDGE TOP, 10.00	ISM 2.4 GHz Band	Bluetooth, 10670-AAA	2440.0	6.96	1.81	39.5

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7645, 2023-09-20	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	60.0 x 100.0	30.0 x 30.0 x 30.0
Grid Steps [mm]	10.0 x 10.0	5.0 x 5.0 x 1.5
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.401	0.412
psSAR10g [W/Kg]	0.201	0.207
Power Drift [dB]		-0.00
M2/M1 [%]		81.8
Dist 3dB Peak [mm]		10.5



Measurement Report for SM_F956U, CHEEK, ISM 2.4 GHz Band, IEEE 802.15.1 Bluetooth (GFSK, DH5), Channel 39 (2441.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
RightHead, HSL	CHEEK, 0.00	ISM 2.4 GHz Band	Bluetooth, 10032-CAA	2441.0	6.96	1.78	37.9

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7645, 2023-09-20	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	100.0 x 200.0	30.0 x 30.0 x 30.0
Grid Steps [mm]	10.0 x 10.0	5.0 x 5.0 x 1.5
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.099	0.097
psSAR10g [W/Kg]	0.047	0.048
Power Drift [dB]	0.08	
M2/M1 [%]	81.2	
Dist 3dB Peak [mm]	8.1	



Measurement Report for SM_F956U, EDGE TOP, ISM 2.4 GHz Band, IEEE 802.15.1 Bluetooth (GFSK, DH5), Channel 39 (2441.0 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	EDGE TOP, 10.00	ISM 2.4 GHz Band	Bluetooth, 10032-CAA	2441.0	6.96	1.78	37.9

Hardware Setup


Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
Twin-SAM V8.0 (30deg probe tilt) - 2038	HBBL-600-10000	EX3DV4 - SN7645, 2023-09-20	DAE4 Sn1670, 2023-05-24

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	60.0 x 100.0	30.0 x 30.0 x 30.0
Grid Steps [mm]	10.0 x 10.0	5.0 x 5.0 x 1.5
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.128	0.131
psSAR10g [W/Kg]	0.063	0.065
Power Drift [dB]	0.09	
M2/M1 [%]	81.0	
Dist 3dB Peak [mm]	10.1	



Measurement Report for SM_F956U, BACK, Custom Band, CW, Channel 4 (13.6 MHz)

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz]	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	BACK, 0.00	Custom Band	CW, 0--	13.6	16.33	0.717	56.6

Hardware Setup

Phantom	TSL (Tissue Simulating Liquid)	Probe, Calibration Date	DAE, Calibration Date
ELI V6.0 (20deg probe tilt) - 2005	HBBL-600-10000	EX3DV4 - SN7313, 2024-02-21	DAE4 Sn912, 2023-11-17

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	120.0 x 210.0	36.0 x 36.0 x 30.0
Grid Steps [mm]	15.0 x 15.0	6.0 x 6.0 x 1.5
Sensor Surface [mm]	3.0	1.4

Measurement Results

	Area Scan	Zoom Scan
psSAR1g [W/Kg]	0.021	0.028
psSAR10g [W/Kg]	0.015	0.010
Power Drift [dB]	0.04	
M2/M1 [%]	59.5	
Dist 3dB Peak [mm]	6.0	

