




PCTEST ENGINEERING LABORATORY, INC.

7185 Oakland Mills Road, Columbia, MD 21046 USA

Tel. 410.290.6652 / Fax 410.290.6654

<http://www.pctestlab.com>



HEARING AID COMPATIBILITY

Applicant Name:

Samsung Electronics Co., Ltd.
129, Samsung-ro, Maetan dong,
Yeongtong-gu, Suwon-si
Gyeonggi-do 443-742, Korea

Date of Testing:

01/26/2015 - 01/28/2015

Test Site/Location:

PCTEST Lab, Columbia, MD, USA

Test Report Serial No.:

0Y1501190102-R3.A3L

FCC ID:**A3LSMG920V****APPLICANT:****SAMSUNG ELECTRONICS CO., LTD.****Scope of Test:**

Audio Band Magnetic Testing (T-Coil)

Application Type:

Certification

FCC Rule Part(s):

CFR § 20.19(b)

HAC Standard:

ANSI C63.19-2011

EUT Type:

CTIA Test Plan for Hearing Aid Compatibility Rev 3.0, November 2013

Model(s):

Portable Handset

Test Device Serial No.:

SM-G920V

Pre-Production Sample [S/N: 073BC]

C63.19-2011 HAC Category: T3 (SIGNAL TO NOISE CATEGORY)

This revised Test Report (S/N: 0Y1501190102-R3.A3L) supersedes and replaces the previously issued test report on the same subject device for the same type of testing as indicated. Please discard or destroy the previously issued test report(s) and dispose of it accordingly.

This wireless portable device has been shown to be hearing-aid compatible under the above rated category, specified in ANSI/IEEE Std. C63.19-2011 and has been tested in accordance with the specified measurement procedures. Hearing-Aid Compatibility is based on the assumption that all production units will be designed electrically identical to the device tested in this report. Test results reported herein relate only to the item(s) tested. For North American bands only.

I attest to the accuracy of data. All measurements reported herein were performed by me or were made under my supervision and are correct to the best of my knowledge and belief. I assume full responsibility for the completeness of these measurements and vouch for the qualifications of all persons taking them.

Randy Ortanez
President

CTIA Authorized Test Lab
LAB CODE 20020221-00



FCC ID: A3LSMG920V		HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 1 of 41

T A B L E O F C O N T E N T S

1.	INTRODUCTION	3
2.	EUT DESCRIPTION.....	4
3.	ANSI C63.19-2011 PERFORMANCE CATEGORIES	5
4.	METHOD OF MEASUREMENT	7
5.	FCC 3G MEASUREMENTS.....	17
6.	TEST SUMMARY	19
7.	MEASUREMENT UNCERTAINTY	27
8.	EQUIPMENT LIST.....	28
9.	CALIBRATION CERTIFICATES.....	29
10.	CONCLUSION.....	36
11.	REFERENCES	37
12.	TEST SETUP PHOTOGRAPHS	39

FCC ID: A3LSMG920V	 PCTEST This report is valid for 18 months from the date of issue.	HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 2 of 41

1. INTRODUCTION

On July 10, 2003, the Federal Communications Commission (FCC) adopted new rules requiring wireless manufacturers and service providers to provide digital wireless phones that are compatible with hearing aids. The FCC has modified the exemption for wireless phones under the Hearing Aid Compatibility Act of 1998 (HAC Act) in WT Docket 01-309 RM-8658¹ to extend the benefits of wireless telecommunications to individuals with hearing disabilities. These benefits encompass business, social and emergency communications, which increase the value of the wireless network for everyone. Approximately 500 million people worldwide and 30 million people in the United States suffer from hearing loss.

Compatibility Tests Involved:

The standard calls for wireless communications devices to be measured for:

- RF Electric-field emissions
- RF Magnetic-field emissions
- T-coil mode, magnetic-signal strength in the audio band
- T-coil mode, magnetic-signal frequency response through the audio band
- T-coil mode, magnetic-signal and noise articulation index

The hearing aid must be measured for:

- RF immunity in microphone mode
- RF immunity in T-coil mode

In the following tests and results, this report includes the evaluation for a wireless communications device.




Figure 1-1 Hearing Aid *in-vitu*

¹ FCC Rule & Order, WT Docket 01-309 RM-8658

FCC ID: A3LSMG920V	 PCTEST This report is valid for 12 months from the date of issue.	HAC (T-COIL) TEST REPORT	 Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset	Page 3 of 41

2. EUT DESCRIPTION



FCC ID: A3LSMG920V
 Applicant: Samsung Electronics Co., Ltd.
 129, Samsung-ro, Maetan dong,
 Yeongtong-gu, Suwon-si
 Gyeonggi-do 443-742, Korea
 Model(s): SM-G920V
 Serial Number: 073BC
 HW Version: G920V.07
 SW Version: G920V.001
 Antenna: Internal Antenna
 HAC Test Configurations:
 Cell. CDMA, 1013, 384, 777, BT Off, WLAN Off, LTE Off
 PCS CDMA, 25, 600, 1175, BT Off, WLAN Off, LTE Off
 GSM 850, 128, 190, 251, BT Off, WLAN Off, LTE Off
 GSM 1900, 512, 661, 810, BT Off, WLAN Off, LTE Off
 UMTS V, 4132, 4183, 4233, BT Off, WLAN Off, LTE Off
 UMTS II, 9262, 9400, 9538, BT Off, WLAN Off, LTE Off
 EUT Type: Portable Handset

Air-Interface	Band (MHz)	Type Transport	HAC Tested	Simultaneous But Not Tested	Voice over Digital Transport OTT Capability	WIFI Low Power	Additional GSM Power Reduction
GSM	850	VO	Yes	Yes: WiFi or BT	N/A	N/A	No
	1900		No	Yes: WiFi or BT	Yes	N/A	No
	GRPS/EDGE	DT	No	Yes: WiFi or BT	N/A	N/A	N/A
UMTS	850	VD	Yes	Yes: WiFi or BT	N/A	N/A	N/A
	1900		No	Yes: WiFi or BT	Yes	N/A	N/A
	HSPA	DT	No	Yes: WiFi or BT	N/A	N/A	N/A
CDMA	835	VO	Yes	Yes: WiFi or BT	N/A	N/A	N/A
	1900		No	Yes: WiFi or BT	Yes	N/A	N/A
	EVDO	DT	No	Yes: WiFi or BT	N/A	N/A	N/A
LTE	700	VD	No ¹	Yes: WiFi or BT	Yes	N/A	N/A
	850						
	1700						
	1900						
WIFI	2450	VD	No ¹	Yes: CDMA, GSM, UMTS, or LTE	Yes	N/A	N/A
	5200						
	5300						
	5500						
	5800						
BT	2450	DT	No	Yes: CDMA, GSM, UMTS or LTE	N/A	N/A	N/A
Type Transport		Notes: 1. Not tested in accordance with the guidance issued by OET in KDB publication 285076 D02 T-Coil testing for CMRS IP.					
VO = Voice Only							
DT = Digital Data - Not intended for CMRS Service							
VD = CMRS and Data Transport							

Table 2: A3LSMG920V HAC Air Interfaces

FCC ID: A3LSMG920V		HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 4 of 41

3. ANSI C63.19-2011 PERFORMANCE CATEGORIES

I. MAGNETIC COUPLING

Axial and Radial Field Intensity

All orientations of the magnetic field, in the axial, horizontal and vertical position along the measurement plane shall be ≥ -18 dB(A/m) at 1 kHz in a 1/3 octave band filter per §8.3.1.

Frequency Response

The frequency response of the axial component of the magnetic field shall follow the response curve specified in EIA RS-504-1983, over the frequency range 300 Hz – 3000 Hz per §8.3.2.




Figure 3-1
Magnetic field frequency response for Wireless Devices with an axial field
 ≤ -15 dB(A/m) at 1 kHz




Figure 3-2
Magnetic Field frequency response for wireless devices with an axial field that exceeds
 -15 dB(A/m) at 1 kHz

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT	 Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset	Page 5 of 41

Signal Quality

The table below provides the signal quality requirement for the intended audio magnetic signal from a wireless device. Only the RF immunity of the hearing aid is measured in T-coil mode. It is assumed that a hearing aid can have no immunity to an interference signal in the audio band, which is the intended reception band for this mode. The only criterion that can be measured is the RF immunity in T-coil mode. This is measured using the same procedure as the audio coupling mode at the same levels.

The signal quality of the axial and radial components of the magnetic field was used to determine the T-coil mode category.

Category	Telephone RF Parameters
	Wireless Device Signal Quality (Signal + Noise-to-noise ratio in dB)
T1	0 to 10 dB
T2	10 to 20 dB
T3	20 to 30 dB
T4	> 30 dB

Table 3-1
Magnetic Coupling Parameters

FCC ID: A3LSMG920V	 PCTEST This report is valid for 18 months from the date of issue.	HAC (T-COIL) TEST REPORT	 Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset	Page 6 of 41

4. METHOD OF MEASUREMENT

I. Test Setup

The equipment was connected as shown in an acoustic/RF hemi-anechoic chamber:




Figure 4-1
Validation Setup with Helmholtz Coil




Figure 4-2
T-Coil Test Setup

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT	 Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset	Page 7 of 41

II. Scanning Mechanism

Manufacturer:	TEM
Accuracy:	± 0.83 cm/meter
Minimum Step Size:	0.1 mm
Maximum speed	6.1 cm/sec
Line Voltage:	115 VAC
Line Frequency:	60 Hz
Material Composite:	Delrin (Acetal)
Data Control:	Parallel Port
Dynamic Range (X-Y-Z):	45 x 31.75 x 47 cm
Dimensions:	36" x 25" x 38"
Operating Area:	36" x 49" x 55"
Reflections:	< -20 dB (in anechoic chamber)




Figure 4-3
RF Near-Field Scanner

III. 3GPP2 Normal Test Signal (speech)

Manufacturer: 3GPP2 (TIA 1042 §3.3.1)

Stimulus Type: Modified-IRS weighted, multi-talker speech signal, 4 Male and 4 Female speakers (alternating)

Single Sample Duration: 51.62 seconds

Activity Level: 77.4%





Figure 4-4
Temporal Characteristic of Normal Test Signal

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT	 Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset	Page 8 of 41

ABM1 Measurement Block Diagram :



ABM2 Measurement Block Diagram :




Figure 4-5 Magnetic Measurement Processing Steps

IV. Test Procedure

1. Ambient Noise Check per C63.19 §7.3.1
 - a. Ambient interference was monitored using a Real-Time Analyzer between 100-10,000 Hz with 1/3 octave filtering.
 - b. "A-weighting" and Half-Band Integration was applied to the measurements.
 - c. Since this measurement was measured in the same method as ABM2 measurements, this level was verified to be less than 10 dB below the lowest measurement signal (which is the highest ABM2 measurement for a T4 WD). Therefore the maximum noise level for a T4 WD with an ABM1 = -18 dBA/m is:

$$-18 - 30 - 10 = -58 \text{ dBA/m}$$
2. Measurement System Validation (See Figure 4-1)
 - a. The measurement system including the probe, pre-amplifier and acquisition system were validated as an entire system to ensure the reliability of test measurements.
 - b. ABM1 Validation

The magnetic field at the center of the Helmholtz coil is given by the equation (per C63.19 Annex D.9.1):

$$H_c = \frac{NI}{r\sqrt{1.25^3}} = \frac{N\left(\frac{V}{R}\right)}{r\sqrt{1.25^3}}$$

Where H_c = magnetic field strength in amperes per meter
 N = number of turns per coil

For the Helmholtz Coil, $N=20$; $r=0.08\text{m}$; $R=10.193\Omega$ and using $V=57\text{mV}$:

$$H_c = \frac{20 \cdot \left(\frac{0.057}{10.193}\right)}{0.08 \cdot \sqrt{1.25^3}} = 1.0003 \text{ A/m}$$

Therefore a pure tone of 1kHz was applied into the coils such that 57 mV was observed across the 10 Ω resistor. The voltmeter used for measurement was verified to be capable of measurements in the audio band range. This theoretically generates an expected field of 1 A/m in the center of the Helmholtz coil which was used to validate the probe

FCC ID: A3LSMG920V		HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 9 of 41

measurement at 1 A/m. This was verified to be within ± 0.5 dB of the 1 A/m value (see Page 26).

c. Frequency Response Validation

The frequency response through the Helmholtz Coil was verified to be within 0.5 dB relative to 1 kHz, between 300 – 3000 Hz using the Normal speech signal as shown below:




Figure 4-6 Frequency Response Validation

d. ABM2 Measurement Validation

WD noise measurements are filtered with A-weighting and Half-Band Integration over a frequency range of 100Hz – 10kHz to process ABM2 measurements. Below is the verification of the system processing A-weighting and Half-Band integration between system input to output within 0.5 dB of the theoretical result:

Table 4-1
ABM2 Frequency Response Validation

f (Hz)	HBI, A - Measured (dB re 1kHz)	HBI, A - Theoretical (dB re 1kHz)	dB Var.
100	-16.180	-16.170	-0.010
125	-13.257	-13.250	-0.007
160	-10.347	-10.340	-0.007
200	-8.017	-8.010	-0.007
250	-5.925	-5.920	-0.005
315	-4.045	-4.040	-0.005
400	-2.405	-2.400	-0.005
500	-1.212	-1.210	-0.002
630	-0.349	-0.350	0.001
800	0.071	0.070	0.001
1000	0.000	0.000	0.000
1250	-0.503	-0.500	-0.003
1600	-1.513	-1.510	-0.003
2000	-2.778	-2.780	0.002
2500	-4.316	-4.320	0.004
3150	-6.166	-6.170	0.004
4000	-8.322	-8.330	0.008
5000	-10.573	-10.590	0.017
6300	-13.178	-13.200	0.022
8000	-16.241	-16.270	0.029
10000	-19.495	-19.520	0.025

FCC ID: A3LSMG920V	 PCTEST This report is valid until 01/08/2014	HAC (T-COIL) TEST REPORT	 Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset	Page 10 of 41




Figure 4-7
ABM2 Frequency Response Validation

The ABM2 result is a power sum from 100 Hz to 10 kHz with half-band integration and A-weighting. To verify the power sum measurement, a power sum over the full band was measured and verified to track with the source level (See Figure 4-8). Therefore the setup in this step was used to verify the power sum post-processing for ABM2 measurements. See below block diagram:




Figure 4-8
ABM2 Validation Block Diagram

The power summed output results for a known input were compared to the multi-meter results to verify any deviation in the post-processing implemented with the power-sum.

Table 4-2
ABM2 Power Sum Validation

WN Input (dBV)	Power Sum (dBV)	Multimeter-Full (dBV)	Dev (dB)
-60	-60.36	-60.2	0.16
-50	-50.19	-50.13	0.06
-40	-40.14	-40.03	0.11
-30	-30.13	-30.01	0.12
-20	-20.12	-20	0.12
-10	-10.14	-10	0.14

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT	 Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset	Page 11 of 41




Figure 4-9
ABM2 Power Sum Validation

3. Measurement Test Setup

a. Fine scan above the WD (TEM)

- i. A multitone signal was applied to the handset such that the phone acoustic output was stable within 1dB over the probe settling time and with the acoustic output level at the C63.19 specified levels (below). The measurement step size was in 2 mm increments at a distance of 10 mm between the surface of the wireless device as shown below:




Figure 4-10
Measurement Distance

- ii. After scanning, the planar field maximum point was determined. The position of the probe was moved to this location to setup the test using the Sound Check system.
- iii. These steps were repeated for the other T-coil orientations (of axial or radial transverse) per Figure 4-15 after a T-coil orientation was fully measured with the Sound Check system.

b. Speech Signal Setup to Base Station Simulator

- i. C63.19 Table 7-1 states audio reference input levels for various technologies:

Standard	Technology	Input Level (dBm0)
TIA/EIA/IS-2000	CDMA	-18
J-STD-007	GSM (217 Hz)	-16
T1/T1P1/3GPP	UMTS (WCDMA)	-16
iDEN™	TDMA (22 and 11 Hz)	-18

FCC ID: A3LSMG920V		HAC (T-COIL) TEST REPORT			Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset			Page 12 of 41

The CMU200 audio levels were determined using base station simulator manufacturer calibration procedures resulting in the below corresponding voltages relative to handset test point level (in dBm0):

Table 4-3
CMU200 Voltage Input Levels for Audio

dBm0 Ref.		Voltage		Notes
3.14 dBm0	990.5 mV	-0.08 dBV	From GSM "DECODER CAL". (What is needed through Encoder for FS)	
-16 dBm0	109.4 mV	-19.2 dBV	For Speechcod/Handset Low	
dBm0 Ref.		Voltage		Notes
3.14 dBm0	1068.5 mV	0.58 dBV	From UMTS "DECODER CAL". (What is needed through Encoder for FS)	
-16 dBm0	118.0 mV	-18.6 dBV	For Handset Low	
dBm0 Ref.		Input Voltage		Notes
3.14 dBm0	1052.0 mV	0.4 dBV	From CDMA2K "DECODER CAL". (What is needed through Encoder for FS)	
-18 dBm0	92.260 mV	-20.7 dBV	For 8k Enhanced (Low)	

- c. Real-Time Analyzer (RTA)
 - i. The Real-Time Analyzer was configured to analyze measurements using 1/3 Octave band weighted filtering.
- d. WD Radio Configuration Selection
 - A. The device was chosen to be tested in the worst-case ABM2 condition under EFR (GSM); AMR 12.2 kbps (UMTS); RC1/SO68 (CDMA - EVRC) (see below for GSM, see Section 5 for more information regarding worst-case configurations for CDMA and UMTS.):




Figure 4-11
Vocoder Analysis for ABM Noise for GSM

4. Signal Quality Data Analysis

- a. Narrow-band Magnetic Intensity
 - i. The standard specifies a 1 kHz 1/3 octave band minimum field intensity for a sine tone. The ABM1 measurements were evaluated at 1 kHz with 1/3 octave band filtering over an averaged period of 10 seconds.
- b. Frequency Response
 - i. The appropriate frequency response curve was measured to curves in Figure 3-1 or Figure 3-2 between 300 – 3000 Hz using digital linear averaging (limit lines chosen according to measurement found in step 4a.) A linear average over 3x

the length of the speech signal (3x sampling) was performed. A 10 second delay was configured in the measurement process of the stimulus to ensure handset vocoder latency effects and echo cancellation devices (if any) were appropriately stabilized during measurements.

- ii. The appropriate post-processing was applied according to the system processing chain illustrated in Figure 4-12. All R10 frequencies were plotted with respect to 0dB at 1 kHz value and aligned with respect to the EIA-504 mask.




Figure 4-12 Frequency Response Block Diagram

- iii. The margin is represented by the closest measured data point on the curve to the EIA-504 limit lines, in dB.
- c. Signal Quality Index
 - i. Ensuring the WD was at maximum RF power, maximum volume, backlight on, display on, maximum contrast setting, keypad lights on (when possible) with no audio signal through the vocoder, the WD was measured over at least 100 Hz – 10,000 Hz, maximized over 5 seconds with a 50ms sample time for the ABM2 measurement (5 second time period is used in noise measurements under standards such as IEEE 269, etc.)
 - ii. After applying half-band integration and A-weighting to the result, a power sum was applied over each 1/3 octave bandwidth frequency to obtain an ABM2 value.
 - iii. This result was subtracted from the ABM1 result in step a, to obtain the Signal Quality.

V. Test Setup




Figure 4-13
Audio Magnetic Field Test Setup

VI. Deviation from C63.19 Test Procedure

None.

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT	 SAMSUNG	Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 14 of 41

VII. Air Interface Technologies Tested

According to the April 2013 TCB workshop slides, OTT data services are outside the current definition of a managed CMRS service and are currently not required to be evaluated.

VoLTE and VoIP over WIFI CMRS air interfaces were not tested in accordance with the guidance issued by OET in KDB publication 285076 D02 T-Coil testing for CMRS IP.

VIII. Wireless Device Channels and Frequencies

The frequencies listed in the table below are those that lie in the center of the bands used for cellular telephony. Low, middle and high channels were tested in each band for compliance evaluation to ensure the maximum emission is captured across the entire band.

To facilitate setting of a base station simulator for ABM measurements, specific band plan channel numbers are listed that may be used in lieu of the band center frequencies.

Table 4-4
Center Channels and Frequencies

Test frequencies & associated channels	
Channel	Frequency (MHz)
Cellular 850	
384 (CDMA)	836.52
190 (GSM)	836.60
4183 (UMTS)	836.60
PCS 1900	
600 (CDMA)	1880
661 (GSM)	1880
9400 (UMTS)	1880

IX. RF Emission Effect on T-coil Measurements




Figure 4-14

High power RF Emissions Effect with HAC Dipole on the T-coil Probe System 10mm between dipole maximum and magnetic probe

FCC ID: A3LSMG920V	 PCTEST This report is valid for 18 months from the date of issue.	HAC (T-COIL) TEST REPORT	 SAMSUNG	Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 15 of 41

X. Test Flow

The flow diagram below was followed (From C63.19):




Figure 4-15
C63.19 T-Coil Signal Test Process

FCC ID: A3LSMG920V		HAC (T-COIL) TEST REPORT			Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset			Page 16 of 41

5. FCC 3G MEASUREMENTS

I. CDMA Test Configurations

Radio Configuration 1, Service Option 68 was used for the testing according to the CTIA Test Plan and also as one of the worst-case configuration for the handset due to vocoder gating from the EVRC logic. See below plot for an example of ABM noise comparison between operational field service options and radio configurations for a CDMA2000 handset:




Figure 5-1
CDMA Audio Band Magnetic Noise

II. UMTS Test Configurations

AMR at 12.2kbps, 13.6kbps SRB was used for the testing as the worst-case configuration for the handset. See below plot for ABM noise comparison between vocoder rates:




Figure 5-2
UMTS Audio Band Magnetic Noise

FCC ID: A3LSMG920V		HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 17 of 41

III. ABM Measurements

Table 5-1
FCC 3G ABM Measurements for A3LSMG920V (CDMA)

Codec Setting:	RC1/SO68	RC3/SO68	RC4/SO68	Orientation	Channel
ABM1 Pre-test (dBA/m)	2.030	2.010	2.010	Radial	25
ABM2 Pre-test (dBA/m) (A-weight, Half-Band Int.)	-36.29	-47.17	-46.07		
S+N/N (dB)	38.32	49.18	48.08		

- Mute on; Backlight on; Max Volume, Max Contrast
- Power Control Bits = "All Up"

Table 5-2
FCC 3G ABM Measurements for A3LSMG920V (UMTS)

Codec Setting:	AMR 12.2kbps	AMR 7.95kbp	AMR 4.75kbp	Orientation	Channel
ABM1 Pre-test (dBA/m)	2.150	2.360	2.200	Radial	9538
ABM2 Pre-test (dBA/m) (A-weight, Half-Band Int.)	-48.06	-48.04	-49.09		
S+N/N (dB)	50.21	50.40	51.29		

- Mute on; Backlight on; Max Volume, Max Contrast
- TPC="All 1s"



Figure 5-3
Audio Band Magnetic Curve Measurement Block Diagram

FCC ID: A3LSMG920V		HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 18 of 41

6. TEST SUMMARY

I. T-Coil Test Summary

Table 6-1
Table of Results for CDMA

C63.19 Sec.	Mode	Band	Test Description	Minimum Limit*	Measured	Verdict
				dBA/m	dBA/m	PASS/FAIL
8.3.1	CDMA	Cellular	Intensity, Axial	-18	9.4	PASS
8.3.1			Intensity, Radial	-18	2.0	PASS
8.3.4			Signal-to-Noise/Noise, Axial	20	40.3	PASS
8.3.4			Signal-to-Noise/Noise, Radial	20	39.9	PASS
8.3.2			Frequency Response, Axial	0	1.0	PASS
8.3.1	CDMA	PCS	Intensity, Axial	-18	9.0	PASS
8.3.1			Intensity, Radial	-18	1.9	PASS
8.3.4			Signal-to-Noise/Noise, Axial	20	40.1	PASS
8.3.4			Signal-to-Noise/Noise, Radial	20	38.6	PASS
8.3.2			Frequency Response, Axial	0	1.0	PASS

Note: The above summary table represents the worst-case numerical values according to configurations in Table 6-5.

Table 6-2
Table of Results for GSM

C63.19 Sec.	Mode	Band	Test Description	Minimum Limit*	Measured	Verdict
				dBA/m	dBA/m	PASS/FAIL
8.3.1	GSM	Cellular	Intensity, Axial	-18	9.5	PASS
8.3.1			Intensity, Radial	-18	2.3	PASS
8.3.4			Signal-to-Noise/Noise, Axial	20	24.8	PASS
8.3.4			Signal-to-Noise/Noise, Radial	20	23.0	PASS
8.3.2			Frequency Response, Axial	0	1.4	PASS
8.3.1	GSM	PCS	Intensity, Axial	-18	9.5	PASS
8.3.1			Intensity, Radial	-18	2.3	PASS
8.3.4			Signal-to-Noise/Noise, Axial	20	27.7	PASS
8.3.4			Signal-to-Noise/Noise, Radial	20	25.5	PASS
8.3.2			Frequency Response, Axial	0	1.3	PASS

Note: The above summary table represents the worst-case numerical values according to configurations in Table 6-6.

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 19 of 41

Table 6-3
Table of Results for UMTS

C63.19 Sec.	Mode	Band	Test Description	Minimum Limit*	Measured	Verdict
				dBA/m	dBA/m	PASS/FAIL
8.3.1	UMTS	Cellular	Intensity, Axial	-18	9.8	PASS
8.3.1			Intensity, Radial	-18	2.1	PASS
8.3.4			Signal-to-Noise/Noise, Axial	20	55.0	PASS
8.3.4			Signal-to-Noise/Noise, Radial	20	52.3	PASS
8.3.2			Frequency Response, Axial	0	1.3	PASS
8.3.1	UMTS	PCS	Intensity, Axial	-18	9.7	PASS
8.3.1			Intensity, Radial	-18	2.1	PASS
8.3.4			Signal-to-Noise/Noise, Axial	20	52.9	PASS
8.3.4			Signal-to-Noise/Noise, Radial	20	50.6	PASS
8.3.2			Frequency Response, Axial	0	1.4	PASS

Note: The above summary table represents the worst-case numerical values according to configurations in Table 6-7.

Table 6-4
Consolidated Tabled Results

	Volume Setting	Cellular		PCS	
		Axial	Radial	Axial	Radial
Freq. Response Margin	Maximum	PASS	N/A	PASS	N/A
Magnetic Intensity Verdict		PASS	PASS	PASS	PASS
FCC SNR Verdict		PASS	PASS	PASS	PASS

Note: Result shown is for T-coil category only.

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 20 of 41

II. Raw Handset Data

Table 6-5
Raw Data Results for CDMA

Volume	Cellular Band							
	Axial			Radial				
	1013	384	777	1013	384	777		
Maximum	ABM1, dBA/m	9.35	9.54	9.42	1.95	2.11		
	ABM2, dBA/m	-32.80	-32.60	-30.86	-38.68	-39.17		
	Ambient Noise, dBA/m	-61.97	-61.97	-61.97	-63.23	-63.23		
	Freq. Response Margin (dB)	0.98	1.00	1.05	N/A	N/A		
	S+N/N (dB)	42.15	42.14	40.28	40.63	41.28		
	S+N/N per orientation (dB)	40.28			39.94			
	C63.19-2011 Rating per orientation	T4			T4			
Volume	PCS Band							
	Axial			Radial				
	25	600	1175	25	600	1175		
Maximum	ABM1, dBA/m	9.02	8.98	9.00	2.00	2.09		
	ABM2, dBA/m	-31.03	-31.75	-31.97	-36.62	-39.19		
	Ambient Noise, dBA/m	-61.97	-61.97	-61.97	-63.23	-63.23		
	Freq. Response Margin (dB)	1.01	1.00	1.07	N/A	N/A		
	S+N/N (dB)	40.05	40.73	40.97	38.62	41.28		
	S+N/N per orientation (dB)	40.05			38.62			
	C63.19-2011 Rating per orientation	T4			T4			
T-coil Coordinates (cm)	[x,y] from bottom left	2.6, 2.6			2.6, 2.0			

Notes:

1. Power Configuration: CDMA: Power Control Bits = "All Up"
2. Phone Condition: Mute on; Backlight on; Max Volume, Max Contrast
3. Vocoder Configuration: RC1/SO68 (CDMA - EVRC)
4. 'Radial' orientation refers to radial transverse.
5. Speech Signal: 3GPP2 Normal Test Signal.

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 21 of 41

Table 6-6
Raw Data Results for GSM

	Volume	Cellular Band							
		Axial			Radial				
		128	190	251	128	190	251		
ABM1, dBA/m	Maximum	9.52	9.51	9.53	2.26	2.28	2.28		
ABM2, dBA/m		-15.44	-15.30	-15.99	-20.85	-20.75	-21.32		
Ambient Noise, dBA/m		-61.97	-61.97	-61.97	-63.23	-63.23	-63.23		
Freq. Response Margin (dB)		1.39	1.43	1.38	N/A	N/A	N/A		
S+N/N (dB)		24.96	24.81	25.52	23.11	23.03	23.60		
S+N/N per orientation (dB)		24.81			23.03				
C63.19-2011 Rating per orientation		T3			T3				
T-coil Coordinates (cm)		[x,y] from bottom left	2.6, 2.6			2.6, 2.0			
	Volume	PCS Band							
		Axial			Radial				
		512	661	810	512	661	810		
ABM1, dBA/m	Maximum	9.54	9.53	9.52	2.28	2.26	2.27		
ABM2, dBA/m		-18.43	-18.26	-18.16	-23.42	-23.24	-23.25		
Ambient Noise, dBA/m		-61.97	-61.97	-61.97	-63.23	-63.23	-63.23		
Freq. Response Margin (dB)		1.33	1.32	1.36	N/A	N/A	N/A		
S+N/N (dB)		27.97	27.79	27.68	25.70	25.50	25.52		
S+N/N per orientation (dB)		27.68			25.50				
C63.19-2011 Rating per orientation		T3			T3				

Notes:

1. Power Configuration: GSM850: PCL=5, GSM1900: PCL=0;
2. Phone Condition: Mute on; Backlight on; Max Volume, Max Contrast
3. Vocoder Configuration: EFR (GSM);
4. 'Radial' orientation refers to radial transverse.
5. Speech Signal: 3GPP2 Normal Test Signal.

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 22 of 41

Table 6-7
Raw Data Results for UMTS

	Volume	Cellular Band						
		Axial			Radial			
		4132	4183	4233	4132	4183	4233	
ABM1, dBA/m	Maximum	9.75	9.77	9.80	2.18	2.19	2.13	
ABM2, dBA/m		-45.21	-45.85	-45.50	-50.57	-50.55	-50.17	
Ambient Noise, dBA/m		-61.97	-61.97	-61.97	-63.23	-63.23	-63.23	
Freq. Response Margin (dB)		1.36	1.33	1.45	N/A	N/A	N/A	
S+N/N (dB)		54.96	55.62	55.30	52.75	52.74	52.30	
S+N/N per orientation (dB)		54.96			52.30			
C63.19-2011 Rating per orientation		T4		T4				
		PCS Band						
	Volume	Axial			Radial			
		9262	9400	9538	9262	9400	9538	
		9.77	9.74	9.77	2.16	2.08	2.08	
ABM1, dBA/m	Maximum	-44.16	-43.89	-43.15	-49.75	-48.92	-48.48	
ABM2, dBA/m		-61.97	-61.97	-61.97	-63.23	-63.23	-63.23	
Ambient Noise, dBA/m		1.43	1.41	1.42	N/A	N/A	N/A	
Freq. Response Margin (dB)		53.93	53.63	52.92	51.91	51.00	50.56	
S+N/N (dB)		52.92			50.56			
S+N/N per orientation (dB)		T4		T4				
C63.19-2011 Rating per orientation								
T-coil Coordinates (cm)	[x,y] from bottom left	2.6, 2.6			2.6, 2.0			

Notes:

1. Power Configuration: UMTS: TPC="All 1s";
2. Phone Condition: Mute on; Backlight on; Max Volume, Max Contrast
3. Vocoder Configuration: AMR 12.2 kbps (UMTS);
4. 'Radial' orientation refers to radial transverse.
5. Speech Signal: 3GPP2 Normal Test Signal.

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 23 of 41

III. Frequency Response Graph





Figure 6-1


Axial Frequency Response

Note: User T-coil Mode (**Settings→Accessibility→Hearing→Hearing aids**) was set to ON for Frequency Response compliance. This frequency response represents the worst-case ABM2 test configuration according to Tables 6-5, 6-6, and 6-7.

IV. 1 kHz Vocoder Application Check



This model was verified to be within the linear region for ABM1 measurements at -18 dBm0 for CDMA. This measurement was taken in the axial configuration above the maximum location.



This model was verified to be within the linear region for ABM1 measurements at -16 dBm0 for GSM and UMTS. This measurement was taken in the axial configuration above the maximum location.

FCC ID: A3LSMG920V	 PCTEST This report is valid until 01/08/2014	HAC (T-COIL) TEST REPORT	 Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset	Page 24 of 41

V. Undesirable Audio Magnetic Band Plots (ABM2)




Figure 6-2
Worst-case ABM2 Plot for CDMA

Note: This plot represents the data from the location/configuration resulting in the highest ABM2 result shown in Table 6-5.




Figure 6-3
Worst-case ABM2 Plot for GSM

Note: This plot represents the data from the location/configuration resulting in the highest ABM2 result shown in Table 6-6.




Figure 6-4
Worst-case ABM2 Plot for UMTS

Note: This plot represents the data from the location/configuration resulting in the highest ABM2 result shown in Table 6-7.

FCC ID: A3LSMG920V	 PCTEST This report is valid for 18 months from the date of issue.	HAC (T-COIL) TEST REPORT	 Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset	Page 25 of 41

VI. T-Coil Validation Test Results




Figure 6-5
Helmholtz Coil Validation for Frequency Response

Table 6-8
Helmholtz Coil Validation Table of Results

Item	Target	Result	Verdict
Signal Validation			
Frequency Response, from limits	> 0 dB	0.72	PASS
Magnetic Intensity, -10 dBA/m	-10 ± 0.5 dB	-9.647	PASS
Noise Validation			
Axial Environmental Noise	< - 58 dBA/m	-61.97	PASS
Radial Environmental Noise	< - 58 dBA/m	-63.23	PASS

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT	 Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset	Page 26 of 41

7. MEASUREMENT UNCERTAINTY

Table 7-1
Uncertainty Estimation Table

Contribution	Data +/- %	Data +/- dB	Data Type	Probability distribution	Divisor	Standard uncertainty	Standard Uncertainty (dB)
ABM Noise	7.0%	0.29	Std. Dev.	Normal k=1	1.00	7.0%	
RF Reflections	4.7%	0.20	Specification	Rectangular	1.73	2.7%	
Reference Signal Level	12.2%	0.50	Specification	Rectangular	1.73	7.0%	
Positioning Accuracy	10.0%	0.41	Uncertainty	Rectangular	1.73	5.8%	
Probe Coil Sensitivity	12.2%	0.50	Specification	Rectangular	1.73	7.0%	
Probe Linearity	2.4%	0.10	Std. Dev.	Normal k=1	1.00	2.4%	
Cable Loss	2.8%	0.12	Specification	Rectangular	1.73	1.6%	
Frequency Analyzer	5.0%	0.21	Specification	Rectangular	1.73	2.9%	
System Repeatability	5.0%	0.21	Std. Dev.	Normal k=1	1.00	5.0%	
WD Repeatability	9.0%	0.37	Std. Dev.	Normal k=1	1.00	9.0%	
Positioner Accuracy	1.0%	0.04	Specification	Rectangular	1.73	0.6%	
Combined standard uncertainty, $uc (k=1)$						17.7%	0.71
Expanded uncertainty (k=2), 95% confidence level						35.3%	1.31

Notes:

1. Test equipments are calibrated according to techniques outlined in NIS81, NIS3003 and NIST Tech Note 1297.
2. All equipments have traceability according to NIST. Measurement Uncertainties are defined in further detail in NIS 81 and NIST Tech Note 1297 and UKAS M3003.

Measurement uncertainty reflects the quality and accuracy of a measured result as compared to the true value. Such statements are generally required when stating results of measurements so that it is clear to the intended audience that the results may differ when reproduced by different facilities. Measurement results vary due to the measurement uncertainty of the instrumentation, measurement technique, and test engineer. Most uncertainties are calculated using the tolerances of the instrumentation used in the measurement, the measurement setup variability, and the technique used in performing the test. While not generally included, the variability of the equipment under test also figures into the overall measurement uncertainty. Another component of the overall uncertainty is based on the variability of repeated measurements (so-called Type A uncertainty). This may mean that the Hearing Aid compatibility tests may have to be repeated by taking down the test setup and resetting it up so that there are a statistically significant number of repeat measurements to identify the measurement uncertainty. By combining the repeat measurement results with that of the instrumentation chain using the technique contained in NIS 81 and NIS 3003, the overall measurement uncertainty was estimated.

FCC ID: A3LSMG920V	 PCTEST This report is valid for 12 months from the date of issue.	HAC (T-COIL) TEST REPORT	 Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset	Page 27 of 41

8. EQUIPMENT LIST

Table 8-1
Equipment List

Manufacturer	Model	Description	Cal Date	Cal Interval	Cal Due	Serial Number
Control Company	36934-158	Wall-Mounted Thermometer	4/29/2014	Biennial	4/29/2016	122014488
Listen	SoundConnect	Microphone Power Supply	3/14/2014	Annual	3/14/2015	PS2612
Listen	SoundCheck	Acoustic Analyzer System	10/17/2014	Annual	10/17/2015	01-20-03368
NI	4474	Data Acquisition Card	N/A		N/A	N/A
Rohde & Schwarz	CMU200	Base Station Simulator	4/24/2014	Annual	4/24/2015	836371/0079
Seekonk	NC-100	Torque Wrench (8" lb)	3/18/2014	Triennial	3/18/2016	N/A
TEM	Axial T-Coil Probe	Axial T-Coil Probe	9/16/2014	Annual	9/16/2015	TEM-1124
TEM	Radial T-Coil Probe	Radial T-Coil Probe	9/16/2014	Annual	9/16/2015	TEM-1130
TEM	Helmholtz Coil	Helmholtz Coil	4/8/2014	Annual	4/8/2015	925
TEM		HAC System Controller with Software	N/A		N/A	N/A
TEM		HAC Positioner	N/A		N/A	N/A

FCC ID: A3LSMG920V	 PCTEST [®] This device has been tested and found to comply with the limits for a Class B device.	HAC (T-COIL) TEST REPORT	 SAMSUNG	Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 28 of 41

9. CALIBRATION CERTIFICATES

FCC ID: A3LSMG920V	 PCTEST This report is valid for 1 year from the date of issue.	HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 29 of 41

West Caldwell Calibration Laboratories Inc.

Certificate of Calibration

for

AXIAL T COIL PROBE

Manufactured by: TEM CONSULTING
Model No: AXIAL T COIL PROBE
Serial No: TEM-1124
Calibration Recall No: 24538

Submitted By:

Customer: JUSTIN CHAO
Company: PCTEST ENGINEERING LAB
Address: 6660-B DOBBIN ROAD
COLUMBIA MD 21045

The subject instrument was calibrated to the indicated specification using standards traceable to the National Institute of Standards and Technology or to accepted values of natural physical constants. This document certifies that the instrument met the following specification upon its return to the submitter.

West Caldwell Calibration Laboratories Procedure No. AXIAL T C TEM

Upon receipt for Calibration, the instrument was found to be:

Within (X) see attached Report of Calibration.

the tolerance of the indicated specification.

RLH
9/19/2014

West Caldwell Calibration Laboratories' calibration control system meets the requirements, ISO 10012-1 MIL-STD-45662A, ANSI/NCSL Z540-1, IEC Guide 25, ISO 9001:2008 and ISO 17025.

Note: With this Certificate, Report of Calibration is included.

Approved by:

Calibration Date: 16-Sep-14

FC

Certificate No: 24538 - 1

Felix Christopher (QA Mgr.)

QA Doc. #1051 Rev. 2.0 10/1/01

ISO/IEC 17025:2005

Certificate Page 1 of 1

West Caldwell
Calibration
Laboratories, Inc.
uncompromised calibration
1575 State Route 96, Victor, NY 14564, U.S.A.



Calibration Lab. Cert. # 1533.01

FCC ID: A3LSMG920V		HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 30 of 41



1575 State Route 96, Victor NY 14564

ISO/IEC 17025: 2005



Calibration Lab. Cert. # 1533.01

REPORT OF CALIBRATION

for
TEM Consulting LP Axial T Coil Probe

Model No.: Axial T Coil Probe


Serial No.: TEM-1124

Company : PCTEST Engineering Lab.

I. D. No: 80578

Calibration results:			Before data:	After data:
Probe Sensitivity measured with Helmholtz Coil				
<i>Helmholtz Coil;</i>				Before & after data same: ...X.....
the number of turns on each coil;	10	No.		
the radius of each coil, in meters;	0.204	m		
the current in the coils, in amperes;	0.09	A		Laboratory Environment:
<i>Helmholtz Coil Constant;</i>	7.09	A/m/V		Ambient Temperature: 22.2 °C
<i>Helmholtz Coil magnetic field;</i>	5.97	A/m		Ambient Humidity: 45.9 % RH
Probe Sensitivity at	1000	Hz.		Ambient Pressure: 99.5 kPa
was	-60.22	dBV/A/m		Calibration Date: 16-Sep-14
	0.975	mV/A/m		Re-calibration Due: 16-Sep-15
Probe resistance	901	Ohms		Report Number: 24538 -1
				Control Number: 24538
The above listed instrument meets or exceeds the tested manufacturer's specifications.				
This Calibration is traceable through NIST test numbers: 287708				
The expanded uncertainty of calibration: 0.30dB at 95% confidence level with a coverage factor of k=2.				

Graph represents Probes Frequency Response.



The above listed instrument was checked using calibration procedure documented in West Caldwell Calibration Laboratories Inc. procedure : **Rev. 7.0 Jan. 24, 2014 Doc. # 1038 HCATEMC**

Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NCSL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Cal. Date: 16-Sep-2014
Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Measurements performed by:
Felix Christopher

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 HCATEMC

Page 1 of 2

FCC ID: A3LSMG920V		HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 31 of 41

West Caldwell Calibration Laboratories Inc.

1575 State Route 96, Victor NY 14564

Tel. (585) 586-3900 FAX (585) 586-4327

Calibration Data Record

for
TEM Consulting LP Axial T Coil Probe

Model No.: Axial T Coil Probe

Serial No.: TEM-1124

Company : PCTEST Engineering Lab.

Test	Function	Tolerance	Measured values		
			Before	Out	Remarks
1.0	Probe Sensitivity at	1000 Hz. dB/V/A/m	-60.22		
2.0	Probe Level Linearity	dB Ref. (0 dB)	6 0 -6 -12	6.00 0.00 -6.00 -12.10	
3.0	Probe Frequency Response	Hz Ref. (0 dB)	100 126 158 200 251 316 398 501 631 794 1000 1259 1585 1995 2512 3162 3981 5012 6310 7943 10000	-20.0 -18.0 -16.0 -14.0 -12.0 -10.0 -8.0 -6.0 -4.1 -2.0 0.0 1.9 3.9 5.9 7.9 9.9 11.9 13.9 15.9 18.0 20.2	

Instruments used for calibration:				Date of Cal.	Traceability No.	Due Date
HP	34401A	S/N 36064102		8-Oct-2013	,287708	8-Oct-2014
HP	34401A	S/N 36102471		8-Oct-2013	,287708	8-Oct-2014
HP	33120A	S/N 36043716		8-Oct-2013	,287708	8-Oct-2014
B&K	2133	S/N 1583254		6-Jan-2014	683/284413-14	7-Jan-2015

Cal. Date: 16-Sep-2014

Tested by: Felix Christopher

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 HCATEMC

Page 2 of 2

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 32 of 41

West Caldwell Calibration Laboratories Inc.

Certificate of Calibration

for

RADIAL T COIL PROBE

Manufactured by: TEM CONSULTING
Model No: RADIAL T COIL PROBE
Serial No: TEM-1130
Calibration Recall No: 24538

Submitted By:

Customer: JUSTIN CHAO
Company: PCTEST ENGINEERING LAB
Address: 6660-B DOBBIN ROAD
COLUMBIA MD 21045

The subject instrument was calibrated to the indicated specification using standards traceable to the National Institute of Standards and Technology or to accepted values of natural physical constants. This document certifies that the instrument met the following specification upon its return to the submitter.

West Caldwell Calibration Laboratories Procedure No. RADIAL T TEM

Upon receipt for Calibration, the instrument was found to be:

Within (X) see attached Report of Calibration.

the tolerance of the indicated specification.

9/19/2014

West Caldwell Calibration Laboratories' calibration control system meets the requirements, ISO 10012-1 MIL-STD-45662A, ANSI/NCSL Z540-1, IEC Guide 25, ISO 9001:2008 and ISO 17025.

Note: With this Certificate, Report of Calibration is included.

Approved by:

Calibration Date: 16-Sep-14

Certificate No: 24538 - 2

Felix Christopher (QA Mgr.)
ISO/IEC 17025:2005

QA Doc. #1051 Rev. 2.0 10/1/01

Certificate Page 1 of 1

West Caldwell
Calibration
Laboratories, Inc.
uncompromised calibration
1575 State Route 96, Victor, NY 14564, U.S.A.



Calibration Lab. Cert. # 1533.01

FCC ID: A3LSMG920V		HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 33 of 41



1575 State Route 96, Victor NY 14564

ISO/IEC 17025: 2005



Calibration Lab. Cert. # 1533.01

REPORT OF CALIBRATION

TEM Consulting LP Radial T Coil Probe

for
Model No.: Radial T Coil Probe

Serial No.: TEM-1130

Company : PCTEST Engineering Lab.

I. D. No: 80579


Calibration results:	Before data:	After data:
Probe Sensitivity measured with Helmholtz Coil		
<i>Helmholtz Coil:</i>		Before & after data same: ...X.....
the number of turns on each coil; 10	No. 0.204	Laboratory Environment:
the radius of each coil, in meters; 0.09	m A	Ambient Temperature: 22.2 °C
the current in the coils, in amperes; 7.09	A/m/V	Ambient Humidity: 45.9 % RH
<i>Helmholtz Coil Constant;</i> 5.97	A/m	Ambient Pressure: 99.5 kPa
<i>Helmholtz Coil magnetic field;</i> 907	Ohms	Calibration Date: 16-Sep-14
Probe Sensitivity at 1000	Hz.	Re-calibration Due: 16-Sep-15
was -60.58	dBV/A/m	Report Number: 24538 -2
0.936	mV/A/m	Control Number: 24538
Probe resistance		

The above listed instrument meets or exceeds the tested manufacturer's specifications.

This Calibration is traceable through NIST test numbers: 287708

The expanded uncertainty of calibration: 0.30dB at 95% confidence level with a coverage factor of k=2.

Graph represents Probes Frequency Response.



The above listed instrument was checked using calibration procedure documented in West Caldwell

Calibration Laboratories Inc. procedure : Rev. 7.0 Jan. 24, 2014 Doc. # 1038 HCRTEMC

Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures

intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NCSL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Cal. Date: 16-Sep-2014
Calibrated on WCCL system type 9700

Measurements performed by:
Felix Christopher

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 HCRTEMC

Page 1 of 2

FCC ID: A3LSMG920V		HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 34 of 41

West Caldwell Calibration Laboratories Inc.

1575 State Route 96, Victor NY 14564
 Tel. (585) 586-3900 FAX (585) 586-4327

Calibration Data Record

TEM Consulting LP Radial T Coil Probe

for
Model No.: Radial T Coil Probe

Serial No.: TEM-1130

Company : PCTEST Engineering Lab.

Test	Function	Tolerance	Measured values		
			Before	Out	Remarks
1.0	Probe Sensitivity at	1000 Hz. dBV/A/m	-60.58		
2.0	Probe Level Linearity	dB Ref. (0 dB)	6 0 -6 -12	6.03 0.00 -6.03 -12.05	
3.0	Probe Frequency Response	Hz Ref. (0 dB)	100 126 158 200 251 316 398 501 631 794 1000 1259 1585 1995 2512 3162 3981 5012 6310 7943 10000	-19.8 -18.0 -16.0 -13.9 -12.0 -10.0 -8.0 -6.0 -4.0 -2.0 0.0 2.0 4.0 6.0 7.9 9.9 11.9 13.9 16.0 18.0 20.2	

Instruments used for calibration:			Date of Cal.	Traceability No.	Due Date
HP	34401A	S/N 36064102	8-Oct-2013	,287708	8-Oct-2014
HP	34401A	S/N 36102471	8-Oct-2013	,287708	8-Oct-2014
HP	33120A	S/N 36043716	8-Oct-2013	,287708	8-Oct-2014
B&K	2133	S/N 1583254	6-Jan-2014	683/284413-14	7-Jan-2015

Cal. Date: 16-Sep-2014

Tested by: Felix Christopher

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 HCRTEMC

Page 2 of 2

FCC ID: A3LSMG920V	 PCTEST	HAC (T-COIL) TEST REPORT	 SAMSUNG	Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 35 of 41

10. CONCLUSION

The measurements taken in accordance with the procedures provided in the CTIA Test Plan for Hearing Aid Compatibility Rev 2.0, April 2010, indicate that the wireless communications device complies with the HAC limits specified in the ANSI C63.19 Standard and FCC WT Docket No. 01-309 RM-8658. Precise laboratory measures were taken to assure repeatability of the tests. The tested device complies with the requirements in respect to all parameters specific to the test. The test results and statements relate only to the item(s) tested.

The measurement system and techniques presented in this evaluation are proposed in the ANSI standard as a means of best approximating wireless device compatibility with a hearing-aid. The literature is under continual re-construction.

FCC ID: A3LSMG920V	 PCTEST This report is valid for 12 months from the date of issue.	HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 36 of 41

11. REFERENCES

1. ANSI C63.19-2007, American National Standard for Methods of Measurement of Compatibility between Wireless communication devices and Hearing Aids.", New York, NY, IEEE, June 2007
2. FCC Office of Engineering and Technology KDB, "285076 D01 HAC Guidance v04," October 31, 2013
3. FCC Office of Engineering and Technology KDB, "285076 D02 T-Coil Testing for CMRS IP v01r01," October 31, 2013
4. FCC Public Notice DA 06-1215, *Wireless Telecommunications Bureau and Office of Engineering and Technology Clarify Use of Revised Wireless Phone Hearing Aid Compatibility Standard*, June 6, 2006
5. FCC 3G Review Guidance, Laboratory Division OET FCC, May/June 2006
6. Berger, H. S., "Compatibility Between Hearing Aids and Wireless Devices," Electronic Industries Forum, Boston, MA, May, 1997
7. Berger, H. S., "Hearing Aid and Cellular Phone Compatibility: Working Toward Solutions," *Wireless Telephones and Hearing Aids: New Challenges for Audiology*, Gallaudet University, Washington, D.C., May, 1997 (To be reprinted in the American Journal of Audiology).
8. Berger, H. S., "Hearing Aid Compatibility with Wireless Communications Devices," *IEEE International Symposium on Electromagnetic Compatibility*, Austin, TX, August, 1997.
9. Bronaugh, E. L., "Simplifying EMI Immunity (Susceptibility) Tests in TEM Cells," in the 1990 IEEE International Symposium on Electromagnetic Compatibility Symposium Record, Washington, D.C., August 1990, pp. 488-491
10. Byme, D. and Dillon, H., The National Acoustics Laboratory (NAL) New Procedure for Selecting the Gain and Frequency Response of a Hearing Aid, *Ear and Hearing* 7:257-265, 1986.
11. Crawford, M. L., "Measurement of Electromagnetic Radiation from Electronic Equipment using TEM Transmission Cells," *U.S. Department of Commerce, National Bureau of Standards, NBSIR 73-306*, Feb. 1973.
12. Crawford, M. L., and Workman, J. L., "Using a TEM Cell for EMC Measurements of Electronic Equipment," *U.S. Department of Commerce, National Bureau of Standards. Technical Note 1013*, July 1981.
13. EHIMA GSM Project, Development phase, Project Report (1st part) Revision A. Technical-Audiological Laboratory and Telecom Denmark, October 1993.
14. EHIMA GSM Project, Development phase, Part II Project Report. Technical-Audiological Laboratory and Telecom Denmark, June 1994.
15. EHIMA GSM Project Final Report, Hearing Aids and GSM Mobile Telephones: Interference Problems, Methods of Measurement and Levels of Immunity. Technical-Audiological Laboratory and Telecom Denmark, 1995.

FCC ID: A3LSMG920V	 PCTEST This report is valid until 01/28/2015.	HAC (T-COIL) TEST REPORT			Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset			Page 37 of 41

16. HAMPIS Report, Comparison of Mobile phone electromagnetic near field with an upscaled electromagnetic far field, using hearing aid as reference, 21 October 1999.
17. Hearing Aids/GSM, Report from OTWIDAM, Technical-Audiological Laboratory and Telecom Denmark, April 1993.
18. IEEE 100, The Authoritative Dictionary of IEEE Standards Terms, Seventh Edition.
19. Joyner, K. H. et. al., Interference to Hearing Aids by the New Digital Mobile Telephone System, Global System for Mobile (GSM) Communication Standard, National Acoustic Laboratory, Australian Hearing Series, Sydney 1993.
20. Joyner, K. H., et. al., Interference to Hearing Aids by the Digital Mobile Telephone System, Global System for Mobile Communications (GSM), NAL Report #131, National Acoustic Laboratory, Australian Hearing Series, Sydney, 1995.
21. Kecker, W. T., Crawford, M. L., and Wilson, W. A., "Construction of a Transverse Electromagnetic Cell", U.S. Department of Commerce, National Bureau of Standards, Technical Note 1011, Nov. 1978.
22. Konigstein, D., and Hansen, D., "A New Family of TEM Cells with enlarged bandwidth and Optimized working Volume," in the Proceedings of the 7th International Symposium on EMC, Zurich, Switzerland, March 1987; 50:9, pp. 127-132.
23. Kuk, F., and Hjorstgaard, N. K., "Factors affecting interference from digital cellular telephones," Hearing Journal, 1997; 50:9, pp 32-34.
24. Ma, M. A., and Kanda, M., "Electromagnetic Compatibility and Interference Metrology," U.S. Department of Commerce, National Bureau of Standards, Technical Note 1099, July 1986, pp. 17-43.
25. Ma, M. A., Sreenivashiah, I. , and Chang, D. C., "A Method of Determining the Emission and Susceptibility Levels of Electrically Small Objects Using a TEM Cell," U.S. Department of Commerce, National Bureau of Standards, Technical Note 1040, July 1981.
26. McCandless, G. A., and Lyregaard, P. E., Prescription of Gain/Output (POGO) for Hearing Aids, Hearing Instruments 1:16-21, 1983
27. Skopec, M., "Hearing Aid Electromagnetic Interference from Digital Wireless Telephones," IEEE Transactions on Rehabilitation Engineering, vol. 6, no. 2, pp. 235-239, June 1998.
28. Technical Report, GSM 05.90, GSM EMC Considerations, European Telecommunications Standards Institute, January 1993.
29. Victorian, T. A., "Digital Cellular Telephone Interference and Hearing Aid Compatibility—an Update," Hearing Journal 1998; 51:10, pp. 53-60
30. Wong, G. S. K., and Embleton, T. F. W., eds., AIP Handbook of Condenser Microphones: Theory, Calibration and Measurements, AIP Press.

FCC ID: A3LSMG920V	 PCTEST This report is valid until 01/08/2014	HAC (T-COIL) TEST REPORT		Reviewed by: Quality Manager
Filename: 0Y1501190102-R3.A3L	Test Dates: 01/26/2015 - 01/28/2015	EUT Type: Portable Handset		Page 38 of 41