

**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Client **HCT (Dymstec)**

Certificate No: **ES3-3076_Jul18/2**

CALIBRATION CERTIFICATE(Replacement of No: ES3-3076_Jul18)

Object: **ES3DV3 - SN:3076**

Calibration procedure(s): **QA CAL-01.v9, QA CAL-12.v9, QA CAL-23.v5, QA CAL-25.v6**
Calibration procedure for dosimetric field probes

Calibration date: **July 26, 2018**

재	제	제	제
확인/발행	SW	SW	SW
일	2018.08.23	2018.08.23	2018.08.23

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	04-Apr-18 (No. 217-02672/02673)	Apr-19
Power sensor NRP-Z91	SN: 103244	04-Apr-18 (No. 217-02672)	Apr-19
Power sensor NRP-Z91	SN: 103245	04-Apr-18 (No. 217-02673)	Apr-19
Reference 20 dB Attenuator	SN: S5277 (20x)	04-Apr-18 (No. 217-02682)	Apr-19
Reference Probe ES3DV2	SN: 3013	30-Dec-17 (No. ES3-3013 Dec17)	Dec-18
DAE4	SN: 660	21-Dec-17 (No. DAE4-660 Dec17)	Dec-18
Secondary Standards	ID	Check Date (in house)	Scheduled Check
Power meter E4419B	SN: GB41293874	06-Apr-16 (in house check Jun-16)	In house check: Jun-20
Power sensor E4412A	SN: MY41498087	06-Apr-16 (in house check Jun-16)	In house check: Jun-20
Power sensor E4412A	SN: 000110210	06-Apr-16 (in house check Jun-16)	In house check: Jun-20
RF generator HP 8648C	SN: US3642U01700	04-Aug-99 (in house check Jun-18)	In house check: Jun-20
Network Analyzer E8358A	SN: US41080477	31-Mar-14 (in house check Oct-17)	In house check: Oct-18

Calibrated by:	Name Claudio Leubler	Function Laboratory Technician	Signature
Approved by:	Name Katja Pokovic	Function Technical Manager	Signature

Issued: August 11, 2018

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
S Service suisse d'étalonnage
C Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Glossary:

TSL	tissue simulating liquid
NORM _{x,y,z}	sensitivity in free space
ConvF	sensitivity in TSL / NORM _{x,y,z}
DCP	diode compression point
CF	crest factor (1/duty_cycle) of the RF signal
A, B, C, D	modulation dependent linearization parameters
Polarization ϕ	ϕ rotation around probe axis
Polarization θ	θ rotation around an axis that is in the plane normal to probe axis (at measurement center), i.e., $\theta = 0$ is normal to probe axis
Connector Angle	information used in DASY system to align probe sensor X to the robot coordinate system

Calibration is Performed According to the Following Standards:

- a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- b) IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- c) IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- d) KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Methods Applied and Interpretation of Parameters:

- **NORM_{x,y,z}**: Assessed for E-field polarization $\theta = 0$ ($f \leq 900$ MHz in TEM-cell; $f > 1800$ MHz: R22 waveguide). NORM_{x,y,z} are only intermediate values, i.e., the uncertainties of NORM_{x,y,z} does not affect the E²-field uncertainty inside TSL (see below ConvF).
- **NORM(f)_{x,y,z}** = NORM_{x,y,z} * frequency_response (see Frequency Response Chart). This linearization is implemented in DASY4 software versions later than 4.2. The uncertainty of the frequency response is included in the stated uncertainty of ConvF.
- **DCP_{x,y,z}**: DCP are numerical linearization parameters assessed based on the data of power sweep with CW signal (no uncertainty required). DCP does not depend on frequency nor media.
- **PAR**: PAR is the Peak to Average Ratio that is not calibrated but determined based on the signal characteristics
- **A_{x,y,z}; B_{x,y,z}; C_{x,y,z}; D_{x,y,z}; VR_{x,y,z}**: A, B, C, D are numerical linearization parameters assessed based on the data of power sweep for specific modulation signal. The parameters do not depend on frequency nor media. VR is the maximum calibration range expressed in RMS voltage across the diode.
- **ConvF and Boundary Effect Parameters**: Assessed in flat phantom using E-field (or Temperature Transfer Standard for $f \leq 800$ MHz) and inside waveguide using analytical field distributions based on power measurements for $f > 800$ MHz. The same setups are used for assessment of the parameters applied for boundary compensation (alpha, depth) of which typical uncertainty values are given. These parameters are used in DASY4 software to improve probe accuracy close to the boundary. The sensitivity in TSL corresponds to NORM_{x,y,z} * ConvF whereby the uncertainty corresponds to that given for ConvF. A frequency dependent ConvF is used in DASY version 4.4 and higher which allows extending the validity from ± 50 MHz to ± 100 MHz.
- **Spherical isotropy (3D deviation from isotropy)**: in a field of low gradients realized using a flat phantom exposed by a patch antenna.
- **Sensor Offset**: The sensor offset corresponds to the offset of virtual measurement center from the probe tip (on probe axis). No tolerance required.
- **Connector Angle**: The angle is assessed using the information gained by determining the NORM_x (no uncertainty required).

ES3DV3 – SN:3076

July 26, 2018

Probe ES3DV3

SN:3076

Manufactured: June 29, 2005
Calibrated: July 26, 2018

Calibrated for DASY/EASY Systems
(Note: non-compatible with DASY2 system!)

ES3DV3- SN:3076

July 26, 2018

DASY/EASY - Parameters of Probe: ES3DV3 - SN:3076

Basic Calibration Parameters

	Sensor X	Sensor Y	Sensor Z	Unc (k=2)
Norm ($\mu\text{V}/(\text{V}/\text{m})^2$) ^A	1.23	1.25	1.17	$\pm 10.1\%$
DCP (mV) ^B	105.1	103.9	105.2	

Modulation Calibration Parameters

UID	Communication System Name		A dB	B dB $\sqrt{\mu\text{V}}$	C	D dB	VR mV	Unc ^E (k=2)
0	CW	X	0.0	0.0	1.0	0.00	229.6	$\pm 3.5\%$
		Y	0.0	0.0	1.0		211.1	
		Z	0.0	0.0	1.0		212.3	

Note: For details on UID parameters see Appendix.

Sensor Model Parameters

	C1 fF	C2 fF	α V^{-1}	T1 $\text{ms}\cdot\text{V}^{-2}$	T2 $\text{ms}\cdot\text{V}^{-1}$	T3 ms	T4 V^{-2}	T5 V^{-1}	T6
X	77.68	554.8	35.26	43.42	4.074	5.10	0.096	0.829	1.014
Y	65.81	478.9	36.19	29.79	3.991	5.10	0.000	0.773	1.013
Z	67.45	484.4	35.40	34.11	3.613	5.10	0.175	0.773	1.012

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

^A The uncertainties of Norm X,Y,Z do not affect the E^1 -field uncertainty inside TSL (see Pages 5 and 6).

^B Numerical linearization parameter: uncertainty not required.

^E Uncertainty is determined using the max. deviation from linear response applying rectangular distribution and is expressed for the square of the field value.

ES3DV3-SN:3076

July 26, 2018

DASY/EASY - Parameters of Probe: ES3DV3 - SN:3076

Calibration Parameter Determined in Head Tissue Simulating Media

f (MHz) ^C	Relative Permittivity ^F	Conductivity (S/m) ^F	ConvF X	ConvF Y	ConvF Z	Alpha ^G	Depth (mm) ^G	Unc (k=2)
6	55.5	0.75	5.48	5.48	5.48	0.10	1.20	± 13.3 %
13	55.5	0.75	5.74	5.74	5.74	0.10	1.20	± 13.3 %
750	41.9	0.89	6.61	6.61	6.61	0.80	1.21	± 12.0 %
835	41.5	0.90	6.33	6.33	6.33	0.65	1.34	± 12.0 %
900	41.5	0.97	6.27	6.27	6.27	0.42	1.64	± 12.0 %
1450	40.5	1.20	5.54	5.54	5.54	0.39	1.46	± 12.0 %
1750	40.1	1.37	5.33	5.33	5.33	0.55	1.37	± 12.0 %
1900	40.0	1.40	5.14	5.14	5.14	0.61	1.34	± 12.0 %
2450	39.2	1.80	4.72	4.72	4.72	0.79	1.30	± 12.0 %
2600	39.0	1.96	4.57	4.57	4.57	0.80	1.24	± 12.0 %

^C Frequency validity above 300 MHz of ± 100 MHz only applies for DASY v4.4 and higher (see Page 2), else it is restricted to ± 50 MHz. The uncertainty is the RSS of the ConvF uncertainty at calibration frequency and the uncertainty for the indicated frequency band. Frequency validity below 300 MHz is ± 10, 25, 40, 50 and 70 MHz for ConvF assessments at 30, 64, 128, 150 and 220 MHz respectively. Validity of ConvF assessed at 6 MHz is 4-9 MHz, and ConvF assessed at 13 MHz is 9-19 MHz. Above 5 GHz frequency validity can be extended to ± 110 MHz.

^F At frequencies below 3 GHz, the validity of tissue parameters (ϵ and σ) can be relaxed to ± 10% if liquid compensation formula is applied to measured SAR values. At frequencies above 3 GHz, the validity of tissue parameters (ϵ and σ) is restricted to ± 6%. The uncertainty is the RSS of the ConvF uncertainty for indicated target tissue parameters.

^G Alpha/Depth are determined during calibration. SPEAG warrants that the remaining deviation due to the boundary effect after compensation is always less than ± 1% for frequencies below 3 GHz and below ± 2% for frequencies between 3-6 GHz at any distance larger than half the probe tip diameter from the boundary.

ES3DV3- SN:3076

July 26, 2018

DASY/EASY - Parameters of Probe: ES3DV3 - SN:3076

Calibration Parameter Determined in Body Tissue Simulating Media

f (MHz) ^c	Relative Permittivity ^f	Conductivity (S/m) ^f	ConvF X	ConvF Y	ConvF Z	Alpha ^g	Depth ^g (mm)	Unc (k=2)
750	55.5	0.96	6.16	6.16	6.16	0.64	1.29	± 12.0 %
835	55.2	0.97	6.03	6.03	6.03	0.73	1.24	± 12.0 %
1750	53.4	1.49	4.98	4.98	4.98	0.63	1.36	± 12.0 %
1900	53.3	1.52	4.76	4.76	4.76	0.53	1.52	± 12.0 %
2450	52.7	1.95	4.45	4.45	4.45	0.77	1.25	± 12.0 %
2600	52.5	2.16	4.32	4.32	4.32	0.80	1.25	± 12.0 %

^c Frequency validity above 300 MHz of ± 100 MHz only applies for DASY v4.4 and higher (see Page 2), else it is restricted to ± 50 MHz. The uncertainty is the RSS of the ConvF uncertainty at calibration frequency and the uncertainty for the indicated frequency band. Frequency validity below 300 MHz is ± 10, 25, 40, 50 and 70 MHz for ConvF assessments at 30, 64, 128, 150 and 220 MHz respectively. Above 5 GHz frequency validity can be extended to ± 110 MHz.


^f At frequencies below 3 GHz, the validity of tissue parameters (ϵ and σ) can be relaxed to ± 10% if liquid compensation formula is applied to measured SAR values. At frequencies above 3 GHz, the validity of tissue parameters (ϵ and σ) is restricted to ± 5%. The uncertainty is the RSS of the ConvF uncertainty for indicated target tissue parameters.

^g Alpha/Depth are determined during calibration. SPEAG warrants that the remaining deviation due to the boundary effect after compensation is always less than ± 1% for frequencies below 3 GHz and below ± 2% for frequencies between 3-6 GHz at any distance larger than half the probe tip diameter from the boundary.

ES3DV3- SN:3076

July 26, 2018

Frequency Response of E-Field (TEM-Cell:ifi110 EXX, Waveguide: R22)





Uncertainty of Frequency Response of E-field: $\pm 6.3\%$ (k=2)

ES3DV3- SN:3076

July 26, 2018

Receiving Pattern (ϕ), $\theta = 0^\circ$





Uncertainty of Axial Isotropy Assessment: $\pm 0.5\%$ (k=2)

ES3DV3- SN:3076

July 26, 2018

Dynamic Range f(SAR_{head})
(TEM cell , f_{eval}= 1900 MHz)




Uncertainty of Linearity Assessment: ± 0.6% (k=2)


ES3DV3- SN:3076

July 26, 2018

Conversion Factor Assessment



Deviation from Isotropy in Liquid Error (ϕ, θ), f = 900 MHz



ES3DV3- SN:3076

July 26, 2018

DASY/EASY - Parameters of Probe: ES3DV3 - SN:3076**Other Probe Parameters**

Sensor Arrangement	Triangular
Connector Angle (°)	-35
Mechanical Surface Detection Mode	enabled
Optical Surface Detection Mode	disabled
Probe Overall Length	337 mm
Probe Body Diameter	10 mm
Tip Length	10 mm
Tip Diameter	4 mm
Probe Tip to Sensor X Calibration Point	2 mm
Probe Tip to Sensor Y Calibration Point	2 mm
Probe Tip to Sensor Z Calibration Point	2 mm
Recommended Measurement Distance from Surface	3 mm

ES3DV3- SN:3076

July 26, 2018

Appendix: Modulation Calibration Parameters

UID	Communication System Name		A dB	B dB μ V	C	D dB	VR mV	Max Unc ¹ (k=2)
0	CW	X	0.00	0.00	1.00	0.00	229.6	$\pm 3.5\%$
		Y	0.00	0.00	1.00		211.1	
		Z	0.00	0.00	1.00		212.3	
10010- CAA	SAR Validation (Square, 100ms, 10ms)	X	9.16	78.76	19.58	10.00	25.0	$\pm 9.6\%$
		Y	8.10	78.11	19.28		25.0	
		Z	8.54	78.68	19.30		25.0	
10011- CAB	UMTS-FDD (WCDMA)	X	1.31	71.44	17.59	0.00	150.0	$\pm 9.6\%$
		Y	0.96	65.85	14.05		150.0	
		Z	1.03	66.82	14.71		150.0	
10012- CAB	IEEE 802.11b WiFi 2.4 GHz (DSSS, 1 Mbps)	X	1.43	66.81	16.97	0.41	150.0	$\pm 9.6\%$
		Y	1.26	64.34	15.13		150.0	
		Z	1.31	64.93	15.53		150.0	
10013- CAB	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 6 Mbps)	X	5.34	67.46	17.65	1.46	150.0	$\pm 9.6\%$
		Y	5.20	67.09	17.31		150.0	
		Z	5.23	67.21	17.38		150.0	
10021- DAC	GSM-FDD (TDMA, GMSK)	X	12.26	84.63	23.29	9.39	50.0	$\pm 9.6\%$
		Y	12.55	86.63	24.10		50.0	
		Z	13.08	86.89	23.92		50.0	
10023- DAC	GPRS-FDD (TDMA, GMSK, TN 0)	X	12.00	84.13	23.17	9.57	50.0	$\pm 9.6\%$
		Y	12.04	85.73	23.83		50.0	
		Z	12.59	86.09	23.69		50.0	
10024- DAC	GPRS-FDD (TDMA, GMSK, TN 0-1)	X	18.85	92.76	24.51	6.56	60.0	$\pm 9.6\%$
		Y	23.06	97.45	25.94		60.0	
		Z	24.36	97.48	25.68		60.0	
10025- DAC	EDGE-FDD (TDMA, 8PSK, TN 0)	X	20.19	102.77	38.33	12.57	50.0	$\pm 9.6\%$
		Y	13.86	93.18	34.75		50.0	
		Z	19.46	103.80	39.07		50.0	
10026- DAC	EDGE-FDD (TDMA, 8PSK, TN 0-1)	X	19.76	99.27	33.67	9.56	60.0	$\pm 9.6\%$
		Y	14.85	93.88	31.91		60.0	
		Z	18.48	99.29	33.89		60.0	
10027- DAC	GPRS-FDD (TDMA, GMSK, TN 0-1-2)	X	81.84	114.49	29.30	4.80	80.0	$\pm 9.6\%$
		Y	100.00	118.52	30.13		80.0	
		Z	100.00	117.35	29.60		80.0	
10028- DAC	GPRS-FDD (TDMA, GMSK, TN 0-1-2-3)	X	100.00	116.87	28.89	3.55	100.0	$\pm 9.6\%$
		Y	100.00	117.78	28.88		100.0	
		Z	100.00	116.71	28.44		100.0	
10029- DAC	EDGE-FDD (TDMA, 8PSK, TN 0-1-2)	X	15.91	95.03	31.16	7.80	80.0	$\pm 9.6\%$
		Y	11.38	88.87	29.06		80.0	
		Z	13.82	93.30	30.72		80.0	
10030- CAA	IEEE 802.15.1 Bluetooth (GFSK, DH1)	X	30.15	99.84	25.84	5.30	70.0	$\pm 9.6\%$
		Y	37.21	104.19	26.92		70.0	
		Z	41.36	104.79	26.85		70.0	
10031- CAA	IEEE 802.15.1 Bluetooth (GFSK, DH3)	X	100.00	118.10	27.80	1.88	100.0	$\pm 9.6\%$
		Y	100.00	116.72	26.72		100.0	
		Z	100.00	116.38	26.67		100.0	

ES3DV3- SN:3076

July 26, 2018

10032-CAA	IEEE 802.15.1 Bluetooth (GFSK, DH5)	X	100.00	122.30	28.43	1.17	100.0	± 9.6 %
		Y	100.00	117.44	25.86		100.0	
		Z	100.00	118.21	26.32		100.0	
10033-CAA	IEEE 802.15.1 Bluetooth (PI/4-DQPSK, DH1)	X	14.42	91.28	25.38	5.30	70.0	± 9.6 %
		Y	10.29	86.58	23.66		70.0	
		Z	12.14	89.11	24.45		70.0	
10034-CAA	IEEE 802.15.1 Bluetooth (PI/4-DQPSK, DH3)	X	10.48	91.53	24.19	1.88	100.0	± 9.6 %
		Y	4.76	79.75	19.71		100.0	
		Z	5.74	82.37	20.69		100.0	
10035-CAA	IEEE 802.15.1 Bluetooth (PI/4-DQPSK, DH5)	X	6.62	86.73	22.48	1.17	100.0	± 9.6 %
		Y	3.05	75.20	17.68		100.0	
		Z	3.60	77.51	18.67		100.0	
10036-CAA	IEEE 802.15.1 Bluetooth (8-DPSK, DH1)	X	15.95	93.13	26.03	5.30	70.0	± 9.6 %
		Y	11.34	88.37	24.34		70.0	
		Z	13.49	91.02	25.14		70.0	
10037-CAA	IEEE 802.15.1 Bluetooth (8-DPSK, DH3)	X	10.41	91.42	24.11	1.88	100.0	± 9.6 %
		Y	4.64	79.43	19.55		100.0	
		Z	5.62	82.11	20.56		100.0	
10038-CAA	IEEE 802.15.1 Bluetooth (8-DPSK, DH5)	X	7.03	87.87	22.93	1.17	100.0	± 9.6 %
		Y	3.12	75.72	17.96		100.0	
		Z	3.70	78.11	18.96		100.0	
10039-CAB	CDMA2000 (1xRTT, RC1)	X	2.48	75.30	18.48	0.00	150.0	± 9.6 %
		Y	1.66	69.18	14.85		150.0	
		Z	1.79	70.23	15.54		150.0	
10042-CAB	IS-54 / IS-136 FDD (TDMA/FDM, PI/4-DQPSK, Halfrate)	X	14.74	87.77	22.95	7.78	50.0	± 9.6 %
		Y	16.09	90.60	23.87		50.0	
		Z	16.98	90.81	23.69		50.0	
10044-CAA	IS-91/EIA/TIA-553 FDD (FDMA, FM)	X	0.00	123.82	2.90	0.00	150.0	± 9.6 %
		Y	0.00	116.34	0.54		150.0	
		Z	0.00	102.58	5.27		150.0	
10048-CAA	DECT (TDD, TDMA/FDM, GFSK, Full Slot, 24)	X	10.75	79.68	23.38	13.80	25.0	± 9.6 %
		Y	10.01	79.38	23.29		25.0	
		Z	10.41	80.20	23.38		25.0	
10049-CAA	DECT (TDD, TDMA/FDM, GFSK, Double Slot, 12)	X	11.22	82.18	22.90	10.79	40.0	± 9.6 %
		Y	10.78	82.85	23.21		40.0	
		Z	11.21	83.30	23.12		40.0	
10056-CAA	UMTS-TDD (TD-SCDMA, 1.28 Mcps)	X	11.83	83.67	23.71	9.03	50.0	± 9.6 %
		Y	10.56	82.61	23.25		50.0	
		Z	11.42	83.99	23.67		50.0	
10058-DAC	EDGE-FDD (TDMA, 8PSK, TN 0-1-2-3)	X	13.01	91.59	29.27	6.55	100.0	± 9.6 %
		Y	9.03	85.01	26.94		100.0	
		Z	10.72	88.68	28.35		100.0	
10059-CAB	IEEE 802.11b WiFi 2.4 GHz (DSSS, 2 Mbps)	X	1.75	69.92	18.34	0.61	110.0	± 9.6 %
		Y	1.44	66.31	16.08		110.0	
		Z	1.51	67.15	16.57		110.0	
10060-CAB	IEEE 802.11b WiFi 2.4 GHz (DSSS, 5.5 Mbps)	X	100.00	128.55	32.96	1.30	110.0	± 9.6 %
		Y	13.71	99.86	25.53		110.0	
		Z	37.52	113.73	29.09		110.0	

ES3DV3- SN:3076

July 26, 2018

10061-CAB	IEEE 802.11b WiFi 2.4 GHz (DSSS, 11 Mbps)	X	16.88	103.58	28.87	2.04	110.0	± 9.6 %
		Y	6.17	86.09	23.34		110.0	
		Z	8.26	90.58	24.79		110.0	
10062-CAC	IEEE 802.11a/h WiFi 5 GHz (OFDM, 6 Mbps)	X	5.04	67.16	16.91	0.49	100.0	± 9.6 %
		Y	4.90	66.78	16.56		100.0	
		Z	4.93	66.90	16.63		100.0	
10063-CAC	IEEE 802.11a/h WiFi 5 GHz (OFDM, 9 Mbps)	X	5.09	67.37	17.07	0.72	100.0	± 9.6 %
		Y	4.95	66.96	16.71		100.0	
		Z	4.97	67.08	16.78		100.0	
10064-CAC	IEEE 802.11a/h WiFi 5 GHz (OFDM, 12 Mbps)	X	5.48	67.76	17.35	0.86	100.0	± 9.6 %
		Y	5.30	67.34	17.00		100.0	
		Z	5.33	67.46	17.07		100.0	
10065-CAC	IEEE 802.11a/h WiFi 5 GHz (OFDM, 18 Mbps)	X	5.38	67.84	17.54	1.21	100.0	± 9.6 %
		Y	5.21	67.40	17.18		100.0	
		Z	5.24	67.52	17.25		100.0	
10066-CAC	IEEE 802.11a/h WiFi 5 GHz (OFDM, 24 Mbps)	X	5.46	68.03	17.80	1.46	100.0	± 9.6 %
		Y	5.28	67.56	17.42		100.0	
		Z	5.31	67.69	17.49		100.0	
10067-CAC	IEEE 802.11a/h WiFi 5 GHz (OFDM, 36 Mbps)	X	5.80	68.19	18.28	2.04	100.0	± 9.6 %
		Y	5.62	67.75	17.90		100.0	
		Z	5.65	67.88	17.98		100.0	
10068-CAC	IEEE 802.11a/h WiFi 5 GHz (OFDM, 48 Mbps)	X	6.00	68.73	18.71	2.55	100.0	± 9.6 %
		Y	5.79	68.20	18.31		100.0	
		Z	5.82	68.34	18.40		100.0	
10069-CAC	IEEE 802.11a/h WiFi 5 GHz (OFDM, 54 Mbps)	X	6.06	68.56	18.86	2.67	100.0	± 9.6 %
		Y	5.87	68.11	18.48		100.0	
		Z	5.90	68.26	18.58		100.0	
10071-CAB	IEEE 802.11g WiFi 2.4 GHz (DSSS/OFDM, 9 Mbps)	X	5.52	67.78	18.07	1.99	100.0	± 9.6 %
		Y	5.37	67.37	17.72		100.0	
		Z	5.39	67.50	17.79		100.0	
10072-CAB	IEEE 802.11g WiFi 2.4 GHz (DSSS/OFDM, 12 Mbps)	X	5.64	68.48	18.44	2.30	100.0	± 9.6 %
		Y	5.46	67.97	18.05		100.0	
		Z	5.49	68.12	18.13		100.0	
10073-CAB	IEEE 802.11g WiFi 2.4 GHz (DSSS/OFDM, 18 Mbps)	X	5.62	68.95	18.91	2.83	100.0	± 9.6 %
		Y	5.62	68.38	18.49		100.0	
		Z	5.65	68.54	18.59		100.0	
10074-CAB	IEEE 802.11g WiFi 2.4 GHz (DSSS/OFDM, 24 Mbps)	X	5.90	69.18	19.27	3.30	100.0	± 9.6 %
		Y	5.68	68.51	18.78		100.0	
		Z	5.71	68.70	18.90		100.0	
10075-CAB	IEEE 802.11g WiFi 2.4 GHz (DSSS/OFDM, 36 Mbps)	X	6.16	69.98	19.91	3.82	90.0	± 9.6 %
		Y	5.88	69.11	19.32		90.0	
		Z	5.92	69.35	19.48		90.0	
10076-CAB	IEEE 802.11g WiFi 2.4 GHz (DSSS/OFDM, 48 Mbps)	X	6.16	69.78	20.03	4.15	90.0	± 9.6 %
		Y	5.90	68.93	19.45		90.0	
		Z	5.93	69.17	19.61		90.0	
10077-CAB	IEEE 802.11g WiFi 2.4 GHz (DSSS/OFDM, 54 Mbps)	X	6.21	69.90	20.15	4.30	90.0	± 9.6 %
		Y	5.94	69.02	19.55		90.0	
		Z	5.97	69.27	19.72		90.0	

ES30V3- SN:3076

July 26, 2018

10081-CAB	CDMA2000 (1xRTT, RC3)	X	1.26	70.70	16.24	0.00	150.0	± 9.6 %
		Y	0.84	64.70	12.17		150.0	
		Z	0.90	65.61	12.90		150.0	
10082-CAB	IS-54 / IS-136 FDD (TDMA/FDM, PI/4-DQPSK, Fullrate)	X	3.15	66.05	10.71	4.77	80.0	± 9.6 %
		Y	2.48	64.66	9.77		80.0	
		Z	2.60	64.89	9.82		80.0	
10090-DAC	GPRS-FDD (TDMA, GMSK, TN 0-4)	X	18.57	92.55	24.48	6.56	60.0	± 9.6 %
		Y	22.66	97.21	25.90		60.0	
		Z	23.88	97.21	25.64		60.0	
10097-CAB	UMTS-FDD (HSDPA)	X	1.98	68.70	16.67	0.00	150.0	± 9.6 %
		Y	1.75	66.38	14.96		150.0	
		Z	1.80	66.87	15.30		150.0	
10098-CAB	UMTS-FDD (HSUPA, Subtest 2)	X	1.94	68.71	16.66	0.00	150.0	± 9.6 %
		Y	1.71	66.33	14.91		150.0	
		Z	1.77	66.83	15.26		150.0	
10099-DAC	EDGE-FDD (TDMA, 8PSK, TN 0-4)	X	19.63	99.08	33.60	9.56	60.0	± 9.6 %
		Y	14.80	93.76	31.87		60.0	
		Z	18.37	99.12	33.83		60.0	
10100-CAE	LTE-FDD (SC-FDMA, 100% RB, 20 MHz, QPSK)	X	3.64	72.34	17.56	0.00	150.0	± 9.6 %
		Y	3.12	69.65	16.07		150.0	
		Z	3.22	70.22	16.37		150.0	
10101-CAE	LTE-FDD (SC-FDMA, 100% RB, 20 MHz, 16-QAM)	X	3.55	68.64	16.52	0.00	150.0	± 9.6 %
		Y	3.31	67.34	15.66		150.0	
		Z	3.36	67.65	15.84		150.0	
10102-CAE	LTE-FDD (SC-FDMA, 100% RB, 20 MHz, 64-QAM)	X	3.64	68.45	16.55	0.00	150.0	± 9.6 %
		Y	3.42	67.30	15.76		150.0	
		Z	3.46	67.57	15.92		150.0	
10103-CAF	LTE-TDD (SC-FDMA, 100% RB, 20 MHz, QPSK)	X	9.28	77.61	20.86	3.98	65.0	± 9.6 %
		Y	8.20	76.35	20.43		65.0	
		Z	8.60	77.04	20.64		65.0	
10104-CAF	LTE-TDD (SC-FDMA, 100% RB, 20 MHz, 16-QAM)	X	9.53	77.20	21.60	3.98	65.0	± 9.6 %
		Y	8.47	75.78	21.04		65.0	
		Z	8.87	76.56	21.33		65.0	
10105-CAF	LTE-TDD (SC-FDMA, 100% RB, 20 MHz, 64-QAM)	X	8.43	74.79	20.82	3.98	65.0	± 9.6 %
		Y	7.55	73.49	20.30		65.0	
		Z	7.91	74.31	20.62		65.0	
10108-CAF	LTE-FDD (SC-FDMA, 100% RB, 10 MHz, QPSK)	X	3.22	71.44	17.37	0.00	150.0	± 9.6 %
		Y	2.77	68.89	15.90		150.0	
		Z	2.86	69.42	16.20		150.0	
10109-CAF	LTE-FDD (SC-FDMA, 100% RB, 10 MHz, 16-QAM)	X	3.23	68.43	16.49	0.00	150.0	± 9.6 %
		Y	2.98	67.08	15.55		150.0	
		Z	3.03	67.38	15.74		150.0	
10110-CAF	LTE-FDD (SC-FDMA, 100% RB, 5 MHz, QPSK)	X	2.66	70.47	17.14	0.00	150.0	± 9.6 %
		Y	2.27	67.90	15.53		150.0	
		Z	2.35	68.44	15.86		150.0	
10111-CAF	LTE-FDD (SC-FDMA, 100% RB, 5 MHz, 16-QAM)	X	2.91	68.82	16.80	0.00	150.0	± 9.6 %
		Y	2.65	67.37	15.70		150.0	
		Z	2.70	67.65	15.89		150.0	

ES3DV3- SN:3076

July 26, 2018

10112-CAF	LTE-FDD (SC-FDMA, 100% RB, 10 MHz, 64-QAM)	X	3.34	68.23	16.47	0.00	150.0	± 9.6 %
		Y	3.10	67.04	15.61		150.0	
		Z	3.15	67.31	15.78		150.0	
10113-CAF	LTE-FDD (SC-FDMA, 100% RB, 5 MHz, 64-QAM)	X	3.06	68.77	16.84	0.00	150.0	± 9.6 %
		Y	2.81	67.49	15.84		150.0	
		Z	2.86	67.74	16.01		150.0	
10114-CAC	IEEE 802.11n (HT Greenfield, 13.5 Mbps, BPSK)	X	5.36	67.55	16.65	0.00	150.0	± 9.6 %
		Y	5.22	67.10	16.30		150.0	
		Z	5.25	67.22	16.36		150.0	
10115-CAC	IEEE 802.11n (HT Greenfield, 81 Mbps, 16-QAM)	X	5.83	68.09	16.92	0.00	150.0	± 9.6 %
		Y	5.61	67.46	16.49		150.0	
		Z	5.64	67.58	16.55		150.0	
10116-CAC	IEEE 802.11n (HT Greenfield, 135 Mbps, 64-QAM)	X	5.50	67.80	16.69	0.00	150.0	± 9.6 %
		Y	5.36	67.37	16.36		150.0	
		Z	5.38	67.48	16.41		150.0	
10117-CAC	IEEE 802.11n (HT Mixed, 13.5 Mbps, BPSK)	X	5.36	67.56	16.67	0.00	150.0	± 9.6 %
		Y	5.24	67.13	16.34		150.0	
		Z	5.26	67.25	16.39		150.0	
10118-CAC	IEEE 802.11n (HT Mixed, 81 Mbps, 16-QAM)	X	5.82	67.96	16.85	0.00	150.0	± 9.6 %
		Y	5.66	67.54	16.54		150.0	
		Z	5.68	67.63	16.58		150.0	
10119-CAC	IEEE 802.11n (HT Mixed, 135 Mbps, 64-QAM)	X	5.46	67.73	16.67	0.00	150.0	± 9.6 %
		Y	5.34	67.34	16.36		150.0	
		Z	5.35	67.44	16.40		150.0	
10140-CAE	LTE-FDD (SC-FDMA, 100% RB, 15 MHz, 16-QAM)	X	3.70	68.45	16.48	0.00	150.0	± 9.6 %
		Y	3.47	67.30	15.69		150.0	
		Z	3.52	67.58	15.85		150.0	
10141-CAE	LTE-FDD (SC-FDMA, 100% RB, 15 MHz, 64-QAM)	X	3.81	68.40	16.58	0.00	150.0	± 9.6 %
		Y	3.59	67.37	15.85		150.0	
		Z	3.63	67.61	15.99		150.0	
10142-CAE	LTE-FDD (SC-FDMA, 100% RB, 3 MHz, QPSK)	X	2.44	70.40	17.07	0.00	150.0	± 9.6 %
		Y	2.04	67.65	15.24		150.0	
		Z	2.12	68.22	15.62		150.0	
10143-CAE	LTE-FDD (SC-FDMA, 100% RB, 3 MHz, 16-QAM)	X	2.81	69.50	16.85	0.00	150.0	± 9.6 %
		Y	2.49	67.76	15.47		150.0	
		Z	2.55	68.08	15.71		150.0	
10144-CAE	LTE-FDD (SC-FDMA, 100% RB, 3 MHz, 64-QAM)	X	2.66	67.82	15.64	0.00	150.0	± 9.6 %
		Y	2.36	66.19	14.27		150.0	
		Z	2.43	66.57	14.56		150.0	
10145-CAF	LTE-FDD (SC-FDMA, 100% RB, 1.4 MHz, QPSK)	X	1.88	69.82	15.94	0.00	150.0	± 9.6 %
		Y	1.39	65.57	12.82		150.0	
		Z	1.48	66.34	13.43		150.0	
10146-CAF	LTE-FDD (SC-FDMA, 100% RB, 1.4 MHz, 16-QAM)	X	4.50	77.19	18.98	0.00	150.0	± 9.6 %
		Y	3.13	71.69	15.74		150.0	
		Z	3.22	71.87	15.88		150.0	
10147-CAF	LTE-FDD (SC-FDMA, 100% RB, 1.4 MHz, 64-QAM)	X	5.51	80.43	20.42	0.00	150.0	± 9.6 %
		Y	3.63	74.65	17.16		150.0	
		Z	3.81	74.36	17.11		150.0	

ES3DV3- SN:3076

July 26, 2018

10149-CAE	LTE-FDD (SC-FDMA, 50% RB, 20 MHz, 16-QAM)	X	3.24	68.48	16.53	0.00	150.0	± 9.6 %
		Y	2.99	67.13	15.59		150.0	
		Z	3.04	67.43	15.77		150.0	
10150-CAE	LTE-FDD (SC-FDMA, 50% RB, 20 MHz, 64-QAM)	X	3.35	68.28	16.51	0.00	150.0	± 9.6 %
		Y	3.11	67.08	15.65		150.0	
		Z	3.16	67.35	15.81		150.0	
10151-CAF	LTE-TDD (SC-FDMA, 50% RB, 20 MHz, QPSK)	X	9.61	79.23	21.61	3.98	65.0	± 9.6 %
		Y	8.51	78.11	21.23		65.0	
		Z	8.98	78.86	21.46		65.0	
10152-CAF	LTE-TDD (SC-FDMA, 50% RB, 20 MHz, 16-QAM)	X	9.23	77.46	21.56	3.98	65.0	± 9.6 %
		Y	8.07	75.84	20.87		65.0	
		Z	8.51	76.72	21.21		65.0	
10153-CAF	LTE-TDD (SC-FDMA, 50% RB, 20 MHz, 64-QAM)	X	9.51	77.96	22.07	3.98	65.0	± 9.6 %
		Y	8.40	76.49	21.46		65.0	
		Z	8.82	77.30	21.77		65.0	
10154-CAF	LTE-FDD (SC-FDMA, 50% RB, 10 MHz, QPSK)	X	2.74	70.98	17.45	0.00	150.0	± 9.6 %
		Y	2.32	68.30	15.79		150.0	
		Z	2.40	68.83	16.11		150.0	
10155-CAF	LTE-FDD (SC-FDMA, 50% RB, 10 MHz, 16-QAM)	X	2.91	68.81	16.80	0.00	150.0	± 9.6 %
		Y	2.65	67.37	15.71		150.0	
		Z	2.70	67.65	15.90		150.0	
10156-CAF	LTE-FDD (SC-FDMA, 50% RB, 5 MHz, QPSK)	X	2.33	70.88	17.23	0.00	150.0	± 9.6 %
		Y	1.89	67.69	15.12		150.0	
		Z	1.98	68.32	15.54		150.0	
10157-CAF	LTE-FDD (SC-FDMA, 50% RB, 5 MHz, 16-QAM)	X	2.51	68.58	15.92	0.00	150.0	± 9.6 %
		Y	2.18	66.57	14.30		150.0	
		Z	2.25	67.01	14.63		150.0	
10158-CAF	LTE-FDD (SC-FDMA, 50% RB, 10 MHz, 64-QAM)	X	3.07	68.80	16.88	0.00	150.0	± 9.6 %
		Y	2.81	67.53	15.88		150.0	
		Z	2.86	67.77	16.04		150.0	
10159-CAF	LTE-FDD (SC-FDMA, 50% RB, 5 MHz, 64-QAM)	X	2.82	68.92	16.17	0.00	150.0	± 9.6 %
		Y	2.28	66.96	14.57		150.0	
		Z	2.35	67.37	14.89		150.0	
10160-CAE	LTE-FDD (SC-FDMA, 50% RB, 15 MHz, QPSK)	X	3.09	69.80	16.96	0.00	150.0	± 9.6 %
		Y	2.79	68.06	15.82		150.0	
		Z	2.85	68.41	16.03		150.0	
10161-CAE	LTE-FDD (SC-FDMA, 50% RB, 15 MHz, 16-QAM)	X	3.23	68.12	16.46	0.00	150.0	± 9.6 %
		Y	3.00	66.95	15.58		150.0	
		Z	3.05	67.21	15.75		150.0	
10162-CAE	LTE-FDD (SC-FDMA, 50% RB, 15 MHz, 64-QAM)	X	3.32	68.06	16.48	0.00	150.0	± 9.6 %
		Y	3.11	67.01	15.66		150.0	
		Z	3.15	67.26	15.82		150.0	
10166-CAF	LTE-FDD (SC-FDMA, 50% RB, 1.4 MHz, QPSK)	X	4.29	70.92	20.04	3.01	150.0	± 9.6 %
		Y	3.99	69.96	19.35		150.0	
		Z	4.07	70.21	19.43		150.0	
10167-CAF	LTE-FDD (SC-FDMA, 50% RB, 1.4 MHz, 16-QAM)	X	5.60	74.10	20.63	3.01	150.0	± 9.6 %
		Y	5.05	72.81	19.82		150.0	
		Z	5.22	73.20	19.95		150.0	

ES3DV3- SN:3076

July 26, 2018

10168-CAF	LTE-FDD (SC-FDMA, 50% RB, 1.4 MHz, 64-QAM)	X	6.00	75.56	21.53	3.01	150.0	± 9.6 %
		Y	5.48	74.58	20.89		150.0	
		Z	5.62	74.77	20.91		150.0	
10169-CAE	LTE-FDD (SC-FDMA, 1 RB, 20 MHz, QPSK)	X	4.35	74.10	21.32	3.01	150.0	± 9.6 %
		Y	3.88	71.30	19.88		150.0	
		Z	3.85	72.00	20.14		150.0	
10170-CAE	LTE-FDD (SC-FDMA, 1 RB, 20 MHz, 16-QAM)	X	6.52	80.39	23.41	3.01	150.0	± 9.6 %
		Y	5.25	77.06	21.95		150.0	
		Z	5.54	77.68	22.09		150.0	
10171-AAE	LTE-FDD (SC-FDMA, 1 RB, 20 MHz, 64-QAM)	X	5.43	76.38	21.00	3.01	150.0	± 9.6 %
		Y	4.35	73.06	19.41		150.0	
		Z	4.65	73.95	19.73		150.0	
10172-CAF	LTE-TDD (SC-FDMA, 1 RB, 20 MHz, QPSK)	X	26.11	103.14	31.43	6.02	65.0	± 9.6 %
		Y	17.44	97.23	29.74		65.0	
		Z	21.81	101.08	30.82		65.0	
10173-CAF	LTE-TDD (SC-FDMA, 1 RB, 20 MHz, 16-QAM)	X	21.26	95.48	27.74	6.02	65.0	± 9.6 %
		Y	18.81	94.80	27.59		65.0	
		Z	20.35	95.83	27.76		65.0	
10174-CAF	LTE-TDD (SC-FDMA, 1 RB, 20 MHz, 64-QAM)	X	18.48	92.02	26.25	6.02	65.0	± 9.6 %
		Y	15.88	91.01	25.95		65.0	
		Z	17.31	91.99	26.13		65.0	
10175-CAF	LTE-FDD (SC-FDMA, 1 RB, 10 MHz, QPSK)	X	4.28	73.71	21.06	3.01	150.0	± 9.6 %
		Y	3.63	70.95	19.62		150.0	
		Z	3.80	71.67	19.90		150.0	
10176-CAF	LTE-FDD (SC-FDMA, 1 RB, 10 MHz, 16-QAM)	X	6.52	80.41	23.42	3.01	150.0	± 9.6 %
		Y	5.26	77.08	21.96		150.0	
		Z	5.55	77.70	22.10		150.0	
10177-CAH	LTE-FDD (SC-FDMA, 1 RB, 5 MHz, QPSK)	X	4.32	73.90	21.17	3.01	150.0	± 9.6 %
		Y	3.66	71.13	19.73		150.0	
		Z	3.83	71.83	19.99		150.0	
10178-CAF	LTE-FDD (SC-FDMA, 1 RB, 5 MHz, 16-QAM)	X	6.42	80.09	23.26	3.01	150.0	± 9.6 %
		Y	5.18	76.79	21.81		150.0	
		Z	5.47	77.43	21.96		150.0	
10179-CAF	LTE-FDD (SC-FDMA, 1 RB, 10 MHz, 64-QAM)	X	5.91	78.18	22.04	3.01	150.0	± 9.6 %
		Y	4.75	74.89	20.53		150.0	
		Z	5.05	75.66	20.76		150.0	
10180-CAF	LTE-FDD (SC-FDMA, 1 RB, 5 MHz, 64-QAM)	X	5.40	76.26	20.93	3.01	150.0	± 9.6 %
		Y	4.34	72.96	19.34		150.0	
		Z	4.63	73.87	19.68		150.0	
10181-CAE	LTE-FDD (SC-FDMA, 1 RB, 15 MHz, QPSK)	X	4.32	73.88	21.16	3.01	150.0	± 9.6 %
		Y	3.65	71.11	19.72		150.0	
		Z	3.83	71.81	19.99		150.0	
10182-CAE	LTE-FDD (SC-FDMA, 1 RB, 15 MHz, 16-QAM)	X	6.41	80.06	23.25	3.01	150.0	± 9.6 %
		Y	5.17	76.77	21.80		150.0	
		Z	5.46	77.41	21.96		150.0	
10183-AAD	LTE-FDD (SC-FDMA, 1 RB, 15 MHz, 64-QAM)	X	5.39	76.24	20.92	3.01	150.0	± 9.6 %
		Y	4.33	72.94	19.33		150.0	
		Z	4.63	73.84	19.67		150.0	

ES3DV3-SN:3076

July 26, 2018

10184-CAE	LTE-FDD (SC-FDMA, 1 RB, 3 MHz, QPSK)	X	4.33	73.92	21.18	3.01	150.0	± 9.6 %
		Y	3.67	71.15	19.74		150.0	
		Z	3.84	71.85	20.01		150.0	
10185-CAE	LTE-FDD (SC-FDMA, 1 RB, 3 MHz, 16-QAM)	X	6.44	80.13	23.28	3.01	150.0	± 9.6 %
		Y	5.20	76.84	21.84		150.0	
		Z	5.49	77.47	21.99		150.0	
10186-AAE	LTE-FDD (SC-FDMA, 1 RB, 3 MHz, 64-QAM)	X	5.42	76.30	20.95	3.01	150.0	± 9.6 %
		Y	4.35	73.00	19.37		150.0	
		Z	4.65	73.91	19.70		150.0	
10187-CAF	LTE-FDD (SC-FDMA, 1 RB, 1.4 MHz, QPSK)	X	4.34	73.95	21.22	3.01	150.0	± 9.6 %
		Y	3.67	71.19	19.79		150.0	
		Z	3.85	71.89	20.05		150.0	
10188-CAF	LTE-FDD (SC-FDMA, 1 RB, 1.4 MHz, 16-QAM)	X	6.67	80.85	23.85	3.01	150.0	± 9.6 %
		Y	5.38	77.54	22.22		150.0	
		Z	5.66	78.11	22.33		150.0	
10189-AAF	LTE-FDD (SC-FDMA, 1 RB, 1.4 MHz, 64-QAM)	X	5.55	76.77	21.22	3.01	150.0	± 9.6 %
		Y	4.45	73.44	19.64		150.0	
		Z	4.75	74.32	19.95		150.0	
10193-CAC	IEEE 802.11n (HT Greenfield, 6.5 Mbps, BPSK)	X	4.79	66.88	16.44	0.00	150.0	± 9.6 %
		Y	4.65	66.47	16.06		150.0	
		Z	4.68	66.60	16.13		150.0	
10194-CAC	IEEE 802.11n (HT Greenfield, 39 Mbps, 16-QAM)	X	5.01	67.29	16.54	0.00	150.0	± 9.6 %
		Y	4.85	66.85	16.17		150.0	
		Z	4.88	66.98	16.24		150.0	
10195-CAC	IEEE 802.11n (HT Greenfield, 65 Mbps, 64-QAM)	X	5.05	67.27	16.53	0.00	150.0	± 9.6 %
		Y	4.89	66.86	16.18		150.0	
		Z	4.92	66.98	16.24		150.0	
10196-CAC	IEEE 802.11n (HT Mixed, 6.5 Mbps, BPSK)	X	4.82	67.00	16.48	0.00	150.0	± 9.6 %
		Y	4.67	66.57	16.09		150.0	
		Z	4.70	66.71	16.17		150.0	
10197-CAC	IEEE 802.11n (HT Mixed, 39 Mbps, 16-QAM)	X	5.03	67.30	16.54	0.00	150.0	± 9.6 %
		Y	4.87	66.87	16.18		150.0	
		Z	4.90	67.00	16.25		150.0	
10198-CAC	IEEE 802.11n (HT Mixed, 65 Mbps, 64-QAM)	X	5.05	67.28	16.54	0.00	150.0	± 9.6 %
		Y	4.90	66.87	16.19		150.0	
		Z	4.93	67.00	16.25		150.0	
10219-CAC	IEEE 802.11n (HT Mixed, 7.2 Mbps, BPSK)	X	4.77	67.03	16.46	0.00	150.0	± 9.6 %
		Y	4.62	66.58	16.05		150.0	
		Z	4.65	66.72	16.13		150.0	
10220-CAC	IEEE 802.11n (HT Mixed, 43.3 Mbps, 16-QAM)	X	5.03	67.31	16.55	0.00	150.0	± 9.6 %
		Y	4.87	66.86	16.18		150.0	
		Z	4.90	67.00	16.25		150.0	
10221-CAC	IEEE 802.11n (HT Mixed, 72.2 Mbps, 64-QAM)	X	5.06	67.23	16.54	0.00	150.0	± 9.6 %
		Y	4.90	66.81	16.18		150.0	
		Z	4.94	66.94	16.25		150.0	
10222-CAC	IEEE 802.11n (HT Mixed, 15 Mbps, BPSK)	X	5.35	67.60	16.68	0.00	150.0	± 9.6 %
		Y	5.22	67.15	16.34		150.0	
		Z	5.24	67.28	16.39		150.0	

ES3DV3- SN:3076

July 26, 2018

10223-CAC	IEEE 802.11n (HT Mixed, 90 Mbps, 16-QAM)	X	5.72	67.80	16.79	0.00	150.0	± 9.6 %
		Y	5.61	67.57	16.58		150.0	
		Z	5.63	67.65	16.61		150.0	
10224-CAC	IEEE 802.11n (HT Mixed, 150 Mbps, 64-QAM)	X	5.42	67.76	16.68	0.00	150.0	± 9.6 %
		Y	5.26	67.25	16.31		150.0	
		Z	5.29	67.38	16.37		150.0	
10225-CAB	UMTS-FDD (HSPA+)	X	3.05	66.56	16.01	0.00	150.0	± 9.6 %
		Y	2.88	65.73	15.22		150.0	
		Z	2.92	65.94	15.38		150.0	
10226-CAA	LTE-TDD (SC-FDMA, 1 RB, 1.4 MHz, 16-QAM)	X	21.78	96.01	27.97	6.02	65.0	± 9.6 %
		Y	19.26	95.51	27.89		65.0	
		Z	20.99	96.47	28.03		65.0	
10227-CAA	LTE-TDD (SC-FDMA, 1 RB, 1.4 MHz, 64-QAM)	X	18.78	92.42	26.46	6.02	65.0	± 9.6 %
		Y	16.98	92.27	26.44		65.0	
		Z	18.08	92.82	26.47		65.0	
10228-CAA	LTE-TDD (SC-FDMA, 1 RB, 1.4 MHz, QPSK)	X	26.41	103.89	31.77	6.02	65.0	± 9.6 %
		Y	19.31	99.68	30.62		65.0	
		Z	23.50	102.98	31.50		65.0	
10229-CAC	LTE-TDD (SC-FDMA, 1 RB, 3 MHz, 16-QAM)	X	21.25	95.47	27.74	6.02	65.0	± 9.6 %
		Y	18.64	94.82	27.60		65.0	
		Z	20.37	95.83	27.76		65.0	
10230-CAC	LTE-TDD (SC-FDMA, 1 RB, 3 MHz, 64-QAM)	X	18.37	91.97	26.25	6.02	65.0	± 9.6 %
		Y	16.49	91.69	26.19		65.0	
		Z	17.61	92.30	26.24		65.0	
10231-CAC	LTE-TDD (SC-FDMA, 1 RB, 3 MHz, QPSK)	X	25.67	103.26	31.52	6.02	65.0	± 9.6 %
		Y	18.66	98.92	30.32		65.0	
		Z	22.73	102.25	31.21		65.0	
10232-CAE	LTE-TDD (SC-FDMA, 1 RB, 5 MHz, 16-QAM)	X	21.25	95.47	27.74	6.02	65.0	± 9.6 %
		Y	18.63	94.81	27.60		65.0	
		Z	20.36	95.83	27.76		65.0	
10233-CAE	LTE-TDD (SC-FDMA, 1 RB, 5 MHz, 64-QAM)	X	18.38	91.99	26.26	6.02	65.0	± 9.6 %
		Y	16.48	91.69	26.19		65.0	
		Z	17.62	92.31	26.24		65.0	
10234-CAE	LTE-TDD (SC-FDMA, 1 RB, 5 MHz, QPSK)	X	24.85	102.50	31.21	6.02	65.0	± 9.6 %
		Y	18.00	98.09	29.97		65.0	
		Z	21.91	101.40	30.87		65.0	
10235-CAE	LTE-TDD (SC-FDMA, 1 RB, 10 MHz, 16-QAM)	X	21.27	95.50	27.75	6.02	65.0	± 9.6 %
		Y	18.65	94.84	27.61		65.0	
		Z	20.39	95.86	27.77		65.0	
10236-CAE	LTE-TDD (SC-FDMA, 1 RB, 10 MHz, 64-QAM)	X	18.47	92.06	26.28	6.02	65.0	± 9.6 %
		Y	16.57	91.78	26.22		65.0	
		Z	17.71	92.39	26.27		65.0	
10237-CAE	LTE-TDD (SC-FDMA, 1 RB, 10 MHz, QPSK)	X	25.88	103.44	31.57	6.02	65.0	± 9.6 %
		Y	18.75	99.04	30.35		65.0	
		Z	22.88	102.40	31.26		65.0	
10238-CAE	LTE-TDD (SC-FDMA, 1 RB, 15 MHz, 16-QAM)	X	21.25	95.48	27.74	6.02	65.0	± 9.6 %
		Y	18.62	94.81	27.60		65.0	
		Z	20.36	95.83	27.76		65.0	

ES3DV3- SN:3076

July 26, 2018

10239-CAE	LTE-TDD (SC-FDMA, 1 RB, 15 MHz, 64-QAM)	X	18.39	92.01	26.27	6.02	65.0	± 9.6 %
		Y	16.48	91.70	26.20		65.0	
		Z	17.62	92.32	26.25		65.0	
10240-CAE	LTE-TDD (SC-FDMA, 1 RB, 15 MHz, QPSK)	X	25.82	103.40	31.56	6.02	65.0	± 9.6 %
		Y	18.70	99.00	30.34		65.0	
		Z	22.82	102.36	31.24		65.0	
10241-CAA	LTE-TDD (SC-FDMA, 50% RB, 1.4 MHz, 16-QAM)	X	14.17	87.13	27.74	6.98	65.0	± 9.6 %
		Y	11.90	84.38	26.55		65.0	
		Z	12.90	86.01	27.18		65.0	
10242-CAA	LTE-TDD (SC-FDMA, 50% RB, 1.4 MHz, 64-QAM)	X	13.75	86.43	27.41	6.98	65.0	± 9.6 %
		Y	10.97	82.54	25.74		65.0	
		Z	11.92	84.22	26.40		65.0	
10243-CAA	LTE-TDD (SC-FDMA, 50% RB, 1.4 MHz, QPSK)	X	12.14	85.96	28.11	6.98	65.0	± 9.6 %
		Y	9.29	80.75	25.83		65.0	
		Z	10.12	82.70	26.67		65.0	
10244-CAC	LTE-TDD (SC-FDMA, 50% RB, 3 MHz, 16-QAM)	X	10.83	81.28	22.12	3.98	65.0	± 9.6 %
		Y	9.18	79.33	21.05		65.0	
		Z	9.58	79.73	21.13		65.0	
10245-CAC	LTE-TDD (SC-FDMA, 50% RB, 3 MHz, 64-QAM)	X	10.76	80.95	21.96	3.98	65.0	± 9.6 %
		Y	9.12	78.99	20.88		65.0	
		Z	9.52	79.41	20.96		65.0	
10246-CAC	LTE-TDD (SC-FDMA, 50% RB, 3 MHz, QPSK)	X	9.94	82.24	22.11	3.98	65.0	± 9.6 %
		Y	8.01	79.62	20.88		65.0	
		Z	8.73	80.80	21.30		65.0	
10247-CAE	LTE-TDD (SC-FDMA, 50% RB, 5 MHz, 16-QAM)	X	8.85	78.39	21.18	3.98	65.0	± 9.6 %
		Y	7.43	76.23	20.06		65.0	
		Z	7.90	77.13	20.43		65.0	
10248-CAE	LTE-TDD (SC-FDMA, 50% RB, 5 MHz, 64-QAM)	X	8.90	78.06	21.06	3.98	65.0	± 9.6 %
		Y	7.49	75.93	19.93		65.0	
		Z	7.96	76.84	20.31		65.0	
10249-CAE	LTE-TDD (SC-FDMA, 50% RB, 5 MHz, QPSK)	X	10.29	82.74	22.67	3.98	65.0	± 9.6 %
		Y	8.60	80.75	21.80		65.0	
		Z	9.32	81.88	22.19		65.0	
10250-CAE	LTE-TDD (SC-FDMA, 50% RB, 10 MHz, 16-QAM)	X	9.43	79.37	22.43	3.98	65.0	± 9.6 %
		Y	8.15	77.66	21.69		65.0	
		Z	8.63	78.56	22.01		65.0	
10251-CAE	LTE-TDD (SC-FDMA, 50% RB, 10 MHz, 64-QAM)	X	9.08	77.69	21.56	3.98	65.0	± 9.6 %
		Y	7.89	76.03	20.77		65.0	
		Z	8.34	76.93	21.13		65.0	
10252-CAE	LTE-TDD (SC-FDMA, 50% RB, 10 MHz, QPSK)	X	10.08	81.60	22.62	3.98	65.0	± 9.6 %
		Y	8.72	80.20	22.10		65.0	
		Z	9.33	81.16	22.40		65.0	
10253-CAE	LTE-TDD (SC-FDMA, 50% RB, 15 MHz, 16-QAM)	X	9.02	76.99	21.46	3.98	65.0	± 9.6 %
		Y	7.89	75.34	20.71		65.0	
		Z	8.31	76.21	21.06		65.0	
10254-CAE	LTE-TDD (SC-FDMA, 50% RB, 15 MHz, 64-QAM)	X	9.34	77.53	21.95	3.98	65.0	± 9.6 %
		Y	8.23	76.00	21.27		65.0	
		Z	8.65	76.82	21.59		65.0	

ES3DV3- SN-3076

July 26, 2018

10255-CAE	LTE-TDD (SC-FDMA, 50% RB, 15 MHz, QPSK)	X	9.45	79.15	21.83	3.98	65.0	± 9.6 %
		Y	8.30	77.85	21.36		65.0	
		Z	8.78	78.67	21.63		65.0	
10256-CAA	LTE-TDD (SC-FDMA, 100% RB, 1.4 MHz, 16-QAM)	X	10.42	80.50	21.27	3.98	65.0	± 9.6 %
		Y	8.51	77.93	19.85		65.0	
		Z	8.90	78.34	19.94		65.0	
10257-CAA	LTE-TDD (SC-FDMA, 100% RB, 1.4 MHz, 64-QAM)	X	10.37	80.09	21.06	3.98	65.0	± 9.6 %
		Y	8.43	77.45	19.59		65.0	
		Z	8.83	77.89	19.70		65.0	
10258-CAA	LTE-TDD (SC-FDMA, 100% RB, 1.4 MHz, QPSK)	X	9.58	81.49	21.48	3.98	65.0	± 9.6 %
		Y	7.31	77.96	19.76		65.0	
		Z	8.00	79.20	20.24		65.0	
10259-CAC	LTE-TDD (SC-FDMA, 100% RB, 3 MHz, 16-QAM)	X	9.07	78.66	21.59	3.98	65.0	± 9.6 %
		Y	7.71	76.71	20.62		65.0	
		Z	8.19	77.61	20.97		65.0	
10260-CAC	LTE-TDD (SC-FDMA, 100% RB, 3 MHz, 64-QAM)	X	9.12	78.49	21.55	3.98	65.0	± 9.6 %
		Y	7.77	76.57	20.59		65.0	
		Z	8.24	77.45	20.93		65.0	
10261-CAC	LTE-TDD (SC-FDMA, 100% RB, 3 MHz, QPSK)	X	10.00	81.98	22.59	3.98	65.0	± 9.6 %
		Y	8.43	80.12	21.81		65.0	
		Z	9.10	81.22	22.18		65.0	
10262-CAE	LTE-TDD (SC-FDMA, 100% RB, 5 MHz, 16-QAM)	X	9.43	79.35	22.41	3.98	65.0	± 9.6 %
		Y	8.15	77.63	21.66		65.0	
		Z	8.63	78.53	21.99		65.0	
10263-CAE	LTE-TDD (SC-FDMA, 100% RB, 5 MHz, 64-QAM)	X	9.08	77.71	21.57	3.98	65.0	± 9.6 %
		Y	7.88	76.03	20.78		65.0	
		Z	8.34	76.93	21.14		65.0	
10264-CAE	LTE-TDD (SC-FDMA, 100% RB, 5 MHz, QPSK)	X	10.04	81.52	22.57	3.98	65.0	± 9.6 %
		Y	8.68	80.09	22.04		65.0	
		Z	9.29	81.07	22.35		65.0	
10265-CAE	LTE-TDD (SC-FDMA, 100% RB, 10 MHz, 16-QAM)	X	9.22	77.46	21.56	3.98	65.0	± 9.6 %
		Y	8.07	75.84	20.87		65.0	
		Z	8.51	76.73	21.22		65.0	
10266-CAE	LTE-TDD (SC-FDMA, 100% RB, 10 MHz, 64-QAM)	X	9.51	77.96	22.07	3.98	65.0	± 9.6 %
		Y	8.40	76.48	21.46		65.0	
		Z	8.82	77.30	21.77		65.0	
10267-CAE	LTE-TDD (SC-FDMA, 100% RB, 10 MHz, QPSK)	X	9.60	79.21	21.61	3.98	65.0	± 9.6 %
		Y	8.51	78.09	21.22		65.0	
		Z	8.97	78.84	21.45		65.0	
10268-CAE	LTE-TDD (SC-FDMA, 100% RB, 15 MHz, 16-QAM)	X	9.60	76.90	21.63	3.98	65.0	± 9.6 %
		Y	8.59	75.57	21.09		65.0	
		Z	8.97	76.30	21.37		65.0	
10269-CAE	LTE-TDD (SC-FDMA, 100% RB, 15 MHz, 64-QAM)	X	9.53	76.58	21.59	3.98	65.0	± 9.6 %
		Y	8.54	75.23	21.03		65.0	
		Z	8.90	75.97	21.31		65.0	
10270-CAE	LTE-TDD (SC-FDMA, 100% RB, 15 MHz, QPSK)	X	9.35	77.33	21.00	3.98	65.0	± 9.6 %
		Y	8.40	76.30	20.65		65.0	
		Z	8.77	76.91	20.83		65.0	

ES3DV3- SN:3076

July 26, 2018

10274-CAB	UMTS-FDD (HSUPA, Subtest 5, 3GPP Rel8.10)	X	2.74	66.79	15.84	0.00	150.0	± 9.6 %
		Y	2.59	65.78	14.93		150.0	
		Z	2.63	66.05	15.13		150.0	
10275-CAB	UMTS-FDD (HSUPA, Subtest 5, 3GPP Rel8.4)	X	1.89	70.13	16.96	0.00	150.0	± 9.6 %
		Y	1.56	66.71	14.72		150.0	
		Z	1.63	67.40	15.18		150.0	
10277-CAA	PHS (QPSK)	X	7.49	72.57	16.65	9.03	50.0	± 9.6 %
		Y	6.43	70.97	15.57		50.0	
		Z	6.57	71.17	15.54		50.0	
10278-CAA	PHS (QPSK, BW 884MHz, Rolloff 0.5)	X	10.57	80.67	21.94	9.03	50.0	± 9.6 %
		Y	8.93	78.42	20.80		50.0	
		Z	9.47	79.42	21.10		50.0	
10279-CAA	PHS (QPSK, BW 884MHz, Rolloff 0.38)	X	10.77	80.90	22.03	9.03	50.0	± 9.6 %
		Y	9.06	78.61	20.88		50.0	
		Z	9.65	79.64	21.20		50.0	
10290-AAB	CDMA2000, RC1, SO55, Full Rate	X	2.05	72.30	16.99	0.00	150.0	± 9.6 %
		Y	1.45	67.21	13.68		150.0	
		Z	1.55	68.14	14.34		150.0	
10291-AAB	CDMA2000, RC3, SO55, Full Rate	X	1.22	70.30	16.05	0.00	150.0	± 9.6 %
		Y	0.82	64.51	12.05		150.0	
		Z	0.89	65.39	12.77		150.0	
10292-AAB	CDMA2000, RC3, SO32, Full Rate	X	1.60	75.63	18.81	0.00	150.0	± 9.6 %
		Y	0.92	66.78	13.59		150.0	
		Z	1.01	68.06	14.48		150.0	
10293-AAB	CDMA2000, RC3, SO3, Full Rate	X	2.25	81.24	21.49	0.00	150.0	± 9.6 %
		Y	1.14	69.80	15.48		150.0	
		Z	1.26	71.30	16.43		150.0	
10295-AAB	CDMA2000, RC1, SO3, 1/8th Rate 25 fr.	X	10.97	82.56	24.20	9.03	50.0	± 9.6 %
		Y	9.82	80.92	23.30		50.0	
		Z	10.33	82.09	23.78		50.0	
10297-AAD	LTE-FDD (SC-FDMA, 50% RB, 20 MHz, QPSK)	X	3.23	71.54	17.43	0.00	150.0	± 9.6 %
		Y	2.78	68.97	15.96		150.0	
		Z	2.87	69.50	16.25		150.0	
10298-AAD	LTE-FDD (SC-FDMA, 50% RB, 3 MHz, QPSK)	X	2.13	70.69	16.73	0.00	150.0	± 9.6 %
		Y	1.65	66.96	14.13		150.0	
		Z	1.74	67.67	14.65		150.0	
10299-AAD	LTE-FDD (SC-FDMA, 50% RB, 3 MHz, 16-QAM)	X	4.48	76.39	19.13	0.00	150.0	± 9.6 %
		Y	3.49	72.60	16.79		150.0	
		Z	3.55	72.64	16.82		150.0	
10300-AAD	LTE-FDD (SC-FDMA, 50% RB, 3 MHz, 64-QAM)	X	3.52	71.59	16.43	0.00	150.0	± 9.6 %
		Y	2.73	68.13	14.07		150.0	
		Z	2.85	68.55	14.32		150.0	
10301-AAA	IEEE 802.16e WIMAX (29:18, 5ms, 10MHz, QPSK, PUSC)	X	6.46	69.98	19.94	4.17	80.0	± 9.6 %
		Y	5.96	68.39	18.82		80.0	
		Z	6.03	68.69	19.06		80.0	
10302-AAA	IEEE 802.16e WIMAX (29:18, 5ms, 10MHz, QPSK, PUSC, 3 CTRL symbols)	X	6.96	70.71	20.76	4.96	80.0	± 9.6 %
		Y	6.49	69.16	19.65		80.0	
		Z	6.64	69.89	20.15		80.0	

ES3DV3- SN:3076

July 26, 2018

10303-AAA	IEEE 802.16e WiMAX (31:15, 5ms, 10MHz, 64QAM, PUSC)	X	6.95	71.26	21.07	4.96	80.0	± 9.6 %
		Y	6.39	69.39	19.77		80.0	
		Z	6.57	70.24	20.35		80.0	
10304-AAA	IEEE 802.16e WiMAX (29:18, 5ms, 10MHz, 64QAM, PUSC)	X	6.39	69.94	19.92	4.17	80.0	± 9.6 %
		Y	5.93	68.42	18.83		80.0	
		Z	6.07	69.09	19.29		80.0	
10305-AAA	IEEE 802.16e WiMAX (31:15, 10ms, 10MHz, 64QAM, PUSC, 15 symbols)	X	11.13	84.86	27.64	6.02	50.0	± 9.6 %
		Y	12.22	87.96	28.58		50.0	
		Z	9.20	80.56	25.46		50.0	
10306-AAA	IEEE 802.16e WiMAX (29:18, 10ms, 10MHz, 64QAM, PUSC, 18 symbols)	X	8.31	76.80	24.47	6.02	50.0	± 9.6 %
		Y	7.10	72.89	22.06		50.0	
		Z	7.53	74.67	23.17		50.0	
10307-AAA	IEEE 802.16e WiMAX (29:18, 10ms, 10MHz, QPSK, PUSC, 18 symbols)	X	8.77	78.27	24.87	6.02	50.0	± 9.6 %
		Y	7.27	73.71	22.23		50.0	
		Z	7.81	75.79	23.45		50.0	
10308-AAA	IEEE 802.16e WiMAX (29:18, 10ms, 10MHz, 16QAM, PUSC)	X	9.01	79.13	25.25	6.02	50.0	± 9.6 %
		Y	9.09	80.42	25.64		50.0	
		Z	7.95	76.42	23.73		50.0	
10309-AAA	IEEE 802.16e WiMAX (29:18, 10ms, 10MHz, 16QAM, AMC 2x3, 18 symbols)	X	8.45	77.06	24.59	6.02	50.0	± 9.6 %
		Y	7.23	73.21	22.23		50.0	
		Z	7.69	75.04	23.35		50.0	
10310-AAA	IEEE 802.16e WiMAX (29:18, 10ms, 10MHz, QPSK, AMC 2x3, 18 symbols)	X	8.44	77.28	24.56	6.02	50.0	± 9.6 %
		Y	7.14	73.15	22.08		50.0	
		Z	7.61	75.04	23.22		50.0	
10311-AAD	LTE-FDD (SC-FDMA, 100% RB, 15 MHz, QPSK)	X	3.60	70.76	17.04	0.00	150.0	± 9.6 %
		Y	3.12	68.32	15.67		150.0	
		Z	3.21	68.83	15.94		150.0	
10313-AAA	IDEN 1:3	X	8.03	77.05	18.42	6.99	70.0	± 9.6 %
		Y	6.51	75.48	17.84		70.0	
		Z	7.11	76.37	18.07		70.0	
10314-AAA	IDEN 1:6	X	9.86	81.46	22.21	10.00	30.0	± 9.6 %
		Y	7.37	78.23	21.16		30.0	
		Z	8.31	80.00	21.70		30.0	
10315-AAB	IEEE 802.11b WiFi 2.4 GHz (DSSS, 1 Mbps, 96pc duty cycle)	X	1.25	66.07	16.65	0.17	150.0	± 9.6 %
		Y	1.11	63.75	14.78		150.0	
		Z	1.15	64.28	15.16		150.0	
10316-AAB	IEEE 802.11g WiFi 2.4 GHz (ERP-OFDM, 6 Mbps, 96pc duty cycle)	X	4.91	67.11	16.64	0.17	150.0	± 9.6 %
		Y	4.77	66.70	16.28		150.0	
		Z	4.80	66.83	16.35		150.0	
10317-AAC	IEEE 802.11a WiFi 5 GHz (OFDM, 6 Mbps, 96pc duty cycle)	X	4.91	67.11	16.64	0.17	150.0	± 9.6 %
		Y	4.77	66.70	16.28		150.0	
		Z	4.80	66.83	16.35		150.0	
10400-AAD	IEEE 802.11ac WiFi (20MHz, 64-QAM, 99pc duty cycle)	X	5.04	67.35	16.54	0.00	150.0	± 9.6 %
		Y	4.87	66.91	16.17		150.0	
		Z	4.90	67.05	16.24		150.0	
10401-AAD	IEEE 802.11ac WiFi (40MHz, 64-QAM, 99pc duty cycle)	X	5.62	67.38	16.58	0.00	150.0	± 9.6 %
		Y	5.49	67.04	16.29		150.0	
		Z	5.51	67.12	16.33		150.0	

ES3DV3- SN:3076

July 26, 2018

10402-AAD	IEEE 802.11ac WiFi (80MHz, 64-QAM, 99pc duty cycle)	X	5.93	67.99	16.71	0.00	150.0	± 9.6 %
		Y	5.79	67.58	16.40		150.0	
		Z	5.82	67.69	16.45		150.0	
10403-AAB	CDMA2000 (1xEV-DO, Rev. 0)	X	2.05	72.30	16.99	0.00	115.0	± 9.6 %
		Y	1.45	67.21	13.68		115.0	
		Z	1.55	68.14	14.34		115.0	
10404-AAB	CDMA2000 (1xEV-DO, Rev. A)	X	2.05	72.30	16.99	0.00	115.0	± 9.6 %
		Y	1.45	67.21	13.68		115.0	
		Z	1.55	68.14	14.34		115.0	
10406-AAB	CDMA2000, RC3, SO32, SCH0, Full Rate	X	32.57	109.30	29.68	0.00	100.0	± 9.6 %
		Y	14.12	95.69	25.24		100.0	
		Z	13.06	93.72	24.51		100.0	
10410-AAE	LTE-TDD (SC-FDMA, 1 RB, 10 MHz, QPSK, UL Subframe=2,3,4,7,8,9, Subframe Conf=4)	X	100.00	119.59	31.23	3.23	80.0	± 9.6 %
		Y	90.23	119.10	30.90		80.0	
		Z	73.63	114.99	29.70		80.0	
10415-AAA	IEEE 802.11b WiFi 2.4 GHz (DSSS, 1 Mbps, 99pc duty cycle)	X	1.03	63.87	15.50	0.00	150.0	± 9.6 %
		Y	0.96	62.27	13.90		150.0	
		Z	0.99	62.66	14.24		150.0	
10416-AAA	IEEE 802.11g WiFi 2.4 GHz (ERP-OFDM, 6 Mbps, 99pc duty cycle)	X	4.79	66.89	16.45	0.00	150.0	± 9.6 %
		Y	4.65	66.50	16.09		150.0	
		Z	4.68	66.63	16.16		150.0	
10417-AAB	IEEE 802.11ah WiFi 5 GHz (OFDM, 6 Mbps, 99pc duty cycle)	X	4.79	66.89	16.45	0.00	150.0	± 9.6 %
		Y	4.65	66.50	16.09		150.0	
		Z	4.68	66.63	16.16		150.0	
10418-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 6 Mbps, 99pc duty cycle, Long preamble)	X	4.77	67.02	16.45	0.00	150.0	± 9.6 %
		Y	4.63	66.62	16.08		150.0	
		Z	4.66	66.75	16.15		150.0	
10419-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 6 Mbps, 99pc duty cycle, Short preamble)	X	4.80	66.98	16.46	0.00	150.0	± 9.6 %
		Y	4.66	66.59	16.10		150.0	
		Z	4.69	66.72	16.17		150.0	
10422-AAB	IEEE 802.11n (HT Greenfield, 7.2 Mbps, BPSK)	X	4.93	66.99	16.47	0.00	150.0	± 9.6 %
		Y	4.79	66.62	16.13		150.0	
		Z	4.82	66.74	16.19		150.0	
10423-AAB	IEEE 802.11n (HT Greenfield, 43.3 Mbps, 16-QAM)	X	5.17	67.43	16.63	0.00	150.0	± 9.6 %
		Y	5.00	67.01	16.28		150.0	
		Z	5.04	67.14	16.35		150.0	
10424-AAB	IEEE 802.11n (HT Greenfield, 72.2 Mbps, 64-QAM)	X	5.07	67.36	16.59	0.00	150.0	± 9.6 %
		Y	4.91	66.93	16.23		150.0	
		Z	4.94	67.06	16.30		150.0	
10425-AAB	IEEE 802.11n (HT Greenfield, 15 Mbps, BPSK)	X	5.63	67.76	16.75	0.00	150.0	± 9.6 %
		Y	5.49	67.36	16.45		150.0	
		Z	5.51	67.45	16.49		150.0	
10426-AAB	IEEE 802.11n (HT Greenfield, 90 Mbps, 16-QAM)	X	5.65	67.78	16.76	0.00	150.0	± 9.6 %
		Y	5.51	67.40	16.46		150.0	
		Z	5.53	67.49	16.50		150.0	

ES3DV3- SN:3076

July 26, 2018

10427-AAB	IEEE 802.11n (HT Greenfield, 150 Mbps, 64-QAM)	X	5.68	67.84	16.78	0.00	150.0	± 9.6 %
		Y	5.53	67.40	16.46		150.0	
		Z	5.55	67.50	16.50		150.0	
10430-AAC	LTE-FDD (OFDMA, 5 MHz, E-TM 3.1)	X	4.47	69.87	18.15	0.00	150.0	± 9.6 %
		Y	4.27	69.57	17.72		150.0	
		Z	4.28	69.46	17.67		150.0	
10431-AAC	LTE-FDD (OFDMA, 10 MHz, E-TM 3.1)	X	4.58	67.49	16.59	0.00	150.0	± 9.6 %
		Y	4.38	66.98	16.12		150.0	
		Z	4.43	67.13	16.21		150.0	
10432-AAC	LTE-FDD (OFDMA, 15 MHz, E-TM 3.1)	X	4.86	67.41	16.59	0.00	150.0	± 9.6 %
		Y	4.68	66.94	16.18		150.0	
		Z	4.72	67.08	16.26		150.0	
10433-AAC	LTE-FDD (OFDMA, 20 MHz, E-TM 3.1)	X	5.09	67.43	16.63	0.00	150.0	± 9.6 %
		Y	4.92	66.98	16.26		150.0	
		Z	4.96	67.12	16.33		150.0	
10434-AAA	W-CDMA (BS Test Model 1, 64 DPCH)	X	4.54	70.42	18.14	0.00	150.0	± 9.6 %
		Y	4.33	70.14	17.66		150.0	
		Z	4.33	70.01	17.61		150.0	
10435-AAE	LTE-TDD (SC-FDMA, 1 RB, 20 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	100.00	119.47	31.18	3.23	80.0	± 9.6 %
		Y	83.98	117.92	30.59		80.0	
		Z	69.49	114.03	29.43		80.0	
10447-AAC	LTE-FDD (OFDMA, 5 MHz, E-TM 3.1, Clipping 44%)	X	3.92	67.58	16.28	0.00	150.0	± 9.6 %
		Y	3.68	66.87	15.56		150.0	
		Z	3.73	67.06	15.71		150.0	
10448-AAC	LTE-FDD (OFDMA, 10 MHz, E-TM 3.1, Clipping 44%)	X	4.38	67.25	16.45	0.00	150.0	± 9.6 %
		Y	4.20	66.74	15.96		150.0	
		Z	4.24	66.89	16.06		150.0	
10449-AAC	LTE-FDD (OFDMA, 15 MHz, E-TM 3.1, Clipping 44%)	X	4.61	67.22	16.49	0.00	150.0	± 9.6 %
		Y	4.46	66.74	16.06		150.0	
		Z	4.49	66.88	16.14		150.0	
10450-AAC	LTE-FDD (OFDMA, 20 MHz, E-TM 3.1, Clipping 44%)	X	4.78	67.16	16.49	0.00	150.0	± 9.6 %
		Y	4.64	66.71	16.09		150.0	
		Z	4.67	66.85	16.17		150.0	
10451-AAA	W-CDMA (BS Test Model 1, 64 DPCH, Clipping 44%)	X	3.88	67.91	16.13	0.00	150.0	± 9.6 %
		Y	3.60	67.09	15.29		150.0	
		Z	3.66	67.30	15.46		150.0	
10456-AAB	IEEE 802.11ac WiFi (160MHz, 64-QAM, 99pc duty cycle)	X	6.48	68.41	16.93	0.00	150.0	± 9.6 %
		Y	6.35	68.02	16.65		150.0	
		Z	6.37	68.11	16.66		150.0	
10457-AAA	UMTS-FDD (DC-HSDPA)	X	3.91	65.57	16.24	0.00	150.0	± 9.6 %
		Y	3.82	65.14	15.81		150.0	
		Z	3.85	65.28	15.90		150.0	
10458-AAA	CDMA2000 (1xEV-DO, Rev. B, 2 carriers)	X	4.04	69.06	17.49	0.00	150.0	± 9.6 %
		Y	3.91	69.08	17.04		150.0	
		Z	3.92	68.98	17.03		150.0	
10459-AAA	CDMA2000 (1xEV-DO, Rev. B, 3 carriers)	X	5.19	66.69	17.73	0.00	150.0	± 9.6 %
		Y	5.12	67.13	17.73		150.0	
		Z	5.12	66.98	17.64		150.0	

ES3DV3- SN:3076

July 26, 2018

10460-AAA	UMTS-FDD (WCDMA, AMR)	X	1.14	72.75	18.76	0.00	150.0	± 9.6 %
		Y	0.80	65.97	14.46		150.0	
		Z	0.86	67.06	15.22		150.0	
10461-AAA	LTE-TDD (SC-FDMA, 1 RB, 1.4 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	100.00	120.87	31.89	3.29	80.0	± 9.6 %
		Y	100.00	121.92	31.94		80.0	
		Z	100.00	120.69	31.42		80.0	
10462-AAA	LTE-TDD (SC-FDMA, 1 RB, 1.4 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	100.00	110.91	27.12	3.23	80.0	± 9.6 %
		Y	72.92	106.78	25.65		80.0	
		Z	38.73	98.41	23.48		80.0	
10463-AAA	LTE-TDD (SC-FDMA, 1 RB, 1.4 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	100.00	109.00	26.18	3.23	80.0	± 9.6 %
		Y	26.58	93.05	21.71		80.0	
		Z	18.76	88.43	20.34		80.0	
10464-AAB	LTE-TDD (SC-FDMA, 1 RB, 3 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	100.00	119.54	31.14	3.23	80.0	± 9.6 %
		Y	100.00	120.34	31.07		80.0	
		Z	100.00	119.15	30.56		80.0	
10465-AAB	LTE-TDD (SC-FDMA, 1 RB, 3 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	100.00	110.60	26.95	3.23	80.0	± 9.6 %
		Y	42.02	99.86	23.89		80.0	
		Z	27.42	94.07	22.27		80.0	
10466-AAB	LTE-TDD (SC-FDMA, 1 RB, 3 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	86.77	106.98	25.63	3.23	80.0	± 9.6 %
		Y	18.06	88.36	20.35		80.0	
		Z	14.47	85.26	19.37		80.0	
10467-AAD	LTE-TDD (SC-FDMA, 1 RB, 5 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	100.00	119.68	31.20	3.23	80.0	± 9.6 %
		Y	100.00	120.51	31.14		80.0	
		Z	100.00	119.30	30.63		80.0	
10468-AAD	LTE-TDD (SC-FDMA, 1 RB, 5 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	100.00	110.70	27.00	3.23	80.0	± 9.6 %
		Y	47.82	101.50	24.32		80.0	
		Z	29.82	95.15	22.57		80.0	
10469-AAD	LTE-TDD (SC-FDMA, 1 RB, 5 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	90.40	107.48	25.74	3.23	80.0	± 9.6 %
		Y	18.38	88.58	20.41		80.0	
		Z	14.65	85.42	19.41		80.0	
10470-AAD	LTE-TDD (SC-FDMA, 1 RB, 10 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	100.00	119.70	31.21	3.23	80.0	± 9.6 %
		Y	100.00	120.53	31.15		80.0	
		Z	100.00	119.32	30.64		80.0	
10471-AAD	LTE-TDD (SC-FDMA, 1 RB, 10 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	100.00	110.67	26.98	3.23	80.0	± 9.6 %
		Y	48.02	101.52	24.31		80.0	
		Z	29.90	95.16	22.57		80.0	
10472-AAD	LTE-TDD (SC-FDMA, 1 RB, 10 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	91.72	107.63	25.77	3.23	80.0	± 9.6 %
		Y	18.43	88.59	20.41		80.0	
		Z	14.68	85.43	19.40		80.0	
10473-AAD	LTE-TDD (SC-FDMA, 1 RB, 15 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	100.00	119.68	31.20	3.23	80.0	± 9.6 %
		Y	100.00	120.51	31.14		80.0	
		Z	100.00	119.30	30.62		80.0	
10474-AAD	LTE-TDD (SC-FDMA, 1 RB, 15 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	100.00	110.68	26.98	3.23	80.0	± 9.6 %
		Y	47.38	101.37	24.27		80.0	
		Z	29.61	95.05	22.54		80.0	
10475-AAD	LTE-TDD (SC-FDMA, 1 RB, 15 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	90.31	107.45	25.73	3.23	80.0	± 9.6 %
		Y	18.22	88.47	20.37		80.0	
		Z	14.56	85.34	19.38		80.0	

ES3DV3- SN:3076

July 26, 2018

10477-AAE	LTE-TDD (SC-FDMA, 1 RB, 20 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	100.00	110.57	26.93	3.23	80.0	± 9.6 %
		Y	43.44	100.23	23.96		80.0	
		Z	28.02	94.31	22.32		80.0	
10478-AAE	LTE-TDD (SC-FDMA, 1 RB, 20 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	88.74	107.21	25.66	3.23	80.0	± 9.6 %
		Y	18.02	86.32	20.32		80.0	
		Z	14.45	85.24	19.34		80.0	
10479-AAA	LTE-TDD (SC-FDMA, 50% RB, 1.4 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	14.05	92.08	26.05	3.23	80.0	± 9.6 %
		Y	10.06	87.22	24.09		80.0	
		Z	9.68	86.17	23.66		80.0	
10480-AAA	LTE-TDD (SC-FDMA, 50% RB, 1.4 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	14.07	87.63	23.41	3.23	80.0	± 9.6 %
		Y	10.81	84.09	21.75		80.0	
		Z	10.21	82.87	21.28		80.0	
10481-AAA	LTE-TDD (SC-FDMA, 50% RB, 1.4 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	13.28	86.17	22.69	3.23	80.0	± 9.6 %
		Y	9.95	82.31	20.89		80.0	
		Z	9.47	81.25	20.47		80.0	
10482-AAB	LTE-TDD (SC-FDMA, 50% RB, 3 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	7.85	81.81	21.32	2.23	80.0	± 9.6 %
		Y	4.70	74.77	18.32		80.0	
		Z	5.29	76.37	18.97		80.0	
10483-AAB	LTE-TDD (SC-FDMA, 50% RB, 3 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	10.51	83.65	22.26	2.23	80.0	± 9.6 %
		Y	7.91	79.70	20.38		80.0	
		Z	7.69	78.97	20.07		80.0	
10484-AAB	LTE-TDD (SC-FDMA, 50% RB, 3 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	10.03	82.70	21.95	2.23	80.0	± 9.6 %
		Y	7.53	78.76	20.05		80.0	
		Z	7.39	78.17	19.79		80.0	
10485-AAD	LTE-TDD (SC-FDMA, 50% RB, 5 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	8.02	82.19	21.87	2.23	80.0	± 9.6 %
		Y	5.00	75.62	19.20		80.0	
		Z	5.60	77.18	19.80		80.0	
10486-AAD	LTE-TDD (SC-FDMA, 50% RB, 5 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	5.92	75.00	19.19	2.23	80.0	± 9.6 %
		Y	4.50	71.39	17.35		80.0	
		Z	4.81	72.27	17.75		80.0	
10487-AAD	LTE-TDD (SC-FDMA, 50% RB, 5 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	5.88	74.55	19.03	2.23	80.0	± 9.6 %
		Y	4.51	71.09	17.24		80.0	
		Z	4.81	71.93	17.62		80.0	
10488-AAD	LTE-TDD (SC-FDMA, 50% RB, 10 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	7.56	79.93	21.34	2.23	80.0	± 9.6 %
		Y	5.23	74.82	19.29		80.0	
		Z	5.73	76.13	19.78		80.0	
10489-AAD	LTE-TDD (SC-FDMA, 50% RB, 10 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	5.85	73.86	19.37	2.23	80.0	± 9.6 %
		Y	4.71	70.94	17.98		80.0	
		Z	4.97	71.73	18.31		80.0	
10490-AAD	LTE-TDD (SC-FDMA, 50% RB, 10 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	5.85	73.36	19.22	2.23	80.0	± 9.6 %
		Y	4.79	70.70	17.92		80.0	
		Z	5.04	71.43	18.23		80.0	
10491-AAD	LTE-TDD (SC-FDMA, 50% RB, 15 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	6.86	76.76	20.26	2.23	80.0	± 9.6 %
		Y	5.24	73.06	18.71		80.0	
		Z	5.62	74.06	19.10		80.0	
10492-AAD	LTE-TDD (SC-FDMA, 50% RB, 15 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	5.94	72.49	19.01	2.23	80.0	± 9.6 %
		Y	5.00	70.16	17.89		80.0	
		Z	5.23	70.83	18.17		80.0	

ES3DV3- SN:3076

July 26, 2018

10493-AAD	LTE-TDD (SC-FDMA, 50% RB, 15 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	5.97	72.20	18.93	2.23	80.0	± 9.6 %
		Y	5.06	70.00	17.85		80.0	
		Z	5.29	70.64	18.12		80.0	
10494-AAE	LTE-TDD (SC-FDMA, 50% RB, 20 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	7.84	78.92	20.84	2.23	80.0	± 9.6 %
		Y	5.71	74.54	19.11		80.0	
		Z	6.18	75.67	19.52		80.0	
10495-AAE	LTE-TDD (SC-FDMA, 50% RB, 20 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	6.11	73.22	19.25	2.23	80.0	± 9.6 %
		Y	5.06	70.66	18.08		80.0	
		Z	5.33	71.38	18.37		80.0	
10496-AAE	LTE-TDD (SC-FDMA, 50% RB, 20 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	6.09	72.66	19.08	2.23	80.0	± 9.6 %
		Y	5.13	70.32	17.99		80.0	
		Z	5.36	70.99	18.26		80.0	
10497-AAA	LTE-TDD (SC-FDMA, 100% RB, 1.4 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	6.88	79.99	20.26	2.23	80.0	± 9.6 %
		Y	3.88	72.23	16.75		80.0	
		Z	4.39	73.84	17.47		80.0	
10498-AAA	LTE-TDD (SC-FDMA, 100% RB, 1.4 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	5.24	73.44	17.21	2.23	80.0	± 9.6 %
		Y	3.35	67.80	14.16		80.0	
		Z	3.69	69.00	14.79		80.0	
10499-AAA	LTE-TDD (SC-FDMA, 100% RB, 1.4 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	5.20	73.01	16.94	2.23	80.0	± 9.6 %
		Y	3.32	67.40	13.88		80.0	
		Z	3.66	68.60	14.51		80.0	
10500-AAB	LTE-TDD (SC-FDMA, 100% RB, 3 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	7.45	80.46	21.41	2.23	80.0	± 9.6 %
		Y	4.97	74.86	19.10		80.0	
		Z	5.50	76.26	19.64		80.0	
10501-AAB	LTE-TDD (SC-FDMA, 100% RB, 3 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	5.84	74.32	19.17	2.23	80.0	± 9.6 %
		Y	4.58	71.12	17.56		80.0	
		Z	4.87	71.94	17.92		80.0	
10502-AAB	LTE-TDD (SC-FDMA, 100% RB, 3 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	5.84	73.94	19.01	2.23	80.0	± 9.6 %
		Y	4.63	70.93	17.45		80.0	
		Z	4.90	71.71	17.80		80.0	
10503-AAD	LTE-TDD (SC-FDMA, 100% RB, 5 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	7.46	79.74	21.26	2.23	80.0	± 9.6 %
		Y	5.17	74.65	19.21		80.0	
		Z	5.67	75.96	19.71		80.0	
10504-AAD	LTE-TDD (SC-FDMA, 100% RB, 5 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	5.83	73.79	19.34	2.23	80.0	± 9.6 %
		Y	4.69	70.87	17.94		80.0	
		Z	4.96	71.66	18.27		80.0	
10505-AAD	LTE-TDD (SC-FDMA, 100% RB, 5 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	5.83	73.28	19.17	2.23	80.0	± 9.6 %
		Y	4.77	70.62	17.87		80.0	
		Z	5.02	71.36	18.19		80.0	
10506-AAD	LTE-TDD (SC-FDMA, 100% RB, 10 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	7.78	78.78	20.78	2.23	80.0	± 9.6 %
		Y	5.67	74.41	19.05		80.0	
		Z	6.14	75.55	19.46		80.0	
10507-AAD	LTE-TDD (SC-FDMA, 100% RB, 10 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	6.09	73.16	19.22	2.23	80.0	± 9.6 %
		Y	5.06	70.61	18.04		80.0	
		Z	5.31	71.32	18.34		80.0	

ES3DV3- SN:3076

July 26, 2018

10508-AAD	LTE-TDD (SC-FDMA, 100% RB, 10 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	6.07	72.60	19.05	2.23	80.0	± 9.6 %
		Y	5.12	70.27	17.95		80.0	
		Z	5.35	70.94	18.23		80.0	
10509-AAD	LTE-TDD (SC-FDMA, 100% RB, 15 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	7.28	75.99	19.77	2.23	80.0	± 9.6 %
		Y	5.79	72.84	18.47		80.0	
		Z	6.14	73.69	18.78		80.0	
10510-AAD	LTE-TDD (SC-FDMA, 100% RB, 15 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	6.43	72.37	18.95	2.23	80.0	± 9.6 %
		Y	5.52	70.24	17.97		80.0	
		Z	5.75	70.87	18.22		80.0	
10511-AAD	LTE-TDD (SC-FDMA, 100% RB, 15 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	6.40	71.93	18.84	2.23	80.0	± 9.6 %
		Y	5.54	69.94	17.91		80.0	
		Z	5.76	70.54	18.15		80.0	
10512-AAE	LTE-TDD (SC-FDMA, 100% RB, 20 MHz, QPSK, UL Subframe=2,3,4,7,8,9)	X	8.17	78.44	20.51	2.23	80.0	± 9.6 %
		Y	6.14	74.43	18.93		80.0	
		Z	6.60	75.48	19.31		80.0	
10513-AAE	LTE-TDD (SC-FDMA, 100% RB, 20 MHz, 16-QAM, UL Subframe=2,3,4,7,8,9)	X	6.46	73.08	19.20	2.23	80.0	± 9.6 %
		Y	5.44	70.66	18.11		80.0	
		Z	5.69	71.35	18.39		80.0	
10514-AAE	LTE-TDD (SC-FDMA, 100% RB, 20 MHz, 64-QAM, UL Subframe=2,3,4,7,8,9)	X	6.33	72.39	19.00	2.23	80.0	± 9.6 %
		Y	5.41	70.18	17.99		80.0	
		Z	5.64	70.82	18.25		80.0	
10515-AAA	IEEE 802.11b WiFi 2.4 GHz (DSSS, 2 Mbps, 99pc duty cycle)	X	1.00	64.16	15.64	0.00	150.0	± 9.6 %
		Y	0.92	62.40	13.91		150.0	
		Z	0.95	62.82	14.27		150.0	
10516-AAA	IEEE 802.11b WiFi 2.4 GHz (DSSS, 5.5 Mbps, 99pc duty cycle)	X	1.25	84.84	23.84	0.00	150.0	± 9.6 %
		Y	0.48	66.58	14.30		150.0	
		Z	0.54	68.43	15.58		150.0	
10517-AAA	IEEE 802.11b WiFi 2.4 GHz (DSSS, 11 Mbps, 99pc duty cycle)	X	0.91	67.48	17.00	0.00	150.0	± 9.6 %
		Y	0.76	63.84	14.12		150.0	
		Z	0.80	64.54	14.68		150.0	
10518-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 9 Mbps, 99pc duty cycle)	X	4.79	66.99	16.45	0.00	150.0	± 9.6 %
		Y	4.65	66.57	16.07		150.0	
		Z	4.68	66.70	16.15		150.0	
10519-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 12 Mbps, 99pc duty cycle)	X	5.05	67.33	16.60	0.00	150.0	± 9.6 %
		Y	4.88	66.89	16.23		150.0	
		Z	4.91	67.02	16.30		150.0	
10520-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 18 Mbps, 99pc duty cycle)	X	4.89	67.32	16.53	0.00	150.0	± 9.6 %
		Y	4.72	66.85	16.14		150.0	
		Z	4.76	66.99	16.22		150.0	
10521-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 24 Mbps, 99pc duty cycle)	X	4.82	67.34	16.52	0.00	150.0	± 9.6 %
		Y	4.65	66.85	16.12		150.0	
		Z	4.69	66.99	16.20		150.0	
10522-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 36 Mbps, 99pc duty cycle)	X	4.84	67.19	16.50	0.00	150.0	± 9.6 %
		Y	4.69	66.80	16.15		150.0	
		Z	4.72	66.93	16.21		150.0	

ES3DV3- SN:3076

July 26, 2018

10523-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 48 Mbps, 99pc duty cycle)	X	4.72	67.17	16.39	0.00	150.0	± 9.6 %
		Y	4.56	66.70	16.00		150.0	
		Z	4.60	66.84	16.07		150.0	
10524-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 54 Mbps, 99pc duty cycle)	X	4.81	67.19	16.51	0.00	150.0	± 9.6 %
		Y	4.65	66.78	16.14		150.0	
		Z	4.68	66.91	16.21		150.0	
10525-AAB	IEEE 802.11ac WiFi (20MHz, MCS0, 99pc duty cycle)	X	4.74	66.22	16.10	0.00	150.0	± 9.6 %
		Y	4.60	65.79	15.72		150.0	
		Z	4.63	65.93	15.79		150.0	
10526-AAB	IEEE 802.11ac WiFi (20MHz, MCS1, 99pc duty cycle)	X	4.97	66.65	16.24	0.00	150.0	± 9.6 %
		Y	4.80	66.20	15.87		150.0	
		Z	4.84	66.34	15.94		150.0	
10527-AAB	IEEE 802.11ac WiFi (20MHz, MCS2, 99pc duty cycle)	X	4.89	66.66	16.21	0.00	150.0	± 9.6 %
		Y	4.71	66.17	15.82		150.0	
		Z	4.75	66.31	15.89		150.0	
10528-AAB	IEEE 802.11ac WiFi (20MHz, MCS3, 99pc duty cycle)	X	4.91	66.68	16.25	0.00	150.0	± 9.6 %
		Y	4.73	66.19	15.85		150.0	
		Z	4.77	66.34	15.93		150.0	
10529-AAB	IEEE 802.11ac WiFi (20MHz, MCS4, 99pc duty cycle)	X	4.91	66.68	16.25	0.00	150.0	± 9.6 %
		Y	4.73	66.19	15.85		150.0	
		Z	4.77	66.34	15.93		150.0	
10531-AAB	IEEE 802.11ac WiFi (20MHz, MCS6, 99pc duty cycle)	X	4.94	66.85	16.28	0.00	150.0	± 9.6 %
		Y	4.75	66.34	15.88		150.0	
		Z	4.79	66.49	15.95		150.0	
10532-AAB	IEEE 802.11ac WiFi (20MHz, MCS7, 99pc duty cycle)	X	4.78	66.78	16.26	0.00	150.0	± 9.6 %
		Y	4.59	66.20	15.82		150.0	
		Z	4.63	66.36	15.90		150.0	
10533-AAB	IEEE 802.11ac WiFi (20MHz, MCS8, 99pc duty cycle)	X	4.92	66.68	16.21	0.00	150.0	± 9.6 %
		Y	4.75	66.20	15.83		150.0	
		Z	4.78	66.35	15.90		150.0	
10534-AAB	IEEE 802.11ac WiFi (40MHz, MCS0, 99pc duty cycle)	X	5.41	66.88	16.30	0.00	150.0	± 9.6 %
		Y	5.26	66.41	15.95		150.0	
		Z	5.28	66.54	16.01		150.0	
10535-AAB	IEEE 802.11ac WiFi (40MHz, MCS1, 99pc duty cycle)	X	5.49	67.03	16.35	0.00	150.0	± 9.6 %
		Y	5.33	66.55	16.00		150.0	
		Z	5.36	66.69	16.06		150.0	
10536-AAB	IEEE 802.11ac WiFi (40MHz, MCS2, 99pc duty cycle)	X	5.34	67.01	16.33	0.00	150.0	± 9.6 %
		Y	5.19	66.53	15.97		150.0	
		Z	5.22	66.66	16.03		150.0	
10537-AAB	IEEE 802.11ac WiFi (40MHz, MCS3, 99pc duty cycle)	X	5.41	66.96	16.30	0.00	150.0	± 9.6 %
		Y	5.26	66.51	15.97		150.0	
		Z	5.29	66.64	16.03		150.0	
10538-AAB	IEEE 802.11ac WiFi (40MHz, MCS4, 99pc duty cycle)	X	5.55	67.08	16.40	0.00	150.0	± 9.6 %
		Y	5.38	66.61	16.06		150.0	
		Z	5.41	66.74	16.12		150.0	
10540-AAB	IEEE 802.11ac WiFi (40MHz, MCS6, 99pc duty cycle)	X	5.42	66.98	16.37	0.00	150.0	± 9.6 %
		Y	5.27	66.54	16.04		150.0	
		Z	5.30	66.66	16.09		150.0	

ES3DV3- SN:3076

July 26, 2018

10541-AAB	IEEE 802.11ac WiFi (40MHz, MCS7, 99pc duty cycle)	X	5.43	67.00	16.38	0.00	150.0	± 9.6 %
		Y	5.26	66.46	15.99		150.0	
		Z	5.29	66.61	16.06		150.0	
10542-AAB	IEEE 802.11ac WiFi (40MHz, MCS8, 99pc duty cycle)	X	5.56	66.93	16.36	0.00	150.0	± 9.6 %
		Y	5.41	66.50	16.03		150.0	
		Z	5.44	66.62	16.09		150.0	
10543-AAB	IEEE 802.11ac WiFi (40MHz, MCS9, 99pc duty cycle)	X	5.68	67.01	16.41	0.00	150.0	± 9.6 %
		Y	5.50	66.51	16.05		150.0	
		Z	5.53	66.65	16.11		150.0	
10544-AAB	IEEE 802.11ac WiFi (80MHz, MCS0, 99pc duty cycle)	X	5.65	66.96	16.26	0.00	150.0	± 9.6 %
		Y	5.53	66.53	15.94		150.0	
		Z	5.55	66.65	16.00		150.0	
10545-AAB	IEEE 802.11ac WiFi (80MHz, MCS1, 99pc duty cycle)	X	5.87	67.32	16.37	0.00	150.0	± 9.6 %
		Y	5.75	66.96	16.10		150.0	
		Z	5.77	67.06	16.14		150.0	
10546-AAB	IEEE 802.11ac WiFi (80MHz, MCS2, 99pc duty cycle)	X	5.78	67.30	16.38	0.00	150.0	± 9.6 %
		Y	5.63	66.83	16.05		150.0	
		Z	5.66	66.96	16.11		150.0	
10547-AAB	IEEE 802.11ac WiFi (80MHz, MCS3, 99pc duty cycle)	X	5.88	67.41	16.42	0.00	150.0	± 9.6 %
		Y	5.72	66.90	16.08		150.0	
		Z	5.75	67.03	16.13		150.0	
10548-AAB	IEEE 802.11ac WiFi (80MHz, MCS4, 99pc duty cycle)	X	6.20	68.48	16.93	0.00	150.0	± 9.6 %
		Y	6.10	68.18	16.69		150.0	
		Z	6.08	68.17	16.68		150.0	
10550-AAB	IEEE 802.11ac WiFi (80MHz, MCS6, 99pc duty cycle)	X	5.79	67.22	16.35	0.00	150.0	± 9.6 %
		Y	5.65	66.77	16.03		150.0	
		Z	5.68	66.90	16.08		150.0	
10551-AAB	IEEE 802.11ac WiFi (80MHz, MCS7, 99pc duty cycle)	X	5.82	67.34	16.37	0.00	150.0	± 9.6 %
		Y	5.68	66.90	16.05		150.0	
		Z	5.70	67.02	16.10		150.0	
10552-AAB	IEEE 802.11ac WiFi (80MHz, MCS8, 99pc duty cycle)	X	5.71	67.10	16.27	0.00	150.0	± 9.6 %
		Y	5.57	66.63	15.94		150.0	
		Z	5.60	66.76	16.00		150.0	
10553-AAB	IEEE 802.11ac WiFi (80MHz, MCS9, 99pc duty cycle)	X	5.81	67.12	16.30	0.00	150.0	± 9.6 %
		Y	5.66	66.67	15.99		150.0	
		Z	5.69	66.81	16.04		150.0	
10554-AAC	IEEE 802.11ac WiFi (160MHz, MCS0, 99pc duty cycle)	X	6.05	67.35	16.36	0.00	150.0	± 9.6 %
		Y	5.93	66.93	16.06		150.0	
		Z	5.95	67.05	16.10		150.0	
10555-AAC	IEEE 802.11ac WiFi (160MHz, MCS1, 99pc duty cycle)	X	6.24	67.80	16.54	0.00	150.0	± 9.6 %
		Y	6.09	67.30	16.21		150.0	
		Z	6.12	67.42	16.26		150.0	
10556-AAC	IEEE 802.11ac WiFi (160MHz, MCS2, 99pc duty cycle)	X	6.22	67.70	16.49	0.00	150.0	± 9.6 %
		Y	6.10	67.29	16.20		150.0	
		Z	6.12	67.40	16.24		150.0	
10557-AAC	IEEE 802.11ac WiFi (160MHz, MCS3, 99pc duty cycle)	X	6.23	67.72	16.53	0.00	150.0	± 9.6 %
		Y	6.09	67.27	16.21		150.0	
		Z	6.11	67.40	16.26		150.0	

ES3DV3- SN:3076

July 26, 2018

10558-AAC	IEEE 802.11ac WiFi (160MHz, MCS4, 99pc duty cycle)	X	6.29	67.93	16.64	0.00	150.0	± 9.6 %
		Y	6.16	67.48	16.33		150.0	
		Z	6.18	67.60	16.38		150.0	
10560-AAC	IEEE 802.11ac WiFi (160MHz, MCS6, 99pc duty cycle)	X	6.30	67.80	16.62	0.00	150.0	± 9.6 %
		Y	6.14	67.29	16.27		150.0	
		Z	6.17	67.42	16.33		150.0	
10561-AAC	IEEE 802.11ac WiFi (160MHz, MCS7, 99pc duty cycle)	X	6.20	67.71	16.61	0.00	150.0	± 9.6 %
		Y	6.05	67.24	16.29		150.0	
		Z	6.08	67.37	16.34		150.0	
10562-AAC	IEEE 802.11ac WiFi (160MHz, MCS8, 99pc duty cycle)	X	6.38	68.26	16.89	0.00	150.0	± 9.6 %
		Y	6.24	67.80	16.57		150.0	
		Z	6.25	67.90	16.61		150.0	
10563-AAC	IEEE 802.11ac WiFi (160MHz, MCS9, 99pc duty cycle)	X	6.59	68.41	16.91	0.00	150.0	± 9.6 %
		Y	6.53	68.21	16.72		150.0	
		Z	6.52	68.24	16.73		150.0	
10564-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 9 Mbps, 99pc duty cycle)	X	5.14	67.16	16.65	0.46	150.0	± 9.6 %
		Y	5.00	66.75	16.29		150.0	
		Z	5.03	66.89	16.37		150.0	
10565-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 12 Mbps, 99pc duty cycle)	X	5.43	67.66	16.97	0.46	150.0	± 9.6 %
		Y	5.27	67.25	16.63		150.0	
		Z	5.30	67.37	16.69		150.0	
10566-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 18 Mbps, 99pc duty cycle)	X	5.26	67.56	16.81	0.46	150.0	± 9.6 %
		Y	5.10	67.12	16.45		150.0	
		Z	5.13	67.25	16.52		150.0	
10567-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 24 Mbps, 99pc duty cycle)	X	5.28	67.90	17.11	0.46	150.0	± 9.6 %
		Y	5.12	67.47	16.77		150.0	
		Z	5.15	67.58	16.82		150.0	
10568-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 36 Mbps, 99pc duty cycle)	X	5.17	67.25	16.56	0.46	150.0	± 9.6 %
		Y	5.01	66.85	16.21		150.0	
		Z	5.04	66.99	16.29		150.0	
10569-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 48 Mbps, 99pc duty cycle)	X	5.21	67.87	17.10	0.46	150.0	± 9.6 %
		Y	5.05	67.47	16.77		150.0	
		Z	5.08	67.57	16.82		150.0	
10570-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 54 Mbps, 99pc duty cycle)	X	5.25	67.68	17.04	0.46	150.0	± 9.6 %
		Y	5.10	67.32	16.72		150.0	
		Z	5.13	67.43	16.78		150.0	
10571-AAA	IEEE 802.11b WiFi 2.4 GHz (DSSS, 1 Mbps, 90pc duty cycle)	X	1.53	66.13	17.54	0.46	130.0	± 9.6 %
		Y	1.30	65.13	15.48		130.0	
		Z	1.36	65.83	15.92		130.0	
10572-AAA	IEEE 802.11b WiFi 2.4 GHz (DSSS, 2 Mbps, 90pc duty cycle)	X	1.57	66.96	17.98	0.46	130.0	± 9.6 %
		Y	1.32	65.68	15.79		130.0	
		Z	1.38	66.42	16.25		130.0	
10573-AAA	IEEE 802.11b WiFi 2.4 GHz (DSSS, 5.5 Mbps, 90pc duty cycle)	X	100.00	142.62	37.57	0.46	130.0	± 9.6 %
		Y	2.03	80.49	20.06		130.0	
		Z	3.14	87.00	22.48		130.0	
10574-AAA	IEEE 802.11b WiFi 2.4 GHz (DSSS, 11 Mbps, 90pc duty cycle)	X	2.27	78.89	22.22	0.46	130.0	± 9.6 %
		Y	1.48	70.93	18.18		130.0	
		Z	1.61	72.27	18.87		130.0	

ES3DV3- SN:3076

July 26, 2018

10575-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 6 Mbps, 90pc duty cycle)	X	4.97	67.04	16.76	0.46	130.0	± 9.6 %
		Y	4.83	66.64	16.40		130.0	
		Z	4.86	66.77	16.47		130.0	
10576-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 9 Mbps, 90pc duty cycle)	X	4.99	67.19	16.82	0.46	130.0	± 9.6 %
		Y	4.85	66.79	16.46		130.0	
		Z	4.88	66.91	16.52		130.0	
10577-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 12 Mbps, 90pc duty cycle)	X	5.26	67.55	17.00	0.46	130.0	± 9.6 %
		Y	5.09	67.14	16.65		130.0	
		Z	5.12	67.26	16.71		130.0	
10578-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 18 Mbps, 90pc duty cycle)	X	5.15	67.72	17.08	0.46	130.0	± 9.6 %
		Y	4.98	67.29	16.73		130.0	
		Z	5.01	67.40	16.78		130.0	
10579-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 24 Mbps, 90pc duty cycle)	X	4.95	67.23	16.55	0.46	130.0	± 9.6 %
		Y	4.77	66.70	16.12		130.0	
		Z	4.81	66.87	16.22		130.0	
10580-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 36 Mbps, 90pc duty cycle)	X	4.99	67.14	16.52	0.46	130.0	± 9.6 %
		Y	4.81	66.66	16.11		130.0	
		Z	4.85	66.82	16.21		130.0	
10581-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 48 Mbps, 90pc duty cycle)	X	5.08	67.89	17.08	0.46	130.0	± 9.6 %
		Y	4.89	67.37	16.68		130.0	
		Z	4.92	67.50	16.74		130.0	
10582-AAA	IEEE 802.11g WiFi 2.4 GHz (DSSS-OFDM, 54 Mbps, 90pc duty cycle)	X	4.91	66.98	16.37	0.46	130.0	± 9.6 %
		Y	4.72	66.46	15.92		130.0	
		Z	4.77	66.65	16.04		130.0	
10583-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 6 Mbps, 90pc duty cycle)	X	4.97	67.04	16.76	0.46	130.0	± 9.6 %
		Y	4.83	66.64	16.40		130.0	
		Z	4.86	66.77	16.47		130.0	
10584-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 9 Mbps, 90pc duty cycle)	X	4.99	67.19	16.82	0.46	130.0	± 9.6 %
		Y	4.85	66.79	16.46		130.0	
		Z	4.88	66.91	16.52		130.0	
10585-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 12 Mbps, 90pc duty cycle)	X	5.26	67.55	17.00	0.46	130.0	± 9.6 %
		Y	5.09	67.14	16.65		130.0	
		Z	5.12	67.26	16.71		130.0	
10586-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 18 Mbps, 90pc duty cycle)	X	5.15	67.72	17.08	0.46	130.0	± 9.6 %
		Y	4.98	67.29	16.73		130.0	
		Z	5.01	67.40	16.78		130.0	
10587-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 24 Mbps, 90pc duty cycle)	X	4.95	67.23	16.55	0.46	130.0	± 9.6 %
		Y	4.77	66.70	16.12		130.0	
		Z	4.81	66.87	16.22		130.0	
10588-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 36 Mbps, 90pc duty cycle)	X	4.99	67.14	16.52	0.46	130.0	± 9.6 %
		Y	4.81	66.66	16.11		130.0	
		Z	4.85	66.82	16.21		130.0	
10589-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 48 Mbps, 90pc duty cycle)	X	5.08	67.89	17.08	0.46	130.0	± 9.6 %
		Y	4.89	67.37	16.68		130.0	
		Z	4.92	67.50	16.74		130.0	
10590-AAB	IEEE 802.11a/h WiFi 5 GHz (OFDM, 54 Mbps, 90pc duty cycle)	X	4.91	66.98	16.37	0.46	130.0	± 9.6 %
		Y	4.72	66.46	15.92		130.0	
		Z	4.77	66.65	16.04		130.0	

ES3DV3- SN:3076

July 26, 2018

10591-AAB	IEEE 802.11n (HT Mixed, 20MHz, MCS0, 90pc duty cycle)	X	5.11	67.08	16.84	0.46	130.0	± 9.6 %
		Y	4.98	66.71	16.50		130.0	
		Z	5.00	66.83	16.57		130.0	
10592-AAB	IEEE 802.11n (HT Mixed, 20MHz, MCS1, 90pc duty cycle)	X	5.31	67.43	16.95	0.46	130.0	± 9.6 %
		Y	5.15	67.05	16.62		130.0	
		Z	5.18	67.17	16.68		130.0	
10593-AAB	IEEE 802.11n (HT Mixed, 20MHz, MCS2, 90pc duty cycle)	X	5.25	67.44	16.89	0.46	130.0	± 9.6 %
		Y	5.09	67.01	16.53		130.0	
		Z	5.12	67.14	16.60		130.0	
10594-AAB	IEEE 802.11n (HT Mixed, 20MHz, MCS3, 90pc duty cycle)	X	5.29	67.54	17.00	0.46	130.0	± 9.6 %
		Y	5.13	67.14	16.67		130.0	
		Z	5.17	67.26	16.73		130.0	
10595-AAB	IEEE 802.11n (HT Mixed, 20MHz, MCS4, 90pc duty cycle)	X	5.29	67.57	16.94	0.46	130.0	± 9.6 %
		Y	5.12	67.13	16.58		130.0	
		Z	5.15	67.26	16.65		130.0	
10596-AAB	IEEE 802.11n (HT Mixed, 20MHz, MCS5, 90pc duty cycle)	X	5.22	67.54	16.93	0.46	130.0	± 9.6 %
		Y	5.05	67.11	16.57		130.0	
		Z	5.08	67.25	16.64		130.0	
10597-AAB	IEEE 802.11n (HT Mixed, 20MHz, MCS6, 90pc duty cycle)	X	5.18	67.53	16.87	0.46	130.0	± 9.6 %
		Y	5.00	67.06	16.48		130.0	
		Z	5.04	67.20	16.56		130.0	
10598-AAB	IEEE 802.11n (HT Mixed, 20MHz, MCS7, 90pc duty cycle)	X	5.16	67.79	17.12	0.46	130.0	± 9.6 %
		Y	4.98	67.30	16.73		130.0	
		Z	5.01	67.43	16.80		130.0	
10599-AAB	IEEE 802.11n (HT Mixed, 40MHz, MCS0, 90pc duty cycle)	X	5.79	67.75	17.03	0.46	130.0	± 9.6 %
		Y	5.65	67.37	16.73		130.0	
		Z	5.67	67.45	16.77		130.0	
10600-AAB	IEEE 802.11n (HT Mixed, 40MHz, MCS1, 90pc duty cycle)	X	6.05	68.52	17.39	0.46	130.0	± 9.6 %
		Y	5.91	68.14	17.10		130.0	
		Z	5.92	68.21	17.13		130.0	
10601-AAB	IEEE 802.11n (HT Mixed, 40MHz, MCS2, 90pc duty cycle)	X	5.87	68.05	17.17	0.46	130.0	± 9.6 %
		Y	5.73	67.66	16.87		130.0	
		Z	5.74	67.74	16.90		130.0	
10602-AAB	IEEE 802.11n (HT Mixed, 40MHz, MCS3, 90pc duty cycle)	X	6.00	68.19	17.16	0.46	130.0	± 9.6 %
		Y	5.82	67.69	16.81		130.0	
		Z	5.85	67.81	16.86		130.0	
10603-AAB	IEEE 802.11n (HT Mixed, 40MHz, MCS4, 90pc duty cycle)	X	6.11	68.53	17.44	0.46	130.0	± 9.6 %
		Y	5.93	68.06	17.11		130.0	
		Z	5.96	68.18	17.17		130.0	
10604-AAB	IEEE 802.11n (HT Mixed, 40MHz, MCS5, 90pc duty cycle)	X	5.81	67.77	17.06	0.46	130.0	± 9.6 %
		Y	5.66	67.35	16.75		130.0	
		Z	5.68	67.45	16.79		130.0	
10605-AAB	IEEE 802.11n (HT Mixed, 40MHz, MCS6, 90pc duty cycle)	X	5.92	68.05	17.21	0.46	130.0	± 9.6 %
		Y	5.78	67.66	16.91		130.0	
		Z	5.79	67.76	16.95		130.0	
10606-AAB	IEEE 802.11n (HT Mixed, 40MHz, MCS7, 90pc duty cycle)	X	5.67	67.50	16.81	0.46	130.0	± 9.6 %
		Y	5.55	67.13	16.51		130.0	
		Z	5.57	67.26	16.58		130.0	

ES3DV3- SN:3076

July 26, 2018

10607-AAB	IEEE 802.11ac WiFi (20MHz, MCS0, 90pc duty cycle)	X	4.93	66.35	16.43	0.46	130.0	± 9.6 %
		Y	4.79	65.95	16.08		130.0	
		Z	4.82	66.07	16.14		130.0	
10608-AAB	IEEE 802.11ac WiFi (20MHz, MCS1, 90pc duty cycle)	X	5.18	66.78	16.58	0.46	130.0	± 9.6 %
		Y	5.01	66.38	16.24		130.0	
		Z	5.04	66.50	16.30		130.0	
10609-AAB	IEEE 802.11ac WiFi (20MHz, MCS2, 90pc duty cycle)	X	5.07	66.72	16.48	0.46	130.0	± 9.6 %
		Y	4.90	66.26	16.10		130.0	
		Z	4.93	66.40	16.18		130.0	
10610-AAB	IEEE 802.11ac WiFi (20MHz, MCS3, 90pc duty cycle)	X	5.12	66.86	16.62	0.46	130.0	± 9.6 %
		Y	4.95	66.41	16.26		130.0	
		Z	4.99	66.54	16.32		130.0	
10611-AAB	IEEE 802.11ac WiFi (20MHz, MCS4, 90pc duty cycle)	X	5.06	66.76	16.52	0.46	130.0	± 9.6 %
		Y	4.88	66.26	16.13		130.0	
		Z	4.92	66.40	16.20		130.0	
10612-AAB	IEEE 802.11ac WiFi (20MHz, MCS5, 90pc duty cycle)	X	5.08	66.88	16.54	0.46	130.0	± 9.6 %
		Y	4.90	66.40	16.16		130.0	
		Z	4.93	66.54	16.23		130.0	
10613-AAB	IEEE 802.11ac WiFi (20MHz, MCS6, 90pc duty cycle)	X	5.10	66.83	16.46	0.46	130.0	± 9.6 %
		Y	4.91	66.34	16.07		130.0	
		Z	4.95	66.49	16.15		130.0	
10614-AAB	IEEE 802.11ac WiFi (20MHz, MCS7, 90pc duty cycle)	X	5.02	67.04	16.69	0.46	130.0	± 9.6 %
		Y	4.84	66.50	16.28		130.0	
		Z	4.87	66.64	16.35		130.0	
10615-AAB	IEEE 802.11ac WiFi (20MHz, MCS8, 90pc duty cycle)	X	5.06	66.55	16.30	0.46	130.0	± 9.6 %
		Y	4.88	66.08	15.91		130.0	
		Z	4.92	66.23	16.00		130.0	
10616-AAB	IEEE 802.11ac WiFi (40MHz, MCS0, 90pc duty cycle)	X	5.60	66.99	16.63	0.46	130.0	± 9.6 %
		Y	5.45	66.57	16.31		130.0	
		Z	5.48	66.68	16.36		130.0	
10617-AAB	IEEE 802.11ac WiFi (40MHz, MCS1, 90pc duty cycle)	X	5.68	67.14	16.66	0.46	130.0	± 9.6 %
		Y	5.52	66.69	16.33		130.0	
		Z	5.54	66.80	16.38		130.0	
10618-AAB	IEEE 802.11ac WiFi (40MHz, MCS2, 90pc duty cycle)	X	5.55	67.17	16.70	0.46	130.0	± 9.6 %
		Y	5.41	66.74	16.38		130.0	
		Z	5.43	66.85	16.43		130.0	
10619-AAB	IEEE 802.11ac WiFi (40MHz, MCS3, 90pc duty cycle)	X	5.57	66.98	16.54	0.46	130.0	± 9.6 %
		Y	5.43	66.56	16.23		130.0	
		Z	5.45	66.68	16.28		130.0	
10620-AAB	IEEE 802.11ac WiFi (40MHz, MCS4, 90pc duty cycle)	X	5.73	67.19	16.70	0.46	130.0	± 9.6 %
		Y	5.56	66.71	16.35		130.0	
		Z	5.59	66.83	16.41		130.0	
10621-AAB	IEEE 802.11ac WiFi (40MHz, MCS5, 90pc duty cycle)	X	5.68	67.17	16.79	0.46	130.0	± 9.6 %
		Y	5.52	66.74	16.48		130.0	
		Z	5.55	66.85	16.52		130.0	
10622-AAB	IEEE 802.11ac WiFi (40MHz, MCS6, 90pc duty cycle)	X	5.66	67.24	16.82	0.46	130.0	± 9.6 %
		Y	5.52	66.85	16.52		130.0	
		Z	5.54	66.94	16.56		130.0	

ES3DV3- SN:3076

July 26, 2018

10623-AAB	IEEE 802.11ac WiFi (40MHz, MCS7, 90pc duty cycle)	X	5.60	67.04	16.62	0.46	130.0	± 9.6 %
		Y	5.42	66.47	16.23		130.0	
		Z	5.45	66.63	16.30		130.0	
10624-AAB	IEEE 802.11ac WiFi (40MHz, MCS8, 90pc duty cycle)	X	5.74	67.00	16.66	0.46	130.0	± 9.6 %
		Y	5.60	66.62	16.37		130.0	
		Z	5.62	66.73	16.41		130.0	
10625-AAB	IEEE 802.11ac WiFi (40MHz, MCS9, 90pc duty cycle)	X	6.06	67.73	17.06	0.46	130.0	± 9.6 %
		Y	6.03	67.72	16.96		130.0	
		Z	6.01	67.70	16.95		130.0	
10626-AAB	IEEE 802.11ac WiFi (80MHz, MCS0, 90pc duty cycle)	X	5.82	67.00	16.54	0.46	130.0	± 9.6 %
		Y	5.70	66.60	16.25		130.0	
		Z	5.72	66.71	16.29		130.0	
10627-AAB	IEEE 802.11ac WiFi (80MHz, MCS1, 90pc duty cycle)	X	6.07	67.45	16.71	0.46	130.0	± 9.6 %
		Y	5.98	67.19	16.49		130.0	
		Z	5.98	67.25	16.51		130.0	
10628-AAB	IEEE 802.11ac WiFi (80MHz, MCS2, 90pc duty cycle)	X	5.92	67.24	16.56	0.46	130.0	± 9.6 %
		Y	5.78	66.81	16.25		130.0	
		Z	5.80	66.93	16.30		130.0	
10629-AAB	IEEE 802.11ac WiFi (80MHz, MCS3, 90pc duty cycle)	X	6.03	67.37	16.61	0.46	130.0	± 9.6 %
		Y	5.88	66.90	16.29		130.0	
		Z	5.90	67.04	16.35		130.0	
10630-AAB	IEEE 802.11ac WiFi (80MHz, MCS4, 90pc duty cycle)	X	6.63	69.29	17.57	0.46	130.0	± 9.6 %
		Y	6.54	69.01	17.33		130.0	
		Z	6.50	68.95	17.31		130.0	
10631-AAB	IEEE 802.11ac WiFi (80MHz, MCS5, 90pc duty cycle)	X	6.51	69.00	17.59	0.46	130.0	± 9.6 %
		Y	6.33	68.48	17.25		130.0	
		Z	6.33	68.53	17.26		130.0	
10632-AAB	IEEE 802.11ac WiFi (80MHz, MCS6, 90pc duty cycle)	X	6.09	67.66	16.94	0.46	130.0	± 9.6 %
		Y	5.94	67.24	16.65		130.0	
		Z	5.96	67.32	16.68		130.0	
10633-AAB	IEEE 802.11ac WiFi (80MHz, MCS7, 90pc duty cycle)	X	6.06	67.60	16.76	0.46	130.0	± 9.6 %
		Y	5.90	67.12	16.43		130.0	
		Z	5.93	67.25	16.48		130.0	
10634-AAB	IEEE 802.11ac WiFi (80MHz, MCS8, 90pc duty cycle)	X	6.02	67.54	16.78	0.46	130.0	± 9.6 %
		Y	5.86	67.06	16.46		130.0	
		Z	5.89	67.19	16.51		130.0	
10635-AAB	IEEE 802.11ac WiFi (80MHz, MCS9, 90pc duty cycle)	X	5.91	66.93	16.24	0.46	130.0	± 9.6 %
		Y	5.75	66.41	15.88		130.0	
		Z	5.78	66.58	15.97		130.0	
10636-AAC	IEEE 802.11ac WiFi (160MHz, MCS0, 90pc duty cycle)	X	6.22	67.39	16.64	0.46	130.0	± 9.6 %
		Y	6.11	67.02	16.36		130.0	
		Z	6.13	67.12	16.40		130.0	
10637-AAC	IEEE 802.11ac WiFi (160MHz, MCS1, 90pc duty cycle)	X	6.45	67.92	16.87	0.46	130.0	± 9.6 %
		Y	6.30	67.45	16.56		130.0	
		Z	6.32	67.56	16.60		130.0	
10638-AAC	IEEE 802.11ac WiFi (160MHz, MCS2, 90pc duty cycle)	X	6.39	67.74	16.76	0.46	130.0	± 9.6 %
		Y	6.29	67.39	16.51		130.0	
		Z	6.30	67.48	16.54		130.0	

ES3DV3- SN:3076

July 26, 2018

10639-AAC	IEEE 802.11ac WiFi (160MHz, MCS3, 90pc duty cycle)	X	6.42	67.83	16.85	0.46	130.0	± 9.6 %
		Y	6.30	67.43	16.57		130.0	
		Z	6.31	67.53	16.61		130.0	
10640-AAC	IEEE 802.11ac WiFi (160MHz, MCS4, 90pc duty cycle)	X	6.47	67.96	16.87	0.46	130.0	± 9.6 %
		Y	6.34	67.55	16.58		130.0	
		Z	6.36	67.66	16.63		130.0	
10641-AAC	IEEE 802.11ac WiFi (160MHz, MCS5, 90pc duty cycle)	X	6.45	67.66	16.73	0.46	130.0	± 9.6 %
		Y	6.31	67.23	16.44		130.0	
		Z	6.33	67.35	16.49		130.0	
10642-AAC	IEEE 802.11ac WiFi (160MHz, MCS6, 90pc duty cycle)	X	6.54	68.02	17.07	0.46	130.0	± 9.6 %
		Y	6.38	67.54	16.75		130.0	
		Z	6.40	67.66	16.80		130.0	
10643-AAC	IEEE 802.11ac WiFi (160MHz, MCS7, 90pc duty cycle)	X	6.35	67.70	16.83	0.46	130.0	± 9.6 %
		Y	6.22	67.26	16.52		130.0	
		Z	6.24	67.39	16.57		130.0	
10644-AAC	IEEE 802.11ac WiFi (160MHz, MCS8, 90pc duty cycle)	X	6.63	68.54	17.28	0.46	130.0	± 9.6 %
		Y	6.48	68.05	16.94		130.0	
		Z	6.49	68.15	16.98		130.0	
10645-AAC	IEEE 802.11ac WiFi (160MHz, MCS9, 90pc duty cycle)	X	6.83	68.64	17.26	0.46	130.0	± 9.6 %
		Y	6.78	68.45	17.08		130.0	
		Z	6.76	68.46	17.09		130.0	
10646-AAE	LTE-TDD (SC-FDMA, 1 RB, 5 MHz, QPSK, UL Subframe=2,7)	X	23.77	102.61	33.72	9.30	60.0	± 9.6 %
		Y	20.40	101.11	33.40		60.0	
		Z	25.01	105.52	34.77		60.0	
10647-AAE	LTE-TDD (SC-FDMA, 1 RB, 20 MHz, QPSK, UL Subframe=2,7)	X	25.18	104.62	34.47	9.30	60.0	± 9.6 %
		Y	20.97	102.45	33.94		60.0	
		Z	26.28	107.39	35.47		60.0	
10648-AAA	CDMA2000 (1x Advanced)	X	0.99	67.29	14.09	0.00	150.0	± 9.6 %
		Y	0.72	63.04	10.75		150.0	
		Z	0.77	63.65	11.35		150.0	
10652-AAC	LTE-TDD (OFDMA, 5 MHz, E-TM 3.1, Clipping 44%)	X	5.04	69.84	18.09	2.23	80.0	± 9.6 %
		Y	4.43	68.06	17.08		80.0	
		Z	4.58	68.58	17.32		80.0	
10653-AAC	LTE-TDD (OFDMA, 10 MHz, E-TM 3.1, Clipping 44%)	X	5.45	69.00	18.04	2.23	80.0	± 9.6 %
		Y	4.93	67.54	17.22		80.0	
		Z	5.06	68.00	17.43		80.0	
10654-AAC	LTE-TDD (OFDMA, 15 MHz, E-TM 3.1, Clipping 44%)	X	5.34	68.69	18.02	2.23	80.0	± 9.6 %
		Y	4.86	67.25	17.22		80.0	
		Z	4.99	67.71	17.43		80.0	
10655-AAD	LTE-TDD (OFDMA, 20 MHz, E-TM 3.1, Clipping 44%)	X	5.40	68.79	18.07	2.23	80.0	± 9.6 %
		Y	4.92	67.31	17.27		80.0	
		Z	5.04	67.77	17.48		80.0	
10658-AAA	Pulse Waveform (200Hz, 10%)	X	11.03	81.69	22.20	10.00	50.0	± 9.6 %
		Y	10.59	82.32	22.47		50.0	
		Z	10.99	82.66	22.36		50.0	
10659-AAA	Pulse Waveform (200Hz, 20%)	X	14.51	87.74	22.90	6.99	60.0	± 9.6 %
		Y	15.68	90.34	23.71		60.0	
		Z	16.52	90.51	23.53		60.0	

ES3DV3- SN:3076

July 26, 2018

10660-AAA	Pulse Waveform (200Hz, 40%)	X	100.00	115.63	28.65	3.98	80.0	± 9.6 %
		Y	100.00	116.20	28.51		80.0	
		Z	100.00	115.23	28.10		80.0	
10661-AAA	Pulse Waveform (200Hz, 60%)	X	100.00	116.29	27.42	2.22	100.0	± 9.6 %
		Y	100.00	115.47	26.60		100.0	
		Z	100.00	114.98	26.47		100.0	
10662-AAA	Pulse Waveform (200Hz, 80%)	X	100.00	121.88	27.79	0.97	120.0	± 9.6 %
		Y	100.00	114.69	24.28		120.0	
		Z	100.00	116.25	25.08		120.0	

^f Uncertainty is determined using the max. deviation from linear response applying rectangular distribution and is expressed for the square of the field value.

**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland





S Schweizerischer Kalibrierdienst
S Service suisse d'étalonnage
C Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates



Accreditation No.: **SCS 0108**

Client **HCT (Dymstec)**

Certificate No: **EX3-3797_Nov17**

CALIBRATION CERTIFICATE		결재	담당자	확인자
Object	EX3DV4 - SN:3797	재	 SW/김재환 2017.12.15	 김진호 2017.12.15
Calibration procedure(s)	QA CAL-01.v9, QA CAL-12.v9, QA CAL-14.v4, QA CAL-23.v5, QA CAL-25.v6 Calibration procedure for dosimetric E-field probes			
Calibration date:	November 22, 2017			
This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate. All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%. Calibration Equipment used (M&TE critical for calibration)				

Primary Standards	ID	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	04-Apr-17 (No. 217-02521/02522)	Apr-18
Power sensor NRP-Z91	SN: 103244	04-Apr-17 (No. 217-02521)	Apr-18
Power sensor NRP-Z91	SN: 103245	04-Apr-17 (No. 217-02525)	Apr-18
Reference 20 dB Attenuator	SN: 55277 (20x)	07-Apr-17 (No. 217-02528)	Apr-18
Reference Probe ES3DV2	SN: 3013	31-Dec-16 (No. ES3-3013_Dec16)	Dec-17
DAE4	SN: 660	7-Dec-16 (No. DAE4-660_Dec16)	Dec-17
Secondary Standards	ID	Check Date (in house)	Scheduled Check
Power meter E4419B	SN: GB41293874	06-Apr-16 (in house check Jun-16)	In house check: Jun-18
Power sensor E4412A	SN: MY41498087	06-Apr-16 (in house check Jun-16)	In house check: Jun-18
Power sensor E4412A	SN: 000110210	06-Apr-16 (in house check Jun-16)	In house check: Jun-18
RF generator HP 8648C	SN: US3542U01700	04-Aug-99 (in house check Jun-16)	In house check: Jun-18
Network Analyzer HP 8753E	SN: US37390585	18-Oct-01 (in house check Oct-17)	In house check: Oct-18

	Name	Function	Signature
Calibrated by:	Jelzon Kasirati	Laboratory Technician	
Approved by:	Katja Pokovic	Technical Manager	
			Issued: November 22, 2017
This calibration certificate shall not be reproduced except in full without written approval of the laboratory.			

**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Glossary:

TSL	tissue simulating liquid
NORM _{x,y,z}	sensitivity in free space
ConvF	sensitivity in TSL / NORM _{x,y,z}
DCP	diode compression point
CF	crest factor (1/duty_cycle) of the RF signal
A, B, C, D	modulation dependent linearization parameters
Polarization φ	φ rotation around probe axis
Polarization θ	θ rotation around an axis that is in the plane normal to probe axis (at measurement center). I.e., $\theta = 0$ is normal to probe axis
Connector Angle	information used in DASY system to align probe sensor X to the robot coordinate system

Calibration is Performed According to the Following Standards:

- IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Methods Applied and Interpretation of Parameters:

- NORM_{x,y,z}:** Assessed for E-field polarization $\theta = 0$ ($f \leq 900$ MHz in TEM-cell; $f > 1800$ MHz: R22 waveguide). NORM_{x,y,z} are only intermediate values, I.e., the uncertainties of NORM_{x,y,z} does not affect the E²-field uncertainty inside TSL (see below ConvF).
- NORM(f)_{x,y,z} = NORM_{x,y,z} * frequency_response** (see Frequency Response Chart). This linearization is implemented in DASY4 software versions later than 4.2. The uncertainty of the frequency response is included in the stated uncertainty of ConvF.
- DCP_{x,y,z}:** DCP are numerical linearization parameters assessed based on the data of power sweep with CW signal (no uncertainty required). DCP does not depend on frequency nor media.
- PAR:** PAR is the Peak to Average Ratio that is not calibrated but determined based on the signal characteristics
- A_{x,y,z}; B_{x,y,z}; C_{x,y,z}; D_{x,y,z}; VR_{x,y,z}:** A, B, C, D are numerical linearization parameters assessed based on the data of power sweep for specific modulation signal. The parameters do not depend on frequency nor media. VR is the maximum calibration range expressed in RMS voltage across the diode.
- ConvF and Boundary Effect Parameters:** Assessed in flat phantom using E-field (or Temperature Transfer Standard for $f \leq 800$ MHz) and inside waveguide using analytical field distributions based on power measurements for $f > 800$ MHz. The same setups are used for assessment of the parameters applied for boundary compensation (alpha, depth) of which typical uncertainty values are given. These parameters are used in DASY4 software to improve probe accuracy close to the boundary. The sensitivity in TSL corresponds to NORM_{x,y,z} * ConvF whereby the uncertainty corresponds to that given for ConvF. A frequency dependent ConvF is used in DASY version 4.4 and higher which allows extending the validity from ± 50 MHz to ± 100 MHz.
- Spherical isotropy (3D deviation from isotropy):** in a field of low gradients realized using a flat phantom exposed by a patch antenna.
- Sensor Offset:** The sensor offset corresponds to the offset of virtual measurement center from the probe tip (on probe axis). No tolerance required.
- Connector Angle:** The angle is assessed using the information gained by determining the NORM_x (no uncertainty required).

EX3DV4 – SN:3797

November 22, 2017

Probe EX3DV4

SN:3797

Manufactured: April 5, 2011
Calibrated: November 22, 2017

Calibrated for DASYS/EASY Systems
(Note: non-compatible with DASYS2 system!)

EX3DV4- SN:3797

November 22, 2017

DASY/EASY - Parameters of Probe: EX3DV4 - SN:3797

Basic Calibration Parameters

	Sensor X	Sensor Y	Sensor Z	Unc (k=2)
Norm ($\mu\text{V}/(\text{V}/\text{m})^2$) ^A	0.61	0.56	0.55	$\pm 10.1\%$
DCP (mV) ^B	98.6	98.7	93.8	

Modulation Calibration Parameters

UID	Communication System Name		A dB	B dB $\sqrt{\mu\text{V}}$	C	D dB	VR mV	Unc ^C (k=2)
0	CW	X	0.0	0.0	1.0	0.00	159.5	$\pm 3.0\%$
		Y	0.0	0.0	1.0		144.5	
		Z	0.0	0.0	1.0		153.6	

Note: For details on UID parameters see Appendix.

Sensor Model Parameters

	C1 fF	C2 fF	α V^{-1}	T1 $\text{ms}\cdot\text{V}^{-2}$	T2 $\text{ms}\cdot\text{V}^{-1}$	T3 ms	T4 V^{-2}	T5 V^{-1}	T6
X	44.59	344.0	37.65	12.56	0.469	5.1	0.000	0.545	1.011
Y	45.15	342.4	36.62	15.66	0.128	5.1	0.748	0.385	1.009
Z	41.67	324.0	38.09	10.33	0.420	5.1	0.000	0.515	1.011

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

^A The uncertainties of Norm X,Y,Z do not affect the E²-field uncertainty inside TSL (see Pages 5 and 6).

^B Numerical linearization parameter: uncertainty not required.

^C Uncertainty is determined using the max. deviation from linear response applying rectangular distribution and is expressed for the square of the field value.

EX3DV4- SN:3797

November 22, 2017

DASY/EASY - Parameters of Probe: EX3DV4 - SN:3797

Calibration Parameter Determined in Head Tissue Simulating Media

f (MHz) ^c	Relative Permittivity ^e	Conductivity (S/m) ^f	ConvF X	ConvF Y	ConvF Z	Alpha ^g	Depth ^h (mm)	Unc (k=2)
150	52.3	0.76	11.69	11.69	11.69	0.00	1.00	± 13.3 %
300	45.3	0.87	10.93	10.93	10.93	0.08	1.25	± 13.3 %
450	43.5	0.87	10.34	10.34	10.34	0.15	1.25	± 13.3 %
750	41.9	0.89	9.58	9.58	9.58	0.49	0.80	± 12.0 %
835	41.5	0.90	9.27	9.27	9.27	0.49	0.85	± 12.0 %
900	41.5	0.97	9.08	9.08	9.08	0.47	0.87	± 12.0 %
1450	40.5	1.20	8.00	8.00	8.00	0.38	0.80	± 12.0 %
1750	40.1	1.37	7.93	7.93	7.93	0.39	0.80	± 12.0 %
1900	40.0	1.40	7.85	7.85	7.85	0.39	0.85	± 12.0 %
2300	39.5	1.67	7.51	7.51	7.51	0.38	0.85	± 12.0 %
2450	39.2	1.80	7.15	7.15	7.15	0.36	0.88	± 12.0 %
2600	39.0	1.96	6.97	6.97	6.97	0.38	0.88	± 12.0 %
3500	37.9	2.91	6.68	6.68	6.68	0.25	1.20	± 13.1 %
5250	35.9	4.71	5.10	5.10	5.10	0.35	1.80	± 13.1 %
5600	35.5	5.07	4.56	4.56	4.56	0.40	1.80	± 13.1 %
5750	35.4	5.22	4.74	4.74	4.74	0.40	1.80	± 13.1 %

^c Frequency validity above 300 MHz of ± 100 MHz only applies for DASY v4.4 and higher (see Page 2), else it is restricted to ± 50 MHz. The uncertainty is the RSS of the ConvF uncertainty at calibration frequency and the uncertainty for the indicated frequency band. Frequency validity below 300 MHz is ± 10, 25, 40, 50 and 70 MHz for ConvF assessments at 30, 64, 128, 150 and 220 MHz respectively. Above 5 GHz frequency validity can be extended to ± 110 MHz.

^e At frequencies below 3 GHz, the validity of tissue parameters (ϵ and σ) can be relaxed to ± 10% if liquid compensation formula is applied to measured SAR values. At frequencies above 3 GHz, the validity of tissue parameters (ϵ and σ) is restricted to ± 5%. The uncertainty is the RSS of the ConvF uncertainty for indicated target tissue parameters.

^g Alpha/Depth are determined during calibration. SPEAG warrants that the remaining deviation due to the boundary effect after compensation is always less than ± 1% for frequencies below 3 GHz and below ± 2% for frequencies between 3-8 GHz at any distance larger than half the probe tip diameter from the boundary.

EX3DV4- SN:3797

November 22, 2017

DASY/EASY - Parameters of Probe: EX3DV4 - SN:3797

Calibration Parameter Determined in Body Tissue Simulating Media

f (MHz) ^c	Relative Permittivity ^F	Conductivity (S/m) ^F	ConvF X	ConvF Y	ConvF Z	Alpha ^G	Depth ^G (mm)	Unc (k=2)
150	61.9	0.80	11.16	11.16	11.16	0.00	1.00	± 13.3 %
300	58.2	0.92	10.89	10.89	10.89	0.05	1.15	± 13.3 %
450	56.7	0.94	10.46	10.46	10.46	0.08	1.20	± 13.3 %
750	55.5	0.96	9.53	9.53	9.53	0.41	0.96	± 12.0 %
835	55.2	0.97	9.27	9.27	9.27	0.53	0.80	± 12.0 %
1750	53.4	1.49	7.88	7.88	7.88	0.38	0.86	± 12.0 %
1900	53.3	1.52	7.61	7.61	7.61	0.42	0.85	± 12.0 %
2300	52.9	1.81	7.39	7.39	7.39	0.32	0.96	± 12.0 %
2450	52.7	1.95	7.23	7.23	7.23	0.38	0.88	± 12.0 %
2600	52.5	2.16	7.00	7.00	7.00	0.28	0.96	± 12.0 %
5250	48.9	5.36	4.61	4.61	4.61	0.40	1.90	± 13.1 %
5600	48.5	5.77	4.06	4.06	4.06	0.45	1.90	± 13.1 %
5750	48.3	5.94	4.32	4.32	4.32	0.45	1.90	± 13.1 %

^c Frequency validity above 300 MHz of ± 100 MHz only applies for DASY v4.4 and higher (see Page 2), else it is restricted to ± 50 MHz. The uncertainty is the RSS of the ConvF uncertainty at calibration frequency and the uncertainty for the indicated frequency band. Frequency validity below 300 MHz is ± 10, 25, 40, 50 and 70 MHz for ConvF assessments at 30, 64, 128, 150 and 220 MHz respectively. Above 5 GHz frequency validity can be extended to ± 110 MHz.


^F At frequencies below 3 GHz, the validity of tissue parameters (ϵ and σ) can be relaxed to ± 10% if liquid compensation formula is applied to measured SAR values. At frequencies above 3 GHz, the validity of tissue parameters (ϵ and σ) is restricted to ± 5%. The uncertainty is the RSS of the ConvF uncertainty for indicated target tissue parameters.

^G Alpha/Depth are determined during calibration. SPEAG warrants that the remaining deviation due to the boundary effect after compensation is always less than ± 1% for frequencies below 3 GHz and below ± 2% for frequencies between 3-6 GHz at any distance larger than half the probe tip diameter from the boundary.

EX3DV4- SN:3797

November 22, 2017

Frequency Response of E-Field (TEM-Cell:ifi110 EXX, Waveguide: R22)





Uncertainty of Frequency Response of E-field: $\pm 6.3\%$ (k=2)

EX3DV4- SN:3797

November 22, 2017

Receiving Pattern (ϕ), $\theta = 0^\circ$





Uncertainty of Axial Isotropy Assessment: $\pm 0.5\%$ (k=2)

EX3DV4- SN:3797

November 22, 2017

Dynamic Range f(SAR_{head})
(TEM cell , f_{eval}= 1900 MHz)




Uncertainty of Linearity Assessment: ± 0.6% (k=2)


EX3DV4- SN:3797

November 22, 2017

Conversion Factor Assessment



Deviation from Isotropy in Liquid Error (ϕ, θ), f = 900 MHz



EX3DV4- SN:3797

November 22, 2017

DASY/EASY - Parameters of Probe: EX3DV4 - SN:3797**Other Probe Parameters**

Sensor Arrangement	Triangular
Connector Angle (°)	69.9
Mechanical Surface Detection Mode	enabled
Optical Surface Detection Mode	disabled
Probe Overall Length	337 mm
Probe Body Diameter	10 mm
Tip Length	9 mm
Tip Diameter	2.5 mm
Probe Tip to Sensor X Calibration Point	1 mm
Probe Tip to Sensor Y Calibration Point	1 mm
Probe Tip to Sensor Z Calibration Point	1 mm
Recommended Measurement Distance from Surface	1.4 mm

Attachment 7. – Dipole Calibration Data

**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Client **HCT (Dymstec)**

Certificate No: **D835V2-441_Sep17**

CALIBRATION CERTIFICATE

Object: **D835V2 - SN:441**

Calibration procedure(s): **QA CAL-05.v9
Calibration procedure for dipole validation kits above 700 MHz.**

Calibration date: **September 21, 2017.**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	04-Apr-17 (No. 217-02521/02522)	Apr-18
Power sensor NRP-Z91	SN: 103244	04-Apr-17 (No. 217-02521)	Apr-18
Power sensor NRP-Z91	SN: 103245	04-Apr-17 (No. 217-02522)	Apr-18
Reference 20 dB Attenuator	SN: 5058 (20k)	07-Apr-17 (No. 217-02528)	Apr-18
Type-N mismatch combination	SN: 5047.2 / 06327	07-Apr-17 (No. 217-02529)	Apr-18
Reference Probe EX3DV4	SN: 7349	31-May-17 (No. EX3-7349_May17)	May-18
DAE4	SN: 601	28-Mar-17 (No. DAE4-601_Mar17)	Mar-18

Secondary Standards	ID #	Check Date (in house)	Scheduled Check
Power meter EPM-442A	SN: GB37480704	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: US37292783	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: MY41092317	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
RF generator R&S SMT-06	SN: 100972	15-Jun-15 (in house check Oct-16)	In house check: Oct-18
Network Analyzer HP 8753E	SN: US37390585	18-Oct-01 (in house check Oct-16)	In house check: Oct-17

Calibrated by:	Name: Michael Weber	Function: Laboratory Technician	Signature: 
----------------	----------------------------	--	--

Approved by:	Name: Katja Pokovic	Function: Technical Manager	Signature: 
--------------	----------------------------	------------------------------------	--

Issued: September 21, 2017

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Glossary:

TSL tissue simulating liquid
ConvF sensitivity in TSL / NORM x,y,z
N/A not applicable or not measured

Calibration is Performed According to the Following Standards:

- a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- b) IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- c) IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- d) KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

- e) DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- *Measurement Conditions:* Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- *Antenna Parameters with TSL:* The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- *Feed Point Impedance and Return Loss:* These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- *Electrical Delay:* One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- *SAR measured:* SAR measured at the stated antenna input power.
- *SAR normalized:* SAR as measured, normalized to an input power of 1 W at the antenna connector.
- *SAR for nominal TSL parameters:* The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.0
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	15 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	835 MHz ± 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	41.5	0.90 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	40.9 ± 6 %	0.93 mho/m ± 6 %
Head TSL temperature change during test	< 0.5 °C	----	----

SAR result with Head TSL

SAR averaged over 1 cm ³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	2.41 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	9.38 W/kg ± 17.0 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	1.55 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	6.07 W/kg ± 16.5 % (k=2)

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	55.2	0.97 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	55.3 ± 6 %	0.98 mho/m ± 6 %
Body TSL temperature change during test	< 0.5 °C	----	----

SAR result with Body TSL

SAR averaged over 1 cm ³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	2.37 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	9.41 W/kg ± 17.0 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	1.55 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	6.16 W/kg ± 16.5 % (k=2)

Appendix (Additional assessments outside the scope of SCS 0108)**Antenna Parameters with Head TSL**

Impedance, transformed to feed point	51.1 Ω - 2.3 $j\Omega$
Return Loss	- 32.1 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	47.6 Ω - 5.0 $j\Omega$
Return Loss	- 24.9 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.371 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
Manufactured on	March 09, 2001

DASY5 Validation Report for Head TSL

Date: 21.09.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 835 MHz; Type: D835V2; Serial: D835V2 - SN:441

Communication System: UID 0 - CW; Frequency: 835 MHz

Medium parameters used: $f = 835$ MHz; $\sigma = 0.93$ S/m; $\epsilon_r = 40.9$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(10.07, 10.07, 10.07); Calibrated: 31.05.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 28.03.2017
- Phantom: Flat Phantom 4.9 (front); Type: QD 00L P49 AA; Serial: 1001
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Head Tissue/Pin=250 mW, d=15mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 62.34 V/m; Power Drift = -0.08 dB


Peak SAR (extrapolated) = 3.75 W/kg

SAR(1 g) = 2.41 W/kg; SAR(10 g) = 1.55 W/kg

Maximum value of SAR (measured) = 3.28 W/kg



Impedance Measurement Plot for Head TSL



DASY5 Validation Report for Body TSL

Date: 21.09.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 835 MHz; Type: D835V2; Serial: D835V2 - SN:441

Communication System: UID 0 - CW; Frequency: 835 MHz

Medium parameters used: $f = 835$ MHz; $\sigma = 0.98$ S/m; $\epsilon_r = 55.3$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(10.2, 10.2, 10.2); Calibrated: 31.05.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 28.03.2017
- Phantom: Flat Phantom 4.9 (Back); Type: QD 00R P49 AA; Serial: 1005
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Body Tissue/Pin=250 mW, d=15mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 59.66 V/m; Power Drift = -0.09 dB

Peak SAR (extrapolated) = 3.57 W/kg


SAR(1 g) = 2.37 W/kg; SAR(10 g) = 1.55 W/kg

Maximum value of SAR (measured) = 3.12 W/kg



0 dB = 3.12 W/kg = 4.94 dBW/kg

Impedance Measurement Plot for Body TSL



**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Client: **HCT (Dymstec)**

Certificate No: **D1900V2-5d061_Mar18**

CALIBRATION CERTIFICATE												
Object	D1900V2 - SN:5d061											
Calibration procedure(s)	QA CAL-05.v10 Calibration procedure for dipole validation kits above 700 MHz											
Calibration date:	March 15, 2018											
<table border="1"> <tr> <td>결 재</td> <td>담당자</td> <td>확인자</td> </tr> <tr> <td></td> <td><i>[Signature]</i></td> <td><i>[Signature]</i></td> </tr> <tr> <td></td> <td>Swiss Calibration Service</td> <td>2018.4.2</td> </tr> </table>				결 재	담당자	확인자		<i>[Signature]</i>	<i>[Signature]</i>		Swiss Calibration Service	2018.4.2
결 재	담당자	확인자										
	<i>[Signature]</i>	<i>[Signature]</i>										
	Swiss Calibration Service	2018.4.2										
This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.												
All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%.												
Calibration Equipment used (M&TE critical for calibration)												
Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration									
Power meter NRP	SN: 104778	04-Apr-17 (No. 217-02521/02522)	Apr-18									
Power sensor NRP-Z91	SN: 103244	04-Apr-17 (No. 217-02521)	Apr-18									
Power sensor NRP-Z91	SN: 103245	04-Apr-17 (No. 217-02522)	Apr-18									
Reference 20 dB Attenuator	SN: 5058 (20k)	07-Apr-17 (No. 217-02528)	Apr-18									
Type-N mismatch combination	SN: 5047.2 / 09327	07-Apr-17 (No. 217-02529)	Apr-18									
Reference Probe EX3DV4	SN: 7349	30-Dec-17 (No. EX3-7349_Dec17)	Dec-18									
DAE4	SN: 601	26-Oct-17 (No. DAE4-601_Oct17)	Oct-18									
Secondary Standards	ID #	Check Date (in house)	Scheduled Check									
Power meter EPM-442A	SN: GB37480704	07-Oct-15 (in house check Oct-16)	In house check: Oct-18									
Power sensor HP 8481A	SN: US37292793	07-Oct-15 (in house check Oct-16)	In house check: Oct-18									
Power sensor HP 8481A	SN: MY41092317	07-Oct-15 (in house check Oct-16)	In house check: Oct-18									
RF generator R&S SMT-06	SN: 100972	15-Jun-15 (in house check Oct-16)	In house check: Oct-18									
Network Analyzer HP 8753E	SN: US37390585	18-Oct-01 (in house check Oct-17)	In house check: Oct-18									
Calibrated by:	Name: Claudio Leubler	Function: Laboratory Technician	Signature: <i>[Signature]</i>									
Approved by:	Name: Katja Pokovic	Function: Technical Manager	Signature: <i>[Signature]</i>									
			Issued: March 15, 2018									
This calibration certificate shall not be reproduced except in full without written approval of the laboratory.												

**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Glossary:

TSL tissue simulating liquid
ConvF sensitivity in TSL / NORM x,y,z
N/A not applicable or not measured

Calibration is Performed According to the Following Standards:

- a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- b) IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- c) IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- d) KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

- e) DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- *Measurement Conditions:* Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- *Antenna Parameters with TSL:* The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- *Feed Point Impedance and Return Loss:* These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- *Electrical Delay:* One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- *SAR measured:* SAR measured at the stated antenna input power.
- *SAR normalized:* SAR as measured, normalized to an input power of 1 W at the antenna connector.
- *SAR for nominal TSL parameters:* The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.0
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	1900 MHz ± 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	40.0	1.40 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	40.5 ± 6 %	1.37 mho/m ± 6 %
Head TSL temperature change during test	< 0.5 °C	---	---

SAR result with Head TSL

SAR averaged over 1 cm ³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	9.88 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	40.1 W/kg ± 17.0 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	5.19 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	21.0 W/kg ± 16.5 % (k=2)

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	53.3	1.52 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	55.2 ± 6 %	1.47 mho/m ± 6 %
Body TSL temperature change during test	< 0.5 °C	---	---

SAR result with Body TSL

SAR averaged over 1 cm ³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	9.64 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	39.6 W/kg ± 17.0 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	5.14 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	20.9 W/kg ± 16.5 % (k=2)

Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL

Impedance, transformed to feed point	51.4 Ω + 6.2 j Ω
Return Loss	- 24.0 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	47.7 Ω + 4.9 j Ω
Return Loss	- 25.1 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.194 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
Manufactured on	December 10, 2004

DASY5 Validation Report for Head TSL

Date: 15.03.2018

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: D1900V2 - SN:5d061

Communication System: UID 0 - CW; Frequency: 1900 MHz

Medium parameters used: $f = 1900$ MHz; $\sigma = 1.37$ S/m; $\epsilon_r = 40.5$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(8.18, 8.18, 8.18); Calibrated: 30.12.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 5.0 (front); Type: QD 000 P50 AA; Serial: 1001
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Head Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 107.8 V/m; Power Drift = -0.09 dB


Peak SAR (extrapolated) = 18.3 W/kg

SAR(1 g) = 9.88 W/kg; SAR(10 g) = 5.19 W/kg

Maximum value of SAR (measured) = 15.1 W/kg



Impedance Measurement Plot for Head TSL



DASY5 Validation Report for Body TSL

Date: 15.03.2018

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: D1900V2 - SN:5d061

Communication System: UID 0 - CW; Frequency: 1900 MHz

Medium parameters used: $f = 1900$ MHz; $\sigma = 1.47$ S/m; $\epsilon_r = 55.2$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(8.15, 8.15, 8.15); Calibrated: 30.12.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 5.0 (back); Type: QD 000 P50 AA; Serial: 1002
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Body Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 101.9 V/m; Power Drift = -0.04 dB


Peak SAR (extrapolated) = 17.1 W/kg

SAR(1 g) = 9.64 W/kg; SAR(10 g) = 5.14 W/kg

Maximum value of SAR (measured) = 13.9 W/kg



Impedance Measurement Plot for Body TSL



**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Client **HCT (Dymstec)**

Certificate No: **D2450V2-965_Feb18**

CALIBRATION CERTIFICATE

Object: **D2450V2 - SN:965**

Calibration procedure(s): **QA CAL-05.v9
Calibration procedure for dipole validation kits above 700 MHz**

Calibration date: **February 16, 2018**

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	04-Apr-17 (No. 217-02521/02522)	Apr-18
Power sensor NRP-Z91	SN: 103244	04-Apr-17 (No. 217-02521)	Apr-18
Power sensor NRP-Z91	SN: 103245	04-Apr-17 (No. 217-02522)	Apr-18
Reference 20 dB Attenuator	SN: 5068 (20k)	07-Apr-17 (No. 217-02528)	Apr-18
Type-N mismatch combination	SN: 5047.2 / 06327	07-Apr-17 (No. 217-02529)	Apr-18
Reference Probe EX3DV4	SN: 7349	30-Dec-17 (No. EX3-7349_Dec17)	Dec-18
DAE4	SN: 601	26-Oct-17 (No. DAE4-601_Oct17)	Oct-18
Secondary Standards	ID #	Check Date (in house)	Scheduled Check
Power meter EPM-442A	SN: GB37480704	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: US37292783	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: MY41092317	07-Oct-15 (in house check Oct-16)	In house check: Oct-18
RF generator R&S SMT-06	SN: 100972	15-Jun-15 (in house check Oct-16)	In house check: Oct-18
Network Analyzer HP 8753E	SN: US37390585	18-Oct-01 (in house check Oct-17)	In house check: Oct-18

	Name	Function	Signature
Calibrated by:	Michael Weber	Laboratory Technician	<i>M. Weber</i>
Approved by:	Katja Pokovic	Technical Manager	<i>K. Pokovic</i>

Issued: February 19, 2018

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

Certificate No: D2450V2-965_Feb18

Page 1 of 8

결	담당자	확인자
재	<i>X Jim</i>	<i>JH</i>
직위/성명	SW 1차장	QC 1차장
일자	2018.03.06	2018.03.06

**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORM x,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

- a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- b) IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- c) IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- d) KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

- e) DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- *Measurement Conditions:* Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- *Antenna Parameters with TSL:* The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- *Feed Point Impedance and Return Loss:* These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- *Electrical Delay:* One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- *SAR measured:* SAR measured at the stated antenna input power.
- *SAR normalized:* SAR as measured, normalized to an input power of 1 W at the antenna connector.
- *SAR for nominal TSL parameters:* The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.0
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	2450 MHz ± 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	39.2	1.80 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	37.9 ± 6 %	1.87 mho/m ± 6 %
Head TSL temperature change during test	< 0.5 °C	---	---

SAR result with Head TSL

SAR averaged over 1 cm ³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	13.1 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	51.1 W/kg ± 17.0 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	6.07 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	23.9 W/kg ± 16.5 % (k=2)

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	52.7	1.95 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	51.4 ± 6 %	2.04 mho/m ± 6 %
Body TSL temperature change during test	< 0.5 °C	---	---

SAR result with Body TSL

SAR averaged over 1 cm ³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	12.9 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	50.2 W/kg ± 17.0 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	5.98 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	23.6 W/kg ± 16.5 % (k=2)

Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL

Impedance, transformed to feed point	54.9 Ω + 4.2 j Ω
Return Loss	- 24.2 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	50.9 Ω + 6.3 j Ω
Return Loss	- 24.0 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.163 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
Manufactured on	November 19, 2014

DASY5 Validation Report for Head TSL

Date: 16.02.2018

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 2450 MHz; Type: D2450V2; Serial: D2450V2 - SN: 965


Communication System: UID 0 - CW; Frequency: 2450 MHz
Medium parameters used: $f = 2450$ MHz; $\sigma = 1.87$ S/m; $\epsilon_r = 37.9$; $\rho = 1000$ kg/m³
Phantom section: Flat Section
Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:


- Probe: EX3DV4 - SN7349; ConvF(7.88, 7.88, 7.88); Calibrated: 30.12.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 5.0 (front); Type: QD 000 P50 AA; Serial: 1001
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Head Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:

Measurement grid: dx=5mm, dy=5mm, dz=5mm
Reference Value = 112.7 V/m; Power Drift = -0.05 dB
Peak SAR (extrapolated) = 26.2 W/kg
SAR(1 g) = 13.1 W/kg; SAR(10 g) = 6.07 W/kg
Maximum value of SAR (measured) = 20.7 W/kg



Impedance Measurement Plot for Head TSL



DASY5 Validation Report for Body TSL

Date: 16.02.2018

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 2450 MHz; Type: D2450V2; Serial: D2450V2 - SN: 965

Communication System: UID 0 - CW; Frequency: 2450 MHz

Medium parameters used: $f = 2450$ MHz; $\sigma = 2.04$ S/m; $\epsilon_r = 51.4$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(8.01, 8.01, 8.01); Calibrated: 30.12.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 5.0 (back); Type: QD 000 P50 AA; Serial: 1002
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Body Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 104.7 V/m; Power Drift = -0.03 dB


Peak SAR (extrapolated) = 25.8 W/kg


SAR(1 g) = 12.9 W/kg; SAR(10 g) = 5.98 W/kg

Maximum value of SAR (measured) = 20.0 W/kg



Impedance Measurement Plot for Body TSL





**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Client **HCT (Dymstec)**

Certificate No: **D2600V2-1106_Dec17**

CALIBRATION CERTIFICATE

Object: **D2600V2 - SN:1106**

Calibration procedure(s): **QA CAL-05.v9
Calibration procedure for dipole validation kits above 700 MHz**

Calibration date: **December 15, 2017**

결 재	담당자	확인자
	<i>[Signature]</i> 2018.06.04 SU 28.013	<i>[Signature]</i> 2018.12.14 67/12/14

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility; environment temperature (22 ± 3)°C and humidity < 70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Power meter NRP	SN: 104778	04-Apr-17 (No. 217-02521/02522)	Apr-18
Power sensor NRP-Z91	SN: 103244	04-Apr-17 (No. 217-02521)	Apr-18
Power sensor NRP-Z91	SN: 103245	04-Apr-17 (No. 217-02522)	Apr-18
Reference 20 dB Attenuator	SN: 5058 (20k)	07-Apr-17 (No. 217-02528)	Apr-18
Type-N mismatch combination	SN: 5047.2 / 06327	07-Apr-17 (No. 217-02529)	Apr-18
Reference Probe EX3DV4	SN: 7349	31-May-17 (No. EX3-7349_May17)	May-18
DAE4	SN: 601	26-Oct-17 (No. DAE4-601_Oct17)	Oct-18

Secondary Standards	ID #	Check Date (In house)	Scheduled Check
Power meter EPM-442A	SN: GB37480704	07-Oct-15 (In house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: US37292783	07-Oct-15 (In house check Oct-16)	In house check: Oct-18
Power sensor HP 8481A	SN: MY41092317	07-Oct-15 (In house check Oct-16)	In house check: Oct-18
RF generator R&S SMT-06	SN: 100972	15-Jun-15 (In house check Oct-16)	In house check: Oct-18
Network Analyzer HP 8753E	SN: US37390585	18-Oct-01 (In house check Oct-17)	In house check: Oct-18

	Name	Function	Signature
Calibrated by:	Leif Klysner	Laboratory Technician	<i>[Signature]</i>
Approved by:	Katja Pokovic	Technical Manager	<i>[Signature]</i>

issued: December 18, 2017

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

**Calibration Laboratory of
Schmid & Partner
Engineering AG**
Zeughausstrasse 43, 8004 Zurich, Switzerland



S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: **SCS 0108**

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORM x,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

- IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
- IEC 62209-1, "Measurement procedure for the assessment of Specific Absorption Rate (SAR) from hand-held and body-mounted devices used next to the ear (frequency range of 300 MHz to 6 GHz)", July 2016
- IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
- KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

- DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- Measurement Conditions:* Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- Antenna Parameters with TSL:* The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- Feed Point Impedance and Return Loss:* These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- Electrical Delay:* One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- SAR measured:* SAR measured at the stated antenna input power.
- SAR normalized:* SAR as measured, normalized to an input power of 1 W at the antenna connector.
- SAR for nominal TSL parameters:* The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.10.0
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	2600 MHz ± 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	39.0	1.96 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	37.1 ± 6 %	2.03 mho/m ± 6 %
Head TSL temperature change during test	< 0.5 °C	----	----

SAR result with Head TSL

SAR averaged over 1 cm ³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	14.5 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	56.4 W/kg ± 17.0 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	6.35 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	25.0 W/kg ± 16.5 % (k=2)

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	52.5	2.16 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	51.0 ± 6 %	2.22 mho/m ± 6 %
Body TSL temperature change during test	< 0.5 °C	----	----

SAR result with Body TSL

SAR averaged over 1 cm ³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	13.9 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	54.6 W/kg ± 17.0 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	6.13 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	24.2 W/kg ± 16.5 % (k=2)

Appendix (Additional assessments outside the scope of SCS 0108)**Antenna Parameters with Head TSL**

Impedance, transformed to feed point	47.8 Ω - 8.3 j Ω
Return Loss	- 21.2 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	44.7 Ω - 5.9 j Ω
Return Loss	- 21.6 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.150 ns
----------------------------------	----------

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
Manufactured on	February 18, 2015

DASY5 Validation Report for Head TSL

Date: 15.12.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 2600 MHz; Type: D2600V2; Serial: D2600V2 - SN: 1106

Communication System: UID 0 - CW; Frequency: 2600 MHz

Medium parameters used: $f = 2600$ MHz; $\sigma = 2.03$ S/m; $\epsilon_r = 37.1$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(7.96, 7.96, 7.96); Calibrated: 31.05.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 5.0 (front); Type: QD 000 P50 AA; Serial: 1001
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Head Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 113.0 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 32.1 W/kg


SAR(1 g) = 14.5 W/kg; SAR(10 g) = 6.35 W/kg

Maximum value of SAR (measured) = 23.6 W/kg



0 dB = 23.6 W/kg = 13.73 dBW/kg

Impedance Measurement Plot for Head TSL



DASY5 Validation Report for Body TSL

Date: 15.12.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 2600 MHz; Type: D2600V2; Serial: D2600V2 - SN: 1106

Communication System: UID 0 - CW; Frequency: 2600 MHz

Medium parameters used: $f = 2600$ MHz; $\sigma = 2.22$ S/m; $\epsilon_r = 51$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN7349; ConvF(7.94, 7.94, 7.94); Calibrated: 31.05.2017;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 5.0 (back); Type: QD 000 P50 AA; Serial: 1002
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Body Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:


Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 104.4 V/m; Power Drift = -0.08 dB


Peak SAR (extrapolated) = 29.9 W/kg

SAR(1 g) = 13.9 W/kg; SAR(10 g) = 6.13 W/kg


Maximum value of SAR (measured) = 22.4 W/kg



Impedance Measurement Plot for Body TSL



Impedance Measurement Plot for Head TSL



DASY5 Validation Report for Body TSL

Date: 13.12.2017

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole D5GHzV2; Type: D5GHzV2; Serial: D5GHzV2 - SN: 1107

Communication System: UID 0 - CW; Frequency: 5250 MHz, Frequency: 5600 MHz, Frequency: 5750 MHz

Medium parameters used: $f = 5250$ MHz; $\sigma = 5.51$ S/m; $\epsilon_r = 47.1$; $\rho = 1000$ kg/m³,Medium parameters used: $f = 5600$ MHz; $\sigma = 5.97$ S/m; $\epsilon_r = 46.5$; $\rho = 1000$ kg/m³,Medium parameters used: $f = 5750$ MHz; $\sigma = 6.18$ S/m; $\epsilon_r = 46.2$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 - SN3503; ConvF(5.14, 5.14, 5.14); Calibrated: 31.12.2016, ConvF(4.57, 4.57, 4.57); Calibrated: 31.12.2016, ConvF(4.51, 4.51, 4.51); Calibrated: 31.12.2016;
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 26.10.2017
- Phantom: Flat Phantom 5.0 (back); Type: QD 000 P50 AA; Serial: 1002
- DASY52 52.10.0(1446); SEMCAD X 14.6.10(7417)

Dipole Calibration for Body Tissue/Pin=100mW, dist=10mm, f=5250 MHz/Zoom Scan,**dist=1.4mm (8x8x7)/Cube 0:** Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 66.06 V/m; Power Drift = -0.04 dB

Peak SAR (extrapolated) = 30.6 W/kg

SAR(1 g) = 7.79 W/kg; SAR(10 g) = 2.17 W/kg

Maximum value of SAR (measured) = 18.5 W/kg

Dipole Calibration for Body Tissue/Pin=100mW, dist=10mm, f=5600 MHz/Zoom Scan,**dist=1.4mm (8x8x7)/Cube 0:** Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 64.93 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 34.6 W/kg

SAR(1 g) = 8.09 W/kg; SAR(10 g) = 2.26 W/kg

Maximum value of SAR (measured) = 19.9 W/kg


Dipole Calibration for Body Tissue/Pin=100mW, dist=10mm, f=5750 MHz/Zoom Scan,**dist=1.4mm (8x8x7)/Cube 0:** Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 62.90 V/m; Power Drift = -0.08 dB

Peak SAR (extrapolated) = 34.0 W/kg

SAR(1 g) = 7.65 W/kg; SAR(10 g) = 2.13 W/kg

Maximum value of SAR (measured) = 19.0 W/kg



Impedance Measurement Plot for Body TSL

