

20230530_SystemPerformancecheck D2450V2_SN939

Frequency: 2450 MHz; Communication System Channel Number: 0; Duty Cycle: 1:1
 Room Ambient Temperature: 23.0°C; Liquid Temperature: 22.0°C
 Medium parameters used: $f = 2450$ MHz; $\sigma = 1.837$ S/m; $\epsilon_r = 38.501$; $\rho = 1000$ kg/m³

DASY5 Configuration:

- Area Scan Setting: Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.012W/kg
- Electronics: DAE4 Sn912; Calibrated: 11/16/2022
- Probe: EX3DV4 - SN7646; ConvF(8.42, 8.42, 8.42) @ 2450 MHz; Calibrated: 3/23/2023
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Phantom: ELI V6.0 (20deg probe tilt); Phantom section: Flat Section ; Type: QD OVA 002 AA
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14 (7483)

Head/2450MHz, Pin=100mW/Area Scan (6x8x1): Measurement grid: dx=12mm, dy=12mm
 Maximum value of SAR (measured) = 7.92 W/kg


Head/2450MHz, Pin=100mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 62.47 V/m; Power Drift = 0.06 dB

Peak SAR (extrapolated) = 11.9 W/kg

SAR(1 g) = 5.24 W/kg; SAR(10 g) = 2.3 W/kg

Maximum value of SAR (measured) = 9.27 W/kg



0 dB = 9.27 W/kg = 9.67 dBW/kg