


THIS DETECTOR IS FOR CO & SMOKE DETECTION USE ONLY. FOR SAFETY INFORMATION AND INSTRUCTIONS REFER TO INSTRUCTION MANUAL: WI2546 HOUSEHOLD USE ONLY.
FOR ALL SIGNAL INDICATORS, PLEASE REFER TO MANUAL.
WARNING HUMIDITY MAY REDUCE BATTERY LIFE.
Test the detector for correct operation using the test button, whenever the battery is replaced.
For repair return to the place of purchase or return to NAPCO.
NAPCO Security Technologies, Inc. 333 Bayview Avenue, Amityville, NY 11701, USA
<http://www.napcosecurity.com>
FCC ID: AD8SMK319



CW

PRIMA SMK-CO
SN ID: 5967815



NAPCO
SMOKE DETECTOR

STD 2034 4th 8 U.L. STD 217 8th
P/15

CO Alarm Response Time	
70 ppm	180 - 240 minutes
150 ppm	10 - 50 minutes
400 ppm	4 - 15 minutes

SE: 1.41 - 2.28 %R
4.4°C - 37.8°C (40°F - 100°F)
TEST DETECTOR WEEKLY

ver. Insert battery into the "+" and "-" ends aligned properly. Please press to check early.