

# Appendix A

## System Validation Plots

### Table of Contents

1. D2450V2-SN: 904 Validation Plot ..... 3

# 1. D2450V2-SN: 904 Validation Plot

Date: 15.05.2024

Test Laboratory: Guangdong Dongdian Testing Service Co., Ltd.

**2450****DUT: Dipole 2450 MHz D2450V2; Serial: D2450V2 - SN:904**Communication System: UID 0, CW (0); Communication System Band: D2450 (2450.0 MHz); Frequency: 2450 MHz; Communication System PAR: 0 dB; PMF: 1  
Medium parameters used:  $f = 2450$  MHz;  $\sigma = 1.822$  S/m;  $\epsilon_r = 39.222$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section

Measurement Standard: DASYS (IEEE/IEC/ANSI C63.19-2011)

DASY Configuration:

- Probe: EX3DV4 - SN3906; ConvF(7.95, 7.95, 7.95); Calibrated: 29.04.2024;
- Sensor-Surface: 3mm (Mechanical Surface Detection), Sensor-Surface: 4mm (Mechanical Surface Detection),  $z = 1.0, 31.0$
- Electronics: DAE4 Sn1366; Calibrated: 29.04.2024
- Phantom: ELI v5.0; Type: QDOVA002AA; Serial: TP:1197
- DASY52 52.8.8(1222); SEMCAD X 14.6.10(7331)

**Configuration/tilt/Area Scan (6x11x1):** Measurement grid: dx=10mm, dy=10mm  
Maximum value of SAR (measured) = 14.6 W/kg**Configuration/tilt/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm  
Reference Value = 87.75 V/m; Power Drift = -0.18 dB  
Peak SAR (extrapolated) = 26.4 W/kg  
SAR(1 g) = 12.8 W/kg; SAR(10 g) = 6.01 W/kg