



**NOTIFIER**  
by Honeywell

**SWIFT**  
MONITOR MODULE  
N04-5217-050

COUNTRY OF ORIGIN: MEXICO

SIGMA INC  
**UL**  
LISTED  
3KGS

**FM**  
APPROVED

FIRE ALARM EQUIPMENT  
3.3V

↑  
TOP

T1 B (\*) FOR INDOOR, DRY APPLICATIONS ONLY  
SEE 156-4067 REV. 004 FOR INSTALLATION INSTRUCTIONS  
ALL CIRCUITS ARE POWER LIMITED

T2 B (-) WARNING: REPLACE BATTERIES WITH PANASONIC CR123A OR  
DURACELL DL123A BATTERIES. USE OF ANOTHER BATTERY  
MAY PRESENT RISK OF FIRE OR EXPLOSION.

THIS DEVICE COMPLIES WITH PART 15 OF THE FCC RULES.  
OPERATION IS SUBJECT TO THE FOLLOWING TWO CONDITIONS:  
(1) THIS DEVICE MAY NOT CAUSE HARMFUL INTERFERENCE, AND  
(2) THIS DEVICE MUST ACCEPT ANY INTERFERENCE RECEIVED  
INCLUDING INTERFERENCE THAT MAY CAUSE UNDESIRABLE OPERATION.

FCC ID: AUBSWIFMONITOR  
E1: 573X-SWIFMONITOR  
REMOVAL OF LABEL PROHIBITED  
E1AT: WWW.FIREPAT.NET

REMOVE BATTERIES FROM  
DEVICE PRIOR TO SHIPPING.  
RETURN TO:  
NOTIFIER  
NORTHFORD, CT U.S.A.



TENS



ONES

LOOP

ADDRESS