



**SYSTEM  
SENSOR**



**SWIFT<sup>®</sup>**  
**MODEL NO. W-SYNC**  
CONTROL MODULE  
N04-0003-050

COUNTRY OF  
ORIGIN: MEXICO



SIGNALING



LISTED

3KGS

FIRE ALARM  
EQUIPMENT

3.3V



T1 CTRL +

FOR INDOOR, DRY APPLICATIONS ONLY  
ALL CIRCUITS ARE POWER LIMITED

T2 CTRL -

**WARNING** REPLACE BATTERIES WITH PANASONIC CR123  
OR DURACELL DL123A BATTERIES. USE OF ANOTHER  
BATTERY MAY PRESENT RISK OF FIRE OR EXPLOSION.  
SEE I56-6518 FOR INSTALLATION INSTRUCTIONS.

T3 SUP +

THIS DEVICE COMPLIES WITH PART 15 OF THE FCC RULES.  
OPERATION IS SUBJECT TO THE FOLLOWING TWO CONDITIONS:  
(1) THIS DEVICE MAY NOT CAUSE HARMFUL INTERFERENCE, AND  
(2) THIS DEVICE MUST ACCEPT ANY INTERFERENCE RECEIVED  
INCLUDING INTERFERENCE THAT MAY CAUSE  
UNDESIRABLE OPERATION.

T4 SUP -

T5 24V +

FCC: AUBSWIFTSYNC  
IC: 573X-SWIFTSYNC  
REMOVAL OF LABEL  
PROHIBITED  
PAT: WWW.FIREPAT.NET

REMOVE BATTERIES FROM  
DEVICE PRIOR TO SHIPPING.  
RETURN TO:  
HONEYWELL  
EL PASO, TX U.S.A.


T6 24V -

T7 SYNC +

T8 SYNC -



TENS



ONES

LOOP

ADDRESS