

Interactive Technologies Inc

EXHIBIT A ID Label / Location

Model: 60-874-95R

Power Input: 120 VAC, 15W
Power Output: 8 VAC, 300 mA

TRANSFORMER

This Equipment should be installed in accordance with chapter 2 of the National Fire Alarm Code ANSI/NFPA 72-1993 (National Fire Protection Association, Batterymarch Park, Quincy, MA 02669)

INTERNAL BATTERY: 8VDC The battery is automatically tested every 4 hours.

REPLACE BATTERY EVERY 3-5 YEARS WITH EXACT REPLACEMENT ONLY: Interlogix Part Number 34-057
Wiring Diagram: See installation Manual 466-1821.

This system is intended to be checked by a qualified technician at least every three years.

This device complies with FCC rules Part 15. Operation is subject to the following two conditions: 1) this device may not cause harmful interference and (2) this device must accept any interference that may be received, including interference that may cause undesired operation.

Interlogix Inc.
2266 North 2nd Street
North St. Paul, MN 55109

FCC ID: B4Z-785B-ALGRO

WARNING:

DO NOT CONNECT TO A RECEPTACLE CONTROLLED BY A SWITCH. HIGH VOLTAGE; DISCONNECT TELCO BEFORE SERVICING. CAUTION: IMPROPER CONNECTIONS MAY RESULT IN DAMAGE TO THE EQUIPMENT.

US Patents 4,855,713, 4,864,636 and others pending

422-1932-02 Rev A

02/20/02 10:52 AM

FCC ID: B4Z-785B-ALGRO

W:\iti2\vol2\PRJ\DEG\ACTIVE\60-874-95R Allegro\Approvals-Listings-Technical File\FCC\Part 15
Submittal\peices\id_label.DOC