

Test Laboratory: Compliance Certification Services

System Performance Check - D1450V2

DUT: Dipole 1450 MHz; Type: D1450V2; Serial: 1020

Communication System: System Check Signal - CW; Frequency: 1450 MHz; Duty Cycle: 1:1

Medium parameters used: $f = 1450$ MHz; $\sigma = 1.36$ mho/m; $\epsilon_r = 52.2$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Room Ambient Temperature: 24.0 deg. C; Liquid Temperature: 23.0 deg. C

DASY4 Configuration:

- Area Scan setting - Find Secondary Maximum Within: 2.0 dB and with a peak SAR value greater than 0.0012W/kg
- Probe: EX3DV4 - SN3686; ConvF(7.13, 7.13, 7.13); Calibrated: 3/23/2009
- Sensor-Surface: 3mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn427; Calibrated: 10/20/2008
- Phantom: Flat Phantom ELI4.0; Type: QDOVA001BA; Serial: SN:1003
- Measurement SW: DASY4, V4.7 Build 80; Postprocessing SW: SEMCAD, V1.8 Build 186

d=10mm, Pin=250mW/Area Scan (7x7x1): Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (measured) = 9.82 mW/g

d=10mm, Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm


Reference Value = 85.8 V/m; Power Drift = 0.068 dB

Peak SAR (extrapolated) = 54.8 W/kg

SAR(1 g) = 32.2 mW/g; SAR(10 g) = 18 mW/g

Normalized to target power = 1 W and actual power = 0.25 W

Maximum value of SAR (measured) = 40.1 mW/g



0 dB = 40.1mW/g

Test Laboratory: Compliance Certification Services

System Performance Check - D1450V2

DUT: Dipole 1450 MHz; Type: D1450V2; Serial: 1020

Communication System: System Check Signal - CW; Frequency: 1450 MHz; Duty Cycle: 1:1

d=10mm, Pin=250mW/Area Scan (7x7x1): Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (measured) = 9.82 mW/g

d=10mm, Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 85.8 V/m; Power Drift = 0.068 dB

Peak SAR (extrapolated) = 54.8 W/kg

SAR(1 g) = 32.2 mW/g; SAR(10 g) = 18 mW/g

Normalized to target power = 1 W and actual power = 0.25 W

Maximum value of SAR (measured) = 40.1 mW/g

d=10mm, Pin=250mW/Z Scan (1x1x34): Measurement grid: dx=20mm, dy=20mm, dz=3mm

Maximum value of SAR (measured) = 10.0 mW/g

