

## APPENDIX B: SYSTEM VERIFICATION

# ELEMENT

**DUT: Dipole 3500.0 MHz; Type: D3500V2 - SN1055**

Communication System: UID: 0, CW; Frequency: 3500.0 MHz  
Medium: 3600 Head; Medium parameters used:  
f = 3500.0 MHz; cond = 2.91 S/m; perm = 36.5; density = 1000 kg/m<sup>3</sup>  
Phantom Section: Flat; Space: 10 mm

Test Date: 07/10/2022; Ambient Temp: 21.6°C; Tissue Temp: 20.6°C

Probe: EX3DV4 - SN7639; ConvF:(7.58,7.58,7.58); Calibrated: 2021-11-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1646; Calibrated: 2021-11-11  
Phantom: Twin-SAM V8.0; Serial: 1736  
Measurement SW: DASY Module SAR V16.2.0.1425

## 3500 MHz System Verification at 20 dBm (100 mW)


**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0 mm, dy=10.0 mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0 mm, dy=5.0 mm, dz=1.4 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 18.8 W/kg

**SAR(1 g) = 6.84 W/kg; SAR(10 g) = 2.56 W/kg**

Deviation (1 g) = 0.88%; Deviation (10 g) = -2.18%;



# ELEMENT

**DUT: Dipole 3700.0 MHz; Type: D3700V2 - SN1002**

Communication System: UID: 0, CW; Frequency: 3700.0 MHz  
Medium: 3600 Head; Medium parameters used:  
f = 3700.0 MHz; cond = 3.06 S/m; perm = 36.2; density = 1000 kg/m<sup>3</sup>  
Phantom Section: Flat; Space: 10 mm

Test Date: 07/10/2022; Ambient Temp: 21.6°C; Tissue Temp: 20.6°C

Probe: EX3DV4 - SN7639; ConvF:(7.39,7.39,7.39); Calibrated: 2021-11-16  
Sensor-Surface: 1.4mm (VMS + 6p)  
Electronics: DAE4 Sn1646; Calibrated: 2021-11-11  
Phantom: Twin-SAM V8.0; Serial: 1736  
Measurement SW: DASY Module SAR V16.2.0.1425

## 3700 MHz System Verification at 20 dBm (100 mW)

**Area Scan (40.0 x 80.0):** Measurement grid: dx=10.0 mm, dy=10.0 mm

**Zoom Scan (28.0 x 28.0 x 28.0):** Measurement grid: dx=5.0 mm, dy=5.0 mm, dz=1.4 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 18.8 W/kg

**SAR(1 g) = 6.73 W/kg; SAR(10 g) = 2.45 W/kg**

Deviation (1 g) = -2.18%; Deviation (10 g) = -1.61%;

