


| | | | |
|--|--|---|--|
| PHOTOELECTRONIC DETECTION PRINCIPLE AND 135°F (57°C) THERMAL MAXIMUM INSTALLATION AMBIENT TEMPERATURE 100°F (37.8°C) S911 | | ADEMCO | |
| | | MODEL 5808AP | |
| | | SMOKE DETECTOR/TRANSMITTER | |
| | | FCC ID: CFS8DL5808AP | |
| UL LISTED | | THIS DEVICE COMPLIES WITH PART 15 OF THE FCC RULES. OPERATION IS SUBJECT TO THE FOLLOWING CONDITIONS: (1) THIS DEVICE MAY NOT CAUSE HARMFUL INTERFERENCE, AND (2) MUST ACCEPT ANY INTERFERENCE RECEIVED, INCLUDING INTERFERENCE THAT MAY CAUSE UNDESIRABLE OPERATION | |
| SMOKE-AUTOMATIC FIRE DETECTOR WITH INTEGRAL HEAT DETECTOR FOR OPEN AREA PROTECTION. | | | |
| ISSUE NO. N10742 | | | |
| WARNING: REPLACE BOTH BATTERIES WITH JAPANAGONIC OR 123A OR ADEMCO 466 ONLY. WAIT 15 SECONDS AFTER REMOVAL OF OLD BATTERIES BEFORE INSERTING NEW BATTERIES. | | ADEMCO SMOKE DETECTOR TRANSMITTER | |
| USE OF ANOTHER BATTERY MAY PRESENT RISK OF FIRE OR EXPLOSION. SEE OWNER'S MANUAL FOR SAFETY PRECAUTIONS. | | Honeywell International Inc. 165 Eileen Way Syosset, NY 11791 | |
| NO4-1251-15 MADE IN MEXICO | | FM APPROVED | |
| | |  | |
| | | TEST WEEKLY BY DEPRESSING THE TEST BUTTON. | |