

ASSY	REV	PRODUCTION RELEASE	DNM	6/16/00

SW1: DIP SWITCH SETTING		APPROVALS	DATE
ON	OFF		
1 REPEATING TRANSMISSIONS ONCE EVERY 4 SECONDS	ONE TRANSMISSION PER CHANGE OF STATE OF LOOP INPUT	CHECKED BY	
2 LOOP INPUT RESPONSE IS FOR NORMALLY OPEN CONTACT	LOOP INPUT RESPONSE IS FOR NORMALLY CLOSED CONTACT	APPROVED BY	
3 SLOW LOOP INPUT RESPONSE	FAST LOOP INPUT RESPONSE		
4 TRANSMISSION INHIBIT FOR 3 MINUTES FOLLOWING RESTORE TRANSMISSION	NO TRANSMISSION INHIBIT		

PCB (REF) K4667 REV A		165 EILEEN WAY SYOSSET, NEW YORK 11791	
TITLE		DRAWING NUMBER	
COMPUTER		581708	
FILE NAME		581708.SCH	
DATE: 10/1/99		SHEET 1 OF 1	

