



**ADEMCO Inc. PROWLTOUCHC**

**FCC / ISED STATEMENT**

This device complies with Part 15 of the FCC Rules, and ISED's license-exempt RSSs. Operation is subject to the following two conditions: (1) This Device may not cause harmful interference. (2) This device must accept any interference received, including that may cause undesired operation.  
FCC ID: CFS8DLPROWLTOUCH See Instructions 800-25191 Rev. A dtd 6/19  
IC: 573F-PROWLTOUCH  
HVIN: PROWLTOUCHC Country of Origin: China

This equipment should be installed in accordance with Chapter 2 of the National Fire Alarm Code, ANSI/NFPA 72, (National Fire Protection Association, Batterymarch Park, Quincy, MA 02269). Printed information describing proper installation, operation, testing, maintenance, evacuation planning, and repair service is to be provided with this equipment.

**Warning: Owner's Instruction Notice:** Not to be removed by anyone except occupant  
**Avertissement : Avis du propriétaire :** « Ne doit être retiré par personne, sauf l'occupant. »

**WEEKLY TESTING IS REQUIRED** 800-25193A 8/19 Rev A

**800-25193A PROWLTOUCH  
8/19 Rev A**