

*EQUIPMENT: WLS906NB433 Smoke Detector*  
*FCC ID: F5300NB906*

---

**Rationale for Compliance with Transmission Requirements**

- 15.231(a)(1) :** Not applicable. This equipment has no provision for manual operation.
- 15.231(a)(2) :** Not applicable as per 15.231(a)(4).
- 15.231(a)(3) :** Supervisory transmissions occur at the rate of one transmission of 40 ms duration every 64 minutes..
- 15.231(a)(4) :** This equipment is used for fire, security and safety of life. See attached time domain graph.