

DSC

Thursday, December 11, 2014



High 0°
Low 0°



M/N: SCW9067C
IC: 160A-SCW9067
CAN ICES-3 (B)/NMB-3(B)
FCC ID: F5315SCW9067

Contains
M/N: CNN0301 with
FCC ID: MIVCNN0301 IC: 4160A-CNN0301
Made in China



This equipment should be in accordance with Chapter 2 of the National Fire Alarm Code
ANSI/NFPA 72-1993 (National Fire Protection Association, Batterymarch Park Quincy,
MA 02559) Internal Battery is 12 VDC. The battery is automatically tested every second.
Replace rechargeable battery with IQ Battery/24, UL985 or IQ Battery/04, UL 1023 Printed
information describing proper installation, operation, testing, maintenance, evacuation
planning, and repair service is to be provided with this equipment. Refer to the IQ Panel
Quick Guide for proper installation.
**WARNING: OWNER'S INSTRUCTION NOTICE: NOT TO BE
REMOVED BY ANYONE EXCEPT OCCUPANT.**
**ATTENTION: NOTICE D'INSTRUCTION DU PROPRIÉTAIRE:
NON ÊTRE ENLEVÉ PAR UNE PERSONNE AUTRE OCCUPANT**
This system must be checked by a qualified technician at least once every three (3) years.