

Test Laboratory: Compliance Certification Services
File Name: D2450V2_013003_mW.da4

DUT: Dipole Type & Serial Number: D2450V2 SN 706
Program: System Validation; D2450V2 SN 706

Communication System: D2450V2 SN 706; Frequency: 2450 MHz; Duty Cycle: 1:1
Medium: Head 2450 MHz ($\sigma = 1.8809$ mho/m, $\epsilon = 39.98$, $\rho = 1000$ kg/m³)
Phantom section: FlatSection

DASY4 Configuration:

- Probe: ET3DV6 - SN1578; ConvF(4.5, 4.5, 4.5); Calibrated: 2/22/2002
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn500; Calibrated: 2/26/2002
- Phantom: SAM 1 - TP: 1185
- Software: DASY4, V4.0 Build 51

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=7.5mm, dy=7.5mm

Reference Value = 85.8 V/m

Peak SAR = 37.9 mW/g

SAR(1 g) = 14 mW/g; SAR(10 g) = 5.89 mW/g

Power Drift = 0.03 dB

Area Scan (9x9x1): Measurement grid: dx=10mm, dy=10mm

