

## **EMC EMISSIONS - TEST REPORT (In Part)**

Test Report No.	3162583DEN-004D	Issue Date:	Thursday 18/Dec/2008
Model / Serial No.	MN: EN1242 /SN: 3803179		
Product Type	Wireless Smoke Sensor		
Client	Inovonics Wireless Corporati	ion	
Manufacturer	Inovonics Wireless Corporati	ion	
License holder	Inovonics Wireless Corporati	ion	
Address	315 - CTC Boulevard		
	Louisville, CO 80027		
Test Criteria Applied Test Result	FCC 47 CFR Part 15.2 PASS		R 15: RADIO FREQUENCY
Test Project Number References	3162583	DEVICES	- Intentional Radiators
Total Pages Including Appendices:	26		
Randy Thompson	~	Midwel	Spoto
Tested By : Randy	Thompson Revi	ewed By! Micha	ael <i>"</i> Spataro

REVISION SUMMARY - The following changes have been made to this Report:

TED TEDIO	table is the following changes have been made to this report.							
Rev.	Revision Statement	Author	Revision Date	Reviewer				
	Initial Release of Document	See above	See above					

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This report must not be used to claim product endorsement by NVLAP, NIST nor any other agency of the U.S. Government. Measurement uncertainty is not incorporated in to the PASS/FAIL results as stated above. A statement of uncertainty is made on page 2 and is for informational purposes.

### DIRECTORY

Documentation	Page(s)
Test report	1 - 26
Directory	2
Test Regulations	3
General Remarks	4
Test-setup Photographs	5 - 6
Appendix A	
Test Data Sheets and Test Equipment Used	7 - 13
Appendix B	
Test Plan/Constructional Data Form	14 - 21
Appendix C	
Measurement Protocol/Test Procedures	22 - 26

### STATEMENT OF MEASUREMENT UNCERTAINTY

The data and results referenced in this document are true and accurate. The measurement uncertainty for Conducted Emissions in the frequency range of 150 kHz - 30 MHz is calculated to be  $\pm 3.14 \text{dB}$  and for Radiated Emissions is calculated to be  $\pm 4.4 \text{dB}$  in the frequency range of 10 kHz - 1000 MHz at 3m and  $\pm 4.9 \text{dB}$  in the frequency range of 1 - 18 GHz at 3m. For testing at  $10 \text{m} \pm 4.8 \text{dB}$  in the frequency range of 30 - 1000 MHz. For Disturbance Power,  $\pm 3.3 \text{dB}$  in the frequency range of 30 - 1000 MHz. For Flicker and Harmonics testing the equipment used is calibrated by the manufacture and is with in the tolerances specified in 61000-3-2/3. These uncertainties have been calculated using CISPR 16-4-2:2003 and represent a 95% confidence level (k=2).

EUT Received Date: 22-August-2008

Testing Start Date: 22-August-2008

Testing End Date: 22-August-2008

The tests were performed according to following regulations:

1. FCC CFR47 Part 15 subpart C

**Emission Test Results:** 

Conducted Emissions 15.207 - NA

**Test Result** 

Minimum limit margin 0.0 dB at 0.0 MHz

Remarks: EUT is powered via battery.

Radiated Unintentional and Spurious Emissions 15.247(D) /15.205/209 - NA

Test Result

Minimum limit margin 0.0 dB at 0.0 MHz

Remarks: Refer to Report: 3162583DEN-004B

Peak Output Power 15.247 (b)(2) - PASS

**Test Result** 

Minimum limit margin - 6.5 dB at 927.6 MHz

Remarks: High Channel

Radiated Emissions 15.205/15.247(d) - PASS

**Test Result** 

Minimum limit margin - 9.4 dB at 2707.21 MHz

Remarks: Low Channel

Project File: 3162583 Page 3 of 26

Fax: 303 449 6160

Voice: 303 786 7999

5541 Central Avenue, Suite 110 Boulder, Colorado 80301

### **GENERAL REMARKS:**

The following remarks are to be considered as "where applicable" and are taken into account while completing any FCC/IC/ETSI radio tests at Intertek.

Testing was performed in 3 different orthogonal axis to determine the worst case emissions from the device. The worst case emissions measurements are shown in this report.

FCC CFR47 Part 15.31: Measurement Standards: In any case where the device is powered off a battery, a fresh battery was used during test. In cases where the device is powered off an AC supply, voltage was varied per Part 15.31 to find worst case emissions.

FCC CFR47 Part 15.35: Measurement Detector Functions and Bandwidths: FCC Part 15.35 was utilized when performing the measurements within this report.

Whenever possible the approved test procedures specified in FCC DA 00-705 for FHSS devices was used for testing.

### **Limit Calculation:**

At the time of testing, Intertek was unable to obtain the gain of the antenna for the EUT from the manufacture of the EUT or from the manufacture of the antenna. Therefore, the following calculation was used to determine the field strength limit for a test distance of 3m.

This calculation assumes ideal isotropic radiation from the source.

P = 20\*log(E)-95.2289

P is power in dBm E is uV/m

**EUT** is battery powered.

Only the fundamental and harmonics of the fundamental are covered in this report, as requested by the customer.

<u>Sample:</u> ⊠Production	□Prototype	□See Annex B	
Modifications re	quired to pass:	None	
Test Specification	on Deviations: A	dditions to or Exclusion	ons from: None

Project File: 3162583 Page 4 of 26

Fax: 303 449 6160

Voice: 303 786 7999

Rev.No 1


Test-setup photo(s): Radiated Intentional Emissions: Worst-Case Axis 3





Appendix A	
Test Data Sheets	
and  Test Equipment Used	
, see <u> </u>	

Project File: 3162583 Page 7 of 26



# Field Strength Measurements Fundamental and Spurious of the Transmitter

Test Report #:	3162583	Test Area:	Pinewood Site 1 (3m)	Temperature:	22.1	°C		
Test Method:	FCC 15.247	Test Date:	22-Aug-2008	Relative Humidity:	34.6	<del></del> %		
EUT Model #:	EN1242	EUT Power:	3.3VDC Battery	Air Pressure:	99.1	kPa		
EUT Serial #:	3803179	_		<u>.</u>				
Manufacturer:	Inovonics Wireless Corporation			Lev	Level Key			
EUT Description:	Wireless Smoke Detector			Pk – Peak	Nb – Na	arrow Band		
Notes:				Qp – QuasiPeak	Bb – Br	oad Band		
				Av - Average				

FREQ	LEVEL	CABLE / ANT / PREAMP	FINAL	POL / HGT / AZ	Duty Cycle Correction	Final Corrected	Limit	DELTA
(MHz)	(dBuV)	(dB) (dB\m) (dB)	(dBuV)	(m) (DEG)	(dB)	(dBuV/m)	(dBuV/m)	(dB)

The following Duty Cycle was declared by the manufacturer:

### 20.8%

Averaging method for pulsed signals and calculation in accordance to FCC CFR47 Part 15.35 utilized to calculate field strength emissions.

The testing performed in accordance to FCC CFR47 Part 15.205 (restricted bands of operation) and 15.247 emissions and delta limits were calculated as follows:

Final Corrected Peak Measurement - Duty Cycle Correction Factor\* = Final Calculated Emission

The Final Calculated Emission was then compared to the Limits in CFR47 Part 15.209 and 15.247 and the emission/limit delta was calculated. the DTCF is calculated as follows 20\*log<sub>10</sub>(duty cycle in 100mS) "not to exceed 20dB"

### Part 15.247 and 15.205 Respectively


Fundamer	ntal Measure	ments						
Low Chan	nel Axis 1 - I	EUT is Flat on the tab	le.					
902.39	75.3 Pk	3.6 / 22.7 / 0.0	101.6	V / 2.3 / 30.0	0.0	101.6	119.2	-17.6
902.39	80.8 Pk	3.6 / 22.7 / 0.0	107.1	H / 1.0 / 320.0	0.0	107.1	119.2	-12.1
Axis 2 - El	JT is Vertica	l on the table.				_		
902.4	76.8 Pk	3.6 / 22.7 / 0.0	103.1	H / 2.3 / 0.0	0.0	103.1	119.2	-16.1
902.39	75.6 Pk	3.6 / 22.7 / 0.0	101.9	V / 1.2 / 210.0	0.0	101.9	119.2	-17.3
Axis 3 - El	JT is Vertica	l on the table & Rota	ed 90 Deg.	_		_		
902.39	81.5 Pk	3.6 / 22.7 / 0.0	107.7	V / 1.1 / 155.0	0.0	107.7	119.2	-11.5
902.39	78.0 Pk	3.6 / 22.7 / 0.0	104.2	H / 1.0 / 35.0	0.0	104.2	119.2	-15.0
Mid Chanr	nel Axis 1							
914.8	83.5 Pk	3.6 / 22.7 / 0.0	109.9	H / 1.0 / 325.0	0.0	109.9	119.2	-9.3
914.8	78.3 Pk	3.6 / 22.7 / 0.0	104.7	V / 1.3 / 10.0	0.0	104.7	119.2	-14.5
Axis 2								
914.79	78.5 Pk	3.6 / 22.7 / 0.0	104.9	V / 1.1 / 1.5	0.0	104.9	119.2	-14.3
914.8	76.5 Pk	3.6 / 22.7 / 0.0	102.9	H / 2.4 / 358.0	0.0	102.9	119.2	-16.3
Axis 3								
914.8	75.5 Pk	3.6 / 22.7 / 0.0	101.9	H / 2.6 / 358.0	0.0	101.9	119.2	-17.3
914.8	83.8 Pk	3.6 / 22.7 / 0.0	110.2	V / 1.1 / 10.0	0.0	110.2	119.2	-9.0
High Char	nel Axis 1							

Project File: 3162583 Page 9 of 26

5541 Central Avenue, Suite 110 Boulder, Colorado 80301 Voice: 303 786 7999 Fax: 303 449 6160

(MHz)	FREQ	LEVEL	CABLE / ANT / PREAMP	FINAL	POL / HGT / AZ	Duty Cycle Correction	Final Corrected	Limit	DELTA
927.6 83.1 Pk 3.6 / 22.8 / 0.0 109.6 H / 1.4 / 78.0 0.0 109.6 119.2 -9.6 Axis 2  927.8 81.3 Pk 3.6 / 22.8 / 0.0 106.6 H / 13 / 355.0 0.0 106.6 119.2 -12.6 927.8 81.3 Pk 3.6 / 22.8 / 0.0 107.8 V / 1.0 / 270.0 0.0 107.8 119.2 -11.4 Axis 3  927.6 86.2 Pk 3.6 / 22.8 / 0.0 112.7 V / 1.1 / 82.0 0.0 112.7 119.2 -6.5 927.6 82.0 Pk 3.6 / 22.8 / 0.0 108.4 H / 1.1 / 106.0 0.0 108.4 119.2 -10.8 Axis 3 was determined to be the worst case axis  All Harmonics - Low Channel  Harmoni	(MHz)	(dBuV)	(dB) (dB\m) (dB)	(dBuV)	(m) (DEG)	(dB)	(dBuV/m)	(dBuV/m)	(dB)
Axis   2	927.6	80.0 Pk	3.6 / 22.8 / 0.0	106.5	V / 1.2 / 78.0	0.0	106.5	119.2	-12.7
927.6 80.1 Pk 36/228/0.0 106.6 H/1.3/365.0 0.0 106.6 119.2 -12.6 927.6 81.3 Pk 36/228/0.0 107.8 V/1.0/270.0 0.0 107.8 119.2 -11.4 Axis 3  927.6 86.2 Pk 3.6/22.8/0.0 112.7 V/1.1/82.0 0.0 112.7 119.2 -6.5 927.6 82.0 Pk 3.6/22.8/0.0 108.4 H/1.1/106.0 0.0 108.4 119.2 -10.8 Axis 3 was determined to be the worst case axis  AII Harmonics - Low Channel  Harmonics - Low Channel  Harmonics - Low Channel  1804.85 88.1 Pk 3.0/26.3/38.1 82.3 V/1.0/0.0 -13.6 88.7 87.7 -19.0 1804.85 88.1 Pk 3.0/26.3/38.1 82.3 V/1.2/213.0 -13.6 66.7 87.7 -22.0 2707.21 62.8 Pk 3.8/29.7/38.1 58.2 V/1.2/213.0 -13.6 44.6 54.0 -9.4 2707.22 61.1 Pk 3.0/26.3/38.5 56.5 H/2.2/32.3 -13.6 42.9 54.0 -11.1 3609.62 52.1 Pk 5.0/31.7/38.5 50.3 V/1.8/98.0 -13.6 36.7 54.0 -17.3 3609.62 52.1 Pk 5.0/31.7/38.5 50.3 V/1.8/98.0 -13.6 36.7 54.0 -17.3 3609.62 52.1 Pk 5.0/31.7/38.5 52.8 H/1.3/142.0 -13.6 36.8 54.0 -17.2 4512.05 53.2 Pk 6.6/32.3/40.7 50.4 H/1.4/20.0 -13.6 36.8 54.0 -17.2 4512.05 53.2 Pk 6.6/32.3/40.7 50.4 H/1.4/20.0 -13.6 36.8 54.0 -17.2 4512.05 53.2 Pk 6.6/32.3/40.7 50.4 H/1.4/30.0 -13.6 37.8 54.0 -16.2 5414.46 43.2 Pk 6.9/34.3/39.9 40.7 H/1.3/350.0 -13.6 37.8 54.0 -22.1 54.0 -22.1 5414.45 39.4 Pk 6.9/34.3/39.9 40.7 H/1.3/350.0 -13.6 37.8 54.0 -22.1 5414.45 39.4 Pk 6.9/34.3/39.9 44.5 V/1.6/250.0 -13.6 30.9 54.0 -22.1 5414.45 39.4 Pk 6.9/34.3/39.9 44.5 V/1.6/250.0 -13.6 30.9 54.0 -22.1 5414.6 43.2 Pk 6.9/34.3/39.9 44.5 V/1.6/250.0 -13.6 30.9 54.0 -22.1 5414.6 43.2 Pk 6.9/34.3/39.9 44.5 V/1.6/250.0 -13.6 30.9 54.0 -22.1 5414.6 43.2 Pk 6.9/34.3/39.9 44.5 V/1.6/250.0 -13.6 36.9 54.0 -17.2 41.6 531.6 54.0 54.0 Fk 7.7 41.6 55.0 Fk 7.7 41.6 5	927.6	83.1 Pk	3.6 / 22.8 / 0.0	109.6	H / 1.4 / 78.0	0.0	109.6	119.2	-9.6
927.6 81.3 Pk 3.6 / 22.8 / 0.0 107.8 V / 1.0 / 270.0 0.0 107.8 119.2 -11.4 Axis 3    927.6 86.2 Pk 3.6 / 22.8 / 0.0 112.7 V / 1.1 / 82.0 0.0 112.7 119.2 -6.5    927.8 82.0 Pk 3.6 / 22.8 / 0.0 108.4 H / 1.1 / 106.0 0.0 108.4 119.2 -10.8    Axis 3 was determined to be the worst case axis    All Harmonics will be measured in Axis 3    Harmonics - Low Channel    1804.85 91.1 Pk 3.0 / 26.3 / 38.1 82.3 V / 1.0 / 0.0 -13.6 68.7 87.7 -19.0    1804.85 91.1 Pk 3.0 / 26.3 / 38.1 82.3 V / 1.0 / 0.0 -13.6 68.7 87.7 -22.0    2707.21 62.8 Pk 3.8 / 29.7 / 38.1 58.2 V / 1.2 / 213.0 -13.6 44.6 54.0 94.4    2707.22 61.1 Pk 3.8 / 29.7 / 38.1 58.2 V / 1.2 / 213.0 -13.6 44.6 54.0 94.4    2707.22 61.1 Pk 5.0 / 31.7 / 38.5 50.3 V / 1.8 / 98.0 -13.6 36.7 54.0 -11.1    3609.62 54.6 Pk 5.0 / 31.7 / 38.5 52.8 H / 1.3 / 142.0 -13.6 36.7 54.0 -11.3    3609.62 52.1 Pk 5.0 / 31.7 / 38.5 52.8 H / 1.3 / 142.0 -13.6 36.7 54.0 -11.2    4512.05 52.2 Pk 6.6 / 32.3 / 40.7 50.4 H / 1.4 / 20.0 -13.6 36.8 54.0 -17.2    4512.05 52.2 Pk 6.6 / 32.3 / 40.7 50.4 H / 1.4 / 20.0 -13.6 36.8 54.0 -17.2    5414.45 39.4 Pk 6.9 / 34.3 / 39.9 40.7 H / 1.3 / 350.0 -13.6 36.8 54.0 -17.2    5414.46 43.2 Pk 6.9 / 34.3 / 39.9 44.5 V / 1.6 / 20.7 0 -13.6 39.9 54.0 -22.8    5414.46 43.2 Pk 6.9 / 34.3 / 39.9 44.5 V / 1.6 / 20.7 0 -13.6 39.9 54.0 -22.3    5414.46 43.2 Pk 6.8 / 38.2 / 40.4 53.5 H / 1.4 / 30.0 -13.6 39.9 87.7 -47.8    5416.9 50.0 Pk 8.5 / 37.9 / 48.5 47.9 V / 1.0 / 13.5 0 -13.6 39.9 87.7 -47.8    5416.9 50.0 Pk 8.3 / 37.1 / 47.5 50.5 H / 1.8 / 350.0 -13.6 36.9 54.0 -17.1    5416.9 50.0 Pk 8.3 / 37.1 / 47.5 50.5 H / 1.8 / 350.0 -13.6 36.9 54.0 -17.1    5416.9 50.0 Pk 8.3 / 37.1 / 47.5 50.5 H / 1.8 / 350.0 -13.6 36.9 54.0 -17.1    5416.9 50.0 Pk 8.5 / 37.9 / 48.5 47.9 V / 1.0 / 13.5 0 -13.6 36.9 54.0 -17.1    5416.9 50.0 Pk 8.5 / 37.9 / 48.5 47.9 V / 1.0 / 13.5 0 -13.6 36.9 54.0 -17.1    5416.9 50.0 Pk 8.5 / 37.9 / 48.5 47.9 V / 1.0 / 1.3 / 30.0 -13.6 36.9 54.0 -17.1    5416.9 50.0 Pk 8.5 / 37.9 / 48.5 47.9 V / 1.0 / 13.6 36.9 54.0 -17.1    5416.9 50.0 Pk 8.5 /	Axis 2								
Axis 3	927.6	80.1 Pk	3.6 / 22.8 / 0.0	106.6	H / 1.3 / 355.0	0.0	106.6	119.2	-12.6
927.6 86.2 Pk 3.6 / 22.8 / 0.0 112.7 V / 1.1 / 82.0 0.0 112.7 119.2 -6.5 927.6 82.0 Pk 3.6 / 22.8 / 0.0 108.4 H / 1.1 / 106.0 0.0 108.4 119.2 -10.8   Axis 3 was determined to be the worst case axis  All Harmonics vill be measured in Axis 3  Harmonics vill be measured in Axis 3  Harmonics Low Channel  1804.85 91.1 Pk 3.0 / 26.3 / 38.1 82.3 V / 1.0 / 0.0 -13.6 68.7 87.7 -19.0 1804.85 91.1 Pk 3.0 / 26.3 / 38.1 79.3 H / 1.6 / 32.3 -13.6 65.7 87.7 -22.0 2707.21 62.8 Pk 3.8 / 29.7 / 38.1 58.2 V / 1.2 / 213.0 -13.6 44.6 54.0 -9.4 2707.22 61.1 Pk 3.8 / 29.7 / 38.1 58.2 V / 1.2 / 213.0 -13.6 42.9 54.0 -11.1 3609.62 54.6 Pk 5.0 / 31.7 / 38.5 50.3 V / 18.9 9.0 -13.6 36.7 54.0 -11.1 3609.62 54.6 Pk 5.0 / 31.7 / 38.5 50.3 V / 18.9 9.0 -13.6 36.7 54.0 -11.4 4512.05 52.1 Pk 6.6 / 32.3 / 40.7 50.4 H / 1.4 / 20.0 -13.6 36.8 54.0 -17.2 4512.05 52.2 Pk 6.6 / 32.3 / 40.7 50.4 H / 1.4 / 20.0 -13.6 36.8 54.0 -17.2 5414.46 43.2 Pk 6.9 / 34.3 / 39.9 40.7 H / 1.3 / 350.0 -13.6 37.8 54.0 -16.2 5414.46 43.2 Pk 6.9 / 34.3 / 39.9 44.5 V / 1.6 / 50.7 0 -13.6 37.8 54.0 -22.1 16.3 63.6 56.8 Pk 8.2 / 35.2 / 40.4 59.7 V / 1.6 / 30.7 0 -13.6 30.9 54.0 -23.1 6316.8 50.5 Pk 8.2 / 35.2 / 40.4 59.7 V / 1.6 / 30.5 0 -13.6 46.1 87.7 41.6 6316.8 50.5 Pk 8.2 / 35.2 / 40.4 59.7 V / 1.6 / 30.5 0 -13.6 30.9 54.0 -23.1 6316.9 50.5 Pk 8.2 / 35.2 / 40.4 59.7 V / 1.6 / 30.0 -13.6 30.9 54.0 -23.1 6316.9 50.5 Pk 8.2 / 35.2 / 40.4 59.7 V / 1.6 / 30.5 0 -13.6 46.1 87.7 47.8 84.0 19.2 19.0 19.0 19.0 19.0 19.0 19.0 19.0 19.0	927.6	81.3 Pk	3.6 / 22.8 / 0.0	107.8	V / 1.0 / 270.0	0.0	107.8	119.2	-11.4
927.6 82.0 Pk 3.6 / 22.8 / 10.0 108.4 H / 1.1 / 106.0 0.0 108.4 119.2 1-10.8  Axis 3 was determined to be the worst case axis  All Harmonics will be measured in Axis 3  Harmonics - Low Channel  1904.85 91.1 Pk 3.0 / 26.3 / 38.1 82.3 V / 1.0 / 0.0 1-13.6 68.7 87.7 1-19.0  1904.85 91.1 Pk 3.0 / 26.3 / 38.1 79.3 H / 1.6 / 32.3 1-13.6 65.7 87.7 2-22.0  2707.21 62.8 Pk 3.8 / 29.7 / 38.1 58.2 V / 1.2 / 213.0 1-13.6 44.6 54.0 9.4  2707.22 61.1 Pk 3.8 / 29.7 / 38.1 56.5 H / 2.2 / 32.3 1-13.6 42.9 54.0 1-11.1  3609.62 52.1 Pk 5.0 / 31.7 / 38.5 50.3 V / 1.8 / 98.0 1-13.6 36.7 54.0 1-17.3  3609.62 52.1 Pk 6.6 / 32.3 / 40.7 50.4 H / 1.4 / 20.0 1-13.6 36.7 54.0 1-17.2  4512.05 52.1 Pk 6.6 / 32.3 / 40.7 50.4 H / 1.4 / 20.0 1-13.6 36.8 54.0 1-12.2  4512.05 52.1 Pk 6.6 / 32.3 / 40.7 50.4 H / 1.4 / 20.0 1-13.6 36.8 54.0 1-16.2  4514.45 39.4 Pk 6.9 / 34.3 / 39.9 40.7 H / 1.3 / 350.0 1-13.6 37.8 54.0 1-62  5414.46 43.2 Pk 6.9 / 34.3 / 39.9 44.5 V / 1.6 / 207.0 1-13.6 30.9 54.0 2-26.9  5414.46 43.2 Pk 6.9 / 34.3 / 39.9 44.5 V / 1.6 / 305.0 1-13.6 30.9 54.0 2-23.1  6316.9 50.5 Pk 8.2 / 35.2 / 40.4 59.7 V / 1.6 / 305.0 1-13.6 46.1 87.7 4-16.6  3616.9 50.5 Pk 8.2 / 35.2 / 40.4 59.7 V / 1.6 / 305.0 1-13.6 30.9 87.7 4-78.8  7219.3 38.4 Pk 8.9 / 37.3 / 47.5 50.5 H / 1.8 / 30.0 1-13.6 34.3 54.0 1-19.7  9024.11 50.5 Pk 8.3 / 37.1 / 47.5 50.5 H / 1.18 / 350.0 1-13.6 34.3 54.0 1-19.7  9024.19 50.5 Pk 8.5 / 37.9 / 48.5 44.9 V / 1.0 / 13.5 0 1-13.6 34.3 54.0 1-19.7  9024.19 50.5 Pk 8.5 / 37.9 / 48.5 44.9 V / 1.0 / 13.5 0 1-13.6 34.8 54.0 1-19.7  9024.19 50.5 Pk 8.5 / 37.9 / 48.5 44.9 V / 1.0 / 13.5 0 1-13.6 34.8 54.0 1-19.7  9024.19 50.5 Pk 8.5 / 37.9 / 48.5 47.9 V / 1.5 / 150.0 1-13.6 34.3 54.0 1-19.7  9024.19 50.5 Pk 8.5 / 37.9 / 48.5 47.9 V / 1.5 / 150.0 1-13.6 34.3 54.0 1-19.7  9024.19 50.6 Pk 8.5 / 37.9 / 48.5 48.4 H / 1.7 / 17.1 / 150.0 1-13.6 34.8 54.0 1-19.7  1829.65 92.1 Pk 8.5 / 37.9 / 48.5 48.4 H / 1.7 / 17.1 / 150.0 1-13.6 34.8 54.0 1-19.7  1829.65 92.1 Pk 8.5 / 37.9 / 48.5 54.0 1-15.5 36.9 34.8 54.0 1-15.5 36.9 34.9 54.0 1-15.5 3	Axis 3								
Axis 3 was determined to be the worst case axis All Harmonics will be measured in Axis 3  Harmonics - Low Channel  1804.85 91.1 Pk 3.0 / 26.3 / 38.1 82.3 V / 1.0 / 0.0 -13.6 68.7 87.7 -19.0  1804.85 88.1 Pk 3.0 / 26.3 / 38.1 79.3 H / 11.6 / 32.3 -13.6 65.7 87.7 -22.0  7207.21 62.8 Pk 3.8 / 29.7 / 38.1 56.2 V / 1.2 / 213.0 -13.6 44.6 54.0 -9.4  2707.22 61.1 Pk 3.8 / 29.7 / 38.1 56.5 H / 22 / 32.3 -13.6 42.9 54.0 -11.1  3609.62 52.1 Pk 5.0 / 31.7 / 38.5 50.3 V / 1.8 / 98.0 -13.6 36.7 54.0 -17.3  3609.62 54.6 Pk 5.0 / 31.7 / 38.5 52.8 H / 11.3 / 142.0 -13.6 39.2 54.0 -14.8 81.2 (2.5 2.1 Pk 6.6 / 32.3 / 40.7 50.4 H / 1.4 / 20.0 -13.6 39.2 54.0 -14.8 81.2 (2.5 52.1 Pk 6.6 / 32.3 / 40.7 50.4 H / 1.4 / 20.0 -13.6 36.8 54.0 -17.2 4512.05 52.1 Pk 6.6 / 32.3 / 40.7 50.4 H / 1.4 / 20.0 -13.6 37.8 54.0 -16.2 5414.45 39.4 Pk 6.9 / 34.3 / 39.9 40.7 H / 1.3 / 350.0 -13.6 27.1 54.0 -26.9 5414.46 43.2 Pk 6.9 / 34.3 / 39.9 40.7 H / 1.1 / 3/ 350.0 -13.6 27.1 54.0 -26.9 54.0 -26.1 54.4 64 43.2 Pk 6.9 / 34.3 / 39.9 44.5 V / 1.6 / 207.0 -13.6 30.9 54.0 -23.1 6316.8 56.8 Pk 8.2 / 35.2 / 40.4 53.5 H / 1.4 / 304.0 -13.6 39.9 87.7 -47.8 6316.9 56.8 Pk 8.2 / 35.2 / 40.4 53.5 H / 1.4 / 304.0 -13.6 39.9 87.7 -47.8 6316.9 50.5 Pk 8.3 / 35.1 / 47.5 50.5 H / 1.4 / 304.0 -13.6 39.9 87.7 -47.8 7219.3 38.4 Pk 8.1 / 36.2 / 39.9 39 H / 1.0 / 0.0 -13.6 30.9 54.0 -23.1 6316.9 50.5 Pk 8.3 / 37.1 / 47.5 47.9 V / 2.0 / 163.0 -13.6 34.3 54.0 -19.7 -47.8 121.6 9 52.5 Pk 8.3 / 37.1 / 47.5 50.5 H / 1.8 / 350.0 -13.6 69.9 90.2 -20.3 87.7 -58.4 Harmonics Mid Channel  1829.65 92.1 Pk 8.3 / 37.1 / 47.5 50.5 H / 1.8 / 350.0 -13.6 69.9 90.2 -20.3 67.7 -62.3 12.6 69.0 Pk 8.5 / 37.9 / 48.5 47.9 V / 1.5 / 299.0 -13.6 34.3 54.0 -19.7 -47.8 121.6 9 52.5 Pk 8.3 / 37.1 / 47.5 50.5 H / 1.8 / 350.0 -13.6 69.9 90.2 -20.3 67.7 -62.3 12.6 69.0 Pk 8.5 / 37.9 / 48.5 47.9 V / 1.5 / 299.0 -13.6 34.3 54.0 -19.7 -47.8 121.6 9 52.5 Pk 8.3 / 37.1 / 47.5 50.5 H / 1.1 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1.5 / 1	927.6	86.2 Pk	3.6 / 22.8 / 0.0	112.7	V / 1.1 / 82.0	0.0	112.7	119.2	-6.5
All Harmonics - Low Channel   1804.85   91.1 Pk   3.0 / 26.3 / 38.1   82.3   V / 1.0 / 10.0   -13.6   68.7   87.7   -19.0   1804.85   88.1 Pk   3.0 / 26.3 / 38.1   58.2   V / 1.0 / 21.0   -13.6   68.7   87.7   -22.0   2707.21   62.8 Pk   3.8 / 29.7 / 38.1   58.2   V / 1.2 / 213.0   -13.6   44.6   54.0   -9.4   2707.22   61.1 Pk   3.8 / 29.7 / 38.1   56.5   H / 2.2 / 32.3   -13.6   42.9   54.0   -11.1   3609.62   52.1 Pk   5.0 / 31.7 / 38.5   50.3   V / 1.8 / 98.0   -13.6   36.7   54.0   -11.3   3609.62   52.1 Pk   5.0 / 31.7 / 38.5   50.3   V / 1.8 / 98.0   -13.6   36.7   54.0   -17.3   4512.05   52.1 Pk   5.0 / 31.7 / 38.5   50.3   V / 1.8 / 98.0   -13.6   36.8   54.0   -17.2   4512.05   52.1 Pk   6.6 / 32.3 / 40.7   50.4   H / 1.4 / 20.0   -13.6   36.8   54.0   -17.2   4512.05   52.1 Pk   6.6 / 32.3 / 40.7   50.4   H / 1.4 / 20.0   -13.6   36.8   54.0   -17.2   4512.05   53.2 Pk   6.6 / 32.3 / 40.7   51.4   V / 1.6 / 55.0   -13.6   37.8   54.0   -16.2   5414.45   39.4 Pk   6.9 / 34.3 / 39.9   40.7   H / 1.1 / 3 / 350.0   -13.6   27.1   54.0   -26.9   5414.46   43.2 Pk   6.9 / 34.3 / 39.9   40.7   H / 1.6 / 207.0   -13.6   37.8   54.0   -16.2   5414.85   56.8 Pk   8.2 / 35.2 / 40.4   59.7   V / 1.6 / 207.0   -13.6   39.9   87.7   -41.6   6316.9   50.5 Pk   8.2 / 35.2 / 40.4   59.7   V / 1.6 / 305.0   -13.6   46.1   87.7   -41.6   6316.9   50.5 Pk   8.1 / 30.2 / 39.9   39.1   H / 1.0 / 30.0   -13.6   29.3   67.7   -58.4   67.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4	927.6	82.0 Pk	3.6 / 22.8 / 0.0	108.4	H / 1.1 / 106.0	0.0	108.4	119.2	-10.8
All Harmonics - Low Channel   1804.85   91.1 Pk   3.0 / 26.3 / 38.1   82.3   V / 1.0 / 10.0   -13.6   68.7   87.7   -19.0   1804.85   88.1 Pk   3.0 / 26.3 / 38.1   58.2   V / 1.0 / 21.0   -13.6   68.7   87.7   -22.0   2707.21   62.8 Pk   3.8 / 29.7 / 38.1   58.2   V / 1.2 / 213.0   -13.6   44.6   54.0   -9.4   2707.22   61.1 Pk   3.8 / 29.7 / 38.1   56.5   H / 2.2 / 32.3   -13.6   42.9   54.0   -11.1   3609.62   52.1 Pk   5.0 / 31.7 / 38.5   50.3   V / 1.8 / 98.0   -13.6   36.7   54.0   -11.3   3609.62   52.1 Pk   5.0 / 31.7 / 38.5   50.3   V / 1.8 / 98.0   -13.6   36.7   54.0   -17.3   4512.05   52.1 Pk   5.0 / 31.7 / 38.5   50.3   V / 1.8 / 98.0   -13.6   36.8   54.0   -17.2   4512.05   52.1 Pk   6.6 / 32.3 / 40.7   50.4   H / 1.4 / 20.0   -13.6   36.8   54.0   -17.2   4512.05   52.1 Pk   6.6 / 32.3 / 40.7   50.4   H / 1.4 / 20.0   -13.6   36.8   54.0   -17.2   4512.05   53.2 Pk   6.6 / 32.3 / 40.7   51.4   V / 1.6 / 55.0   -13.6   37.8   54.0   -16.2   5414.45   39.4 Pk   6.9 / 34.3 / 39.9   40.7   H / 1.1 / 3 / 350.0   -13.6   27.1   54.0   -26.9   5414.46   43.2 Pk   6.9 / 34.3 / 39.9   40.7   H / 1.6 / 207.0   -13.6   37.8   54.0   -16.2   5414.85   56.8 Pk   8.2 / 35.2 / 40.4   59.7   V / 1.6 / 207.0   -13.6   39.9   87.7   -41.6   6316.9   50.5 Pk   8.2 / 35.2 / 40.4   59.7   V / 1.6 / 305.0   -13.6   46.1   87.7   -41.6   6316.9   50.5 Pk   8.1 / 30.2 / 39.9   39.1   H / 1.0 / 30.0   -13.6   29.3   67.7   -58.4   67.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4   87.7   -62.3   87.7   -68.4									
Harmonics - Low Channel	Axis 3 was	determined	I to be the worst case	axis					
1804.85   91.1 Pk   3.0 / 26.3 / 38.1   82.3   V / 1.0 / 0.0   13.6   68.7   87.7   -19.0   1804.85   88.1 Pk   3.0 / 26.3 / 38.1   79.3   H / 1.6 / 32.3   -13.6   65.7   87.7   -22.0   2707.21   62.8 Pk   3.8 / 29.7 / 38.1   58.2   V / 1.2 / 213.0   -13.6   44.6   54.0   -9.4   2707.22   61.1 Pk   3.8 / 29.7 / 38.1   56.5   H / 2.2 / 32.3   -13.6   42.9   54.0   -11.1   3609.62   52.1 Pk   5.0 / 31.7 / 38.5   50.3   V / 1.8 / 98.0   -13.6   36.7   54.0   -11.3   3609.62   54.6 Pk   5.0 / 31.7 / 38.5   50.3   V / 1.8 / 98.0   -13.6   39.2   54.0   -14.8   4512.05   52.1 Pk   6.6 / 32.3 / 40.7   50.4   H / 1.4 / 20.0   -13.6   36.8   54.0   -17.2   4512.05   53.2 Pk   6.6 / 32.3 / 40.7   50.4   H / 1.4 / 20.0   -13.6   36.8   54.0   -17.2   4512.05   53.2 Pk   6.6 / 32.3 / 40.7   51.4   V / 1.6 / 55.0   -13.6   37.8   54.0   -16.2   5414.45   39.4 Pk   6.9 / 34.3 / 39.9   40.7   H / 1.3 / 350.0   -13.6   37.8   54.0   -26.9   5414.46   33.2 Pk   6.9 / 34.3 / 39.9   44.5   V / 1.6 / 207.0   -13.6   30.9   54.0   -23.1   6316.85   56.8 Pk   8.2 / 35.2 / 40.4   59.7   V / 1.6 / 305.0   -13.6   46.1   87.7   -41.6   6316.9   50.5 Pk   8.2 / 35.2 / 40.4   53.5   H / 1.4 / 304.0   -13.6   39.9   87.7   -47.8   47.8   47.9   47.9   47.8   47.9   47.9   47.8   47.9   47									
1804.85	Harmonics	s - Low Char	nnel	<del> </del>			1		
2707.21         62.8 Pk         3.8/29.7/38.1         56.2         V/1.2/213.0         -13.6         44.6         54.0         -9.4           2707.22         61.1 Pk         3.8/29.7/38.1         56.5         H/2.2/32.3         -13.6         42.9         54.0         -11.1           3609.62         52.1 Pk         50.731.7/38.5         50.3         V/1.8/98.0         -13.6         36.7         54.0         -17.3           3609.62         52.1 Pk         6.6/32.3/40.7         50.4         H/1.3/142.0         -13.6         36.8         54.0         -17.2           4512.05         52.1 Pk         6.6/32.3/40.7         51.4         V/1.6/50.0         -13.6         36.8         54.0         -17.2           4512.05         53.2 Pk         6.6/93.3/3/39.9         40.7         H/1.3/350.0         -13.6         37.8         540         -16.2           5414.45         39.4 Pk         6.9/34.3/39.9         44.5         V/1.6/207.0         -13.6         30.9         54.0         -23.1           6316.9         50.5 Pk         8.2/35.2/40.4         59.7         V/1.6/305.0         -13.6         46.1         87.7         -47.8           7219.31         34.5 Pk         8.1/36.2/39.9         39 <t< td=""><td>1804.85</td><td>91.1 Pk</td><td>3.0 / 26.3 / 38.1</td><td>82.3</td><td>V / 1.0 / 0.0</td><td>-13.6</td><td>68.7</td><td>87.7</td><td>-19.0</td></t<>	1804.85	91.1 Pk	3.0 / 26.3 / 38.1	82.3	V / 1.0 / 0.0	-13.6	68.7	87.7	-19.0
2707.22         61.1 Pk         3.8/29.7/38.1         56.5         H/2.2/32.3         -13.6         42.9         54.0         -11.1           3609.62         52.1 Pk         5.0/31.7/38.5         50.3         V/1.8/98.0         -13.6         36.7         54.0         -17.3           3609.62         54.6 Pk         5.0/31.7/38.5         52.8         H/1.3/142.0         -13.6         39.2         54.0         -14.8           4512.05         52.1 Pk         6.6/32.3/40.7         50.4         H/1.4/20.0         -13.6         36.8         54.0         -17.2           4512.05         52.1 Pk         6.6/32.3/40.7         51.4         V/1.6/55.0         -13.6         36.8         54.0         -17.2           4512.05         52.1 Pk         6.6/32.3/40.7         51.4         V/1.6/55.0         -13.6         37.8         54.0         -26.9           5414.45         39.4 Pk         6.9/34.3/39.9         40.7         H/1.6/207.0         -13.6         27.1         54.0         -26.9           5414.46         43.2 Pk         6.9/34.3/39.9         42.9         V/1.6/305.0         -13.6         39.9         87.7         -41.6           6316.9         50.5 Pk         8.2/35.2/40.4         53.5 <t< td=""><td>1804.85</td><td>88.1 Pk</td><td>3.0 / 26.3 / 38.1</td><td>79.3</td><td>H / 1.6 / 32.3</td><td>-13.6</td><td>65.7</td><td>87.7</td><td>-22.0</td></t<>	1804.85	88.1 Pk	3.0 / 26.3 / 38.1	79.3	H / 1.6 / 32.3	-13.6	65.7	87.7	-22.0
3609.62         52.1 PK         5.0/31.7/38.5         50.3         V/1.8/98.0         -13.6         36.7         54.0         -17.3           3609.62         54.6 PK         5.0/31.7/38.5         52.8         H/1.3/142.0         -13.6         39.2         54.0         -14.8           4512.05         52.1 PK         6.6/32.3/40.7         50.4         H/1.4/20.0         -13.6         36.8         54.0         -17.2           4512.05         53.2 PK         6.6/32.3/40.7         51.4         V/1.6/55.0         -13.6         37.8         54.0         -16.2           5414.45         39.4 PK         6.9/34.3/39.9         40.7         H/1.3/350.0         -13.6         27.1         54.0         -26.9           5414.46         43.2 PK         6.9/34.3/39.9         44.5         V/1.6/207.0         -13.6         30.9         54.0         -23.1           6316.85         56.8 PK         8.2/35.2/40.4         59.7         V/1.6/305.0         -13.6         46.1         87.7         -41.6           6316.9         50.5 PK         8.2/35.2/40.4         53.5         H/1.4/304.0         -13.6         29.3         87.7         -58.4           7219.3         38.4 PK         8.1/36.2/39.9         39 <td< td=""><td>2707.21</td><td>62.8 Pk</td><td>3.8 / 29.7 / 38.1</td><td>58.2</td><td>V / 1.2 / 213.0</td><td>-13.6</td><td>44.6</td><td>54.0</td><td>-9.4</td></td<>	2707.21	62.8 Pk	3.8 / 29.7 / 38.1	58.2	V / 1.2 / 213.0	-13.6	44.6	54.0	-9.4
3609.62         54.6 Pk         5.0/31.7/38.5         52.8         H/1.3/142.0         -13.6         39.2         54.0         -14.8           4512.05         52.1 Pk         6.6/32.3/40.7         50.4         H/1.4/20.0         -13.6         36.8         54.0         -17.2           4512.05         53.2 Pk         6.6/32.3/40.7         51.4         V/1.6/55.0         -13.6         37.8         54.0         -16.2           5414.46         39.4 Pk         6.9/34.3/39.9         40.7         H/1.3/350.0         -13.6         27.1         54.0         -26.9           5414.46         43.2 Pk         6.9/34.3/39.9         44.5         V/1.6/207.0         -13.6         30.9         54.0         -23.1           5414.46         43.2 Pk         6.9/34.3/39.9         44.5         V/1.6/305.0         -13.6         30.9         54.0         -23.1           6316.9         50.5 Pk         8.2/35.2/40.4         53.5         H/1.4/304.0         -13.6         39.9         87.7         -47.8           7219.3         38.4 Pk         8.1/36.2/39.9         39         H/1.0/0.0         -13.6         29.3         87.7         -62.3           8121.69         50.0 Pk         8.3/37.1/47.5         47.9	2707.22	61.1 Pk	3.8 / 29.7 / 38.1	56.5	H / 2.2 / 32.3	-13.6	42.9	54.0	-11.1
4512.05         52.1 Pk         6.6/32.3/40.7         50.4         H/1.4/20.0         -13.6         36.8         54.0         -17.2           4512.05         53.2 Pk         6.6/32.3/40.7         51.4         V/1.6/55.0         -13.6         37.8         54.0         -16.2           5414.45         39.4 Pk         6.9/34.3/39.9         40.7         H/1.3/350.0         -13.6         27.1         54.0         -26.9           5414.46         43.2 Pk         6.9/34.3/39.9         44.5         V/1.6/207.0         -13.6         30.9         54.0         -23.1           6316.85         56.8 Pk         8.2/35.2/40.4         59.7         V/1.6/305.0         -13.6         46.1         87.7         -41.6           6316.9         50.5 Pk         8.2/35.2/40.4         53.5         H/1.4/304.0         -13.6         39.9         87.7         -47.8           7219.31         34.5 Pk         8.1/36.2/39.9         39         H/1.0/0.0         -13.6         25.4         87.7         -62.3           8121.69         50.0 Pk         8.3/37.1/47.5         47.9         V/2.0/163.0         -13.6         34.3         54.0         -19.7           8121.69         52.5 Pk         8.3/37.1/47.5         50.5 <td< td=""><td>3609.62</td><td>52.1 Pk</td><td>5.0 / 31.7 / 38.5</td><td>50.3</td><td>V / 1.8 / 98.0</td><td>-13.6</td><td>36.7</td><td>54.0</td><td>-17.3</td></td<>	3609.62	52.1 Pk	5.0 / 31.7 / 38.5	50.3	V / 1.8 / 98.0	-13.6	36.7	54.0	-17.3
4512.05         53.2 Pk         6.6/32.3/40.7         51.4         V/1.6/55.0         -13.6         37.8         54.0         -16.2           5414.45         39.4 Pk         6.9/34.3/39.9         40.7         H/1.3/350.0         -13.6         27.1         54.0         -26.9           5414.46         43.2 Pk         6.9/34.3/39.9         44.5         V/1.6/207.0         -13.6         30.9         54.0         -23.1           6316.85         56.8 Pk         8.2/35.2 / 40.4         59.7         V/1.6/305.0         -13.6         46.1         87.7         -41.6           6316.9         50.5 Pk         8.2/35.2 / 40.4         53.5         H/1.4/304.0         -13.6         39.9         87.7         -47.8           7219.3         38.4 Pk         8.1/36.2 / 39.9         42.9         V/1.0/315.0         -13.6         29.3         87.7         -58.4           7219.31         34.5 Pk         8.1/36.2 / 39.9         39         H/1.0/0.0         -13.6         25.4         87.7         -62.3           8121.69         50.0 Pk         8.3/37.1/47.5         47.9         V/2.0/163.0         -13.6         36.9         54.0         -17.1           9024.09         50.0 Pk         8.5/37.9/48.5         47.9	3609.62	54.6 Pk	5.0 / 31.7 / 38.5	52.8	H / 1.3 / 142.0	-13.6	39.2	54.0	-14.8
5414.45         39.4 Pk         6.9/34.3/39.9         40.7         H/1.3/350.0         -13.6         27.1         54.0         -26.9           5414.46         43.2 Pk         6.9/34.3/39.9         44.5         V/1.6/207.0         -13.6         30.9         54.0         -23.1           6316.85         56.8 Pk         8.2/35.2/40.4         59.7         V/1.6/305.0         -13.6         46.1         87.7         -41.6           6316.9         50.5 Pk         8.2/35.2/40.4         53.5         H/1.4/304.0         -13.6         39.9         87.7         -47.8           7219.3         38.4 Pk         8.1/36.2/39.9         39         H/1.0/0.0         -13.6         29.3         87.7         -58.4           7219.31         34.5 Pk         8.1/36.2/39.9         39         H/1.0/0.0         -13.6         25.4         87.7         -62.3           8121.69         50.0 Pk         8.3/37.1/47.5         47.9         V/2.0/163.0         -13.6         36.9         54.0         -19.7           8121.69         50.0 Pk         8.5/37.9/48.5         47.9         V/1.5/299.0         -13.6         36.9         54.0         -17.1           9024.09         50.0 Pk         8.5/37.9/48.5         48.4         H/	4512.05	52.1 Pk	6.6 / 32.3 / 40.7	50.4	H / 1.4 / 20.0	-13.6	36.8	54.0	-17.2
5414.46         43.2 Pk         6.9/34.3/39.9         44.5         V/1.6/207.0         -13.6         30.9         54.0         -23.1           6316.85         56.8 Pk         8.2/35.2/40.4         59.7         V/1.6/305.0         -13.6         46.1         87.7         -41.6           6316.9         50.5 Pk         8.2/35.2/40.4         53.5         H/1.4/304.0         -13.6         39.9         87.7         -47.8           7219.3         38.4 Pk         8.1/36.2/39.9         42.9         V/1.0/315.0         -13.6         29.3         87.7         -58.4           7219.31         34.5 Pk         8.1/36.2/39.9         39         H/1.0/0.0         -13.6         25.4         87.7         -62.3           8121.69         50.0 Pk         8.3/37.1/47.5         47.9         V/2.0/163.0         -13.6         34.3         54.0         -19.7           8121.69         52.5 Pk         8.3/37.1/47.5         50.5         H/1.8/350.0         -13.6         36.9         54.0         -17.1           9024.11         50.5 Pk         8.5/37.9/48.5         47.9         V/1.5/299.0         -13.6         34.3         54.0         -19.7           Harmonics - Mid Channel         182.9         8.5/37.9/48.5         48.4 </td <td>4512.05</td> <td>53.2 Pk</td> <td>6.6 / 32.3 / 40.7</td> <td>51.4</td> <td>V / 1.6 / 55.0</td> <td>-13.6</td> <td>37.8</td> <td>54.0</td> <td>-16.2</td>	4512.05	53.2 Pk	6.6 / 32.3 / 40.7	51.4	V / 1.6 / 55.0	-13.6	37.8	54.0	-16.2
6316.85         56.8 Pk         8.2/35.2/40.4         59.7         V/1.6/305.0         -13.6         46.1         87.7         -41.6           6316.9         50.5 Pk         8.2/35.2/40.4         53.5         H/1.4/304.0         -13.6         39.9         87.7         -47.8           7219.3         38.4 Pk         8.1/36.2/39.9         42.9         V/1.0/315.0         -13.6         29.3         87.7         -58.4           7219.31         34.5 Pk         8.1/36.2/39.9         39         H/1.0/0.0         -13.6         25.4         87.7         -62.3           8121.69         50.0 Pk         8.3/37.1/47.5         47.9         V/2.0/163.0         -13.6         34.3         54.0         -19.7           8121.69         52.5 Pk         8.3/37.1/47.5         50.5         H/1.8/350.0         -13.6         36.9         54.0         -17.1           9024.09         50.0 Pk         8.5/37.9/48.5         47.9         V/1.5/299.0         -13.6         34.3         54.0         -19.7           Harmonics - Mid Channel         1829.65         92.1 Pk         3.0/26.4/38.0         83.5         H/1.7/186.0         -13.6         69.9         90.2         -20.3           1829.65         92.1 Pk         3.0/26.4/3		39.4 Pk	6.9 / 34.3 / 39.9	40.7	H / 1.3 / 350.0	-13.6	27.1	54.0	-26.9
6316.9         50.5 Pk         8.2/35.2/40.4         53.5         H/1.4/304.0         -13.6         39.9         87.7         -47.8           7219.3         38.4 Pk         8.1/36.2/39.9         42.9         V/1.0/315.0         -13.6         29.3         87.7         -58.4           7219.31         34.5 Pk         8.1/36.2/39.9         39         H/1.0/0.0         -13.6         25.4         87.7         -62.3           8121.69         50.0 Pk         8.3/37.1/47.5         47.9         V/2.0/163.0         -13.6         34.3         54.0         -19.7           8121.69         52.5 Pk         8.3/37.1/47.5         50.5         H/1.8/350.0         -13.6         36.9         54.0         -17.1           9024.09         50.0 Pk         8.5/37.9/48.5         47.9         V/1.5/299.0         -13.6         34.3         54.0         -19.7           9024.11         50.5 Pk         8.5/37.9/48.5         48.4         H/1.7/315.0         -13.6         34.8         54.0         -19.2           Harmonics         Mid Channel         30.264/38.0         83.5         H/1.7/186.0         -13.6         69.9         90.2         -20.3           1829.66         90.0 Pk         3.0/26.4/38.0         81.3<	5414.46	43.2 Pk	6.9 / 34.3 / 39.9	44.5	V / 1.6 / 207.0	-13.6	30.9	54.0	-23.1
7219.3         38.4 Pk         8.1/36.2/39.9         42.9         V/1.0/315.0         -13.6         29.3         87.7         -58.4           7219.31         34.5 Pk         8.1/36.2/39.9         39         H/1.0/0.0         -13.6         25.4         87.7         -62.3           8121.69         50.0 Pk         8.3/37.1/47.5         47.9         V/2.0/163.0         -13.6         34.3         54.0         -19.7           8121.69         52.5 Pk         8.3/37.1/47.5         50.5         H/1.8/350.0         -13.6         36.9         54.0         -17.1           9024.09         50.0 Pk         8.5/37.9/48.5         47.9         V/1.5/299.0         -13.6         34.3         54.0         -19.7           9024.11         50.5 Pk         8.5/37.9/48.5         48.4         H/1.7/315.0         -13.6         34.8         54.0         -19.2           Harmonics - Mid Channel           1829.65         92.1 Pk         3.0/26.4/38.0         83.5         H/1.7/186.0         -13.6         69.9         90.2         -20.3           1829.66         90.0 Pk         3.0/26.4/38.0         81.3         V/1.0/15.0         -13.6         67.7         90.2         -22.5           2744.42         58.2	6316.85	56.8 Pk	8.2 / 35.2 / 40.4	59.7		-13.6	46.1	87.7	-41.6
7219.31         34.5 Pk         8.1/36.2/39.9         39         H/1.0/0.0         -13.6         25.4         87.7         -62.3           8121.69         50.0 Pk         8.3/37.1/47.5         47.9         V/2.0/163.0         -13.6         34.3         54.0         -19.7           8121.69         52.5 Pk         8.3/37.1/47.5         50.5         H/1.8/350.0         -13.6         36.9         54.0         -17.1           9024.09         50.0 Pk         8.5/37.9/48.5         47.9         V/1.5/299.0         -13.6         34.3         54.0         -19.7           9024.11         50.5 Pk         8.5/37.9/48.5         48.4         H/1.7/315.0         -13.6         34.8         54.0         -19.7           Harmonics - Mid Channel         Mid Channel         H         1829.65         92.1 Pk         3.0/26.4/38.0         83.5         H/1.7/186.0         -13.6         69.9         90.2         -20.3           1829.66         90.0 Pk         3.0/26.4/38.0         81.3         V/1.0/15.0         -13.6         67.7         90.2         -22.5           2744.42         58.2 Pk         3.8/29.8/38.1         53.7         V/2.0/238.0         -13.6         40.1         54.0         -13.9           2744.47 <td></td> <td></td> <td></td> <td>53.5</td> <td></td> <td>-13.6</td> <td></td> <td>87.7</td> <td>-47.8</td>				53.5		-13.6		87.7	-47.8
8121.69         50.0 Pk         8.3/37.1/47.5         47.9         V/2.0/163.0         -13.6         34.3         54.0         -19.7           8121.69         52.5 Pk         8.3/37.1/47.5         50.5         H/1.8/350.0         -13.6         36.9         54.0         -17.1           9024.09         50.0 Pk         8.5/37.9/48.5         47.9         V/1.5/299.0         -13.6         34.3         54.0         -19.7           9024.11         50.5 Pk         8.5/37.9/48.5         48.4         H/1.7/315.0         -13.6         34.8         54.0         -19.7           Harmonics - Mid Channel           1829.65         92.1 Pk         3.0/26.4/38.0         83.5         H/1.7/186.0         -13.6         69.9         90.2         -20.3           1829.66         90.0 Pk         3.0/26.4/38.0         81.3         V/1.0/15.0         -13.6         67.7         90.2         -22.5           2744.42         58.2 Pk         3.8/29.8/38.1         53.7         V/2.0/238.0         -13.6         40.1         54.0         -13.9           2744.47         60.6 Pk         3.8/29.8/38.1         56.1         H/1.8/135.0         -13.6         42.5         54.0         -11.5           3659.24 <td< td=""><td></td><td></td><td></td><td></td><td>V / 1.0 / 315.0</td><td>-13.6</td><td>29.3</td><td>87.7</td><td></td></td<>					V / 1.0 / 315.0	-13.6	29.3	87.7	
8121.69         52.5 Pk         8.3/37.1/47.5         50.5         H/1.8/350.0         -13.6         36.9         54.0         -17.1           9024.09         50.0 Pk         8.5/37.9/48.5         47.9         V/1.5/299.0         -13.6         34.3         54.0         -19.7           9024.11         50.5 Pk         8.5/37.9/48.5         48.4         H/1.7/315.0         -13.6         34.8         54.0         -19.2           Harmonics - Mid Channel           1829.65         92.1 Pk         3.0/26.4/38.0         83.5         H/1.7/186.0         -13.6         69.9         90.2         -20.3           1829.66         90.0 Pk         3.0/26.4/38.0         81.3         V/1.0/15.0         -13.6         67.7         90.2         -22.5           2744.42         58.2 Pk         3.8/29.8/38.1         53.7         V/2.0/238.0         -13.6         40.1         54.0         -11.5           3659.24         48.3 Pk         5.1/31.8/38.6         46.6         H/1.4/135.0         -13.6         33.0         54.0         -21.0           3659.28         52.0 Pk         5.1/31.8/38.6         50.4         V/1.5/355.0         -13.6         36.8         54.0         -17.2           4574.05 <td< td=""><td></td><td></td><td></td><td></td><td></td><td>-13.6</td><td>25.4</td><td>87.7</td><td>-62.3</td></td<>						-13.6	25.4	87.7	-62.3
9024.09         50.0 Pk         8.5/37.9/48.5         47.9         V/1.5/299.0         -13.6         34.3         54.0         -19.7           9024.11         50.5 Pk         8.5/37.9/48.5         48.4         H/1.7/315.0         -13.6         34.8         54.0         -19.2           Harmonics - Mid Channel           1829.65         92.1 Pk         3.0/26.4/38.0         83.5         H/1.7/186.0         -13.6         69.9         90.2         -20.3           1829.66         90.0 Pk         3.0/26.4/38.0         81.3         V/1.0/15.0         -13.6         67.7         90.2         -22.5           2744.42         58.2 Pk         3.8/29.8/38.1         53.7         V/2.0/238.0         -13.6         40.1         54.0         -13.9           2744.47         60.6 Pk         3.8/29.8/38.1         56.1         H/1.8/135.0         -13.6         42.5         54.0         -11.5           3659.24         48.3 Pk         5.1/31.8/38.6         46.6         H/1.4/135.0         -13.6         33.0         54.0         -21.0           3659.28         52.0 Pk         5.1/31.8/38.6         50.4         V/1.5/355.0         -13.6         36.8         54.0         -17.2           4574.05 <td< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></td<>									
9024.11         50.5 Pk         8.5/37.9/48.5         48.4         H/1.7/315.0         -13.6         34.8         54.0         -19.2           Harmonics - Mid Channel           1829.65         92.1 Pk         3.0/26.4/38.0         83.5         H/1.7/186.0         -13.6         69.9         90.2         -20.3           1829.66         90.0 Pk         3.0/26.4/38.0         81.3         V/1.0/15.0         -13.6         67.7         90.2         -22.5           2744.42         58.2 Pk         3.8/29.8/38.1         53.7         V/2.0/238.0         -13.6         40.1         54.0         -13.9           2744.47         60.6 Pk         3.8/29.8/38.1         56.1         H/1.8/135.0         -13.6         42.5         54.0         -11.5           3659.24         48.3 Pk         5.1/31.8/38.6         46.6         H/1.4/135.0         -13.6         33.0         54.0         -21.0           3659.28         52.0 Pk         5.1/31.8/38.6         50.4         V/1.5/355.0         -13.6         36.8         54.0         -17.2           4574.05         53.8 Pk         6.8/32.4/40.7         52.2         V/1.8/45.0         -13.6         38.7         54.0         -15.3           5488.87									
Harmonics - Mid Channel  1829.65   92.1 Pk   3.0 / 26.4 / 38.0   83.5   H / 1.7 / 186.0   -13.6   69.9   90.2   -20.3    1829.66   90.0 Pk   3.0 / 26.4 / 38.0   81.3   V / 1.0 / 15.0   -13.6   67.7   90.2   -22.5    2744.42   58.2 Pk   3.8 / 29.8 / 38.1   53.7   V / 2.0 / 238.0   -13.6   40.1   54.0   -13.9    2744.47   60.6 Pk   3.8 / 29.8 / 38.1   56.1   H / 1.8 / 135.0   -13.6   42.5   54.0   -11.5    3659.24   48.3 Pk   5.1 / 31.8 / 38.6   46.6   H / 1.4 / 135.0   -13.6   33.0   54.0   -21.0    3659.28   52.0 Pk   5.1 / 31.8 / 38.6   50.4   V / 1.5 / 355.0   -13.6   36.8   54.0   -17.2    4574.05   53.8 Pk   6.8 / 32.4 / 40.7   52.2   V / 1.8 / 45.0   -13.6   38.6   54.0   -15.4    4574.06   53.9 Pk   6.8 / 32.4 / 40.7   52.3   H / 1.7 / 20.0   -13.6   38.7   54.0   -15.3    5488.87   45.1 Pk   6.7 / 34.5 / 40.1   46.3   V / 1.5 / 340.0   -13.6   32.7   90.2   -57.5    5488.9   46.5 Pk   6.7 / 34.5 / 40.1   47.6   H / 1.4 / 290.0   -13.6   34.0   90.2   -56.2    6403.66   54.8 Pk   8.3 / 35.2 / 40.5   57.9   V / 1.5 / 15.0   -13.6   34.0   90.2   -45.9    6403.7   49.8 Pk   8.3 / 35.2 / 40.5   52.9   H / 1.7 / 300.0   -13.6   39.3   90.2   -50.9									
1829.65         92.1 Pk         3.0/26.4/38.0         83.5         H/1.7/186.0         -13.6         69.9         90.2         -20.3           1829.66         90.0 Pk         3.0/26.4/38.0         81.3         V/1.0/15.0         -13.6         67.7         90.2         -22.5           2744.42         58.2 Pk         3.8/29.8/38.1         53.7         V/2.0/238.0         -13.6         40.1         54.0         -13.9           2744.47         60.6 Pk         3.8/29.8/38.1         56.1         H/1.8/135.0         -13.6         42.5         54.0         -11.5           3659.24         48.3 Pk         5.1/31.8/38.6         46.6         H/1.4/135.0         -13.6         33.0         54.0         -21.0           3659.28         52.0 Pk         5.1/31.8/38.6         50.4         V/1.5/355.0         -13.6         36.8         54.0         -17.2           4574.05         53.8 Pk         6.8/32.4/40.7         52.2         V/1.8/45.0         -13.6         38.6         54.0         -15.4           4574.06         53.9 Pk         6.8/32.4/40.7         52.3         H/1.7/20.0         -13.6         38.7         54.0         -15.3           5488.97         45.1 Pk         6.7/34.5/40.1         46.3		•		48.4	H / 1.7 / 315.0	-13.6	34.8	54.0	-19.2
1829.66         90.0 Pk         3.0 / 26.4 / 38.0         81.3         V / 1.0 / 15.0         -13.6         67.7         90.2         -22.5           2744.42         58.2 Pk         3.8 / 29.8 / 38.1         53.7         V / 2.0 / 238.0         -13.6         40.1         54.0         -13.9           2744.47         60.6 Pk         3.8 / 29.8 / 38.1         56.1         H / 1.8 / 135.0         -13.6         42.5         54.0         -11.5           3659.24         48.3 Pk         5.1 / 31.8 / 38.6         46.6         H / 1.4 / 135.0         -13.6         33.0         54.0         -21.0           3659.28         52.0 Pk         5.1 / 31.8 / 38.6         50.4         V / 1.5 / 355.0         -13.6         36.8         54.0         -17.2           4574.05         53.8 Pk         6.8 / 32.4 / 40.7         52.2         V / 1.8 / 45.0         -13.6         38.6         54.0         -15.4           4574.06         53.9 Pk         6.8 / 32.4 / 40.7         52.3         H / 1.7 / 20.0         -13.6         38.7         54.0         -15.3           5488.87         45.1 Pk         6.7 / 34.5 / 40.1         46.3         V / 1.5 / 340.0         -13.6         34.0         90.2         -57.5           5488.9         46.5 Pk <td></td> <td></td> <td></td> <td>00.5</td> <td>11/47/4000</td> <td>40.0</td> <td>00.0</td> <td>00.0</td> <td>00.0</td>				00.5	11/47/4000	40.0	00.0	00.0	00.0
2744.42         58.2 Pk         3.8/29.8/38.1         53.7         V/2.0/238.0         -13.6         40.1         54.0         -13.9           2744.47         60.6 Pk         3.8/29.8/38.1         56.1         H/1.8/135.0         -13.6         42.5         54.0         -11.5           3659.24         48.3 Pk         5.1/31.8/38.6         46.6         H/1.4/135.0         -13.6         33.0         54.0         -21.0           3659.28         52.0 Pk         5.1/31.8/38.6         50.4         V/1.5/355.0         -13.6         36.8         54.0         -17.2           4574.05         53.8 Pk         6.8/32.4/40.7         52.2         V/1.8/45.0         -13.6         38.6         54.0         -15.4           4574.06         53.9 Pk         6.8/32.4/40.7         52.3         H/1.7/20.0         -13.6         38.7         54.0         -15.3           5488.87         45.1 Pk         6.7/34.5/40.1         46.3         V/1.5/340.0         -13.6         32.7         90.2         -57.5           5488.9         46.5 Pk         6.7/34.5/40.1         47.6         H/1.4/290.0         -13.6         34.0         90.2         -56.2           6403.66         54.8 Pk         8.3/35.2/40.5         57.9									
2744.47         60.6 Pk         3.8/29.8/38.1         56.1         H/1.8/135.0         -13.6         42.5         54.0         -11.5           3659.24         48.3 Pk         5.1/31.8/38.6         46.6         H/1.4/135.0         -13.6         33.0         54.0         -21.0           3659.28         52.0 Pk         5.1/31.8/38.6         50.4         V/1.5/355.0         -13.6         36.8         54.0         -17.2           4574.05         53.8 Pk         6.8/32.4/40.7         52.2         V/1.8/45.0         -13.6         38.6         54.0         -15.4           4574.06         53.9 Pk         6.8/32.4/40.7         52.3         H/1.7/20.0         -13.6         38.7         54.0         -15.3           5488.87         45.1 Pk         6.7/34.5/40.1         46.3         V/1.5/340.0         -13.6         32.7         90.2         -57.5           5488.9         46.5 Pk         6.7/34.5/40.1         47.6         H/1.4/290.0         -13.6         34.0         90.2         -56.2           6403.66         54.8 Pk         8.3/35.2/40.5         57.9         V/1.5/15.0         -13.6         39.3         90.2         -50.9           6403.7         49.8 Pk         8.3/35.2/40.5         52.9         <									
3659.24     48.3 Pk     5.1/31.8/38.6     46.6     H/1.4/135.0     -13.6     33.0     54.0     -21.0       3659.28     52.0 Pk     5.1/31.8/38.6     50.4     V/1.5/355.0     -13.6     36.8     54.0     -17.2       4574.05     53.8 Pk     6.8/32.4/40.7     52.2     V/1.8/45.0     -13.6     38.6     54.0     -15.4       4574.06     53.9 Pk     6.8/32.4/40.7     52.3     H/1.7/20.0     -13.6     38.7     54.0     -15.3       5488.87     45.1 Pk     6.7/34.5/40.1     46.3     V/1.5/340.0     -13.6     32.7     90.2     -57.5       5488.9     46.5 Pk     6.7/34.5/40.1     47.6     H/1.4/290.0     -13.6     34.0     90.2     -56.2       6403.66     54.8 Pk     8.3/35.2/40.5     57.9     V/1.5/15.0     -13.6     44.3     90.2     -45.9       6403.7     49.8 Pk     8.3/35.2/40.5     52.9     H/1.7/300.0     -13.6     39.3     90.2     -50.9									
3659.28         52.0 Pk         5.1/31.8/38.6         50.4         V/1.5/355.0         -13.6         36.8         54.0         -17.2           4574.05         53.8 Pk         6.8/32.4/40.7         52.2         V/1.8/45.0         -13.6         38.6         54.0         -15.4           4574.06         53.9 Pk         6.8/32.4/40.7         52.3         H/1.7/20.0         -13.6         38.7         54.0         -15.3           5488.87         45.1 Pk         6.7/34.5/40.1         46.3         V/1.5/340.0         -13.6         32.7         90.2         -57.5           5488.9         46.5 Pk         6.7/34.5/40.1         47.6         H/1.4/290.0         -13.6         34.0         90.2         -56.2           6403.66         54.8 Pk         8.3/35.2/40.5         57.9         V/1.5/15.0         -13.6         44.3         90.2         -45.9           6403.7         49.8 Pk         8.3/35.2/40.5         52.9         H/1.7/300.0         -13.6         39.3         90.2         -50.9									
4574.05         53.8 Pk         6.8/32.4/40.7         52.2         V/1.8/45.0         -13.6         38.6         54.0         -15.4           4574.06         53.9 Pk         6.8/32.4/40.7         52.3         H/1.7/20.0         -13.6         38.7         54.0         -15.3           5488.87         45.1 Pk         6.7/34.5/40.1         46.3         V/1.5/340.0         -13.6         32.7         90.2         -57.5           5488.9         46.5 Pk         6.7/34.5/40.1         47.6         H/1.4/290.0         -13.6         34.0         90.2         -56.2           6403.66         54.8 Pk         8.3/35.2/40.5         57.9         V/1.5/15.0         -13.6         44.3         90.2         -45.9           6403.7         49.8 Pk         8.3/35.2/40.5         52.9         H/1.7/300.0         -13.6         39.3         90.2         -50.9									
4574.06         53.9 Pk         6.8/32.4/40.7         52.3         H/1.7/20.0         -13.6         38.7         54.0         -15.3           5488.87         45.1 Pk         6.7/34.5/40.1         46.3         V/1.5/340.0         -13.6         32.7         90.2         -57.5           5488.9         46.5 Pk         6.7/34.5/40.1         47.6         H/1.4/290.0         -13.6         34.0         90.2         -56.2           6403.66         54.8 Pk         8.3/35.2/40.5         57.9         V/1.5/15.0         -13.6         44.3         90.2         -45.9           6403.7         49.8 Pk         8.3/35.2/40.5         52.9         H/1.7/300.0         -13.6         39.3         90.2         -50.9									
5488.87     45.1 Pk     6.7 / 34.5 / 40.1     46.3     V / 1.5 / 340.0     -13.6     32.7     90.2     -57.5       5488.9     46.5 Pk     6.7 / 34.5 / 40.1     47.6     H / 1.4 / 290.0     -13.6     34.0     90.2     -56.2       6403.66     54.8 Pk     8.3 / 35.2 / 40.5     57.9     V / 1.5 / 15.0     -13.6     44.3     90.2     -45.9       6403.7     49.8 Pk     8.3 / 35.2 / 40.5     52.9     H / 1.7 / 300.0     -13.6     39.3     90.2     -50.9									
5488.9     46.5 Pk     6.7/34.5/40.1     47.6     H/1.4/290.0     -13.6     34.0     90.2     -56.2       6403.66     54.8 Pk     8.3/35.2/40.5     57.9     V/1.5/15.0     -13.6     44.3     90.2     -45.9       6403.7     49.8 Pk     8.3/35.2/40.5     52.9     H/1.7/300.0     -13.6     39.3     90.2     -50.9									
6403.66     54.8 Pk     8.3 / 35.2 / 40.5     57.9     V / 1.5 / 15.0     -13.6     44.3     90.2     -45.9       6403.7     49.8 Pk     8.3 / 35.2 / 40.5     52.9     H / 1.7 / 300.0     -13.6     39.3     90.2     -50.9									
6403.7 49.8 Pk 8.3 / 35.2 / 40.5 52.9 H / 1.7 / 300.0 -13.6 39.3 90.2 -50.9									
- / U.O.   TO,A   N   U.A / U.A / TO,O   TT,T   V / 1.4 / JUU.U   TO,U   JU.O   144.U   TO,O   1 14.U   TO,O	7318.51	40.2 Pk	8.2 / 36.4 / 40.3	44.4	V / 1.4 / 300.0	-13.6	30.8	54.0	-23.2

FREQ	LEVEL	CABLE / ANT / PREAMP	FINAL	POL / HGT / AZ	Duty Cycle Correction	Final Corrected	Limit	DELTA
(MHz)	(dBuV)	(dB) (dB\m) (dB)	(dBuV)	(m) (DEG)	(dB)	(dBuV/m)	(dBuV/m)	(dB)
7318.51	38.5 Pk	8.2 / 36.4 / 40.3	42.7	H / 1.8 / 250.0	-13.6	29.1	54.0	-24.9
8233.31	58.2 Pk	8.4 / 37.1 / 47.7	56	H / 1.6 / 335.0	-13.6	42.4	54.0	-11.6
8233.32	55.5 Pk	8.4 / 37.1 / 47.7	53.3	V / 1.9 / 85.0	-13.6	39.7	54.0	-14.3
9148.11	49.1 Pk	8.8 / 38.1 / 48.6	47.4	H / 1.4 / 300.0	-13.6	33.8	54.0	-20.2
9148.12	51.4 Pk	8.8 / 38.1 / 48.6	49.6	V / 1.9 / 280.0	-13.6	36.0	54.0	-18.0
Harmonics	- High Cha	nnel						
1855.26	89.6 Pk	3.0 / 26.5 / 38.0	81.1	V / 1.1 / 320.0	-13.6	67.5	92.7	-25.2
1855.26	91.2 Pk	3.0 / 26.5 / 38.0	82.6	H / 1.4 / 85.0	-13.6	69.0	92.7	-23.7
2782.82	57.8 Pk	3.8 / 30.0 / 38.1	53.4	H / 1.8 / 10.0	-13.6	39.8	54.0	-14.2
2782.83	55.4 Pk	3.8 / 30.0 / 38.1	51	V / 1.5 / 185.0	-13.6	37.4	54.0	-16.6
3710.44	54.5 Pk	5.2 / 31.9 / 38.4	53.2	H / 2.4 / 300.0	-13.6	39.6	54.0	-14.4
3710.47	52.2 Pk	5.2 / 31.9 / 38.4	50.9	V / 2.2 / 302.0	-13.6	37.3	54.0	-16.7
4638.05	58.5 Pk	6.9 / 32.6 / 40.5	57.5	V / 1.3 / 330.0	-13.6	43.9	54.0	-10.1
4638.1	54.7 Pk	6.9 / 32.6 / 40.5	53.7	H / 1.8 / 70.0	-13.6	40.1	54.0	-13.9
5565.66	49.3 Pk	6.8 / 34.6 / 39.8	50.9	H / 1.5 / 355.0	-13.6	37.3	92.7	-55.4
5565.72	47.0 Pk	6.8 / 34.6 / 39.8	48.6	V / 1.8 / 10.0	-13.6	35.0	92.7	-57.7
6493.26	56.5 Pk	8.5 / 35.3 / 40.2	60.1	V / 1.2 / 10.0	-13.6	46.5	92.7	-46.2
6493.27	55.0 Pk	8.5 / 35.3 / 40.2	58.6	H / 1.9 / 320.0	-13.6	45.0	92.7	-47.7
7420.9	43.6 Pk	8.2 / 36.5 / 39.8	48.4	H / 1.6 / 190.0	-13.6	34.8	54.0	-19.2
7420.9	44.3 Pk	8.2 / 36.5 / 39.8	49.1	V / 1.7 / 50.0	-13.6	35.5	54.0	-18.5
8348.49	59.2 Pk	8.4 / 37.1 / 47.9	56.8	H / 1.6 / 320.0	-13.6	43.2	54.0	-10.8
8348.52	54.0 Pk	8.4 / 37.1 / 47.9	51.6	V / 1.8 / 175.0	-13.6	38.0	54.0	-16.0
9276.14	48.1 Pk	9.0 / 38.2 / 48.5	46.9	V / 1.8 / 175.0	-13.6	33.3	92.7	-59.4
9276.14	48.1 Pk	9.0 / 38.2 / 48.5	46.9	H / 1.4 / 175.0	-13.6	33.3	92.7	-59.4
	-							



Project File: 3162583 Page 12 of 26 Voice: 303 786 7999 Fax: 303 449 6160

# **Project Report**

Begin Date: 8/22/2008 **End Date:** 8/22/2008

Technician Randall Thompson **Project** 3162583

Capital Asset I	DManufacturer	Model #	Serial #	Description	Test Performed	Service Type	Service Date	Service Due
18882	Hewlett-Packard	8566B	2410A00154	Spectrum Analyzer (dc-22 GHz)	R Radiated Emissions	For Cal	11/13/2007	11/13/2008
18887	EMCO	3115	9205-3886	Horn Antenna 1-18GHz	R Radiated Emissions	For Cal	3/6/2008	3/6/2009
18900	Avantek	AFT97-8434-10F	1007	RF Pre-Amplifier (4-8 GHz)	R Radiated Emissions	For Ver	5/2/2008	5/2/2009
18901	Avantek	AWT-18037	1002	RF Pre-Amplifier (8-18 GHz)	R Radiated Emissions	For Ver	5/2/2008	5/2/2009
18906	Mini-Circuits Lab	ZHL-42	N052792-2	RF Pre-Amplifier (1-4 GHz)	R Radiated Emissions	For Ver	5/2/2008	5/2/2009
18808	EMCO	3146	9203-3376	Log Periodic Antenna	R Radiated Emissions	ForCal	10/12/2007	10/12/2008

Voice: 303 786 7999

Fax: 303 449 6160

Appendix B	
Test Plan	
and	
Constructional Data Form	
[Provided by Client]	
[	

Project File: 3162583 Page 14 of 26

### **Request for Estimate & Test Plan**

Please contact with any questions:

Contact:	Bryant Hart
Title:	Account Manager
Phone Number:	(303) 402-5272
Email Address:	Bryant.Hart@Intertek.com

### **Client Information:**

License Holder:	Inovonics Wireless Corp.
Address:	315 CTC Boulevard
Contact:	Jerry Klintz
Title:	Engineering Manager
Phone Number:	303-209-7259
Fax Number:	303-939-8977
Email Address:	Jerry.klintz@inovonics.com

Please fill out the pertinent pages within this document and email this Form to Bryant at <a href="mailto:Bryant.Hart@intertek.com">Bryant.Hart@intertek.com</a> for a quotation. Other pages that do not pertain to your device can be left blank.

I.E. EMC Quote - Pages 1,2 & 3, Add Safety - add Page 4, If a radio is part of the device add page 5 etc.

This document is compiled as a WORD FORM. To enable the FORM tool, right click on the tool bar and select FORMS. You will then be able to add attachments, drawings etc by clicking on the "Lock" Graphic to unlock the FORM document. To make all the check boxes work within the FORM, the "Lock" graphic must be selected. Thank you for all your time and effort on this matter.

Estimates Requested: (Required for all devices)

·	,				
EMC Testing/Services					
Requesting Estimate	On-site/In-Situ Testing				
Pre-Compliance Scans / Engineering test	☐ TCF Compilation/Review Service				
Radio Device Testing and Certification					
	☐ Industry Canada Certification (Receivers required)				
☐ Class 2 Notification Under the R&TTED	☐ TCF Compilation/Review Service				
Safety Testing and Certification					
☐ NRTL Listing	☐ 1 Day Pre-Assessment (conducted at your facility)				
Letter of Findings	☐ CB Report Covering all country Deviations				
☐ CE Report to Cover the LVD/MDD	☐ CB Report Covering - Specify Countries:				
Any Additional Interest(s)					
☐ ISO Certification (Another RFQ is required)	☐ Energy Star Compliance				
☐ FDA 510K Services (Another RFQ is required)	│				
☐ International Approvals Management	☐ Wire and Cable				
Product Verification and Integrity Testing	Other:				

Project File: 3162583 Page 15 of 26

General Product Information: (Required for all Devices) EN1242 Product/Model Number(s): Description of product(s): 900 MHz transmitter Smoke Sensor Household/Office ⊠ Commercial ⊠ Industrial ☐ Hospital Intended Use: Life Supporting Intended Location: Damp Wet Hazardous Location ☑ Dry |

Product Type:	Type: Prototype Production Sample Manufacturing Design Change: Please Describe					
Is it a stand-alone device or part of a system?  Stand Alone Device Component of a System						
If part of a system, please describe system parts and accessories:						
If there is more than one product/model what are the differences?						
Is the Product Enclosure:	Metal 🛛 Plastic 🔲 Both					
Size: Length: 11.4cm	Width: 6.4cm Height: 4.1cm Weight: 101g					
What Voltages/Current does the EUT run at? (AC/DC etc.) – if the unit runs off of DC though it is supplied with an AC/DC converter, please state the operating parameters of the converter.  Rated Voltage:3.0 VDC (internal battery only) Rated Current: 50 mA peak # of Phases/Conductors: # of Power Cords:						
Are their multiple suppliers of power supplies?						
Are there Multiple Modes of Operation?  ☑ Yes ☐ No If Yes Please Describe: Detailed in the product literature						
Is there programmable software?  ☐ Yes ☐ No						
Can all modes of operation be operated simultaneously?  ☐ Yes ☐ No						
In which countries will you be selling the product? United States, Canada						
When can you supply samples of the device and all pertinent documentation (where applicable) to Intertek for testing? 8/20/08						

Project File: 3162583 Page 16 of 26

**EMC Information:** (Required only if EMC work is requested) What EMC certifications are desired? ☐ FCC/ICES (US & Canada) SII (Israel) CE / EMC / MMD AS/NZS (Australia/New Zealand) ☐ BSMI (Taiwan) Korea MIC Certification / RRL VCCI (Japan) Other: Please Specify Highest frequency utilized for device operation: 927.6 MHz List of Clock Frequencies: 16 MHz, 4 MHz, 32.768 KHz, 10 KHz What is the time that it takes for the device to complete a full cycle of operation? (time required to identify any degradation in performance) (please list per mode of operation) 2 sec Total Number of I/O Cables: # Greater than 3m (9.75 feet) in Length # Greater than 30m (97.5 feet) in Length # of cables at a longer length (specify) Number of Dedicated Earth Equalization Ports Number of Ethernet and/or Telecommunications Ports 0 When the device is a compilation of subsystems (in separate chassis) how many interconnecting I/O's are greater than 1 meter in length between the Subsystem chassis? CISPR11/EN 55011 Specific Devices: 1. Does the EUT use RF Energy to affect a material? ☐ Yes ☒ No If yes, state frequency of energy:

Project File: 3162583 Page 17 of 26

General Safety Information: (Required only if Safety Listing/Certification/Testing is requested)					
What Safety certifications are desired?  NRTL Listing US/Canada CB Certification (Worldwide – Outside US/Ca EU Investigation (EU – LVD/MDD) Field Label (Onsite Inspection)	n)	☐ Limited Production Certification/Listing ☐ S Mark ☐ GS Mark ☐ Other: Please Specify			
Please list all applicable safety standards that you would like your device certified under:					
Has the device been tested and certified for product safety before?  A. If it has been previously tested, to which standard		☐ Yes ☐ No Standard tested to:			
and by which organization?  B. Can you provide the test report?		Organization tested by:  ☐ Yes ☐ No			
Do manuals and installation instructions exist? (Not always a necessity for quoting but most useful for complex products)		⊠ Yes □ No			
Power Supply Safety Information:		☐ Yes ☐ No			
A. Is the power supply an approved "off-the-shelf" supply?		Standard tested to:			
B. Can you provide the test report/CB Report?		Organization tested by:   Yes No			
Does the device contain batteries?	What Type? How Many?	e? CR123 LiMnO2 v? 1			
What technology is used? (i.e., lasers, X Ray, etc.)					
If Laser: Class: Output Power:	Bea	eam Divergence Angle: Wavelength:			
Preferred testing location:  Intertek Lab Customer site Intertek Local Lab (May increase turn around time and expense)					

Project File: 3162583 Page 18 of 26

Radio Information: (Required only if the device contains an intentional transmitter)					
What Radio certifications are desired?					
<ul><li></li></ul>	<ul><li>☐ Notified or Competent Body TCF Review</li><li>☐ Other: Please Specify</li></ul>				
Please list the particular radio standards that ap FCC Part 15	pply.				
Operating Frequency:	902.4 – 927.6 MHz				
RF Output Power:	25 mW				
Is there an RF Conducted Port?	☐ Yes ⊠No Description:				
Number of Antennas & Description: (Internal, External, Known Gain, etc.)	1, internal				
Modulation Technique:	2 FSK				
Number of Channels/Number of Discrete frequencies per Channel:	25/1				
Can the device be operated in CW Mode?	∑ Yes ☐ No				
What is the lowest utilized frequency within the device?	10 KHz				

Notes: Please ensure to bring a notch filter covering your fundamental operating frequency.

### **Additional Information:**

This information is required to be filled in to act as a test plan and constructional data form required to be supplied as part of the test report in accordance to the required standards. This information is not required to obtain a quote but should be filled out to show a completed report under the applicable standards for EMC etc. Thank you for your time in effort in completing this section of the RFQ/Test Plan.

Support Equipment
-------------------

Intertek requires our customers provide all support equipment necessary to fully operate the device undergoing testing. This includes any filters required for testing radio devices, computer equipment, etc.

	<u> </u>	,	
Item	Description	Manufacturer	Model No.
1	Laptop Computer		
2			
3			
4			

Cabling	Inform	ation:
Cabling	11110111	ialion.

<u>abillig i</u>	mormation.				
Cable	Function*	Type of Shield	Length	Connectors	Connection**
1					
2					
3					
4					
5					
6					

<sup>\*</sup> Function examples (Ethernet, RS232, USB, Analog, physiological parameter, etc.)

### **Monitoring the EUT:**

Please provide instructions below on how to observe the EUT to verify proper operation in all modes. (including software revision)

Any other information required: (Notes, Photos, Block Diagrams, Drawings, etc.	(.ز
A minimum of a block diagram showing the equipment under test and its support equipment.	

Project File: 3162583 Page 20 of 26

<sup>\*\*</sup> Connection examples (Outside Plant, Patient Coupled, Ring Voltage, etc.)

For Intertek Internal Use Only Please do not fill in the following Information.

Quoting Engineer:							
<b>Emissions Testing Req</b>							
☐Class A ☐Class B 🛭	$oxedsymbol{oxed}$ Radio Device $oxedsymbol{oxed}$	Group	1				
		ICES-0	03			VCCI	
FCC Part 18		BSMI				CISPR 22/EN 55022	
☐ CISPR 11/EN 55011		] IEC/EN	61326			IEC/EN61000-6-3	
☐ IEC/EN61000-6-4		CNS13	438			AS/NZS 3548	
☐ IEC/EN61000-3-2		] IEC/EN	61000-3-3			ETSI/EN 301 489	
Other:							
OATS Testing Voltages							
☐ 100VAC/50 Hz		120VA0	C/60Hz			230VAC/50Hz	
☐ 110VAC/60Hz		220VAC/60Hz				240VAC/50Hz	
Other:							
Immunity Product Fami	ly Standard						
☐ CISPR24/EN 55024		IEC/EN	61000-6-1			IEC/EN 61000-6-2	
☐ IEC/EN 60601-1-2 ☐	Art. Hand.	IEC/EN	61326			CISPR14/ EN 55014-2	
ETSI/EN 301 489		Add Isra	ael Frequencies	<u> </u>			
Other:	•		•				
Immunity Methods							
-			☐ 8kV				
☐ EN61000-4-2	4kV/8kV		12kV	ПО	ther	:	
	☐ 6kV/8kV		15kV	_			
			1 kHz Modulation				
☐ EN61000-4-3	☐ 3V/m		☐ 400 Hz			_	
☐ EN61000-4-3	☐ 10V/m	Modulation L			ther	:	
			☐ 2 Hz Modulation				
☐ EN61000-4-4	☐ 0.5 kV				ا ما		
☐ EN61000-4-4	☐ 1.0 kV		☐ 2.0 kV		ther		
☐ EN61000-4-5	☐ 0.5 kV		☐ 2.0 kV		امط		
EN01000-4-5	☐ 1.0 kV		☐ 4.0 kV	ЦΟ	ther		
			1 kHz Modulation				
☐ EN61000-4-6	3Vrms		☐ 400 Hz		hor	••	
	☐ 10Vrms		Modulation	Other:		•	
			2 Hz Modulation				
☐ EN61000-4-8	☐ 1A/m		☐ 400A/m		ther	••	
	☐ 30A/m				ıııeı	•	
	☐ >95% 0.5 Cy		☐ 30% 25 Cycles				
☐ EN61000-4-11	☐ 30% 0.5 Cycl		☐ >95% 250 Cycles		thai	••	
	60% 5 Cycles	3	☐ >95% 1 Cycle		Other:		
	☐ 60% 50 Cycle	es					
Test Reports Requeste	d						
EMC Reports:	Sa	afety Re	norts:				
Emissions			t Evaluation				
Immunity		Listing				sc. Deliverables:	
🔲 Engineering Data Onl						Other:	
☐ Engineering Data Only ☐ CB Certificate/Report ☐ Ctrief:							
ETSI "Radio"							
Overall Scheduling Time:							
Electromagnetic Compatibility:							
Emissions:		afety:					
Immunity:	Те	esting/Re	eports:				
Radio:							
Other/special notes:							

Project File: 3162583 Page 21 of 26

Appendix C
Measurement Protocol
And Test Procedures
rest i roccuures

### **MEASUREMENT PROTOCOL**

### **GENERAL INFORMATION**

### **Test Methodology**

Conducted and radiated emission testing is performed according to the procedures in ANSI C63.4 & CNS13438.

### **Justification**

The Equipment Under Test (EUT) is configured in a typical user arrangement in accordance with the manufacturer's instructions. A cable is connected to each available port and either terminated with a peripheral into it's characteristic impedance or left unterminated. When appropriate, the cables are manually manipulated with respect to each other to obtain maximum emissions from the unit.

### **CONDUCTED EMISSIONS**

The final level, expressed in  $dB_{\mu}V$ , is arrived at by taking the reading directly from the EMI receiver. This level is compared directly to the applicable limit.

To convert between  $dB\mu V$  and  $\mu V$ , the following conversions apply:

- $dB\mu V = 20(log \mu V)$
- $\mu V = Inverse log(dB\mu V/20)$

### **RADIATED EMISSIONS**

The final level, expressed in  $dB\mu V/m$ , is arrived at by taking the reading from the spectrum analyzer (Level  $dB\mu V$ ) and adding the antenna correction factor and cable loss factor (Factor dB) to it. This result then has the applicable limit subtracted from it to provide the Delta which gives the tabular data as shown in the data sheets in Attachment B.

Example: At a Test Frequency of 30 MHz, with a peak reading on the spectrum analyzer or measuring receiver of 14 dB $\mu$ V:

Measured Level	+	Transducer & Cable Loss factor	= Corrected Reading (dBµV/m)		Specification Limit	•	Corrected Reading	_	Delta Specification
(dBµV)		(dB) <b>14.9</b>		(dBµV/m)	] -	(dB <sub>µ</sub> V/m)			
14.0			28.9	40.0		28.9		-11.1	

Project File: 3162583 Page 23 of 26
Voice: 303 786 7999 Fax: 303 449 6160

### **DETAILS OF TEST PROCEDURES**

### General Standard Information

The test methods used comply with ANSI C63.4-2003 - "Methods of Measurement of Radio-Noise Emissions from Low-Voltage Electrical and Electronic Equipment in the Range of 9 kHz to 40 GHz."

### **Conducted Emissions**


Conducted emissions on the 50 Hz and/or 60 Hz power interface of the EUT are measured in the frequency range of 150 kHz to 30 MHz. The measurements are performed using a receiver, which has CISPR characteristic bandwidth and quasi-peak detection, and a Line Impedance Stabilization Network (LISN), with 50  $\Omega$ /50  $\mu$ H (CISPR 16) characteristics. Table top equipment is placed on a non-conducting table 80 centimeters above the floor and is positioned 40 centimeters from the vertical ground plane (wall) of the screen room. In some cases, a pre-scan using a spectrum analyzer is initially performed on the units comprising the system under test to locate the highest emissions. If the minimum passing margin appears to be less than 20 dB with a peak mode measurement, the emissions are re-measured using a tuned receiver or spectrum analyzer with quasi-peak and average detection and recorded on the data sheets.

### **Radiated Emissions**

Radiated emissions from the EUT are measured in the frequency range of 30 to 22GHz using a spectrum analyzer and appropriate broadband linearly polarized antennas. Measurements between 30 MHz and 1000 MHz are made with 120 kHz/6 dB bandwidth and quasi-peak detection and measurements above 1000 MHz are made with a 1 MHz/6 dB bandwidth and peak detection. Table top equipment is placed on a 1.0 X 1.5 meter non-conducting table 80 centimeters above the ground plane. Floor standing equipment is placed directly on the turntable/ground plane. Interface cables that are closer than 40 centimeters to the ground plane are bundled in the center in a serpentine fashion so they are at least 40 centimeters from the ground plane. Cables to simulators/testers (if used in this test) are routed through the center of the table and to a screen room located outside the test area. The antenna is positioned 3, 10 or 30 meters horizontally from the EUT. To locate maximum emissions from the test sample the antenna is varied in height from 1 to 4 meters, measurement scans are made with both horizontal and vertical antenna polarizations and the EUT are rotated 360 degrees.

Project File: 3162583 Page 24 of 26

### **Conducted Emissions Diagram:**



Fax: 303 449 6160

Voice: 303 786 7999

### **Radiated Emissions Diagram:**

