

Measurement Report for Device, FRONT, Validation band, CW, Channel 10000 (10000.0 MHz)

Device Under Test Properties

Model, Manufacturer	Dimensions [mm]
Source 10G,	100.0 x 100.0 x 172.0

Exposure Conditions

Phantom Section	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor
5G	FRONT, 10.00	Validation band	CW, 0--	10000.0, 10000	1.0

Hardware Setup


Phantom	Medium	Probe, Calibration Date	DAE, Calibration Date
mmWave - 1065	Air -	EUmmWV4 - SN9553_F1-55GHz, 2022-09-09	DAE4 Sn690, 2022-06-15

Scans Setup

Scan Type	5G Scan
Grid Extents [mm]	120.0 x 120.0
Grid Steps [lambda]	0.25 x 0.25
Sensor Surface [mm]	10.0
MAIA	N/A

Measurement Results

Scan Type	5G Scan
Date	2022-12-09
Avg. Area [cm ²]	4.00
psPDn+ [W/m ²]	50.1
psPDtot+ [W/m ²]	50.5
psPDmod+ [W/m ²]	52.8
E _{max} [V/m]	188
Power Drift [dB]	0.10



System Check_Head_6500MHz

DUT:D6.5GHzV2 - SN:1031

Communication System: Validation band; Frequency: 6500.0
Medium: HSL. Medium parameters used: $f=6500.0$ MHz; $\sigma=6.10$ S/m; $\epsilon_r=35.6$
Ambient Temperature: 23.2°C; Liquid Temperature: 22.6°C

DASY6 Configuration:

- Probe: EX3DV4 - SN7630; ConvF(5.65, 5.65, 5.65); Calibrated: 2022-03-04
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1305; Calibrated: 2022-04-27
- Phantom: Twin-SAM 1; Type: SAM Twin; Serial: 2024
- Measurement Software: cDASY6 V6.6.0.13926

Area Scan (51.0 mm x 51.0 mm): Measurement Grid: 8.5 mm x 8.5 mm
SAR (1g) = 8.37 W/kg; SAR (10g) = 2.85 W/kg;

Zoom Scan (22.0 mm x 22.0 mm x 22.0 mm): Measurement Grid: 3.4 mm x 3.4 mm x 1.4 mm
Power Drift = 0.04 dB
SAR (1g) = 13.8 W/kg; SAR (10g) = 2.49 W/kg;
psAPD (4.0cm², sq) = 60.9[W/m²]

