

## System Check\_Head\_6500MHz

### DUT:D6.5GHzV2 - SN:1031


Communication System: Validation band; Frequency: 6500.0  
Medium: HSL. Medium parameters used:  $f=6500.0$  MHz;  $\sigma=6.07$  S/m;  $\epsilon_r=34.1$   
Ambient Temperature: 23.3°C; Liquid Temperature: 22.8°C

#### DASY6 Configuration:

- Probe: EX3DV4 - SN7627; ConvF(5.45, 5.45, 5.45); Calibrated: 2022-06-20
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn690; Calibrated: 2022-06-15
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 1644; Section: Flat
- Measurement Software: cDASY6 V6.6.0.13926
- UID: CW, 0--

**Area Scan (51.0 mm x 51.0 mm):** Measurement Grid: 8.5 mm x 8.5 mm  
SAR (1g) = 24.3 W/kg; SAR (10g) = 4.65 W/kg;

**Zoom Scan (22.0 mm x 22.0 mm x 22.0 mm):** Measurement Grid: 3.4 mm x 3.4 mm x 1.4 mm  
Power Drift = -0.06 dB  
SAR (1g) = 26.6 W/kg; SAR (10g) = 4.88 W/kg;  
psAPD (4.0cm<sup>2</sup>, sq) = 121[W/m<sup>2</sup>]



Measurement Report for Device, FRONT, Validation band, CW, Channel 10000 (10000.0 MHz)

Device Under Test Properties

Model, Manufacturer	Dimensions [mm]
Device,	100.0 x 100.0 x 105.0

Exposure Conditions

Phantom Section	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor
5G	FRONT, 10.00	Validation band	CW, 0--	10000.0, 10000	1.0

Hardware Setup

Phantom	Medium	Probe, Calibration Date	DAE, Calibration Date
mmWave - 1065	Air -	EUmmWV4 - SN9432_F1-55GHz, 2021-11-29	DAE4 Sn690, 2022-06-15

Scans Setup

Scan Type	5G Scan
Grid Extents [mm]	120.0 x 120.0
Grid Steps [lambda]	0.25 x 0.25
Sensor Surface [mm]	10.0
MAIA	N/A

Measurement Results

Scan Type	5G Scan
Date	2022-09-20
Avg. Area [cm <sup>2</sup> ]	4.00
psPDn+ [W/m <sup>2</sup> ]	136
psPDtot+ [W/m <sup>2</sup> ]	137
psPDmod+ [W/m <sup>2</sup> ]	142
E <sub>max</sub> [V/m]	276
Power Drift [dB]	-0.02

