

01_NFC_ASK_Back_0mm_Ch13.56

Communication System: Custom Band; Frequency: 13.600

Medium: HSL. Medium parameters used: $f= 13.600$ MHz; $\sigma= 0.748$ S/m; $\epsilon_r = 53.7$

Ambient Temperature: 23.4°C; Liquid Temperature: 22.8°C

DASY6 Configuration:

- Probe: EX3DV4 - SN7706; ConvF(17.05, 17.05, 17.05); Calibrated: 2023-01-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1691; Calibrated: 2022-12-12
- Phantom: ELI V8.0 (20deg probe tilt); Serial: 2151
- Measurement Software: cDASY6 V6.6.0.13926

Area Scan (120.0 mm x 210.0 mm): Measurement Grid: 15.0 mm x 15.0 mm

SAR (1g) = 0.085 W/kg; SAR (10g) = 0.056 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 6.0 mm x 6.0 mm x 5.0 mm

Power Drift = -0.01 dB

SAR (1g) = 0.076 W/kg; SAR (10g) = 0.025 W/kg;

