

EMERSON | AMS | MODEL A9530 | MADE IN THAILAND

WARNING: Replace Battery only with Tadiran P/N TL-4920M or Emerson A0702PPU. Reference D25902 for installation instructions.



GSA-CUM
Class I Div
Class I Zone
-40°C to 50°C
Type 4x D



ATEX Group
II 1 G Ex
-40°C to 50°C

IECEx Group
Ex II G
Ta -40°C to 50°C



FCC ID: A9530
IC: 1010-1-0000

www.emerson.com
Emerson A0702299U. Reference D25902 for installation instructions.



CSA-C/US CSA20CA80028624
Class I Div.1 Grps. A,B,C & D
Class I Zone 0 AEx / Ex ia IIC T4 Ga
-40°C ≤ Ta ≤ 85°C
Type 4x Enclosure



ATEX CSANo. 20ATEX 2042X
II 1 G Ex ia IIC T4 Ga (135°C)
-40°C ≤ Ta ≤ 85°C IP66

IECEX CSA 20.0002X
Ex ia IIC T4 Ga
Ta -40°C ≤ Ta ≤ 85°C



FCC ID: NL5-A9530M1
IC ID: 3434A-A9530M1
Knoxville USA 37932

