




FCC ID: NZLPL1N

Contains FCC ID: 2AC7Z-ESPS3WROOM1



Label located on bottom side of the device.

MODEL: PL1N
DATE: 2024 November 15

FOR COMPLETE INSTALLATION
INSTRUCTIONS REFER TO MANUAL 550-0799
SEE WEBSITE FOR THE LATEST MANUAL

ASSEMBLED IN USA

DO NOT
PAINT

ALARM SHALL
BE REPLACED
WHEN THE END
OF LIFE SIGNAL
ACTIVATES OR
10 YEARS FROM
THE DATE OF
MANUFACTURE,
WHICHEVER
COMES FIRST.



WARNING

CARBON MONOXIDE CANNOT BE
SEEN OR SMELLED BUT CAN KILL
YOU. IF ALARM SIGNAL SOUNDS
FOUR REPEATING BEEPS:

- 1) OPERATE TEST/RESET
BUTTON
- 2) CALL YOUR EMERGENCY
SERVICES (FIRE DEPARTMENT
OR 911)
- 3) IMMEDIATELY MOVE TO
FRESH AIR (OUTDOORS
OR BY AN OPEN
DOOR/WINDOW)

FCC ID: NZLPL1N
Contains FCC ID: 2AC7Z-ESPS3WROOM1

INSTALLATION DATE

KEEP ALARM COVER
CLEAN USING A SOFT
CLOTH. DO NOT USE
SPRAY CHEMICALS OR
INSECT SPRAYS
DIRECTLY ON ALARM.
DOING SO MAY CAUSE
PERMANENT DAMAGE.



WARNING

ALARM WILL NOT OPERATE IF POWER IS
INTERRUPTED AND BATTERY IS DEAD,
DISCONNECTED, OR IMPROPERLY INSTALLED.

- 1 CHIRP – LOW BATTERY
- 2 CHIRPS – TROUBLE CONDITION OR
ALARM SILENCED. SEE MANUAL.
- 3 CHIRPS – END OF LIFE
- 4 BEEPS – SMOKE ALARM
- 5 BEEPS – CO ALARM



ISSUE NO: 5020688

Single and/or multiple station
Photoelectric Smoke and CO alarm.
Conforms to UL217 9th ed., UL2034
4th ed. Helps to reduce cooking
nuisance alarms.

WARNING

TEST UNIT WEEKLY. START BY TAPPING TEST
BUTTON AND REFER TO SELF-TEST GUIDE IN THE
MANUAL. A LOW OR MISSING BATTERY IS
INDICATED BY THE HORN CHIRPING ONCE EVERY
30-60 SECONDS. REPLACE BATTERY WITH ONLY
LITHIUM ENERGIZER L91 AA (AVAILABLE AT
MANY RETAIL STORES) USE OF ANOTHER
BATTERY TYPE MAY HAVE DETRIMENTAL
EFFECT ON ALARM OPERATION.

OPERATING VOLTAGE: 120VAC 60Hz w/3V BATTERY BACK-UP
OPERATING CURRENT: 0.1A MAX
SENSITIVITY TOLERANCE: 1.54 +/- 0.65 %/FT
ALARM HORN RATING: 79dBA MINIMUM @ 10 FT FREQUENCY 520Hz

Device_ID:

CAUTION

TO AVOID FALSE ALARM, DO NOT
USE WHERE MAXIMUM ROOM
TEMPERATURE WILL EXCEED 100 F

BLACK – LINE HOT
BROWN/YELLOW – TANDEM LINE
WHITE – LINE NEUTRAL

FOR SERVICE RETURN TO: GENTEX CORPORATION, 9001 RILEY STREET, BUILDING 10,
ZEELAND, MI 49464 (833)-70-PLACE www.placehomesolutions.com