United States Regulatory Information: This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions:

(1) this device may not cause harmful interference, and(2) this device must accept any interference received, including interference that may cause undesired operation.

Radios contained in this unit are: Model: GATEWAY-ALTE P/N: GATEWAY-ALTE

## WARNING:

## Owners Instruction Notice

This unit must be checked by a qualified technician at least once every three (3) years.

Internal Battery is Li-ion 3.7V/4400mAh. Replacement batteries are available from a qualified Alpheus Digital, Ltd. dealer. Batteries are expected to last approximately three years under normal conditions

See User Manual for proper operation of this console.

0817A

RESIDENTIAL SECURITY PANEL MODEL: GATEWAY-ALTE TRANSCEIVER FREQUENCY: 345 MHZ RECEIVER ERECUENCY: 345 MHZ POWER SUPPPLY: 5V. 3000Ma

United States Regulatory Information:

This device complies with Part 15 of the ECC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and

(2) this device must accept any interference received, including interference that may cause undesired operation.

Certified to comply with the limits for a Class B digital device pursuant to Part 15 of the FCC Rules. See user instructions if interference to radio reception is suspected.

This device complies with FCC radiation exposure limits set forth for an uncontrolled environment. This equipment should be installed and operated with minimum distance 20cm between the radiator and your body. This transmitter must not be co-located or operating in conjunction with any other antenna or transmitter

Radios contained in this unit are: Model: GATEWAY-ALTE FCC ID: OC7GATEWAYALTE P/N: GATEWAY-ALTE

Fire Protection Regulatory Information: Fire protection must follow NFPA Standard No. 72 (National Fire Protection Association, Batterymarch Park, Quincy, MA 02269), Printed information describing the proper installation. operation, testing, maintenance, evacuation planning, and repair service is to be provided with this equipment.

## IMPORTANT

- MONTHLY TESTING IS RECOMMEND-ED TO ENSURE PROPER OPERATION OF THE SYSTEM.
- 2. DO NOT CONNECT AC POWER TO A SWITCH-CONTROLLED OUTLET.
- 3. CONNECTION OF THE FIRE ALARM SIGNAL TO A FIRE ALARM HEADQUARTERS OR A CENTRAL MONITORING STATION SHALL BE PERMITTED ONLY WITH THE APPROVAL OF THE LOCAL AUTHORITY HAVING JURISDICTION. THE BURGLAR ALARM SIGNAL SHALL NOT BE CONNECTED TO A POLICE EMERGENCY NUMBER.
- US "Patent Pending"
  0817B Made in China