

**MODEL NO. SD4-SS** PHOTO-ELECTRONIC DETECTION PRINCIPLE  
FCC ID: PPJSD4SS418 418MHz WIRELESS SINGLE STATION SMOKE ALARM  
FACTORY SENS. 1.12%-3.33% PER FT. OBSCURATION 85DB SOUNDER

**WARNING:** USE ONLY BATTERIES SPECIFIED IN MARKING. USE OF  
A DIFFERENT BATTERY WILL HAVE A DETRIMENTAL  
EFFECT ON THE SMOKE ALARM OPERATION. REPLACEMENT BATTERY USE PANA-  
SONIC CR123A / DURACELL DL123A ONLY. CONSTANT EXPOSURES TO HIGH OR  
LOW TEMPERATURES OR HIGH HUMIDITY MAY REDUCE BATTERY LIFE. REFER  
TO INSTALL GUIDE 108101 FOR INSTALLATION, MAINTENANCE, OPERATING, AND  
SAFETY INFORMATION/INSTRUCTIONS. INSTALL GUIDE SHOULD BE READ AND RE-  
TAINED. GREEN LED BLINKS EVERY 10 SECONDS - NORMAL (STANDBY), HORN OFF.  
RED LED BLINKS EVERY 1 SECOND - SMOKE ALARM, HORN TEMPORAL PATTERN.  
RED LED BLINKS EVERY 45 SECONDS - LOW BATTERY, HORN CHIRPS EVERY 45  
SECONDS LED BLINKS FOR 7 DAYS. MAINTENANCE NOTE: POWER MUST BE RE-  
MOVED FROM THE DETECTOR BEFORE PERFORMING MAINTENANCE OF ANY KIND  
BY REMOVING THE DETECTOR'S BATTERY. TEST THE DETECTOR AFTER INSTALLA-  
TION, WEEKLY AND AFTER CLEANING (VACUUMING) TO CHECK ALARM FUNCTIONS.  
THIS ALARM CAN ONLY BE USED WITH SILENT CALL SK2-SS & WC08-SS RECEIV-  
ERS. THE BATTERY WARRANTY PERIOD IS NOT A PERFORMANCE CLAIM OF THIS  
DETECTOR.

FOR WARRANTY CLAIMS/REPAIRS SEND TO MANUFACTURER:  
SILENT CALL COMMUNICATIONS 5095 WILLIAMS LAKE RD, WATERFORD, MI 48329  
CALL 800-572-5227 OR VISIT SILENTCALL.COM

This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions:  
(1) This device may not cause harmful interference, and  
(2) This device must accept any interference received, including interference that may cause undesired operation.