

74, Seoicheon-ro 578beon-gil, Majang-myeon, Icheon-si, Gyeonggi-do, 17383, Rep. of KOREA

FCC / IC DFS REPORT

Certification

Applicant Name:

I&C Technology Co., Ltd.

Address:

(Sampyeong-dong , I&C Building), 24, Pangyoro255beon-gil,Bundang-gu Seongnam-si, South Korea Date of Issue:

August 08, 2018

Test Site/Location:

HCT CO., LTD., 74,Seoicheon-ro 578beon-gil,Majang-myeo,Icheon-si, Gyeonggi-do, 17383, Rep. of KOREA

Report No.: HCT-RF-1808-FC005

IC Registration Number: 5944A-6

FCC ID: 2ADXS-WFM60-SFP2501 IC: 12641A-WFM6SFP2501

APPLICANT: I&C Technology Co.,Ltd.

Model(s): WFM60-SFP2501

EUT Type: Dual Module

Max. RF Output Power:

Band	Mode	Frequency Range (MHz)	Power (dBm)	Power (W)
UNII2A -	802.11a	5260 - 5320	14.83	0.03039
	802.11n_HT20	5260 - 5520	14.83	0.03043
LIMILOC	802.11a	5500 5700	13.86	0.02430
UNII2C	802.11n_HT20	5500 – 5700	13.98	0.02502

Modulation type OFDM

FCC Classification: Unlicensed National Information Infrastructure (UNII)

FCC Rule Part(s): Part 15.407(DFS)

Engineering Statement:

The measurements shown in this report were made in accordance with the procedures indicated, and the emissions from this equipment were found to be within the limits applicable. I assume full responsibility for the accuracy and completeness of these measurements, and for the qualifications of all persons taking them. It is further stated that upon the basis of the measurements made, the equipment tested is capable of operation in accordance with the requirements of the FCC / IC Rules under normal use and maintenance.

Report prepared by : Jeong Ho Kim

Engineer of Telecommunication testing center

Approved by : Jong Seok Lee

Manager of Telecommunication testing center

This report only responds to the tested sample and may not be reproduced, except in full, without written approval of the HCT Co., Ltd.

F-TP22-03 (Rev.00) 1 / 22 **HCT CO.,LTD.**



FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

Version

TEST REPORT NO.	DATE	DESCRIPTION
HCT-RF-1808-FC005	August 08, 2018	- First Approval Report

F-TP22-03 (Rev.00) 2 / 22 **HCT CO.,LTD.**



FCC ID : 2ADXS-WFM60-SFP2501 / IC : 12641A-WFM6SFP2501

Table of Contents

1. GENERAL INFORMATION	. 4
2. EUT DESCRIPTION	. 4
3. SCOPE	. 5
4. INSTRUMENT CALIBRATION	. 5
5. FACILITIES AND ACCREDITATIONS	. 5
5.1 FACILITIES	. 5
5.2 EQUIPMENT	. 5
6. SUMMARY OF TEST RESULTS	. 6
7. DESCRIPTION OF DYNAMIC FREQUENCY SELECTION TEST	. 7
7.1 APPLICABILITY	. 7
7.2 REQUIREMENTS	. 8
7.3 DFS DETECTION THRESHOLD VALUES 1	1 0
7.4 PARAMETERS OF DFS TEST SIGNALS 1	1 1
7.5 TEST AND MEASUREMENT SYSTEM1	1 2
7.6 DESCRIPTION OF EUT	1 4
7.7 UNII2A TEST RESULT 1	1 5
7.8 UNII2C TEST RESULT 1	8 ا
8. LIST OF TEST EQUIPMENT	2 1
9. ANNEX A_ TEST SETUP PHOTO	2 2



FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

1. GENERAL INFORMATION

Applicant: I&C Technology Co.,Ltd.

Address: (Sampyeong-dong , I&C Building), 24, Pangyo-ro255beon-gil,Bundang-gu

Seongnam-si, South Korea

FCC ID: 2ADXS-WFM60-SFP2501

IC: 12641A-WFM6SFP2501

EUT Type: Dual Module

Model: WFM60-SFP2501

Date(s) of Tests: July 03, 2018 ~ August 01, 2018

HCT Co., Ltd.

Place of Tests:
74, Seoicheon-ro 578beon-gil, Majang-myeon, Icheon-si, Gyeonggi-do, Korea

2. EUT DESCRIPTION

Model	WFM60-SFP2501			
EUT Type	Dual Module	Dual Module		
Power Supply	3.30 V			
	TX_20 MHz BW:	5260 MHz - 5320 MHz (UNII 2A)/ 5500 MHz - 5700 MHz (UNII 2C)		
Frequency Range	RX_20 MHz BW:	5260 MHz - 5320 MHz (UNII 2A)/ 5500 MHz - 5700 MHz (UNII 2C)		
Troquency rungo	For IC [This restriction (5600-5650 MHz) is for the protection of Environment Canada's weather radars operating in this band.]			
Modulation Type	OFDM(802.11a, 802.11n)			
Antenna Specification	Manufacturer: I&C TECHNOLOGY			
	Antenna type: PCB Antenna			
	Peak Gain : 3.50 dBi (UNII 2A) / 3.34 (UNII 2C)			

F-TP22-03 (Rev.00) 4 / 22 **HCT CO.,LTD.**



FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

3. SCOPE

This report has been prepared to demonstrate compliance with the requirements for Dynamic Frequency Selection(DFS) as stated in KDB 905462 D02 v02. Testing was performed in accordance with the measurement procedure described in FCC KDB 905462 D02 v02.

4. INSTRUMENT CALIBRATION

The measuring equipment, which was utilized in performing the tests documented herein, has been calibrated in accordance with the manufacturer's recommendations for utilizing calibration equipments, which is traceable to recognized national standards.

Espectially, all antenna for measurement is calibrated in accordance with the requirements of C63.5 (Version : 2017).

5. FACILITIES AND ACCREDITATIONS

5.1 FACILITIES

The SAC(Semi-Anechoic Chamber) and conducted measurement facility used to collect the radiated data are located at the 74, Seoicheon-ro 578beon-gil, Majang-myeon, Icheon-si, Gyeonggi-do, Korea. The site is constructed in conformance with the requirements of ANSI C63.4. (Version :2014) and CISPR Publication 22. Detailed description of test facility was submitted to the Commission and accepted dated April 02, 2018 (Registration Number: KR0032).

For ISED, test facility was accepted dated October 19, 2015(Registration Number: 5944A-6)

5.2 EQUIPMENT

Spectrum analyzers with pre-selectors and quasi-peak detectors are used to perform measurements. Calibrated wideband preamplifiers, coaxial cables, and coaxial attenuators are also used for making measurements. All receiving equipment conforms to CISPR Publication 16-1, "Radio Interference Measuring Apparatus and Measurement Methods."

F-TP22-03 (Rev.00) 5 / 22 **HCT CO.,LTD.**



6. SUMMARY OF TEST RESULTS

FCC ID: 2ADXS-WFM60-SFP2501/

: HC1-RF-1808-FC005 IC : 12641A-WFM6SFP2501

Band	Parameter	Limit	Result
	Channel Move Time	10 seconds	PASS
UNII2A	Channel Closing Transmission Time	200 ms + aggregate of 60 ms over remaining 10 second period	PASS
	Non-occupancy Period	30 minutes	PASS
	Channel Move Time	10 seconds	PASS
UNII2C	Channel Closing Transmission Time	200 ms + aggregate of 60 ms over remaining 10 second period	PASS
	Non-occupancy Period	30 minutes	PASS

F-TP22-03 (Rev.00) 6 / 22 **HCT CO.,LTD.**



FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

7. DESCRIPTION OF DYNAMIC FREQUENCY SELECTION TEST 7.1 APPLICABILITY

The following table from KDB905462 D02 v02(04/08/2016) lists the applicable requirements for the DFS testing. The device evaluated in this report is considered a client device without radar detection capability.

	Operation Mode			
Requirement	Master	Client Without Radar	Client With Radar	
		Detection	Detection	
Non-Occupancy Period	Yes	Not required	Yes	
DFS Detection Threshold	Yes	Not required	Yes	
Channel Availability Check Time	Yes	Not required	Not required	
Uniform Spreading	Yes	Not required	Not required	
U-NII Detection Bandwidth	Yes	Not required	Yes	

Table 1-1. DFS Applicability

	Operation Mode			
Requirement	Mootor	Client Without Radar	Client With Radar	
	Master	Detection	Detection	
DFS Detection Threshold	Yes	Not required	Yes	
Channel Closing Transmission Time	Yes	Yes	Yes	
Channel Move Time	Yes	Yes	Yes	
U-NII Detection Bandwidth	Yes	Not required	Yes	

Table 1-2. DFS Applicability During Normal Operation



FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

7.2 REQUIREMENTS

Per KDB905462 D02 v02(04/08/2016) the following are the requirements for Client Devices:

- a) A Client Device will not transmit before having received appropriate control signals from a Master Device.
- b) A Client Device will stop all its transmissions whenever instructed by a Master Device to which it is associated and will meet the Channel Move Time and Channel Closing Transmission Time requirements.
 - The Client Device will not resume any transmissions until it has again received control signals from a Master Device.
- c) If a Client Device is performing In-Service Monitoring and detects a Radar Waveform above the DFS Detection Threshold, it will inform the Master Device. This is equivalent to the Master Device detecting the Radar Waveform and d) through f) of section 5.1.1 apply.
- d) Irrespective of Client Device or Master Device detection the Channel Move Time and Channel Closing Transmission Time requirements remain the same.

F-TP22-03 (Rev.00) 8 / 22 **HCT CO.,LTD.**



FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

Channel Move Time and Channel Closing Transmission Time requirements are listed following table.

Parameter	Value
Non-occupancy period	Minimum 30 minutes
Channel Availability Check Time	60 seconds
Channel Move Time	10 seconds
Channel Move Time	See Note 1.
	200 milliseconds + an
Channel Closing Transmission Time	Aggregate of 60 milliseconds over
Channel Closing Transmission Time	Remaining 10 second period. See Notes
	1 and 2.
	Minimum 100 % of the U-NII
U-NII Detection Bandwidth	99 % transmission
	Power bandwidth. See Note 3.

Note 1: Channel Move Time and the Channel Closing Transmission Time should be performed with

Radar Type 0. The measurement timing begins at the end of the Radar Type 0 burst.

Note 2: The Channel Closing Transmission Time is comprised of 200 milliseconds starting at the beginning of The Channel Move Time plus any additional intermittent control signals required to facilitate a Channell move (an aggregate of 60 milliseconds) during the remainder of the 10 second period. The aggregate duration of control signals will not count quiet periods in between transmissions.

Note3: During the U-NII Detection Bandwidth detection test, radar type 0 should be used.

For each frequency step the minimum percentage of detection is 90 percent. Measurements are performed With no data traffic.

Table 1-3: DFS Response requirements



FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

7.3 DFS DETECTION THRESHOLD VALUES

The DFS detection thresholds are defined for Master devices and Client Devices with In-service monitoring. These detection thresholds are listed in the following table.

Maximum Transmit Power	Value (See Notes 1 and 2)
≥ 200 milliwatt	-64 dBm
< 200 milliwatt	-62 dBm

Note 1: This is the level at the input of the receiver assuming a 0 dBi receive antenna.

Note 2: Throughout these test procedures an additional 1 dB has been added to the amplitude of

the test transmission waveforms to account for variations in measurement equipment. This will

ensure that the test signal is at or above the detection threshold level to trigger a DFS response.

Table 1-4: Detection Thresholds for Master Devices and Client Devices with Radar Detection



FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

7.4 PARAMETERS OF DFS TEST SIGNALS

As the EUT is a Client Device with no Radar Detection only one type radar pulse is required for the testing. Radar Pulse type 0 was used in the evaluation of the Client device for the purpose of measuring the Channel Move Time and the Channel Closing Transmission Time. Table 1-5 lists the parameters for the Short Pulse Radar Waveforms. A plot of the Radar pulse Type 0 used for testing is included in Section 7.7 of this report.

Radar Type	Pulse Width (µsec)	PRI (μsec)	Number Of Pulses	Minimum Percentage of Successful Detection	Minimum Number of Trials
0	1	1428	18	See Note 1	See Note 1
1	1	Test A: 15 unique PRI values Randomly selected From the list of 23 PRI values in Table 5a Test B: 15 unique PRI values Randomly selected within the range of 518-3066 µ sec, with a minimum increment of 1 µ sec, excluding PRI values selected in Test A	Roundup 1 360 19·10 ⁶ PRI µsec	60%	30
2	1-5	150-230	23-29	60%	30
3	6-10	200-500	16-18	60%	30
4	11-20	200-500	12-16	60%	30
				80%	120

Note1: Short pulse Radar Type 0 should be used for the detection bandwidth test, channel move time, and channel closing time tests.

Table 1-5: Parameters for Short Pulse Radar Waveforms



FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

7.5 TEST AND MEASUREMENT SYSTEM

General Test Setup Procedure:

- 1. The EUT was operating 802.11a, 802.11n_HT20 mode during the test.
- 2. Connect FCC approved Master AP to a network, via wired Ethernet, that allows connection to an FTP server.
- 3. Associate the EUT with the Master AP.
- 4. Launch the FTP application on the EUT.
- 5. Connect to the FTP server application to the FTP server hosting the file
- 6. Initiate an FTP download of the file from the host.
- 7. Monitor the channel loading during transfer.
- 8. Reduce the maximum allowed data rate for the Master AP, using the AP's GUI interface.
- 9. Repeat steps 5-7 until the channel loading is as close to 20 % as possible.
- 10. Record the data rate setting on the Master AP and the channel loading.
- 11. While the system is performing an FTP transfer using the settings form item 9 above, perform the Channel Closing Transmission Time and Channel Move Time Measurements as required by KDB905462 D02 v02 using a conducted test.

PROCEDURE

The KDB905462 D02 v02 describes a radiated test setup and a conducted test setup. A radiated test setup was used for this testing. Figure 3-1 shows the typical test setup. Each one channel selected between 5260 and 5320 MHz, 5500 and 5700 is chosen for the testing.




Figure 3-1. Conducted Test Setup for DFS



FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

1. The radar pulse generator is setup to provide a pulse at the frequency that the Master and Client are operating. A Type 0 radar pulse with a 1 μs pulse width and a 1428 μs PRI is used for the testing.

2. The vector signal generator is adjusted to provide the radar burst (18 pulses) at a level of

approximately -62 dBm at the antenna of the Master device.

3. The Client Device (EUT) is set up per the diagram in Figure 3-1 and communications between the

Master device and the Client is established.

4. Software to ping the client is permitted to simulate data transfer but must have random ping intervals.

We used 'iperf' software.

5. The spectrum analyzer is set to record about 15 sec window to any transmissions occurring up to

and after 10 sec.

6. The system is again setup and the monitoring time is shortened in order to capture the Channel

Closing Transmission Time. This time is measured to insure that the Client ceases transmission within 200 ms and the aggregate of emissions occurring after 200 ms up to 10 sec do not exceed 60

ms.

(Note: the channel may be different since the Master and Client have changed channels due to the

detection of the initial radar pulse.)

7. After the initial radar burst the channel is monitored for 30 minutes to insure no transmissions or

beacons occur. A second monitoring setup is used to verify that the Master and Client have both

moved to different channels.

SYSTEM CALIBRATION

A-50-ohm load is connected in place of the spectrum analyzer, and the spectrum analyzer is

connected to a coaxial cable. The signal generator is set to CW mode. The amplitude of the

signal generator is adjusted to yield a level of - 62 dBm as measured on the spectrum analyzer.

Without changing any of the instrument settings, the spectrum analyzer is reconnected to the

common port of the spectrum analyzer combiner or divider.

The spectrum analyzer displays the level of the signal generator higher than the client TX

level. Because we can not search the signal generator in the spectrum analyzer when the

signal generator level is - 62 dBm. The spectrum analyzer will still indicate the level higher

than the client TX level.



FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

7.6 DESCRIPTION OF EUT

The EUT operates over the UNII 2A and UNII 2C band.

The EUT is a slave device without radar detection.

The EUT antenna has a gain of 3.50 dBi in 5260 MHz - 5320 MHz band and 3.34 dBi in 5500 MHz - 5700 MHz band.

The highest power level within these bands in 18.33 dBm EIRP in the 5260 MHz - 5320 MHz band and 17.32 dBm EIRP in the 5500 MHz – 5700 MHz band.

The EUT one transmitter/receiver chain connected to a coaxial cable to perform conducted tests.

TPC is not required since the maximum EIRP is less than 500 mW.

The EUT utilizes the 802.11a/n architecture.

The nominal channel bandwidth is implemented: 20 MHz

F-TP22-03 (Rev.00) 1 4 / 22 **HCT CO.,LTD.**




FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

7.7 UNII2A TEST RESULT

Test using the widest BW mode available for the link _ [802.11a Mode : ch60]

■ Type0 Radar Pulse

Type0 PRI



Type0 Radar Pulse Number



Marker Descriptions:


Number of Pulse Form M1R to M1: 18




FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

■ RESULT PLOTS_(UNII2A Band)

Time Display, Non WLAN Channel Traffic



Time Display, WLAN Channel Traffic (Streaming Video)





FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501



- · Channel Move Time: 0.041607 s(Limit: 10 s)
- · Channel Closing Transmission Time, Aggregate Time After 200 ms: 0.001818 s(Limit: 60 ms)

Non-occupancy Period – Monitoring live time spectrum analyzer – Elapse time 30 minutes






FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

7.8 UNII2C TEST RESULT


Test using the widest BW mode available for the link _ [802.11a Mode: ch100]

■ Type0 Radar Pulse

Type0 PRI



Type0 Radar Pulse Number



Marker Descriptions:


Number of Pulse Form M1R to M1: 18




FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

■ RESULT PLOTS_(UNII2C Band)

Time Display, Non WLAN Channel Traffic




Time Display, WLAN Channel Traffic (Streaming Video)





FCC ID: 2ADXS-WFM60-SFP2501/



- · Channel Move Time: 0.045082 s(Limit: 10 s)
- · Channel Closing Transmission Time, Aggregate Time After 200 ms: 0.001493 s (Limit: 60 ms)

Non-occupancy Period – Monitoring live spectrum analyzer – Elapse time 30 minutes





FCC ID: 2ADXS-WFM60-SFP2501 / IC: 12641A-WFM6SFP2501

8. LIST OF TEST EQUIPMENT

Manufacturer	Model / Equipment	Calibration	Calibration	Serial No.	
		Date	interval		
SAMSUNG	WEA453e /	N/A	N/A	S2LF812265	
ELECTRONICS	Wireless AP (Master Device)	IN/A	14/74	(FCC ID: A3LWEA453E)	
ADLINK	PXI/DFS Measurement System(S/G)	03/22/2018	Annual	302581/735	
ADLINK	PXI/DFS Measurement System(S/A)	03/22/2018	Annual	303582/113	
Agilent	N9020A / Signal Analyzer	06/08/2018	Annual	MY51110085	
Agilent	87300B / Directional Coupler	11/20/2017	Annual	3116A03621	
Cernex	CDPU5260404K / 4 Way Power Divider	03/06/2018	Annual	14695	
Agilent	8493C / Attenuator(10 dB)	07/10/2018	Annual	07560	
WEINSCHEL	2-3 / Attenuator(3 dB)	10/12/2017	Annual	BR0617	
Weinschel	AF9003-69-31 / Step Attenuator	10/12/2017	Annual	5701	
Narda	4426-4 / 4 Way Power Divider	02/08/2018	Annual	11927	

F-TP22-03 (Rev.00) 2 1 / 22 **HCT CO.,LTD.**



FCC ID : 2ADXS-WFM60-SFP2501 / IC : 12641A-WFM6SFP2501

9. ANNEX A_ TEST SETUP PHOTO

Please refer to test setup photo file no. as follows;

No.	Description
1	HCT-RF-1808-FC005-P

F-TP22-03 (Rev.00) 2 2 / 22 **HCT CO.,LTD.**