


Test Laboratory: Compliance Certification Services
File Name: 1L-CH_0.078 mW.da4

EUT Setup Configuration 1



Test Laboratory: Compliance Certification Services
File Name: 1L-CH_0.078 mW.da4

Applicant: Twinhead Model Name: P22T

Program: EUT Setup Configuration 1; Air temp 24.5 deg C & Liquid temp 22.4 deg C

Communication System: DSSS; Frequency: 2412 MHz; Duty Cycle: 1:1
Medium: Muscle 2450 MHz ($\sigma = 1.945$ mho/m, $\epsilon = 50.76$, $\rho = 1000$ kg/m³)
Phantom section: FlatSection

DASY4 Configuration:

- Probe: ET3DV6 - SN1577; ConvF(4.7, 4.7, 4.7); Calibrated: 2/7/2003
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn427; Calibrated: 2/4/2003
- Phantom: SAM 2 - TP:1050
- Software: DASY4, V4.0 Build 51

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=7.5mm, dy=7.5mm


Reference Value = 3.66 V/m

Peak SAR = 0.172 mW/g

SAR(1 g) = 0.078 mW/g; SAR(10 g) = 0.041 mW/g

Power Drift = 0.02 dB

Area Scan (11x26x1): Measurement grid: dx=10mm, dy=10mm



Test Laboratory: Compliance Certification Services

File Name: 2M-CH_0.0567 mW.da4

Applicant: Twinhead Model Name: P22T

Program: EUT Setup Configuration 1; Air temp 24.5 deg C & Liquid temp 22.4 deg C

Communication System: DSSS; Frequency: 2437 MHz; Duty Cycle: 1:1

Medium: Muscle 2450 MHz ($\sigma = 1.945$ mho/m, $\epsilon = 50.76$, $\rho = 1000$ kg/m³)

Phantom section: FlatSection

DASY4 Configuration:

- Probe: ET3DV6 - SN1577; ConvF(4.7, 4.7, 4.7); Calibrated: 2/7/2003

- Sensor-Surface: 4mm (Mechanical Surface Detection)

- Electronics: DAE3 Sn427; Calibrated: 2/4/2003

- Phantom: SAM 2 - TP:1050

- Software: DASY4, V4.0 Build 51

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=7.5mm, dy=7.5mm


Reference Value = 2.94 V/m

Peak SAR = 0.128 mW/g

SAR(1 g) = 0.0567 mW/g; SAR(10 g) = 0.0295 mW/g

Power Drift = 0.08 dB

Area Scan (11x26x1): Measurement grid: dx=10mm, dy=10mm



Test Laboratory: Compliance Certification Services
File Name: 3H-CH_0.0378 mW.da4

Applicant: Twinhead Model Name: P22T

Program: EUT Setup Configuration 1; Air temp 24.5 deg C & Liquid temp 22.3 deg C

Communication System: DSSS; Frequency: 2462 MHz; Duty Cycle: 1:1
Medium: Muscle 2450 MHz ($\sigma = 1.945$ mho/m, $\epsilon = 50.76$, $\rho = 1000$ kg/m³)
Phantom section: FlatSection

DASY4 Configuration:

- Probe: ET3DV6 - SN1577; ConvF(4.7, 4.7, 4.7); Calibrated: 2/7/2003
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn427; Calibrated: 2/4/2003
- Phantom: SAM 2 - TP:1050
- Software: DASY4, V4.0 Build 51

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=7.5mm, dy=7.5mm


Reference Value = 2.51 V/m

Peak SAR = 0.0878 mW/g

SAR(1 g) = 0.0378 mW/g; SAR(10 g) = 0.0196 mW/g


Power Drift = -0.12 dB

Area Scan (11x26x1): Measurement grid: dx=10mm, dy=10mm



Test Laboratory: Compliance Certification Services
File Name: 1L-CH_0.102 mW.da4

EUT Setup Configuration 2



Test Laboratory: Compliance Certification Services
File Name: 1L-CH_0.102 mW.da4

Applicant: Twinhead Model Name: P22T

Program: EUT Setup Configuration 2; Air temp 24.5 deg C & Liquid temp 22.2 deg C

Communication System: DSSS; Frequency: 2412 MHz; Duty Cycle: 1:1
Medium: Muscle 2450 MHz ($\sigma = 1.9763$ mho/m, $\epsilon = 50.65$, $\rho = 1000$ kg/m³)
Phantom section: FlatSection

DASY4 Configuration:

- Probe: ET3DV6 - SN1577; ConvF(4.7, 4.7, 4.7); Calibrated: 2/7/2003
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn427; Calibrated: 2/4/2003
- Phantom: SAM 2 - TP:1050
- Software: DASY4, V4.0 Build 51

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=7.5mm, dy=7.5mm


Reference Value = 5.52 V/m

Peak SAR = 0.229 mW/g

SAR(1 g) = 0.102 mW/g; SAR(10 g) = 0.0525 mW/g

Power Drift = 0.08 dB

Area Scan (11x27x1): Measurement grid: dx=10mm, dy=10mm



Test Laboratory: Compliance Certification Services
File Name: 1L-CH_0.0785 mW.da4

Applicant: Twinhead Model Name: P22T

Program: EUT Setup Configuration 2; Air temp 24.5 deg C & Liquid temp 22.2 deg C

Communication System: DSSS; Frequency: 2412 MHz; Duty Cycle: 1:1
Medium: Muscle 2450 MHz ($\sigma = 1.9763$ mho/m, $\epsilon = 50.65$, $\rho = 1000$ kg/m³)
Phantom section: FlatSection

DASY4 Configuration:

- Probe: ET3DV6 - SN1577; ConvF(4.7, 4.7, 4.7); Calibrated: 2/7/2003
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn427; Calibrated: 2/4/2003
- Phantom: SAM 2 - TP:1050
- Software: DASY4, V4.0 Build 51

Zoom Scan (5x5x7)/Cube 1: Measurement grid: dx=7.5mm, dy=7.5mm



Reference Value = 5.52 V/m

Peak SAR = 0.162 mW/g

SAR(1 g) = 0.0785 mW/g; SAR(10 g) = 0.0419 mW/g

Power Drift = 0.09 dB

Area Scan (11x27x1): Measurement grid: dx=10mm, dy=10mm



Test Laboratory: Compliance Certification Services
File Name: 2M-CH_0.0831 mW.da4

Applicant: Twinhead Model Name: P22T

Program: EUT Setup Configuration 2; Air temp 24.5 deg C & Liquid temp 22.2 deg C

Communication System: DSSS; Frequency: 2437 MHz; Duty Cycle: 1:1
Medium: Muscle 2450 MHz ($\sigma = 1.9763$ mho/m, $\epsilon = 50.65$, $\rho = 1000$ kg/m³)
Phantom section: FlatSection

DASY4 Configuration:

- Probe: ET3DV6 - SN1577; ConvF(4.7, 4.7, 4.7); Calibrated: 2/7/2003
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn427; Calibrated: 2/4/2003
- Phantom: SAM 2 - TP:1050
- Software: DASY4, V4.0 Build 51

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=7.5mm, dy=7.5mm


Reference Value = 4.09 V/m

Peak SAR = 0.2 mW/g

SAR(1 g) = 0.0831 mW/g; SAR(10 g) = 0.0415 mW/g

Power Drift = 0.05 dB

Area Scan (11x27x1): Measurement grid: dx=10mm, dy=10mm



Test Laboratory: Compliance Certification Services
File Name: 2M-CH_0.0557 mW.da4

Applicant: Twinhead Model Name: P22T

Program: EUT Setup Configuration 2; Air temp 24.5 deg C & Liquid temp 22.2 deg C

Communication System: DSSS; Frequency: 2437 MHz; Duty Cycle: 1:1
Medium: Muscle 2450 MHz ($\sigma = 1.9763$ mho/m, $\epsilon = 50.65$, $\rho = 1000$ kg/m³)
Phantom section: FlatSection

DASY4 Configuration:

- Probe: ET3DV6 - SN1577; ConvF(4.7, 4.7, 4.7); Calibrated: 2/7/2003
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn427; Calibrated: 2/4/2003
- Phantom: SAM 2 - TP:1050
- Software: DASY4, V4.0 Build 51

Zoom Scan (5x5x7)/Cube 1: Measurement grid: dx=7.5mm, dy=7.5mm



Reference Value = 4.09 V/m

Peak SAR = 0.121 mW/g

SAR(1 g) = 0.0557 mW/g; SAR(10 g) = 0.0293 mW/g

Power Drift = 0.05 dB

Area Scan (11x27x1): Measurement grid: dx=10mm, dy=10mm



Test Laboratory: Compliance Certification Services
File Name: 3H-CH_0.0477 mW.da4

Applicant: Twinhead Model Name: P22T

Program: EUT Setup Configuration 2; Air temp 24.5 deg C & Liquid temp 22.3 deg C

Communication System: DSSS; Frequency: 2462 MHz; Duty Cycle: 1:1
Medium: Muscle 2450 MHz ($\sigma = 1.9763$ mho/m, $\epsilon = 50.65$, $\rho = 1000$ kg/m³)
Phantom section: FlatSection

DASY4 Configuration:

- Probe: ET3DV6 - SN1577; ConvF(4.7, 4.7, 4.7); Calibrated: 2/7/2003
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn427; Calibrated: 2/4/2003
- Phantom: SAM 2 - TP:1050
- Software: DASY4, V4.0 Build 51

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=7.5mm, dy=7.5mm



Reference Value = 3.78 V/m

Peak SAR = 0.114 mW/g

SAR(1 g) = 0.0477 mW/g; SAR(10 g) = 0.0242 mW/g

Power Drift = -0.02 dB

Area Scan (11x27x1): Measurement grid: dx=10mm, dy=10mm



Test Laboratory: Compliance Certification Services
File Name: 3H-CH_0.0346 mW.da4

Applicant: Twinhead Model Name: P22T

Program: EUT Setup Configuration 2; Air temp 24.5 deg C & Liquid temp 22.3 deg C

Communication System: DSSS; Frequency: 2462 MHz; Duty Cycle: 1:1
Medium: Muscle 2450 MHz ($\sigma = 1.9763$ mho/m, $\epsilon = 50.65$, $\rho = 1000$ kg/m³)
Phantom section: FlatSection

DASY4 Configuration:

- Probe: ET3DV6 - SN1577; ConvF(4.7, 4.7, 4.7); Calibrated: 2/7/2003
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE3 Sn427; Calibrated: 2/4/2003
- Phantom: SAM 2 - TP:1050
- Software: DASY4, V4.0 Build 51

Zoom Scan (5x5x7)/Cube 1: Measurement grid: dx=7.5mm, dy=7.5mm

Reference Value = 3.78 V/m

Peak SAR = 0.072 mW/g

SAR(1 g) = 0.0346 mW/g; SAR(10 g) = 0.0183 mW/g

Power Drift = -0.02 dB

Area Scan (11x27x1): Measurement grid: dx=10mm, dy=10mm

