



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

FCC Rules and Regulations / Intentional Radiators

Operational in the Band 13.553-13.567 MHz

Part 15, Subpart C, Section 15.225

THE FOLLOWING **"MEETS"** THE ABOVE TEST SPECIFICATION

Formal Name: TPS Console & TPS Irrigation Console

Kind of Equipment: Medical Electrical Equipment (RFID Tag)

Test Configuration: The TPS Irrigation Console is connected to the footswitch and handpieces via cables plugged into ports. Formula Shaver with buttons is running and an SE5 with buttons and a Saber Drill is plugged in. Two Corcom Line Filters were tested. (Tested at 120 vac, 60 Hz)

Model Number(s): 5100-001-000 & 5100-050-000

Model(s) Tested: 5100-050-000

Serial Number(s): NA

Date of Tests: July 3, 2003

Test Conducted For: Stryker Instruments  
4100 East Milham  
Kalamazoo, Michigan 49001

**NOTICE:** "This report must not be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government". Please see the "Additional Description of Equipment Under Test" page listed inside of this report. This report must not be reproduced (except in full), without the approval of D.L.S. Electronic Systems.



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

SIGNATURE PAGE

Report By:

Arnom C. Rowe  
Test Engineer  
EMC-001375-NE

Reviewed By:

William Stumpf  
OATS Manager

Approved By:

Brian Mattson  
General Manager

Company Official:

Stryker Instruments




Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 6009

United States Department of Commerce  
 National Institute of Standards and Technology

# NVLAP<sup>®</sup>

Certificate of Accreditation



**D.L.S. ELECTRONIC SYSTEMS, INC.**  
 WHEELING, IL

is recognized by the National Voluntary Laboratory Accreditation Program  
 for satisfactory compliance with criteria set forth in NIST Handbook 150:2001,  
 all requirements of ISO/IEC 17025:1999, and relevant requirements of ISO 9002:1994.  
 Accreditation is awarded for specific services, listed on the Scope of Accreditation, for:

**ELECTROMAGNETIC COMPATIBILITY AND TELECOMMUNICATIONS**

September 30, 2003

Effective through \_\_\_\_\_

*David F. Alderman*

For the National Institute of Standards and Technology  
 NVLAP Lab Code: 100276-0

NVLAP-01C (06-01)



Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 6009



ISO/IEC 17025:1999  
 ISO 9002:1994

## Scope of Accreditation



Revised Scope 06/04/2003

Page: 1 of 4

**ELECTROMAGNETIC COMPATIBILITY  
 AND TELECOMMUNICATIONS**

NVLAP LAB CODE 100276-0

**D.L.S. ELECTRONIC SYSTEMS, INC.**

1250 Peterson Drive  
 Wheeling, IL 60090-6454  
 Mr. Brian J. Mattson  
 Phone: 847-537-6400 Fax: 847-537-6488  
 E-Mail: [bmattson@dlsemc.com](mailto:bmattson@dlsemc.com)  
 URL: <http://www.dlsemc.com>

*NVLAP Code Designation / Description*

**Emissions Test Methods:**

|           |  |
|-----------|--|
| 12/CIS11  | IEC/CISPR 11 (1990) and EN 55011 (1998): Limits and Methods of Measurement of Electromagnetic Disturbance Characteristics of Industrial, Scientific, and Medical Radio-Frequency Equipment                   |
| 12/CIS14  | CISPR 14-1 (March 30, 2000): Limits and methods of measurement of radio interference characteristics of household electrical appliances, portable tools and similar electrical apparatus - Part 1: Emissions |
| 12/CIS14a | EN 55014-1 (1993) with Amendments A1 (1997) & A2 (1999)  |
| 12/CIS14b | AS/NZS 1044 (1995)   |
| 12/CIS14c | CNS 13783-1  |
| 12/CIS22  | IEC/CISPR 22 (1997) and EN 55022 (1998): Limits and methods of measurement of radio disturbance characteristics of information technology equipment  |

September 30, 2003

Effective through

For the National Institute of Standards and Technology



Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 6009

National Institute  
of Standards and Technology



National Voluntary  
Laboratory Accreditation Program

ISO/IEC 17025:1999  
ISO 9002:1994

## Scope of Accreditation



Page: 2 of 4

Revised Scope 06/04/2003

### ELECTROMAGNETIC COMPATIBILITY AND TELECOMMUNICATIONS

NVLAP LAB CODE 100276-0

D.L.S. ELECTRONIC SYSTEMS, INC.

**NVLAP Code    Designation / Description**

|           |  |
|-----------|--|
| 12/CIS22a | IEC/CISPR 22:1993: Limits and methods of measurement of radio disturbance characteristics of information technology equipment, Amendment 1:1995, and Amendment 2:1996. |
| 12/CIS22b | CNS 13438:1997: Limits and Methods of Measurement of Radio Interference Characteristics of Information Technology Equipment  |
| 12/F01    | ANSI C63.4 (2001) - cited in FCC Method - 47 CFR Part 15 - Digital Devices   |
| 12/F01a   | Conducted Emissions, Power Lines, 150 KHz to 30 MHz  |
| 12/F01b   | Radiated Emissions   |
| 12/T51    | AS/NZS 3548: Electromagnetic Interference - Limits and Methods of Measurement of Information Technology Equipment  |

**Immunity Test Methods:**

|        |  |
|--------|--|
| 12/I01 | IEC 61000-4-2 (1995) and Amendment 1 (1998): Electrostatic Discharge Immunity Test                         |
| 12/I02 | IEC 61000-4-3 (1995) and Amendment 1 (1998): Radiated, Radio-Frequency Electromagnetic Field Immunity Test |
| 12/I03 | IEC 61000-4-4 (1995): Electrical Fast Transient/Burst Immunity Test  |

September 30, 2003

Effective through

For the National Institute of Standards and Technology



Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 6009



ISO/IEC 17025:1999  
 ISO 9002:1994

## Scope of Accreditation



Revised Scope 06/04/2003

Page: 3 of 4

**ELECTROMAGNETIC COMPATIBILITY  
 AND TELECOMMUNICATIONS**

**NVLAP LAB CODE 100276-0**

**D.L.S. ELECTRONIC SYSTEMS, INC.**

***NVLAP Code      Designation / Description***

|        |  |
|--------|--|
| 12/I04 | IEC 61000-4-5 (1995): Surge Immunity Test  |
| 12/I05 | IEC 61000-4-6 (1996): Immunity to Conducted Disturbances, Induced Radio-Frequency Fields       |
| 12/I06 | IEC 61000-4-8 (1993): Power Frequency Magnetic Field Immunity Test                             |
| 12/I07 | IEC 61000-4-11 (1994): Voltage Dips, Short Interruptions and Voltage Variations Immunity Tests |

**MIL-STD-462 : Conducted Emissions:**

12/A18          MIL-STD-461 Version E Method CE106

**MIL-STD-462 : Conducted Susceptibility:**

|        |                                    |
|--------|------------------------------------|
| 12/B12 | MIL-STD-462 Version D Method CS101 |
| 12/B13 | MIL-STD-462 Version D Method CS103 |
| 12/B25 | MIL-STD-461 Version E Method CS114 |
| 12/B26 | MIL-STD-461 Version E Method CS115 |
| 12/B27 | MIL-STD-461 Version E Method CS116 |

September 30, 2003

Effective through

For the National Institute of Standards and Technology



Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 6009



ISO/IEC 17025:1999  
 ISO 9002:1994

## Scope of Accreditation



Page: 4 of 4

Revised Scope 06/04/2003

**ELECTROMAGNETIC COMPATIBILITY  
 AND TELECOMMUNICATIONS**

**NVLAP LAB CODE 100276-0**

**D.L.S. ELECTRONIC SYSTEMS, INC.**

*NVLAP Code Designation / Description*

**MIL-STD-462 : Radiated Emissions:**

- 12/D04 MIL-STD-462 Version D Method RE101
- 12/D05 MIL-STD-462 Version D Method RE102
- 12/D06 MIL-STD-462 Version D Method RE103

**MIL-STD-462 : Radiated Susceptibility:**

- 12/E08 MIL-STD-462 Version D Method RS101
- 12/E09 MIL-STD-462 Version D Method RS103

September 30, 2003

*Effective through*

*For the National Institute of Standards and Technology*



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 6009

## TABLE OF CONTENTS

|      |   |    |
|------|---|----|
| i.   | Cover Page .....                            | 1  |
| ii.  | Signature Page .....                        | 2  |
| iii. | NVLAP Certificate of Accreditation .....    | 3  |
| iv.  | NVLAP Scope of Accreditation .....          | 4  |
| v.   | Table of Contents .....                     | 8  |
| 1.0  | Summary of Test Report .....                | 10 |
| 2.0  | Introduction .....                          | 10 |
| 3.0  | Object .....                                | 10 |
| 4.0  | Test Set-Up .....                           | 11 |
| 5.0  | Test Equipment .....                        | 12 |
| 6.0  | Description of Test Sample .....            | 13 |
| 7.0  | Additional Description of Test Sample ..... | 16 |
| 8.0  | Photo Information and Test Set-Up .....     | 17 |
| 9.0  | Radiated Photos Taken During Testing .....  | 18 |
| 9.0  | Conducted Photos Taken During Testing ..... | 20 |
| 10.0 | Results of Tests .....                      | 21 |
| 11.0 | Conclusion .....                            | 21 |
|      | TABLE 1 – EQUIPMENT LIST .....              | 22 |





Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 6009

## TABLE OF CONTENTS

|   |    |
|---|----|
| Appendix A – Operation within the Band 13.553-13.567 MHz.....                               | 24 |
| 1.0 Conducted Emission Measurements.....  | 25 |
| 1.0 Conducted Data and Charts taken during testing using Corcom Filter 6ED4C .....          | 26 |
| 1.0 Conducted Data and Charts taken during testing using Corcom Filter 6ED8C .....          | 33 |
| 2.0 Band Edge and Restrict Band Compliance.....   | 40 |
| 2.0 Graph(s) taken showing the Band Edge and Restrict Band Compliance Part 15.225 (b) ..... | 41 |
| 3.0 Field Strength of Spurious Emission Measurements .....                                  | 43 |
| 3.0 Radiated Data and Charts taken of the Fundamental Emissions .....                       | 45 |
| 3.0 Radiated Data and Charts taken using Corcom Filters 6ED4C & 6ED8C .....                 | 49 |
| 4.0 Frequency Stability (Temperature).....  | 56 |
| 4.0 Graphs taken for Frequency Stability when varying the Temperature .....                 | 57 |
| 5.0 Frequency Stability (Voltage).....  | 66 |
| 5.0 Graphs taken for Frequency Stability when varying the Voltage.....                      | 67 |



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 6009

## 1.0 SUMMARY OF TEST REPORT

It was found that the TPS Console & TPS Irrigation Console, Model Number(s) 5100-050-000 & 5100-001-000, **"meets"** the radio interference conducted and radiated emission requirements of the FCC "Rules and Regulations", Part 15, Subpart C, Section 15.225 for operational in the 13.553-13.567 MHz Band. It should be noted that the amount of margin was only 2.6 dB at 56.315 MHz, radiated. The normal tolerance of the test equipment is  $\pm 3$  dB. Due to this tolerance and the variation in normal production, a margin of at least 6 dB is recommended.

This test report relates only to the items tested and contains the following number of pages.

|         |    |
|---------|----|
| Text:   | 69 |
| Charts: | 13 |

## 2.0 INTRODUCTION

On July 3, 2003, a series of radio frequency interference measurements was performed on TPS Console & TPS Irrigation Console, Model Number(s) 5100-050-000 & 5100-001-000, Serial Number: NA. The tests were performed according to the procedures of the FCC as stated in the "Methods of Measurement of Radio-Noise Emissions for Low-Voltage Electrical and Electronic Equipment in the Range of 9 kHz to 40 GHz" found in the American National Standards Institute, ANSI C63.4-2000. Tests were performed by personnel of D.L.S. Electronic Systems, Inc. who are responsible to Donald L. Sweeney, Senior EMC Engineer.

## 3.0 OBJECT

The purpose of this series of tests was to determine if the test sample could meet the radio frequency interference emission requirements of the FCC "Rules and Regulations", Part 15, Subpart C, Sections 15.209 & 15.225 for Intentional Radiators operating in the Band 13.553-13.567 MHz.



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 6009

#### 4.0 TEST SET-UP

All emission tests were performed at D.L.S. Electronic Systems, Inc. and set up according to the American National Standards Institute, ANSI C63.4-2000, Section 8, (Figures 11a and 11b).

All emissions tests were performed with the test item placed on a 80 cm high rotating non-conductive table, located in the test room. Equipment normally operated on the floor was placed on a metal covered turntable which is flush with the surrounding conducting ground plane. The ground plane has an electrical isolation layer over its surface approximately 7 mm thick. The EUT is separated from the turntable ground plane by a non-conductive layer. The equipment under test was set up according to ANSI C63.4-2000, Sections 6, 7 and 8.



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 6009

## 5.0 TEST EQUIPMENT (Bandwidths and Detector Function)

All preliminary data was taken using Peak Detector Functions as required. This information was then used to determine the frequencies of maximum emissions. Above 1000 MHz, final data was taken using the Peak Detector.

Below 1000 MHz, final data was taken using the ESI 26/ESI 40 Rohde & Schwarz Receivers. These plots were made using the Peak Detector functions, with manual measurements performed on the questionable frequencies using the Average Detector Function of the Rohde & Schwarz Receivers as required.

The bandwidths shown below are specified by ANSI C63.4-2000, Section 4.2.

| Frequency Range   | Bandwidth (-6 dB) |
|-------------------|-------------------|
| 10 to 150 kHz     | 200 Hz            |
| 150 kHz to 30 MHz | 9 kHz             |
| 30 MHz to 1 GHz   | 120 kHz           |
| Above 1 GHz       | 1 MHz             |

A list of the equipment used can be found in Table 1. All primary equipment was calibrated against known reference standards with a verified traceable path to NIST.



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 6009

## 6.0 DESCRIPTION OF TEST SAMPLE: (See also Paragraph 7.0)

### 6.1 Description:

The TPS Irrigation Console 5100-050-000 was the unit used during testing since it is the worst case scenerio. The standard TPS Console 5100-001-000 is identical to the TPS Irrigation Console 5100-050-000 minus the irrigation pump.

The TPS System is used for drilling, cutting and shaping bone for surgical procedures. The handpieces may be controlled via handswitch or foot operated footswitch control. The handpiece motor speeds are user selectable via a touch screen on the TPS Console Display and they vary from 6,000 rpm to 75,000 rpm. The system also incorporates an irrigation pump which operates in one of two modes. On demand when the handpiece is activated or in Flush Mode which is a continuous run operation. The TPS System also has the capability of recognizing which cutters are placed into the handpieces via RF.

This application is for identifying what kind of tool is being used by a surgeon to prevent mis-use, because the settings are automatically select such. rpm's and speed .



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 6009

6.0 DESCRIPTION OF TEST SAMPLE: (CONT)

6.2 PHYSICAL DIMENSIONS OF EQUIPMENT UNDER TEST

.98' long x .75' wide x .5' high

6.3 LINE FILTER USED:

Corcom Filter 6ED4C or  
Corcom Filter 6ED8C

6.4 INTERNAL CLOCK FREQUENCIES:

Switching Power Supply Frequencies:

100 kHz

Clock Frequencies:

24 MHz, 13.56 MHz, 12 MHz, 6 MHz, & .285 MHz



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

## 6.0 DESCRIPTION OF TEST SAMPLE: (CONT')

### 6.5 DESCRIPTION OF ALL CIRCUIT BOARDS:

- |                                       |                         |
|---------------------------------------|-------------------------|
| 1. TPS + Control Board Assembly       | PN: 5100-002-161 Rev 10 |
| 2. LCD Screen Interface Assembly      | PN: 5100-002-162 Rev 3  |
| 3. TPS Irrigation Pump Board Assembly | PN: 5100-001-327 Rev B  |
| 4. Universal 400 Watt Power Supply    | PN: 5100-002-345 Rev 9  |



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

7.0 ADDITIONAL DESCRIPTION OF TEST SAMPLE:  
(See also Paragraph 6.0)

1: There were no changes made at D.L.S. Electronic Systems, Inc.

I certify that the above, as described in paragraph 8.0, describes the equipment tested and will be manufactured as stated.

By: \_\_\_\_\_  
Signature Title

For: \_\_\_\_\_  
Company Date





Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

## 8.0 PHOTO INFORMATION AND TEST SET-UP

- Item 0 TPS Irrigation Console  
Model Number: 5100-050-000, Serial Number: NA
- Item 1 Stryker Endoscopy SE5/TPS
- Item 2 Stryker Formula Shaver
- Item 3 Stryker Saber Drill  
Model Number 5100-120, SN: 0310600363
- Item 4 Non-shielded AC Power Line Cord. 2m
- Item 5 Stryker TPS Footswitch  
Model Number 5100-8, SN: 99102653



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

## 9.0 RADIATED PHOTOS TAKEN DURING TESTING






Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

9.0 RADIATED PHOTOS TAKEN DURING TESTING (CON'T)







Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

## 9.0 CONDUCTED PHOTOS TAKEN DURING TESTING





Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

## 10.0 RESULTS OF TESTS

The radio interference emission charts results can be seen on the pages at the end of this report. Data sheets indicating the test measurements taken during testing can also be found at the end of this report. Those points on the emission charts shown with a yellow mark are background frequencies which were verified during testing.

## 11.0 CONCLUSION

It was found that the TPS Console & TPS Irrigation Console, Model Number(s) 5100-001-000 & 5100-050-000 **"meets"** the radio interference conducted and radiated emission requirements of the FCC "Rules and Regulations", Part 15, Subpart C, Section 15.225 for operational in the 13.553-13.567 MHz Band. It should be noted that the amount of margin was only 2.6 dB at 56.315 MHz, radiated. The normal tolerance of the test equipment is  $\pm 3$  dB. Due to this tolerance and the variation in normal production, a margin of at least 6 dB is recommended.



Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

TABLE 1 – EQUIPMENT LIST

| Test Equipment     | Manufacturer    | Model Number | Serial Number | Frequency Range  | Cal Due Dates |
|--------------------|-----------------|--------------|---------------|------------------|---------------|
| Spectrum Analyzer  | Hewlett/Packard | 8566B        | 2240A002041   | 100 Hz – 22 GHz  | 10/03         |
| Quasi-Peak Adapter | Hewlett/Packard | 85650A       | 2043A00121    | 10 kHz – 1 GHz   | 10/03         |
| Spectrum Analyzer  | Hewlett/Packard | 8566B        | 2421A00452    | 100 Hz – 22 GHz  | 2/04          |
| Quasi-Peak Adapter | Hewlett/Packard | 85650A       | 2043A00450    | 10 kHz – 1 GHz   | 2/04          |
| Spectrum Analyzer  | Hewlett/Packard | 8591A        | 3009A00700    | 9 kHz – 1.8 GHz  | 3/04          |
| Receiver           | Electrometrics  | EMC-30       | 44168         | 10 kHz – 1 GHz   | 9/03          |
| Receiver           | Rohde & Schwarz | ESI 26       | 837491/010    | 20 Hz – 26 GHz   | 11/03         |
| Receiver           | Rohde & Schwarz | ESI 40       | 837808/006    | 20 Hz – 40 GHz   | 12/03         |
| Receiver           | Rohde & Schwarz | ESI 40       | 837808/005    | 20 Hz – 40 GHz   | 12/03         |
| Antenna            | EMCO            | 3104C        | 00054891      | 20 MHz – 200 MHz | 2/04          |
| Antenna            | Electrometrics  | LPA-25       | 1114          | 200 MHz – 1 GHz  | 3/04          |
| Antenna            | EMCO            | 3104C        | 00054892      | 20 MHz – 200 MHz | 3/04          |

All primary equipment is calibrated against known reference standards with a verified traceable path to NIST.



Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

TABLE 1 – EQUIPMENT LIST

| Test Equipment | Manufacturer    | Model Number     | Serial Number | Frequency Range  | Cal Due Dates |
|----------------|-----------------|------------------|---------------|------------------|---------------|
| Antenna        | Electrometrics  | 3146             | 1205          | 200 MHz – 1 GHz  | 3/04          |
| Antenna        | EMCO            | 3104C            | 97014785      | 20 MHz – 200 MHz | 2/04          |
| Antenna        | EMCO            | 3146             | 97024895      | 200 MHz – 1 GHz  | 3/04          |
| Antenna        | EMCO            | 3115             | 2479          | 1 GHz – 18 GHz   | 8/03          |
| Antenna        | EMCO            | 3115             | 99035731      | 1 GHz – 18 GHz   | 4/04          |
| Antenna        | Rohde & Schwarz | HUF-Z1           | 829381001     | 20 MHz – 1 GHz   | 2/04          |
| Antenna        | Rohde & Schwarz | HUF-Z1           | 829381005     | 20 MHz – 1 GHz   | 8/03          |
| LISN           | Solar           | 8012-50-R-24-BNC | 8305116       | 10 MHz – 30 MHz  | 8/03          |
| LISN           | Solar           | 8012-50-R-24-BNC | 814548        | 10 MHz – 30 MHz  | 8/03          |
| LISN           | Solar           | 9252-50-R-24-BNC | 961019        | 10 MHz – 30 MHz  | 12/03         |
| LISN           | Solar           | 9252-50-R-24-BNC | 971612        | 10 MHz – 30 MHz  | 10/03         |
| LISN           | Solar           | 9252-50-R-24-BNC | 92710620      | 10 MHz – 30 MHz  | 7/03          |

All primary equipment is calibrated against known reference standards with a verified traceable path to NIST.



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

## APPENDIX A

### TEST PROCEDURE

Part 15, Subpart C, Section 15.225a-c

OPERATION WITHIN THE BAND 13.553-13.567 MHz





Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

## 1.0 CONDUCTED EMISSION MEASUREMENTS

The conducted emissions were measured over the frequency range from .45 MHz to 30 MHz in accordance with the power line measurements, as specified in FCC Part 15, Subpart C, Section 15.207 and ANSI C63.4-1992. Since the device is operated from the public utility lines, the 120 Vac, 60 Hz power leads, high and low sides were measured by connecting the measuring equipment to the appropriate meter terminal of the LISN. All signals were then recorded. During the test, the cables were placed and items moved (when appropriate) to maximize emissions. The allowed levels for Intentional Radiators shall not exceed 250 uV (47.96 dBuV) at any frequency between 450 kHz and 30 MHz, as stated in Section 15.207a.

All test measurements were made at a screen room temperature of **73°F** at **48%** relative humidity



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

CONDUCTED DATA

AND

CHARTS TAKEN DURING TESTING

USING CORCOM FILTER 6ED4C

PART 15.207


**FCC Part 15 Class B**

**Voltage Mains Test**

EUT: TPS Plus (with CORCOM 6ED4C)  
Manufacturer: Stryker Instruments  
Operating Condition: 70 deg. F, 59% R.H.  
Test Site: DLS OF Screen Room  
Operator: Craig Brandt  
Test Specification: 120 VAC, 60 Hz Line 1  
Comment: Formula Shaver  
Date: 07-18-03

**SCAN TABLE: "FCC ClassB Voltage"**

| Short Description: | FCC Class B Voltage | IF      | Transducer  |
|--------------------|---------------------|---------|-------------|
| Start Stop Step    | Detector Meas.      | Bandw.  |             |
| Frequency          | Width               | Time    |             |
| 150.0 kHz          | 30.0 MHz            | 4.0 kHz | 9 kHz       |
|                    | MaxPeak             | 10.0 ms | LISN 971612 |
|                    | Average             |         |             |



x : MES 718TPSL1FCC\_fin QP  
 + : MES 718TPSL1FCC\_fin AV  
 — : MES 718TPSL1FCC\_pre PK  
 — : MES 718TPSL1FCC\_pre AV  
 — : LIM FCC ClassB V QP New  
 — : LIM FCC ClassB V AV New

Voltage Amplitude QP Limit  
 Voltage Amplitude AV Limit

**MEASUREMENT RESULT: "718TPSL1FCC\_fin\_QP"**

7/18/2003 9:56AM

| Frequency<br>MHz | Level<br>dBµV | Transd<br>dB | Limit<br>dBµV | Margin<br>dB | Line | PE  |
|------------------|---------------|--------------|---------------|--------------|------|-----|
| 0.198000         | 50.00         | 10.2         | 64            | 13.7         | 1    | --- |
| 0.298000         | 49.40         | 10.2         | 60            | 10.9         | 1    | --- |
| 0.598000         | 43.60         | 10.1         | 56            | 12.4         | 1    | --- |
| 0.698000         | 45.70         | 10.1         | 56            | 10.3         | 1    | --- |
| 0.798000         | 43.20         | 10.1         | 56            | 12.8         | 1    | --- |
| 0.898000         | 43.40         | 10.1         | 56            | 12.6         | 1    | --- |
| 0.998000         | 41.30         | 10.2         | 56            | 14.7         | 1    | --- |
| 1.098000         | 38.40         | 10.2         | 56            | 17.6         | 1    | --- |
| 1.198000         | 38.60         | 10.2         | 56            | 17.4         | 1    | --- |
| 1.494000         | 35.80         | 10.3         | 56            | 20.2         | 1    | --- |
| 5.822000         | 19.30         | 11.0         | 60            | 40.7         | 1    | --- |
| 13.546000        | 20.00         | 11.7         | 60            | 40.0         | 1    | --- |
| 13.562000        | 42.80         | 11.7         | 60            | 17.2         | 1    | --- |
| 13.578000        | 18.40         | 11.7         | 60            | 41.6         | 1    | --- |
| 24.522000        | 19.60         | 12.3         | 60            | 40.4         | 1    | --- |

**MEASUREMENT RESULT: "718TPSL1FCC\_fin\_AV"**

7/18/2003 9:56AM

| Frequency<br>MHz | Level<br>dBµV | Transd<br>dB | Limit<br>dBµV | Margin<br>dB | Line | PE  |
|------------------|---------------|--------------|---------------|--------------|------|-----|
| 0.198000         | 47.10         | 10.2         | 54            | 6.6          | 1    | --- |
| 0.302000         | 42.80         | 10.2         | 50            | 7.4          | 1    | --- |
| 0.598000         | 39.00         | 10.1         | 46            | 7.0          | 1    | --- |
| 0.698000         | 42.80         | 10.1         | 46            | 3.2          | 1    | --- |
| 0.798000         | 41.30         | 10.1         | 46            | 4.7          | 1    | --- |
| 0.898000         | 38.80         | 10.1         | 46            | 7.2          | 1    | --- |
| 0.998000         | 34.90         | 10.2         | 46            | 11.1         | 1    | --- |
| 1.098000         | 33.90         | 10.2         | 46            | 12.1         | 1    | --- |
| 1.198000         | 34.60         | 10.2         | 46            | 11.4         | 1    | --- |
| 1.298000         | 32.20         | 10.2         | 46            | 13.8         | 1    | --- |
| 5.182000         | 13.40         | 10.9         | 50            | 36.6         | 1    | --- |
| 5.282000         | 12.50         | 11.0         | 50            | 37.5         | 1    | --- |
| 5.382000         | 12.50         | 11.0         | 50            | 37.5         | 1    | --- |
| 13.562000        | 30.00         | 11.7         | 50            | 20.0         | 1    | --- |
| 24.002000        | 17.40         | 12.3         | 50            | 32.6         | 1    | --- |

**FCC Part 15 Class B**


**Voltage Mains Test**

EUT: TPS Plus (with CORCOM 6ED4C)  
Manufacturer: Stryker Instruments  
Operating Condition: 70 deg. F, 59% R.H.  
Test Site: DLS OF Screen Room  
Operator: Craig Brandt  
Test Specification: 120 VAC, 60 Hz Line 2  
Comment: Formula Shaver  
Date: 07-18-03

**SCAN TABLE: "FCC ClassB Voltage"**

| Short Description: | Start | Stop | Step  | FCC Class B Voltage | IF     | Transducer  |
|--------------------|-------|------|-------|---------------------|--------|-------------|
| Frequency          | kHz   | kHz  | Width | Detector            | Bandw. |             |
|                    |       |      |       | Time                |        |             |
| 150.0              | 30.0  | 30.0 | 4.0   | MaxPeak             | 9 kHz  | LISN 971612 |
|                    |       |      |       | Average             |        |             |

Level [dBμV]



Frequency [Hz]

- x : MES 718TPSL2FCC\_fin QP
- + : MES 718TPSL2FCC\_fin AV
- : MES 718TPSL2FCC\_pre PK
- : MES 718TPSL2FCC\_pre AV
- : LIM FCC ClassB V QP New
- : LIM FCC ClassB V AV New

Voltage Amplitude QP Limit  
Voltage Amplitude AVG Limit

**MEASUREMENT RESULT: "718TPSL2FCC\_fin\_QP"**

7/18/2003 10:05AM

| Frequency<br>MHz | Level<br>dBµV | Transd<br>dB | Limit<br>dBµV | Margin<br>dB | Line | PE  |
|------------------|---------------|--------------|---------------|--------------|------|-----|
| 0.298000         | 47.90         | 10.2         | 60            | 12.3         | 1    | --- |
| 0.398000         | 43.00         | 10.1         | 58            | 14.9         | 1    | --- |
| 0.598000         | 42.10         | 10.1         | 56            | 13.9         | 1    | --- |
| 0.698000         | 43.30         | 10.1         | 56            | 12.7         | 1    | --- |
| 0.794000         | 42.20         | 10.1         | 56            | 13.8         | 1    | --- |
| 0.894000         | 43.90         | 10.1         | 56            | 12.1         | 1    | --- |
| 0.994000         | 41.80         | 10.2         | 56            | 14.2         | 1    | --- |
| 1.094000         | 38.70         | 10.2         | 56            | 17.3         | 1    | --- |
| 1.194000         | 38.90         | 10.2         | 56            | 17.1         | 1    | --- |
| 1.294000         | 34.90         | 10.2         | 56            | 21.1         | 1    | --- |
| 5.658000         | 21.30         | 11.0         | 60            | 38.7         | 1    | --- |
| 13.534000        | 19.80         | 11.7         | 60            | 40.2         | 1    | --- |
| 13.558000        | 45.50         | 11.7         | 60            | 14.5         | 1    | --- |
| 13.574000        | 22.00         | 11.7         | 60            | 38.0         | 1    | --- |
| 24.470000        | 20.30         | 12.3         | 60            | 39.7         | 1    | --- |

**MEASUREMENT RESULT: "718TPSL2FCC\_fin\_AV"**

7/18/2003 10:05AM

| Frequency<br>MHz | Level<br>dBµV | Transd<br>dB | Limit<br>dBµV | Margin<br>dB | Line | PE  |
|------------------|---------------|--------------|---------------|--------------|------|-----|
| 0.298000         | 42.20         | 10.2         | 50            | 8.0          | 1    | --- |
| 0.398000         | 37.20         | 10.1         | 48            | 10.7         | 1    | --- |
| 0.598000         | 37.40         | 10.1         | 46            | 8.6          | 1    | --- |
| 0.698000         | 40.50         | 10.1         | 46            | 5.5          | 1    | --- |
| 0.794000         | 40.60         | 10.1         | 46            | 5.4          | 1    | --- |
| 0.894000         | 39.40         | 10.1         | 46            | 6.6          | 1    | --- |
| 0.994000         | 35.40         | 10.2         | 46            | 10.6         | 1    | --- |
| 1.094000         | 34.10         | 10.2         | 46            | 11.9         | 1    | --- |
| 1.194000         | 34.80         | 10.2         | 46            | 11.2         | 1    | --- |
| 1.294000         | 32.10         | 10.2         | 46            | 13.9         | 1    | --- |
| 5.366000         | 12.80         | 11.0         | 50            | 37.2         | 1    | --- |
| 13.558000        | 32.60         | 11.7         | 50            | 17.4         | 1    | --- |
| 13.574000        | 12.70         | 11.7         | 50            | 37.3         | 1    | --- |
| 18.674000        | 13.80         | 12.2         | 50            | 36.2         | 1    | --- |
| 24.002000        | 19.00         | 12.3         | 50            | 31.0         | 1    | --- |





Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

CONDUCTED DATA

AND

CHARTS TAKEN DURING TESTING

USING CORCOM FILTER 6ED8C

PART 15.207

**FCC Part 15 Class B**


**Voltage Mains Test**

EUT: TPS Plus (with CORCOM 6ED8C)  
Manufacturer: Stryker Instruments  
Operating Condition: 70 deg. F, 59% R.H.  
Test Site: DLS OF Screen Room  
Operator: Craig Brandt  
Test Specification: 120 VAC, 60 Hz Line 1  
Comment: Formula Shaver  
Date: 07-18-03

**SCAN TABLE: "FCC ClassB Voltage"**

| Short Description: | FCC Class B Voltage | IF      | Transducer  |
|--------------------|---------------------|---------|-------------|
| Start Stop Step    | Detector Meas.      | Bandw.  |             |
| Frequency          | Width               | Time    |             |
| 150.0 kHz          | 30.0 MHz            | 4.0 kHz | 10.0 ms     |
|                    |                     | MaxPeak | 9 kHz       |
|                    |                     | Average | LISN 971612 |

Level [dBμV]



Frequency [Hz]

- x : MES 718TPSL1FCC2\_fin\_QP
- + : MES 718TPSL1FCC2\_fin\_AV
- : MES 718TPSL1FCC2\_pre\_PK
- : MES 718TPSL1FCC2\_pre\_AV
- : LIM FCC ClassB V\_QP New
- : LIM FCC ClassB V\_AV New

Voltage Amplitude QP Limit  
Voltage Amplitude AVG Limit

**MEASUREMENT RESULT: "718TPSL1FCC2\_fin\_QP"**

7/18/2003 10:49AM

| Frequency<br>MHz | Level<br>dBµV | Transd<br>dB | Limit<br>dBµV | Margin<br>dB | Line | PE  |
|------------------|---------------|--------------|---------------|--------------|------|-----|
| 0.298000         | 47.50         | 10.2         | 60            | 12.8         | 1    | --- |
| 0.398000         | 43.00         | 10.1         | 58            | 14.9         | 1    | --- |
| 0.598000         | 42.20         | 10.1         | 56            | 13.8         | 1    | --- |
| 0.694000         | 45.50         | 10.1         | 56            | 10.5         | 1    | --- |
| 0.794000         | 43.40         | 10.1         | 56            | 12.6         | 1    | --- |
| 0.894000         | 44.20         | 10.1         | 56            | 11.8         | 1    | --- |
| 0.994000         | 41.90         | 10.2         | 56            | 14.1         | 1    | --- |
| 1.094000         | 38.40         | 10.2         | 56            | 17.6         | 1    | --- |
| 1.190000         | 41.40         | 10.2         | 56            | 14.6         | 1    | --- |
| 1.490000         | 36.10         | 10.3         | 56            | 19.9         | 1    | --- |
| 5.158000         | 20.00         | 10.9         | 60            | 40.0         | 1    | --- |
| 5.454000         | 19.60         | 11.0         | 60            | 40.4         | 1    | --- |
| 6.446000         | 18.40         | 11.1         | 60            | 41.6         | 1    | --- |
| 13.550000        | 26.70         | 11.7         | 60            | 33.3         | 1    | --- |
| 13.566000        | 36.50         | 11.7         | 60            | 23.5         | 1    | --- |

**MEASUREMENT RESULT: "718TPSL1FCC2\_fin\_AV"**

7/18/2003 10:49AM

| Frequency<br>MHz | Level<br>dBµV | Transd<br>dB | Limit<br>dBµV | Margin<br>dB | Line | PE  |
|------------------|---------------|--------------|---------------|--------------|------|-----|
| 0.298000         | 41.00         | 10.2         | 50            | 9.3          | 1    | --- |
| 0.398000         | 37.10         | 10.1         | 48            | 10.8         | 1    | --- |
| 0.598000         | 37.30         | 10.1         | 46            | 8.7          | 1    | --- |
| 0.698000         | 40.00         | 10.1         | 46            | 6.0          | 1    | --- |
| 0.794000         | 41.60         | 10.1         | 46            | 4.4          | 1    | --- |
| 0.894000         | 39.80         | 10.1         | 46            | 6.2          | 1    | --- |
| 0.994000         | 35.40         | 10.2         | 46            | 10.6         | 1    | --- |
| 1.094000         | 33.10         | 10.2         | 46            | 12.9         | 1    | --- |
| 1.190000         | 36.60         | 10.2         | 46            | 9.4          | 1    | --- |
| 1.290000         | 34.90         | 10.2         | 46            | 11.1         | 1    | --- |
| 5.158000         | 12.40         | 10.9         | 50            | 37.6         | 1    | --- |
| 5.258000         | 11.00         | 11.0         | 50            | 39.0         | 1    | --- |
| 13.550000        | 17.10         | 11.7         | 50            | 32.9         | 1    | --- |
| 13.570000        | 16.60         | 11.7         | 50            | 33.4         | 1    | --- |
| 18.674000        | 15.20         | 12.2         | 50            | 34.8         | 1    | --- |

**FCC Part 15 Class B**


**Voltage Mains Test**

EUT: TPS Plus (with CORCOM 6ED8C)  
Manufacturer: Stryker Instruments  
Operating Condition: 70 deg. F, 59% R.H.  
Test Site: DLS OF Screen Room  
Operator: Craig Brandt  
Test Specification: 120 VAC, 60 Hz Line 2  
Comment: Formula Shaver  
Date: 07-18-03

**SCAN TABLE: "FCC ClassB Voltage"**

| Short Description: | FCC Class B Voltage | IF      | Transducer  |
|--------------------|---------------------|---------|-------------|
| Start Stop Step    | Detector Meas.      | Bandw.  |             |
| Frequency          | Width               | Time    |             |
| 150.0 kHz          | 30.0 MHz            | 4.0 kHz | 9 kHz       |
|                    | MaxPeak             | 10.0 ms | LISN 971612 |
|                    | Average             |         |             |

Level [dBμV]



Frequency [Hz]

- x : MES 718TPSL2FCC2\_fin QP
- + : MES 718TPSL2FCC2\_fin AV
- : MES 718TPSL2FCC2\_pre PK
- : MES 718TPSL2FCC2\_pre AV
- : LIM FCC ClassB V QP New
- : LIM FCC ClassB V AV New

Voltage Amplitude QP Limit  
Voltage Amplitude AVG Limit

**MEASUREMENT RESULT: "718TPSL2FCC2\_fin\_QP"**

7/18/2003 10:39AM

| Frequency<br>MHz | Level<br>dBµV | Transd<br>dB | Limit<br>dBµV | Margin<br>dB | Line | PE  |
|------------------|---------------|--------------|---------------|--------------|------|-----|
| 0.298000         | 49.90         | 10.2         | 60            | 10.4         | 1    | --- |
| 0.398000         | 43.30         | 10.1         | 58            | 14.6         | 1    | --- |
| 0.598000         | 42.90         | 10.1         | 56            | 13.1         | 1    | --- |
| 0.698000         | 44.20         | 10.1         | 56            | 11.8         | 1    | --- |
| 0.794000         | 42.70         | 10.1         | 56            | 13.3         | 1    | --- |
| 0.894000         | 44.50         | 10.1         | 56            | 11.5         | 1    | --- |
| 0.994000         | 42.30         | 10.2         | 56            | 13.7         | 1    | --- |
| 1.094000         | 39.10         | 10.2         | 56            | 16.9         | 1    | --- |
| 1.194000         | 38.90         | 10.2         | 56            | 17.1         | 1    | --- |
| 1.490000         | 36.90         | 10.3         | 56            | 19.1         | 1    | --- |
| 5.322000         | 16.00         | 11.0         | 60            | 44.0         | 1    | --- |
| 5.358000         | 20.80         | 11.0         | 60            | 39.2         | 1    | --- |
| 13.562000        | 37.70         | 11.7         | 60            | 22.3         | 1    | --- |
| 27.150000        | 17.10         | 12.6         | 60            | 42.9         | 1    | --- |
| 27.578000        | 16.90         | 12.7         | 60            | 43.1         | 1    | --- |

**MEASUREMENT RESULT: "718TPSL2FCC2\_fin\_AV"**

7/18/2003 10:39AM

| Frequency<br>MHz | Level<br>dBµV | Transd<br>dB | Limit<br>dBµV | Margin<br>dB | Line | PE  |
|------------------|---------------|--------------|---------------|--------------|------|-----|
| 0.198000         | 44.60         | 10.2         | 54            | 9.0          | 1    | --- |
| 0.298000         | 45.00         | 10.2         | 50            | 5.3          | 1    | --- |
| 0.598000         | 38.20         | 10.1         | 46            | 7.8          | 1    | --- |
| 0.698000         | 41.10         | 10.1         | 46            | 4.9          | 1    | --- |
| 0.798000         | 39.00         | 10.1         | 46            | 7.0          | 1    | --- |
| 0.894000         | 39.90         | 10.1         | 46            | 6.1          | 1    | --- |
| 0.994000         | 36.10         | 10.2         | 46            | 9.9          | 1    | --- |
| 1.094000         | 34.30         | 10.2         | 46            | 11.7         | 1    | --- |
| 1.194000         | 34.40         | 10.2         | 46            | 11.6         | 1    | --- |
| 1.294000         | 31.30         | 10.2         | 46            | 14.7         | 1    | --- |
| 5.162000         | 12.60         | 10.9         | 50            | 37.4         | 1    | --- |
| 5.262000         | 11.00         | 11.0         | 50            | 39.0         | 1    | --- |
| 5.362000         | 10.90         | 11.0         | 50            | 39.1         | 1    | --- |
| 5.658000         | 10.90         | 11.0         | 50            | 39.1         | 1    | --- |
| 13.558000        | 25.90         | 11.7         | 50            | 24.1         | 1    | --- |



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

## 2.0 BAND EDGE AND RESTRICT BAND COMPLIANCE

The field strength of any emissions appearing outside the 13.553 to 13.567 MHz band shall not exceed the general radiated emissions limits as stated Section 15.209. The fundamental from the TPS Irrigation Console transmitter shall not be inside the restrict band 13.36 TO 13.41 MHZ.

**NOTE:**

See the following page (s) for the graph (s) made showing compliance for Band Edge and Restrict Band:





Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

## GRAPH (s) TAKEN SHOWING THE BAND EDGE AND RESTRICT BAND COMPLIANCE

### PART 15.225 (b)




Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

DLS Electronic Systems, Inc.

FCC Part 15.225  
 Output Power / Band Edges  
 Test Distance: 10 meters

Company: Stryker Instruments  
 Model: TPS Plus  
 Date: 06-02-03



Date: 2.JUN.2003 13:13:10

Output Power = 47.89 dBuV/m at 10 meters.  
 Limit = 99 dBuV/m at 10 meters.  
 Margin = 51.11 dB



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

### 3.0 FIELD STRENGTH OF SPURIOUS EMISSION MEASUREMENTS SECTION 15.225 (a & b)

The radiated measurements made at D.L.S. Electronic Systems, Inc., for the TPS Irrigation Console, Model Number: 5100-050-000, are shown in tabulated and graph form. Preliminary radiation measurements were performed at a 3 meter test distance with the limits adjusted linearly when required. The frequency range from 9 kHz to over 960 MHz, depending upon the fundamental frequency as stated in Part 15.33a, was automatically scanned and plotted at various angles.

Measurements for the TPS Irrigation Console were made up to 1000 MHz, in accordance with Section 15.33a for Intentional Radiators with a fundamental frequency of 13.56 MHz. For intentional radiators, the frequency range to be investigated is determined by the lowest radio frequency generated by the device without going below 9 kHz, up to at least the tenth harmonic of the highest fundamental frequency or 1000 MHz, whichever is lower. At those frequencies where significant signals were detected, measurements were made at an open field test site, located at Genoa City, Wisconsin, FCC file number **31040/SIT**, to determine the actual radiation levels.

All signals in the frequency range of 9 kHz to 30 MHz were measured with a low frequency Loop Antenna as a pickup device. From 30 to 200 MHz, a Biconical Antenna or tuned dipoles were used and from 200 MHz to 1000 MHz, a Log Periodic or Tuned Dipoles were used. During the test the EUT, peripheral equipment and cables were configured to meet the conditions in ANSI C63.4-2000, Clauses 6 & 8. The equipment under test was rotated and the antenna was raised and lowered from 1 meter to 4 meters to find the maximum level. In order to find maximum emissions, the cables were moved through all the positions the equipment would be expected to experience in the field. Tests were made in the vertical polarization with the Loop Antenna, rotated 360° around its vertical axis. Tests were also made in both the horizontal and vertical planes of polarization with the Biconical and Log Periodic. In each case, the table was rotated to find the maximum emissions.



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

### 3.0 FIELD STRENGTH OF SPURIOUS EMISSION MEASUREMENTS (CON'T)

When the equipment is out of limit at 3 meters, and the signals from the equipment at 30 meters cannot be recorded due to the background, a representative sample of these frequencies were re-measured at various distances such as 4, 5, 6, 8, 15 meters and the greatest distance that can be measured to demonstrate graphically that the emissions are dropping off and will be under the limit at the specified distance. All signals were then recorded. The allowed levels for Intentional Radiators operating in the 13.553 MHz to 13.567 MHz band shall not exceed 10,000 uV measured at 30 meters as specified in FCC, Part 15, Section 15.225(a). The field strength of any emissions appearing outside of this band shall not exceed the general radiated emissions limits shown in Section 15.209.

#### **NOTE:**

All radiated emissions measurements were made at a test room temperature of **72°F** at **56%** relative humidity.



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

RADIATED DATA

AND CHARTS TAKEN OF

FUNDAMENTAL SPURIOUS EMISSIONS

PART 15.209

**FCC 15.225**

**Radiated Emissions**


EUT: TPS Plus  
Manufacturer: Stryker Instruments  
Operating Condition: 70 deg F; 40% R.H.  
Test Site: Site 3  
Operator: Craig Brandt  
Test Specification: 120 V; 60 Hz  
Comment: continuous transmit  
Date: 6/2/2003

**TEXT: "Site 3 LowH 10M"**

Short Description: Test Set-up 10kHz to 30MHz H  
TEST EQUIPMENT: Receiver --- Rohde&Schwarz ESI40 SN: 837808/006

Antennas --- Electro-Metrics ALR-25 SN: 557

TEST SET-UP: EuT Measured at 10 Meters with H-FIELD Antenna



**MEASUREMENT RESULT: "C6201\_FH\_Final"**

6/26/2003 2:39PM

| Frequency | Level      | Antenna<br>Factor | System<br>Loss | Total<br>Level | Limit        | Margin | Height<br>Ant. | EuT<br>Angle | Final<br>Detector | Comment     |
|-----------|------------|-------------------|----------------|----------------|--------------|--------|----------------|--------------|-------------------|-------------|
| MHz       | dB $\mu$ V | dB $\mu$ V/m      | dB             | dB $\mu$ V/m   | dB $\mu$ V/m | dB     | m              | deg          |                   |             |
| 13.560000 | 36.86      | 36.34             | -25.2          | 48.0           | 99.0         | 51.0   | 1.00           | 315          | QUASI-PEAK        | Fundamental |





Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

RADIATED DATA  
  
AND CHARTS TAKEN FOR  
  
FIELD STRENGTH  
  
SPURIOUS EMISSION MEASUREMENTS  
  
USING CORCOM FILTERS 6ED4C & 6ED8C  
  
PART 15.209

**FCC Part 15 Class B**

**Electric Field Strength**

EUT: TPS Plus  
Manufacturer: Stryker Instruments  
Operating Condition: 73 degF; 59%R.H.  
Test Site: DLS OF Site 3  
Operator: Craig Brandt  
Test Specification: 120 V 60 Hz  
Comment: Formula Shaver, CORCOM 6ED8C and CORCOM 6ED4C  
Date: 07/17/2003


**TEXT: "Site 3 MidV 3M"**

Short Description: Test Set-up Vert30-1000MHz  
TEST EQUIPMENT: Receiver --- Rohde&Schwarz ESI 26 SN: 837491/010

Antennas ---  
Biconical -- EMCO 3104C SN: 9701-4785  
Log Periodic -- EMCO 3146 SN: 9702-4895

Pre-Amp --- Rohde&Schwarz TS-PR10 SN: 032001/005

TEST SET-UP: EuT Measured at 3 Meters with VERTICAL Antenna Polarisation



**MEASUREMENT RESULT: "A7171\_F1V\_Final"**

7/17/2003 12:43PM

| Frequency  | Level      | Antenna      | System | Total        | Limit        | Margin | Height | EuT   | Final      | Comment      |
|------------|------------|--------------|--------|--------------|--------------|--------|--------|-------|------------|--------------|
| MHz        | dB $\mu$ V | Factor       | Loss   | Level        | dB $\mu$ V/m | dB     | Ant.   | Angle | Detector   |              |
|            |            | dB $\mu$ V/m | dB     | dB $\mu$ V/m | dB $\mu$ V/m |        | m      | deg   |            |              |
| 0.000000   | 0.00       | 0.00         | 0.0    | 0.0          | 0.0          | 0.0    | 0.00   | 0     |            |              |
| 56.315000  | 51.05      | 10.38        | -24.1  | 37.4         | 40.0         | 2.6    | 1.00   | 180   | QUASI-PEAK | 6ED8C filter |
| 40.670000  | 48.53      | 11.39        | -24.4  | 35.6         | 40.0         | 4.4    | 1.00   | 135   | QUASI-PEAK | None         |
| 48.025000  | 45.40      | 11.67        | -24.2  | 32.9         | 40.0         | 7.1    | 1.00   | 180   | QUASI-PEAK | None         |
| 122.055000 | 43.68      | 12.80        | -23.2  | 33.3         | 43.5         | 10.2   | 1.00   | 270   | QUASI-PEAK | None         |
| 141.785000 | 40.83      | 11.84        | -23.0  | 29.6         | 43.5         | 13.9   | 1.00   | 45    | QUASI-PEAK | 6ED8C filter |
| 54.675000  | 38.55      | 10.87        | -24.1  | 25.3         | 40.0         | 14.7   | 1.00   | 315   | QUASI-PEAK | None         |
| 162.705000 | 34.74      | 13.57        | -22.8  | 25.5         | 43.5         | 18.0   | 1.00   | 0     | QUASI-PEAK | None         |
| 56.740000  | 35.80      | 10.26        | -24.1  | 22.0         | 40.0         | 18.0   | 1.00   | 0     | QUASI-PEAK | None         |
| 208.010000 | 35.72      | 11.62        | -22.4  | 25.0         | 43.5         | 18.5   | 1.00   | 270   | QUASI-PEAK | None         |
| 147.980000 | 35.76      | 12.02        | -23.0  | 24.8         | 43.5         | 18.7   | 1.00   | 200   | QUASI-PEAK | None         |
| 379.680000 | 26.86      | 15.31        | -21.2  | 21.0         | 46.0         | 25.0   | 1.00   | 315   | QUASI-PEAK | None         |
| 230.680000 | 31.06      | 11.80        | -22.2  | 20.6         | 46.0         | 25.4   | 1.00   | 270   | QUASI-PEAK | None         |
| 352.560000 | 26.75      | 14.97        | -21.6  | 20.1         | 46.0         | 25.9   | 1.00   | 180   | QUASI-PEAK | None         |
| 424.010000 | 25.25      | 15.97        | -21.2  | 20.0         | 46.0         | 26.0   | 1.00   | 225   | QUASI-PEAK | None         |
| 219.990000 | 30.54      | 11.54        | -22.3  | 19.8         | 46.0         | 26.2   | 1.00   | 0     | QUASI-PEAK | None         |

**FCC Part 15 Class B**

**Electric Field Strength**

EUT: TPS Plus  
Manufacturer: Stryker Instruments  
Operating Condition: 73 degF; 59%R.H.  
Test Site: DLS OF Site 3  
Operator: Craig Brandt  
Test Specification: 120 V 60 Hz  
Comment: Formula Shaver, CORCOM 6ED8C and CORCOM 6ED4C  
Date: 07/17/2003


**TEXT: "Site 3 MidH 3M"**

Short Description: Test Set-up Horz30-1000MHz  
TEST EQUIPMENT: Receiver --- Rohde&Schwarz ESI 40 SN: 837808/006

Antennas ---  
Biconical -- EMCO 3104C SN: 9701-4785  
Log Periodic -- EMCO 3146 SN: 9702-4895

Pre-Amp --- Rohde&Schwarz TS-PR10 SN: 032001/005

TEST SET-UP: EuT Measured at 3 Meters with HORIZONTAL Antenna Polarisation



**MEASUREMENT RESULT: "A7171\_F1H\_Final"**

7/17/2003 12:39PM

| Frequency  | Level      | Antenna      | System | Total        | Limit        | Margin | Height | EuT   | Final      | Comment |
|------------|------------|--------------|--------|--------------|--------------|--------|--------|-------|------------|---------|
| MHz        | dB $\mu$ V | Factor       | Loss   | Level        | dB $\mu$ V/m | dB     | Ant.   | Angle | Detector   |         |
|            |            | dB $\mu$ V/m | dB     | dB $\mu$ V/m | dB $\mu$ V/m |        | m      | deg   |            |         |
| 0.000000   | 0.00       | 0.00         | 0.0    | 0.0          | 0.0          | 0.0    | 0.00   | 0     |            |         |
| 86.500000  | 45.63      | 8.54         | -23.6  | 30.6         | 40.0         | 9.4    | 2.00   | 135   | QUASI-PEAK | None    |
| 162.720000 | 41.44      | 13.58        | -22.8  | 32.2         | 43.5         | 11.3   | 2.20   | 90    | QUASI-PEAK | None    |
| 81.335000  | 38.91      | 6.90         | -23.7  | 22.1         | 40.0         | 17.9   | 3.00   | 315   | QUASI-PEAK | None    |
| 67.795000  | 38.26      | 7.31         | -24.0  | 21.6         | 40.0         | 18.4   | 3.50   | 270   | QUASI-PEAK | None    |
| 268.010000 | 35.35      | 13.30        | -22.0  | 26.6         | 46.0         | 19.4   | 1.00   | 90    | QUASI-PEAK | None    |
| 406.800000 | 31.86      | 15.86        | -21.2  | 26.5         | 46.0         | 19.5   | 1.00   | 135   | QUASI-PEAK | None    |
| 208.010000 | 34.59      | 11.62        | -22.4  | 23.8         | 43.5         | 19.7   | 2.00   | 225   | QUASI-PEAK | None    |
| 120.025000 | 33.57      | 12.68        | -23.2  | 23.0         | 43.5         | 20.5   | 2.00   | 315   | QUASI-PEAK | None    |
| 272.010000 | 33.83      | 13.42        | -22.0  | 25.3         | 46.0         | 20.7   | 1.00   | 135   | QUASI-PEAK | None    |
| 276.000000 | 33.48      | 13.60        | -21.9  | 25.1         | 46.0         | 20.9   | 1.00   | 180   | QUASI-PEAK | None    |
| 295.990000 | 31.49      | 15.00        | -21.8  | 24.7         | 46.0         | 21.3   | 1.60   | 270   | QUASI-PEAK | None    |
| 144.020000 | 32.13      | 11.81        | -23.0  | 20.9         | 43.5         | 22.6   | 2.00   | 45    | QUASI-PEAK | None    |
| 36.390000  | 30.40      | 11.48        | -24.5  | 17.4         | 40.0         | 22.6   | 4.00   | 180   | QUASI-PEAK | None    |
| 113.325000 | 29.06      | 12.71        | -23.3  | 18.5         | 43.5         | 25.0   | 2.50   | 315   | QUASI-PEAK | None    |
| 223.990000 | 30.75      | 11.53        | -22.3  | 20.0         | 46.0         | 26.0   | 1.30   | 225   | QUASI-PEAK | None    |



Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

4.0 FREQUENCY STABILITY - PART 2.1055a (Temperature)

The frequency stability was measured from -30° to +50° centigrade at intervals of 10° centigrade throughout the range. Prior to each frequency measurement, the equipment was left alone for a sufficient period of time (approximately 30 minutes or more) to allow the components of the TPS Irrigation Console oscillator circuitry to stabilize. The following information was taken:

**FREQUENCY STABILITY FOR TEMPERATURE VARIATION IN MHz:**

|      |             |
|------|-------------|
| -20° | 13.56009288 |
| -10° | 13.56011942 |
| 0°   | 13.56019903 |
| +10° | 13.56022557 |
| +20° | 13.56014596 |
| +30° | 13.56011942 |
| +40° | 13.56011942 |
| +50° | 13.56017249 |

**Worst Case Variance:**

**13560225.57 Hz**

As stated in Part 15, Section 15.225 (c), the Frequency Tolerance and Margin for this range are as follows:

**Ambient Frequency: = 13560145.96 Hz**

**Frequency Tolerance: = 0.0001**

**13560145.96 \* 0.0001 = 1356 Hz**

**This is well within the specified limits.**





Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

## GRAPHS TAKEN FOR FREQUENCY

STABILITY WHEN VARYING THE

TEMPERATURE

PART 2.1055A

This is well within the specified limits.




Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

DLS Electronic Systems, Inc.

FCC Part 15.225  
Frequency Stability – Temperature  
With test fixture, in temperature chamber

Company: Stryker Instruments  
Model: TPS Plus  
Date: 06-03-03



Date: 3 JUN 2003 10:35:51

Temperature = -20 deg. C




Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

DLS Electronic Systems, Inc.

FCC Part 15.225  
 Frequency Stability – Temperature  
 With test fixture, in temperature chamber

Company: Stryker Instruments  
 Model: TPS Plus  
 Date: 06-03-03



Date: 3 JUN 2003 09:57:51

Temperature = -10 deg. C




Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

DLS Electronic Systems, Inc.

FCC Part 15.225  
 Frequency Stability – Temperature  
 With test fixture, in temperature chamber

Company: Stryker Instruments  
 Model: TPS Plus  
 Date: 06-03-03



Date: 3 JUN 2003 09:31:42

Temperature = 0 deg. C




Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

DLS Electronic Systems, Inc.

FCC Part 15.225  
 Frequency Stability – Temperature  
 With test fixture, in temperature chamber

Company: Stryker Instruments  
 Model: TPS Plus  
 Date: 06-03-03



Date: 3 JUN 2003 08:58:11

Temperature = +10 deg. C




Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

DLS Electronic Systems, Inc.

FCC Part 15.225  
 Frequency Stability – Temperature  
 With test fixture, in temperature chamber

Company: Stryker Instruments  
 Model: TPS Plus  
 Date: 06-02-03



Date: 2 JUN 2003 15:12:14

Temperature = +20 deg. C




Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

DLS Electronic Systems, Inc.

FCC Part 15.225  
Frequency Stability – Temperature  
With test fixture, in temperature chamber

Company: Stryker Instruments  
Model: TPS Plus  
Date: 06-02-03



Date: 2.JUN.2003 15:38:51

Temperature = +30 deg. C




Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

DLS Electronic Systems, Inc.

FCC Part 15.225  
 Frequency Stability – Temperature  
 With test fixture, in temperature chamber

Company: Stryker Instruments  
 Model: TPS Plus  
 Date: 06-02-03



Date: 2 JUN 2003 16:01:16

Temperature = +40 deg. C






Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

DLS Electronic Systems, Inc.

FCC Part 15.225  
 Frequency Stability – Temperature  
 With test fixture, in temperature chamber

Company: Stryker Instruments  
 Model: TPS Plus  
 Date: 06-02-03



Date: 3 JUN 2003 08:10:49

Temperature = +50 deg. C



Company: Stryker Instruments  
 Model Tested: 5100-050-000 & 5100-001-000  
 Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

5.0 FREQUENCY STABILITY - PART 2.1055d (**Voltage**)

The frequency stability of TPS Irrigation Console was measured by varying the primary supply voltage from 85% to 115% of nominal value for all equipment other than hand carried battery equipment.

**FREQUENCY STABILITY FOR VOLTAGE VARIATION:**

85% 13559973.46  
 100% 13560000.00  
 115% 13560172.50

**This is well within the specified limits.**

**FREQUENCY STABILITY FOR HAND HELD DEVICES:**

For hand carried, battery powered equipment, the supply voltage was reduced to the battery operating end point specified by the manufacturer. Readings were taken at the reduced end point and with a fresh battery:

**Fresh Battery versus Battery end point:**

Frequency #1 **0 Hz**  
 Frequency #2 **0 Hz**  
 Frequency #3 **0 Hz**  
 Frequency #4 **0 Hz**  
 Frequency #5 **0 Hz**  
 Frequency #6 **0 Hz**

As stated in Part 15, Section 15.225 (c), the Frequency Tolerance and Margin for this range are as follows:

**Frequency Tolerance: 0.0001**

**Limit: 1356 Hz**

**This test was not run since the device is connect to the AC power line.**



Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

GRAPHS TAKEN FOR FREQUENCY  
STABILITY WHEN VARYING THE  
PRIMARY SUPPLY VOLTAGE

PART 2.1055d

This is well within the specified limits.




Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

DLS Electronic Systems, Inc.

FCC Part 15.225  
Frequency Stability – Supply Voltage  
Test Distance: 10 meters

Company: Stryker Instruments  
Model: TPS Plus  
Date: 06-02-03



Date: 2.JUN.2003 13:43:11

Blue = 120 Volt supply  
Green = 102 Volt supply  
Limit = 1.356 kHz




Company: Stryker Instruments  
Model Tested: 5100-050-000 & 5100-001-000  
Report Number: 10207

1250 Peterson Dr., Wheeling, IL 60090

DLS Electronic Systems, Inc.

FCC Part 15.225  
Frequency Stability – Supply Voltage  
Test Distance: 10 meters

Company: Stryker Instruments  
Model: TPS Plus  
Date: 06-02-03



Date: 2.JUN.2003 13:50:14

Blue = 120 Volt supply  
Green = 138 Volt supply  
Limit = 1.356 kHz