

carbon monoxide alarm

Power

Alarm

4 Flashes = Alarm
Move to Fresh Air

1 Flash = Trouble

Test / Hush



MODEL: SW-ATT-CO

For servicing, return to
SecureWireless
5817 Dryden Place Suite 104
Carlsbad, CA 92008

Engineering Samples
Not for Sale

WARNING USE ONLY BATTERIES

SPECIFIED. USE OF A DIFFERENT BATTERY
MAY HAVE DETRIMENTAL EFFECT ON ALARM
OPERATION.

To replace batteries: Remove batteries and
replace with 3 fresh AA batteries. Use only
Duracell MN 1500 or MX 1500 or
Energizer E91.

Date of Mfg:

Alarm response time: 400
PPM within 4 - 15 minutes

Single Station
Carbon Monoxide
Alarm conforms to
UL 2034 Std.
P/N: 2533-7139-00

WITH 2 AAA BATTERIES USE ONLY BATTERIES
1500 or MX 1500, Energizer E91, Gold Peak 1500
or Golden Power G1R6A