

**FCC Part 1 Subpart I
FCC Part 2 Subpart J**

RF EXPOSURE REPORT

FOR

LINGO BIOSENSOR

MODEL NAME: 44600

FCC ID: QXS-LINBS1

REPORT NUMBER: R14826084-E2

ISSUE DATE: 2023-10-19

Prepared for
**ABBOTT DIABETICS CARE INC.
1360 SOUTH LOOP RD
ALAMEDA, CA 94502, UNITED STATES**

Prepared by
**UL LLC
12 LABORATORY DR.
RESEARCH TRIANGLE PARK, NC 27709 USA
TEL: (919) 549-1400**



Revision History

Rev.	Issue Date	Revisions	Revised By
V1	2023-10-19	Initial Issue	Charles Moody

TABLE OF CONTENTS

1. ATTESTATION OF TEST RESULTS	4
2. TEST METHODOLOGY	5
3. REFERENCES	5
4. FACILITIES AND ACCREDITATION	5
5. DECISION RULES AND MEASUREMENT UNCERTAINTY	6
5.1. METROLOGICAL TRACEABILITY	6
5.2. DECISION RULES.....	6
6. DEVICE UNDER TEST	6
7. STANDALONE SAR TEST EXCLUSION CONSIDERATIONS	7
7.1. FCC.....	7

1. ATTESTATION OF TEST RESULTS

COMPANY NAME: Abbott Diabetics Care Inc.
1360 South Loop Rd
Alameda, CA 94502, United States

EUT DESCRIPTION: Lingo Biosensor

MODEL NAME: 44600

SERIAL NUMBER: E07A006F94E7430F

SAMPLE RECEIVED DATE: 2023-09-28, 2023-10-03

DATE TESTED: 2023-10-04

APPLICABLE STANDARDS	
STANDARD	TEST RESULTS
FCC PART 1 SUBPART I & PART 2 SUBPART J	Complies

UL LLC tested the above equipment in accordance with the requirements set forth in the above standards. The test results show that the equipment tested is capable of demonstrating compliance with the requirements as documented in this report.

The results documented in this report apply only to the tested sample, under the conditions and modes of operation as described herein. It is the manufacturer's responsibility to assure that additional production units of this model are manufactured with identical electrical and mechanical components. All samples tested were in good operating condition throughout the entire test program. Measurement Uncertainties are published for informational purposes only and were not taken into account unless noted otherwise.

This document may not be altered or revised in any way unless done so by UL LLC and all revisions are duly noted in the revisions section. Any alteration of this document not carried out by UL LLC will constitute fraud and shall nullify the document.

Approved & Released
For UL LLC By:

Prepared By:



Michael Antola
Staff Engineer
Consumer, Medical and IT Segment
UL LLC

Charles Moody
Engineer
Consumer, Medical and IT Segment
UL LLC

2. TEST METHODOLOGY

All calculations were made in accordance with FCC Parts 1.1310, 2.1091, 2.1093, KDB 447498 D01 v06, KDB 447498 D03 V01, IEEE Std C95.1-2005, and IEEE Std C95.3-2002.

This report contains data provided by the customer which can impact the validity of results. UL LLC is only responsible for the validity of results after the integration of the data provided by the customer

Client Provided Data:

- 1.) Max Declared Avg. Output Power (see section 7.1)

3. REFERENCES

Declared maximum average output power is excerpted from client documentation.

4. FACILITIES AND ACCREDITATION

UL LLC is accredited by A2LA, certification #0751.06, for all testing performed within the scope of this report. Testing was performed at the locations noted below.

	Address	ISED CABID	ISED Company Number	FCC Registration
<input checked="" type="checkbox"/>	Building 2800 Perimeter Park Dr. Suite B Morrisville, NC 27560, U.S.A	US0067	27265	825374
<input type="checkbox"/>	Building: 12 Laboratory Dr RTP, NC 27709, U.S.A		2180C	

5. DECISION RULES AND MEASUREMENT UNCERTAINTY

5.1. METROLOGICAL TRACEABILITY

The measuring equipment utilized to perform the tests documented in this report has been calibrated in accordance with the manufacturer's recommendations, and is traceable to recognized national standards.

5.2. DECISION RULES

For all tests where the applicable $U_{LAB} \leq U_{MAX}$ the Decision Rule is based on Simple Acceptance in accordance with ISO Guide 98-4: 2012 Clause 8.2, where $U_{MAX} = 30\%$ (0.3) for RF Exposure evaluations. (Measurement uncertainty is not taken into account when stating conformity with a specified requirement.)

For all tests where the applicable $U_{LAB} > U_{MAX}$ the Decision Rule is based on Guarded Acceptance in accordance with ISO Guide 98-4: 2012 Clause 8.3.2, with a guard band equal to $(U_{LAB} - U_{MAX})$, where $U_{MAX} = 30\%$ (0.3) for RF Exposure evaluations. (Test results are adjusted by the value of the guard band to determine conformity with a specified requirement.)

6. DEVICE UNDER TEST

The EUT is a Lingo Biosensor with a BLE radio. As the declared by the manufacturer, the separation distance to be used for testing was 5mm.

7. STANDALONE SAR TEST EXCLUSION CONSIDERATIONS

7.1. FCC

SAR test exclusion in accordance with KDB 447498 D01 v6.

The 1-g and 10-g SAR test exclusion thresholds for 100 MHz to 6 GHz at test separation distances ≤ 50 mm are determined by:

$[(\text{max. power of channel, including tune-up tolerance, mW}) / (\text{min. test separation distance, mm})] \cdot [f(\text{GHz})] \leq 3.0$, for 1-g SAR and ≤ 7.5 for 10-g extremity SAR, where

- $f_{(\text{GHz})}$ is the RF channel transmit frequency in GHz
- Power and distance are rounded to the nearest mW and mm before calculation
- The result is rounded to one decimal place for comparison

This test exclusion is applicable only when the minimum test separation distance is ≤ 50 mm and for transmission frequencies between 100 MHz and 6 GHz. When the minimum test separation distance is < 5 mm, a distance of 5 mm is applied to determine SAR test exclusion.

The 1-g and 10-g SAR test exclusion thresholds for 100 MHz to 6 GHz at test separation distances > 50 mm are determined by:

1. $\{[\text{Power allowed at numeric threshold for 50 mm}]\} + [(\text{test separation distance} - 50 \text{ mm}) \cdot (f(\text{MHz})/150)]$ mW, for 100 MHz to 1500 MHz
 - $f_{(\text{MHz})}$ is the RF channel transmit frequency in MHz
2. $\{[\text{Power allowed at numeric threshold for 50 mm}]\} + [(\text{test separation distance} - 50 \text{ mm}) \cdot 10]$ mW, for > 1500 MHz and ≤ 6 GHz

SAR Exclusion Calculation Table for Portable Devices (separation distance < 50 mm)

Tx	Frequency (MHz)	Avg Output power		Separation distances (mm)	Calculated Threshold
		dBm	mW		
BLE	2480	-0.50	0.89	5	0.3

Conclusion:

The computed values are < 3 ; therefore, the device qualifies for Standalone SAR test exclusion.

END OF TEST REPORT